

DALMIA CEMENT (B) LIMITED – CEMENT PLANT DALMIAPURAM



Issue No. 01 Rev. No: 00 Effective Date: 01.03.2016 SOP/Elect /25

Issued By: S & P Approved By: Elect. & Inst Head

SOP For LRR Maintenance (SPRS Related)

Scope/Purpose: This SOP is applicable for safe working during LRR Maintenance

Responsibility : Section Supervisor – Electrical

Accountability : Section Head - Electrical

PPE:

1. Safety shoe

2. Safety Helmet

3. Nose mask

4. Rubber Gloves

Tools:

- 1. Box Spanner set
- 2. Ring Spanner set
- 3. Insulated electrical tools
- 4. Earth discharge rod

Hazard Analysis:

Risks associated Mitigating Measures

Injury due to electric shock Ensure LOTO and OFF condition of all electrical circuits Injury due to fall of materials Ensure proper handling mechanism

Training needs:

- 1. Emergency Preparedness
- 2. Maintenance and operation exposure of LRR

Procedure:

- a) Get work permit from the concerned Electrical Section Supervisor.
- b) Ensure Power circuit & Control circuits are in Switched OFF condition (HT feeder, HT & LT Isolators, SPRS panel).
- c) Check & clean the control cubicle.



DALMIA CEMENT (B) LIMITED – CEMENT PLANT DALMIAPURAM



Issue No. 01 Rev. No: 00 Effective Date: 01.03.2016 SOP/Elect /25

Issued By: S & P Approved By: Elect. & Inst Head

SOP For LRR Maintenance (SPRS Related)

- d) Check & clean the Short circuit contactor.
- e) Check & clean the fixed & moving electrode assembly.
- f) Check phase barriers, supporting insulators & LRR tank condition.
- g) Check Electrolyte level & Electrolyte Specific gravity. Add electrolyte, if required.
- h) Check & clean Pilot motor & moving mechanism. Apply lubrication, if necessary.
- i) Check End limit sensors & limit switches.
- j) Check Electrolyte temperature sensor & level sensor.
- k) Check electrolyte circulating pumps.
- 1) Check Heat exchanger.
- m) Check LRR operation in manual/Local mode. After checking in manual/Local mode, put LRR in Auto mode.
- n) Return the Work permit.

Emergency / Emergency Shut OFF:

1. If any injury is there, inform to the Electrical Shift Engineer (251 / 9842994062) or Safety Department (523) or call Emergency number 9865160055

Records/Annexure:

1. JSA is enclosed below.



DALMIA CEMENT (B) LIMITED – CEMENT PLANT DALMIAPURAM



Issue No. 01 Rev. No: 00 Effective Date: 01.03.2016 SOP/Elect /25

Issued By: S & P Approved By: Elect. & Inst Head

SOP For LRR Maintenance (SPRS Related)

JOB SAFETY ANALYSIS: (JSA)

Job Safety Analysis	Job: LRR Maintenance	Date: 18.11.2015	Analysis by: J.Chandrasekaran	Reviewed by:
Title of employee doing job: Electrician	Supervisor: Section Supervisor	Department: Electrical	Section:	Approved by:

Req'd/recommended PPE: Safety Shoe, Safety Helmet, Nose Mask & Rubber Gloves.

Sequence of Basic Job Steps	Potential Hazards	Recommended Safe Job Procedure	What Could Go Wrong	Corrective Action		
Checking Power & Control circuit	Exposure to Live circuit	Use Rubber Gloves & Insulated tools	Damaged Tools	Periodic inspection & Replacement		
Clean the LRR by Air blower	Dust emission	Use Nose Mask	Damaged Nose Mask	Periodic Replacement		
Manual operation of LRR	Injury due to Bounce/Slip of handle	Ensuring proper engagement of Gear wheel operating Handle	Damaged Handle / Handle lock mechanism is not in tact	Before manual operation, Ensure the Handle condition & Handle Lock mechanism		