



A review of PID control, tuning methods and applications

Rakesh P. Borase^{1,2} · D. K. Maghade³ · S. Y. Sondkar¹ · S. N. Pawar²

Received: 11 June 2020 / Revised: 18 June 2020 / Accepted: 2 July 2020
© Springer-Verlag GmbH Germany, part of Springer Nature 2020

Abstract

This article provides a study of modern and classical approaches used for PID tuning and its applications in various domains. Most of the control systems that are implemented to date with the use of PID control because of its simple structure, ease of implementation, and active research in tuning the PID for a long time. The techniques reviewed in the paper are in the order from classical to modern optimization rules used for the PID tuning. This paper attempts to address the literature review of PID control in an era of control system and bio-medical applications. The development of classical PID to the integration of intelligent control to it, has been surveyed by consideration of various application domains. The primary purpose of this document is to provide a detailed point of information for the people to understand the command of PID in different application areas.

Keywords PID · Optimal PID control · Auto-tuning · Robotic manipulator · Process control · Electrical drives · Mechanical systems

1 Introduction

PID controller has a long history in the domain of automatic control. James Watt's developed steam engine and governor in 1769 and it was accepted as a first negative feedback device [1–3]. In 1868, J. C. Maxwell formulates a mathematical model for a governor control of the steam engine [1–3]. Maxwell listed the governors into two categories: moderators and genuine governors. According to modern terminologies, he defines the moderators as controllers with proportional control action only, whereas genuine governors as controllers with both proportional and integral control

actions. Subsequently, Nicolas Minorsky provided a theoretical analysis for the derivative of error, its current rate of change [2]. The contribution from Minorsky, which was initially rejected by naval operators due to staff opposition, was support for the subsequent emergence of modern PID controllers. Elmer Sperry had developed first PID controller in 1911 for the US Navy [3,4]. In 1939, however, the Taylor Instrument Companies released a fully revised version of their "Fulscope" pneumatic controller [5]. This new device developed an action called "pre-act" along with proportional and reset control actions. Similarly, the Foxboro Instrument Company put forward the term "Hyper-reset" with proportional and reset action while introducing their pneumatic controller called "Stabilog" in the same year. Both "Pre-act" and "Hyper-reset" delivered a control that is commensurate to the derivative of the error signal. correspondingly, reset (also known as "floating") offers action that is commensurate to the integral of the error signal [4,5]. The outcome of these two activities was that both the controllers were offered PID control. After a few years, the problem of steady-state error in the proportional controller was minimized by adjusting the point to some arbitrary value until the error gets zero. This resetting "integrated" the error and became known as the proportional-Integral controller [4,5]. The first pneumatic controller with a derivative action was developed by Taylor instrument companies in 1940, which minimized overshooting problems. But

✉ Rakesh P. Borase
rakesh.borase@rait.ac.in

D. K. Maghade
maghade@gmail.com

S. Y. Sondkar
shilpa.sondkar@vit.edu

S. N. Pawar
sushantnpawar@gmail.com

¹ Vishwakarma Institute of Technology, 666, Upper Indiranagar, Bibwewadi, Pune, Maharashtra 411 037, India

² Department of Instrumentation Engineering, Ramrao Adik Institute of Technology, Navi Mumbai, MH 400 706, India

³ Government College of Engineering Chandrapur, Chandrapur, Maharashtra 442403, India

the engineers were not able to identify the appropriate PID controllers' parameters until 1942 when Ziegler and Nichols tuning regulations were implemented. And, automatic PID controllers were commonly used for industrial use during the mid-1950s [5]. In later stages, researchers have more focused on Tuning of the PID control which includes self-tuning and Auto-tuning [6–14], Genetic tuning of PID [15], Robust and Optimal tuning [16] etc. Also, Intelligent PID and PID based control strategies are introduced in [17–20], fuzzy PID in [21–23], Optimal PID controller design in [13,24–27], adaptive PID control [28] and Fractional order PID [29–32] are proposed.

As shown in Fig. 1 PID control employs three modes algorithm, i.e., proportional, integral and derivative. The proportional term incorporates appropriate proportional changes for error (which is the difference between the setpoint and process variable) to the control output.

The integral term examines the process variable over time and it corrects the output by reducing the offset from process variable. Derivative control mode monitors the rate of change of the process variable and therefore changes the output when there are unusual variations. The user adjusts each parameter of the three control functions to obtain the desired performance from the process. Due to their simple structure, easy implementation and maintenance, PID controllers are the most extensively used controllers in the motion control, process control, power electronics, hydraulics, pneumatics, and manufacturing industries etc. [33]. PID controller delivers good performance with a cost / benefit ratio which is difficult for other types of controllers. They are also prevalent in modern applications, like self-driving cars, Unmanned aircraft vehicle, and autonomous robots, for the same purpose [34]. In most of the control system applications 90–95 % of control loops are of PID form.

This review work initially focused on basics of PID and PID tuning methods introduced in previous literature. Then, in further stages of the paper, different domains where the explicitly used PID controller is discussed along with the PID control strategies used in the respective domains. The latest advancement in PID is discussed in this paper which makes it an intelligent one. And finally, the future research direction of PID control techniques has been presented.

2 PID controller structure and tuning methods

2.1 Structures of PID controllers

Commonly used structures for PID controllers are of parallel and series type:

- Parallel Type: In this form, Proportional P, integral I or derivative D action occurs in separate equation terms, and with their combined effect the sum is produced. In this type each parameter is independent of others and the corresponding control law is represented as:

$$u(t) = K_c \left(e(t) + \frac{1}{T_i} \int e(t)dt + T_d \frac{de(t)}{dt} \right) \quad (1)$$

where, the proportional gain is $K_p = K_c$, integral time is T_i and $k_i = \frac{K_c}{T_i}$, derivative time is T_d and $k_d = K_c T_d$. This is also known as an ideal representation.


- Series Type: Series or interactive equation derives mainly from the pneumatic and analog electronic circuit characteristics. Just as an ideal PID equation the change in K_c impacts all the three actions, but both derivative and integral constants have the influence on proportional action. This type has the following control law:

$$e_1(t) = e(t) + T_d \frac{de(t)}{dt}$$

$$u(t) = K_c \left(e_1(t) + \frac{1}{T_i} \int e(t)dt \right) \quad (2)$$

Here, gain K_c affects all three portions of the PID structure. On the other hand, the values of the integral and derivative tuning parameters T_d and T_i also affects the proportional term. Therefore modifying T_d tends to impact D and P actions, modifying T_i impact on both the I and P actions, and modifying K_c impacts on all three actions. Most commercial controllers use a series algorithm only, mainly with the non-interactive form (ideal) and some use the interactive form. It is usually difficult to find a perfect model in the practical world. The manipulation and trial and error are therefore still very useful procedures. For instance, if a loop is too aggressive and oscillating too much, naturally the gain should be decreased. This will results in slow down the response and robustness is added to the loop. In the series algorithm this way of thought only works. The decreased gain also raises the controller phase in the parallel algorithm, which may lead to more oscillations and instability depending on the overall tuning. Thus it is easier to grasp the PID behavior intuitively with the the series algorithm, whereas it is far more complex with the ideal algorithm. In the latter, both raising or lowering the gains may generate instability, whereas in series algorithms, lowering the gain would often result in greater stability for self-regulating processes.

Fig. 1 Block diagram of process control using PID



2.2 Tuning methods

2.2.1 Classical tuning methods

Classical methods for PID controller tuning found in the literature include Trial and Error Method, Ziegler–Nichols Step Response Method (1941 and 1942 at Taylor Instrument Company, USA), Ziegler–Nichols Frequency Response Method [35], Relay Tuning Method [36] and Cohen–Coon Method (1953). In addition, Weng Khuen Ho et al. (1996) addressed the efficiency and robustness of well-known PID formulas (Ziegler–Nichols, Cohen–Coon, and tuning formulas) for the processes with deadtime to time constant ratio between 0.1 and 1 [37]. It has been observed that Approximately 1.5 gain margins achieved with Ziegler–Nichols and optimized tuning formulas for calculating Integral Absolute Error (IAE), Integral Square Error (ISE) and Integral time Absolute Error (ITAE) for load disturbances. As the process deadtime to time constant ratio increases from 0.1 to 1 the phase margins increases from about 30 to 60°. Also, Gain margin appropriately 2 and phase margin of about 65° observed with the tuning formulas that optimizes the set-point response. To cancel the process poles these formulas mostly utilizes the PID controller zeroes. Classical tuning methods make certain assumptions about the plant and the desired output, and attempt to obtain some analytical or graphical feature of the process that is then used to determine the controller settings. These methods are simple to implement and has a very fast computation. These methods are good at the initial phase and do not give the desired results all the way due to assumptions made and further tuning is needed.

2.2.2 Intelligent tuning methods

The intricate systems and performance demands of the controller designer necessitate the introduction of new tuning

design techniques following the emergence of classic PID controller tuning techniques. Throughout the years, several useful findings were obtained for PID tuning methods for more performance-specific criteria and to deal with more complicated systems. Earlier the classical tuning methods were only applicable to FOPDT (first-order plus dead-time) and SOPDT (second-order plus dead-time) models only. This is one of the demerit of classical tuning methods of PID control. In 1988, Fong-Chwee et al. introduced self-tuning PID controllers by pole assignment technique. Three types of self-tuning PID controllers have been discussed in it which can provide better control over dead time processes of different natures. Similarly, A. Besharati Rad et al. in [7] proposed a new self-tuning method (An option to ZN technique for auto-tuning). This tuning method is faster and is used to tune PID controllers that do not have an auto-tuning mode. Also, A. Besharati et al. proposed a Newton–Raphson search method which is found to be easy and it eliminates the complex root-solving procedures of the characteristic equation. Koivo and Tantt in [38] carried out a survey of various tuning methods of a PID controller for SISO (Single Input Single Output) and MIMO (Multiple Input Multiple Output) technique. The different approaches for unknown plants are analyzed in his multi-variable case [38], and the findings have been generalized to time-delay systems and distributed parameter systems. In 1992, some researchers have contributed in designing the tuning methods such as auto-tuning [39], genetic algorithm approach [15] and model matching approach [40]. A novel PID Tuning technique based on model matching has been proposed in [40]. The important aspects of this method are: (i) plant transfer function is assumed to be known (ii) reference model match by controlled system while PID tracking (iii) the PID parameters are obtained solving a set of linear equations. The algorithm developed for controller design by LA Aguirre in [40] based on pade coefficients matching and Markov parameters.

LA Aguirre has proposed a simple controller structure, $C(s): C(j\omega)G(j\omega)/[1 + C(j\omega)G(j\omega)] \simeq H(j\omega)$, which can be found from plant transfer function $G(s)$, and $H(s)$ as a reference model. This type of representation can be used in tuning of a tracking PID controller. Brian Porter and AH Jones in [15] have proposed the techniques for genetic algorithms as an alternate way of tuning digital PID controllers. This genetic algorithm is very appealing, since even for digital PID controllers for complex multivariable plants with highly interactive dynamics, the same basic approach can still easily be employed. Also, J. C. Shen in [35] proposed new tuning method and performance assessment formula based on genetic algorithm. Ruano et al. in [39] have proposed a connectionist approach to PID autotuning which is to determine the required PID parameter values with the utilization of integral measures of the step response as the input to neural networks.

Alberto Leva, in 1993 have proposed a relay-based algorithm for automatic PID tuning to assume a process model structure and to achieve regulator tuning by defining one point of process frequency response [8]. The algorithm tends to give satisfactory performance and accuracy if the supposed process structure is close to reality. In 1993, Zhuang and Atherton evaluated the method needed to achieve the optimum settings for their PID-controller. This method is used later to obtain formulas to set the parameters of a controller for FOPDT (first-order plus dead-time) plant which is popular in process industries [9]. Also, in [41], Zhuang and Atherton described the auto-tuning procedure for determining the diagonal PID controller for the TITO (Two Input Two Output) system. This method considers two relay controllers used to achieve the critical frequency and gain of the process used in the tuning formulas. The parameters of the PID controller can then be determined using the generalized Ziegler–Nichols method or the characteristic loci method. In addition, PID tuning has also been investigated using an integral performance optimization mechanism for a TITO system.

Astrom et al. has reviewed various adaptive techniques such as gain scheduling, automatic tuning, adaptation system etc. in [10]. Later, Poulin and Pomerleau in [42] has focused on integrating and unstable processes. They have introduced a systemic PI and PID tuning method. This tuning method is based on a maximum peak-resonance specification which leads to simple expressions of the tuning parameters and is illustrated graphically by the Nichols chart. In 1998 W. Tan et al. [43] introduced PID tuning method by loop-shaping and H_∞ control for stable and integrating processes. While Q. G. Wang in 1999 [44] introduces a new method for PID tuning which achieves high performance for several linear self-regulating processes. It was based on the adaptation of the process frequency response to a specific SOPDT structure capable of modeling both the monotonous and the oscillatory

features of the process. Here, closed-loop poles can be simply assigned using a classical root locus analysis method. This method tested experimentally for the laboratory set-up as well as industry application of Heating Ventilation and Air Conditioning System (HVAC).

In beginning of the 20th century G. Mann in [45], Visioli and Antonio in [46] proposed new PID tuning rules such as time-domain based design analysis and fuzzy logic tuning rules respectively. Cominos and Munro in [47] noted that PID controllers are often improperly tuned, and attempts were carried out to tackle this problem systematically. A brief description of PID theory has been given in his contribution comprising PID tuning methods widely used and to explore a few latest efficient methods. An adaptive control scheme applicable to SISO system was proposed by Haung et al. [48] with the on-line tuning of PID controllers. In the suggested control structure [48] two adaptive loops has been considered. To guarantee the robust stability of the system the first loop evaluates and tunes the controller on-line without betting against nominal design performance. The second loop performs periodic on-line detection when modeling errors occur and retune the controller. After this, the system will treat as a newly configured system to provide effective control performance directly. In later part, Robust and optimal tuning of PI and PID controllers has been proposed in [16] by Birgitta Kristiansson and Bengt Lennartson. In addition, an evaluation procedure, an analytical design method and robust internal model control (RIMC) introduced in the [49]. For PI and PID, it is a slight change in IMC, in which the lambda (tuning factor) is substituted by specific tuning parameters relevant to crucial MF (medium frequency) and HF (high frequency) robustness characteristics. This proposed RIMC in [49] is found to be desirable.

3 PID applications

3.1 PID for process control

In process control, PID controllers are popularly used and are therefore listed in the majority of the automatic control textbooks. In 1977, E.M. Stafford have suggested a method as design aid for approximate PD and PID ON/OFF controllers [50]. Jacobs et al. in [51] emphasised on pH control of industrial process as a contribution towards modern control technology. Computer interface used from a full-scale production process for on-line effluent neutralisation. The analysis consisted of studies, some of which were extended using a computer to control neutralization according to various algorithms and to track performance and simulation studies. The algorithms comprises PID self-tuning control and optimal-k-step-ahead (O.K.) adaptive control. In 1983, Coppus et al. in [52] adapts the multi-variable, feedback-

feedforward controller of Davison to control the binary distillation column. Experiments have shown that it is not possible to explicitly apply a robust controller to the non-linear design of the distillation column. The robust controller was implemented and tested in a masters loop, cascaded in series to the multiloop proportional controlled distillation column. The outcomes of this contribution were i) Better control of the distillation column was achieved with robust feedback and feedforward control cascaded to a simple proportional controller. ii) Excellent set-point tracking and regulatory control performance has been achieved despite major upsets in process operating conditions. iii) The efforts required in tuning the controller are considerably less than tuning a PID controller on multiloop. Later, Thomas et al. in [53] contributed a short article which gives new desaturation strategy for digital PID controllers with a real time application of industrial batch reaction process.

Self-tuning PID controller has been implemented for level control of a lab scale water tank [11] and for Aluminum Rolling Mill [12]. Also, T. Yamamoto and S.L. Shah in [54] have proposed a new multivariable self-tuning PID controller design for level plus temperature control system. Further, P.J. Gawthrop in [55] has contributed by making a comparative evaluation of different adaptive control techniques for temperature control of industrial processes. It includes techniques that are based on a Z-N method, a waveform-analysis based, and least-square identification-based methods for self-tuning. Two industrial applications are used to control the temperature using these techniques: a plastic-on wire extrusion process and a laboratory furnace. Also the control strategies for temperature control of heating plant and Rapid Thermal Processing (RTP) were put forward in [56] (Robust nonlinear control) and [57] (Conventional and auto-adaptive algorithm). Chen and Chang in [58] and Hodel, CE Hall in [59] proposed a Variable Structure PID Control. C-L Chen and F-Y Chang in [58] considered the application of the pH control in the neutralization process with the use of neural/fuzzy variable structural proportional-integral-derivative (neural/fuzzy VSPID) control method. This neural/fuzzy VSPID controller has an identical structure to that of the conventional PID. The PD mode in this controller used to speed up the response in case of large errors, while the PI mode is used to reduce the steady-state offset for small error conditions. Visioli in [60] presented optimal tuning formulas for PID controllers for integral and unstable processes. Also, Optimal PID tuning method uses a direct search algorithms which has been proposed by Daley and Liu in [61]. These approaches can be used in various industrial applications, as well as those of high-order dynamics. The effectiveness of this approach has been demonstrated by the use of two industrial processes: one is a hydraulic system and combustor emission control with sluggish dynamics. The suggested tuning methodology in [61] is rely on the idea that the system

and its controller works in a parallel fashion in real-time. An optimization algorithm will automatically adjust the parameters of the model controller. After that, these can be retrieved to the controller itself. The reference model for a simple second-order system is defined as:

$$Z(s) = \frac{\omega_n^2}{s^2 + 2\zeta\omega_n s + \omega_n^2} \quad (3)$$

Where ζ is damping factor and ω_n is natural frequency of the system. It uses a direct search algorithm that can deal with both extreme non-linearities and discontinuities. The adaptive model is calculated with the help of parameters derived from the least square algorithm. The model form is

$$z_t = \alpha^T \phi_{t-1} \quad (4)$$

where $\alpha = [m_1, m_2, \dots, m_n, n_0, n_1, \dots, n_m]^T$

$$\phi_{t-1} = [-z_{t-1}, -z_{t-2}, \dots, -z_{t-n}, c_{t-d}, c_{t-d-1}, \dots, c_{t-d-m}]^T$$

c_t and z_t are the plant input and output respectively. m_i and n_i , are coefficients of a discrete transfer function and d is the plant delay.

The least squares algorithm is

$$\hat{\alpha}_t = \hat{\alpha}_{t-1} + P_t \phi_{t-1} (y_t - \hat{\alpha}_t^T \phi_{t-1}) \quad (5)$$

$$P_t = \lambda^{-1} (P_{t-1} - P_{t-1} \phi_{t-1} \phi_{t-1}^T (\lambda + \phi_{t-1}^T \phi_{t-1})^{-1}) \quad (6)$$

where $\lambda \in [0, 1]$ is a forgetting factor.

In 2000, Grassi and Tsakalis has proposed PID controller tuning by frequency loop-Shaping technique for the application to diffusion furnace temperature Control [62]. Also, Katebi and Moradi [63] have proposed design of predictive PID controllers with similar features to the model-based predictive controllers (MPC). Bernd-Markus Pfeiffer (Siemens) has introduced a new approach to control polymerization reactor which includes the feed-forward control with those of feedback control in a smart way [64]. An effective method of robust PID control proposed by Skoczowski et al. [65]. This can be conveniently implementable on controllers like PLC to the various applications in process industries. Similarly, some of researchers have put forward PID control strategies for various process control and industrial applications in [66–69] and in [70–73]. In [72] P. Teppa Garrán and G. Garcia introduces active disturbance rejection control (ADRC) for the design of an Optimal PID Controller for a coupled tanks system. In 2018, Eslami et al. [70] and Verma, Padhy [73] have proposed PID based intelligent control methods for water level control of canonical tank system and gas turbine respectively. Sina Razvarz et al. used the PID controller in [71] for fluid flow control in pipelines and proved that the PID controller is indeed the selection for process control

applications. The PID controller's stability is validated in the contribution which was not given attention in earlier research considering flow rate control. In addition, the technique of using the motor-pump arrangement with a torsional actuator is a completely new concept.

3.2 PID for robotic manipulator

Despite the progress of modern control theory, robot manipulator controllers still often use classical PD or PID algorithms, primarily due to their simplicity of concept and explicit tuning procedures. Y. Bestaoui proposed a method of robotic manipulator control based on decentralized pole-placement feedback deduced from the computed torque [74]. Also, Hong Zhang in [75] performs the optimal PID digitally implemented for the robotic manipulators. Later, Paolo Rocco in [76] and Dong Sun et al. in [77] proves the stability of PID control for industrial robot arms. PID control has been extended to nonlinear model of robot manipulators and also to the devices with similar dynamics [78]. Variable structure-based PID control schemes are proposed in [79,80].

Research related to PID controller which is applied to robotic manipulators are being categorized into three areas. The first area includes the tuning of PID gains by applying intelligent control such as fuzzy control [81–83], neural networks [84], or genetic methods [85]. The second area of research is targeted on the PID gain selection methods using control techniques such as optimal controls [86,87] or inverse dynamics controls [88]. The third type of research area comprises PID gain selection methods using a direct stability analysis using Lyapunov stability [89,90] and similarly, in [91] addresses the global asymptotic control of robot manipulators under input constraints, both with and without velocity measurements.

Chang et al. introduced a technique for gain selection of robust PID control for nonlinear Second-Order plants [92]. The technique used in [92] is easy and effective for tuning PID gains applicable to inaccurate models as well. Also, it provides an equivalence relationship between the PID control and TDC (Time delay control) in a discrete-time domain. In recent research work [93], Pradhan and Subudhi proposed a new nonlinear self-tuning PID controller (NSPIDC) to control a flexible-link manipulator (FLM) joint position and link deflection while it is subject to different payloads. Also, in [94] Shaban et al. proposed a new method for discrete time PID called PID+ applied to robotic manipulator.

3.3 PID for electric drives and power applications

The use of PID controllers is widespread in mechanical process automation where motor control is of concern. Also, PID control plays a vital role in power generation applications. CM Liaw et al. presents the quantitative design and deploy-

ment of a 2-degree PID Freedom Controller (2DOFC) for motor drives in [95]. KK Tan et al. in [96] tested the efficacy of a nonlinear PID controller enhanced with a learning technique when applied to piezoelectric actuator's precision motion control. Lin and Jan in [97,98] proposed a robust output tracking control design and genetic algorithm (GA)-based multi-objective PID control for a linear brushless DC motor with modelling uncertainties. The deployment of PID controls used to regulate dc motors has been experimentally shown by Kelly et al. in [99]. Zang et al. in [100] has developed an effective method for analysis and design for the two-inertia system. In [101] Angel and Viola introduces the design methods and analysis for PID controllers applicable to motor-generator system. Also, it Compares integer-order PID controller, the fractional-order PID controller, and the SIMC PID controller. New control strategies such as optimal control, adaptive control are presented in articles [102–104] contributed towards the control mechanism in DC Motor and motor drives. Particle swarm optimization, self-tuning PID controller, optimization of PID controller with genetic algorithm are used in automatic voltage regulator (AVR) system [105–107].

Implementation of PID control for DC-DC converter carried out by Kapat and Krein in [108] and by Seo et al. in [109]. The usage of PID based control strategies are effectively introduced in power generation and power station processes [110–113].

3.4 PID for biomedical applications

Various PID based control approaches are proposed for the biomedical applications such as arterial blood pressure infusion/regulation, muscle relaxation in surgical patients, joint angle control in artificially stimulated muscle, liver transplantation, blood glucose control, control of propofol anesthesia.

In [114], Slate and Sheppard used a nonlinear digital PID controller to regulate arterial blood pressure by infusing sodium nitroprusside into the drug. It is used during open-heart surgery in the cardiac surgical intensive care unit to control high blood pressure. In [115], Satoru Isaka and Anthony V Sebald investigated the application of automatic control strategies for control of arterial blood pressure. A variety of control methods are used in [115], including PID control and its variations, optimum control, adaptive control, rule-based control including blurred control, and neural network control. Denai et al. [116] implemented self-tuning PID regulation of muscle relaxation caused by atracurium in surgical patients. In [117], Veltink et al. also presents the joint angle regulation system for the artificially stimulated muscle.

Expert PID control system and improved PID switching control for blood glucose regulation are proposed in

[118,119]. PID controller is used to model vecuronium pharmacokinetics and pharmacodynamics during liver transplantation by O' Hara et al. in [120]. Robust PID control is proposed by Van Heusden et al. to control of Propofol Anesthesia in Children [121].

3.5 PID for mechanical systems

In industry most of the mechanical systems are controlled by PID control techniques. Research carried out in PID control methods that are applicable to active magnetic bearing (AMB) rotor systems, milling process, quadrotor, constant tension control system, magnetic levitation systems, twin-rotor MIMO systems, pilot crane, gripper, etc.

In [122] Marttinen et al. introduces a simple root-locus method which was used to tune a cascade type of PID controller for the application of pilot crane. Homberg et al. has presented a PID control strategy for laser surface hardening of steel [123]. Juang et al. in [124] introduces a new method using evolutionary computational PID control to a non-linear multi-input multi-output (MIMO) system through a laboratory setup of MIMO twin rotor system (TRMS). In [125], Jose Romero et al. defined a group of mechanical systems (e.g. inertia wheel, cranes, spherical pendulum etc.) that can be stabilized globally using a linear PID. In [126], Chunsheng Wei and Dirk Söffker presents the algorithms and the corresponding results from the design of an AMB controller, including optimisation using a multi-objective genetic algorithm. Similarly, a new active control technique is proposed in [127] to reduce chatter noise in the milling process. Ortiz et al. in [128] introduces the methodology for designing and implementing a non-linear robust controller for the regulation of attitude in an experimental framework of a quadrotor unmanned aerial vehicle (UAV). PID based control strategies are introduced for magnetic levitation systems in [129,130]. A saturation-based tuning method for fuzzy PID controller is proposed to control gripper rotation [131]. Meng et al. in recent research work proposed optimal fractional fuzzy PID control [132] which is used for a constant tension control system.

4 Conclusion and future direction of reasearch

On extensive literature survey we can conclude that the PID controller has become the most widely used controller in various application domains because of its simple structure and easy implementation. The emerging features of automatic tuning have greatly simplified the use of PID control. Recently, fractional-order PID combined with the fuzzy logic system, IMC-PID controller design, optimal PID control, combination of PID-observer structure are gradually got

attention. In the future, PID based control such as optimal fractional order PID, fractional fuzzy PID, self-tuning of PID can be extend it for numerical control systems applications. Also, it can be concluded that the PID can able to provide automatic tuning facility due to which it has received a more attention from the industrial users. The tuning of PID controllers would be a large research area.

References

1. Kang C-G (2016) Origin of stability analysis: "on governors" [historical perspectives]. *IEEE Control Syst Mag* 36(5):77–88
2. Medaglia JD (2019) Clarifying cognitive control and the controllable connectome. *Wiley Interdiscip Rev Cognit Sci* 10(1):1471
3. Åström KJ, Kumar PR (2014) Control: a perspective. *Automatica* 50(1):3–43
4. Bennett S (2000) The past of PID controllers. *Ann Rev Control* 25:43–53
5. Bennett S (1993) Development of the PID controller. *IEEE Control Syst Mag* 13(6):58–62
6. Fong-Chwee T, Sirisena HR (1988) Self-tuning PID controllers for dead time processes. *IEEE Trans Ind Electr* 35(1):119–125
7. Besharati Rad A, Lo WL, Tsang KM (1997) Self-tuning PID controller using Newton–Raphson search method. *IEEE Trans Ind Electr* 44(5):717–725
8. Leva A (1993) PID autotuning algorithm based on relay feedback. In: *IEE Proceedings D (Control Theory and Applications)*, vol 140. pp 328–338. IET
9. Zhuang M, Atherton DP (1993) Automatic tuning of optimum PID controllers. In *IEE Proceedings D (Control Theory and Applications)*, vol 140. pp 216–224. IET
10. Åström KJ, Hägglund T, Hang CC, Ho WK (1993) Automatic tuning and adaptation for PID controllers—a survey. *Contr Eng Pract* 1(4):699–714
11. Gawthrop P (1986) Self-tuning PID controllers: algorithms and implementation. *IEEE Trans Autom Contr* 31(3):201–209
12. Brown RE, Malotis GN, Gibby JA (1993) PID self-tuning controller for aluminum rolling mill. *IEEE Trans Ind Appl* 29(3):578–583
13. Vega P, Prada C, Aleixandre V (1991) Self-tuning predictive PID controller. In: *IEE Proceedings D (Control Theory and Applications)*, vol 138, pp 303–312. IET
14. Khodadadi H, Ghadiri H (2018) Self-tuning PID controller design using fuzzy logic for half car active suspension system. *Int J Dyn Control* 6(1):224–232
15. Porter B, Jones AH (1992) Genetic tuning of digital PID controllers. *Electr Lett* 28(9):843–844
16. Kristiansson B, Lennartson B (2002) Robust and optimal tuning of PI and PID controllers. *IEE Proc Contr Theory Appl* 149(1):17–25
17. Gundes AN, Ozguler AB (2007) PID stabilization of MIMO plants. *IEEE Trans Autom Contr* 52(8):1502–1508
18. Hsieh C-H, Chou J-H (2007) Design of optimal PID controllers for pwm feedback systems with bilinear plants. *IEEE Trans Contr Syst Technol* 15(6):1075–1079
19. Chan YF, Moallem M, Wang W (2007) Design and implementation of modular FPGA-based PID controllers. *IEEE Trans Ind Electro* 54(4):1898–1906
20. Yamamoto T, Takao K, Yamada T (2008) Design of a data-driven PID controller. *IEEE Trans Contr Syst Technol* 17(1):29–39
21. Sio KC, Lee CK (1998) Stability of fuzzy PID controllers. *IEEE Trans Syst Man Cybern Part A Syst Humans* 28(4):490–495

22. Tzafestas S, Papanikolopoulos NP (1990) Incremental fuzzy expert PID control. *IEEE Trans Ind Electr* 37(5):365–371
23. Zhao Z-Y, Tomizuka M, Isaka S (1993) Fuzzy gain scheduling of PID controllers. *IEEE Trans Syst Man Cybern* 23(5):1392–1398
24. Minh Vu K (1992) Optimal setting for discrete PID controllers. In: *IEE Proceedings D (Control Theory and Applications)*, vol 139, pp 31–40. IET
25. Tang K-S, Man KF, Chen G, Kwong S (2001) An optimal fuzzy PID controller. *IEEE Trans Ind Electr* 48(4):757–765
26. Verma B, Padhy PK (2018a) Optimal PID controller design with adjustable maximum sensitivity. *IET Contr Theory Appl* 12(8):1156–1165
27. Zolotas AC, Halikias GD (1999) Optimal design of PID controllers using the QFT method. *IEE Proc Contr Theory Appl* 146(6):585–589
28. Kaya Y, Yamamura S (1962) A self-adaptive system with a variable-parameter PID controller. *Trans Am Instit Electr Eng Part II Appl Ind* 80(6):378–386
29. Zhenbin W, Zhenlei W, Guangyi C, Xinjian Z (2005) Digital implementation of fractional order PID controller and its application. *J Syst Eng Electr* 16(1):116–122
30. Viola J, Angel L (2015) Factorial design for robustness evaluation of fractional PID controllers. *IEEE Lat Am Trans* 13(5):1286–1293
31. Ranjbaran K, Tabatabaei M (2018) Fractional order [PI],[PD] and [PI][PD] controller design using Bode's integrals. *Int J Dyn Contr* 6(1):200–212
32. Bongulwar MR, Patre BM (2018) Design of FOPID controller for fractional-order plants with experimental verification. *Int J Dyn Contr* 6(1):213–223
33. Åström KJ, Hägglund T (2001) The future of PID control. *Contr Eng Pract* 9(11):1163–1175
34. Díaz-Rodríguez Iván D, Sangjin H, Bhattacharyya Shankar P (2019) Analytical design of PID controllers. Springer, Berlin. ISBN 978-3-030-18227-4
35. Ziegler John G, Nichols Nancy B (1942) Optimum settings for automatic controllers. *J Dyn Syst Meas Control Trans ASME* 115:220–222
36. Åström KJ, Hägglund T (1984) Automatic tuning of simple regulators. *IFAC Proc Vol* 17(2):1867–1872
37. Ho WK, Gan OP, Tay EB, Ang EL (1996) Performance and gain and phase margins of well-known PID tuning formulas. *IEEE Trans Contr Syst Technol* 4(4):473–477
38. Koivo HN, Tantt JT (1991) Tuning of PID controllers: Survey of SISO and MIMO techniques. In: Devanathan R (ed) *Intelligent tuning and adaptive control*, pp 75–80. Elsevier
39. Ruano AEB, Fleming PJ, Jones DI (1992) Connectionist approach to PID autotuning. In: *IEE Proceedings D (Control Theory and Applications)*, vol 139, pp 279–285. IET
40. Aguirre LA (1992) PID tuning based on model matching. *Electr Lett* 28(25):2269–2271
41. Zhuang M, Atherton DP (1994) PID controller design for a TITO system. *IEE Proc Contr Theory Appl* 141(2):111–120
42. Poulin E, Pomerleau A (1996) PID tuning for integrating and unstable processes. *IEE Proc Contr Theory Appl* 143(5):429–435
43. Tan W, Liu J, Tam PKS (1998) PID tuning based on loop-shaping H_∞ control. *IEE Proc Contr Theory Appl* 145(6):485–490
44. Wang Q-G, Lee T-H, Fung H-W, Bi Q, Zhang Y (1999) PID tuning for improved performance. *IEEE Trans Contr Syst Technol* 7(4):457–465
45. Mann GKI, Hu B-G, Gosine RG (2001) Time-domain based design and analysis of new PID tuning rules. *IEE Proc Contr Theory Appl* 148(3):251–261
46. Visioli A (2001a) Tuning of PID controllers with fuzzy logic. *IEE Proc Contr Theory Appl* 148(1):1–8
47. Cominos P, Munro N (2002) PID controllers: recent tuning methods and design to specification. *IEE Proc Contr Theory Appl* 149(1):46–53
48. Huang H-P, Roan M-L, Jeng J-C (2002) On-line adaptive tuning for PID controllers. *IEE Proc Contr Theory Appl* 149(1):60–67
49. Lennartson B, Kristiansson B (2009) Evaluation and tuning of robust PID controllers. *IET Contr Theory Appl* 3(3):294–302
50. Stafford EM (1977) Design aid for approximate PD and PID on/off controllers. *Electr Lett* 13(6):163–164
51. Jacobs OLR, Hewkin PF, While C (1980) Online computer control of PH in an industrial process. In: *IEE Proceedings D (Control Theory and Applications)*, vol 127, pp 161–168. IET
52. Coppus GWM, Shah SL, Wood RK (1983) Robust multivariable control of a binary distillation column. In: *IEE Proceedings D (Control Theory and Applications)*, vol 30, pp 201–208. IET
53. Thomas HW, Sandoz DJ, Thomson M (1983) New desaturation strategy for digital PID controllers. In: *IEE Proceedings D (Control Theory and Applications)*, vol 130, pp 188–192. IET
54. Yamamoto T, Shah SL (2004) Design and experimental evaluation of a multivariable self-tuning PID controller. *IEE Proc Control Theory Appl* 151(5):645–652
55. Gawthrop PJ, Nomikos PE, Smith LSPS (1990) Adaptive temperature control of industrial processes: a comparative study. In: *IEE Proceedings D (Control Theory and Applications)*, vol 137, pp 137–144. IET
56. Edwards C, Spurgeon SK (1994) Robust nonlinear control of heating plant. *IEE Proc Contr Theory Appl* 141(4):227–234
57. Dilhac J-M, Ganibal C, Bordeneuve J, Nollhier N (1992) Temperature control in a rapid thermal processor. *IEEE Trans Electr Devices* 39(1):201–203
58. Chen C-L, Chang F-Y (1996) Design and analysis of neural/fuzzy variable structural PID control systems. *IEE Proc Contr Theory Appl* 143(2):200–208
59. Scottedward Hodel A, Hall CE (2001) Variable-structure PID control to prevent integrator windup. *IEEE Trans Ind Electr* 48(2):442–451
60. Visioli A (2001b) Optimal tuning of PID controllers for integral and unstable processes. *IEE Proc Contr Theory Appl* 148(2):180–184
61. Daley S, Liu GP (1999) Optimal PID tuning using direct search algorithms. *Comput Contr Eng J* 10(2):51–56
62. Grassi E, Tsakalis K (2000) PID controller tuning by frequency loop-shaping: application to diffusion furnace temperature control. *IEEE Trans Contr Syst Technol* 8(5):842–847
63. Katebi MR, Moradi MH (2001) Predictive PID controllers. *IEE Proc Contr Theory Appl* 148(6):478–487
64. Pfeiffer BM (2003) PID control of batch processes along pre-optimised trajectories. *Comput Contr Eng J* 14(5):16–21
65. Skoczowski S, Domek S, Pietrusiewicz K, Broel-Plater B (2005) A method for improving the robustness of PID control. *IEEE Trans Ind Electr* 52(6):1669–1676
66. Dinca MP, Gheorghe M, Galvin P (2008) Design of a PID controller for a pcr micro reactor. *IEEE Trans Edu* 52(1):116–125
67. Papadopoulos KG, Papastefanaki EN, Margaritis NI (2012) Explicit analytical PID tuning rules for the design of Type-III control loops. *IEEE Trans Ind Electr* 60(10):4650–4664
68. Gil P, Lucena C, Cardoso A, Palma LB (2014) Gain tuning of fuzzy PID controllers for mimo systems: a performance-driven approach. *IEEE Trans Fuzzy Syst* 23(4):757–768
69. Torres WL, Araujo IBQ, Filho JBM, Junior AGC (2017) Mathematical modeling and PID controller parameter tuning in a didactic thermal plant. *IEEE Lat Am Trans* 15(7):1250–1256
70. Eslami M, Shayesteh MR, Pourahmadi M (2018) Optimal design of PID-based low-pass filter for gas turbine using intelligent method. *IEEE Access* 6:15335–15345

71. Razvarz S, Vargas-Jarillo C, Jafari R, Gegov A (2019) Flow control of fluid in pipelines using PID controller. *IEEE Access* 7:25673–25680
72. Garrañ PT, García G (2017) Design of an optimal PID controller for a coupled tanks system employing adrc. *IEEE Lat Am Trans* 15(2):189–196
73. Verma B, Padhy PK (2018b) Indirect IMC-PID controller design. *IET Contr Theory Appl* 13(2):297–305
74. Bestaoui Y (1989) Decentralised PD and PID robotic regulators. In: *IEE Proceedings D (Control Theory and Applications)*, vol 136. pp 133–145. IET
75. Zhang H, Trott G, Paul RP (1990) Minimum delay PID control of interpolated joint trajectories of robot manipulators. *IEEE Trans Ind Electr* 37(5):358–364
76. Rocco P (1996) Stability of PID control for industrial robot arms. *IEEE Trans Robot Autom* 12(4):606–614
77. Sun D, Songyu H, Shao X, Liu C (2009) Global stability of a saturated nonlinear PID controller for robot manipulators. *IEEE Trans Contr Syst Technol* 17(4):892–899
78. Feng W, O'reilly J, Ballance DJ (2002) MIMO nonlinear PID predictive controller. *IEE Proc Contr Theory Appl* 149(3):203–208
79. Parra-Vega V, Arimoto S, Liu Y-H, Hirzinger G, Akella P (2003) Dynamic sliding PID control for tracking of robot manipulators: theory and experiments. *IEEE Trans Robot Autom* 19(6):967–976
80. Jafarov EM, Alpaslan Parlakci MN, Istefanopulos Y (2004) A new variable structure PID-controller design for robot manipulators. *IEEE Trans Contr Syst Technol* 13(1):122–130
81. Li W, Chang XG, Wahl FM, Farrell J (2001) Tracking control of a manipulator under uncertainty by fuzzy P + ID controller. *Fuzzy Sets Syst* 122(1):125–137
82. Kazemian HB (2002) The SOF-PID controller for the control of a MIMO robot arm. *IEEE Trans Fuzzy Syst* 10(4):523–532
83. Sun YL, Joo Er M (2004) Hybrid fuzzy control of robotics systems. *IEEE Trans Fuzzy Syst* 12(6):755–765
84. Yildirim S, Sukkar MF, Demirci R, Aslantas V (1996) Design of adaptive nns-robust-PID controller for a robot control. In: *Proceedings of the 1996 IEEE International Symposium on Intelligent Control*, pp 508–513. IEEE
85. Kwok DP, Sheng F (1994) Genetic algorithm and simulated annealing for optimal robot arm PID control. In: *Proceedings of the First IEEE Conference on Evolutionary Computation. IEEE World Congress on Computational Intelligence*, pp 707–713. IEEE
86. Park J, Chung WK (2000a) Analytic nonlinear H/sub/spl infin//inverse-optimal control for Euler–Lagrange system. *IEEE Trans Robot Autom* 16(6):847–854
87. Park J, Chung W (2000b) Design of a robust H_∞ PID control for industrial manipulators. *J Dyn Syst Meas Contr* 122(4):803–812
88. Cervantes I, Alvarez-Ramirez J (2001) On the PID tracking control of robot manipulators. *Syst Contr Lett* 42(1):37–46
89. Eriksson E, Jan Wikander (2002) Robust PID design of flexible manipulators through pole assignment. In: *7th International Workshop on Advanced Motion Control. Proceedings (Cat. No. 02TH8623)*, pp 420–425. IEEE
90. Alavarez-Ramirez J, Cervantes I, Bautista R (2002) Robust PID control for robots manipulators with elastic joints. In: *Proceedings of the 2001 IEEE International Conference on Control Applications (CCA'01)(Cat. No. 01CH37204)*, pp 542–547. IEEE
91. Yuxin S, Muller PC, Zheng C (2009) Global asymptotic saturated PID control for robot manipulators. *IEEE Trans Contr Syst Technol* 18(6):1280–1288
92. Chang PH, Jung JH (2008) A systematic method for gain selection of robust PID control for nonlinear plants of second-order controller canonical form. *IEEE Trans Contr Syst Technol* 17(2):473–483
93. Kumar Pradhan S, Subudhi B (2020) Position control of a flexible manipulator using a new nonlinear self tuning PID controller. *IEEE/CAA J Automat Sin* 7:136–149
94. Shaban EM, Sayed H, Abdelhamid A (2019) A novel discrete PID + controller applied to higher order/time delayed nonlinear systems with practical implementation. *Int J Dyn Contr* 7(3):888–900
95. Liaw CM, Chao KH, Chen YK, Chen HC (1998) Quantitative design and implementation of PI-D controller with model-following response for motor drive. *IEE Proc Electr Power Appl* 145(2):98–104
96. Tan KK, Lee TH, Zhou HX (2001) Micro-positioning of linear-piezoelectric motors based on a learning nonlinear PID controller. *IEEE/ASME Trans Mech* 6(4):428–436
97. Lin C-L, Jan H-Y (2002) Multiobjective PID control for a linear brushless DC motor: an evolutionary approach. *IEE Proc Electr Power Appl* 149(6):397–406
98. Lin C-L, Jan H-Y, Shieh N-C (2003) Ga-based multiobjective PID control for a linear brushless DC motor. *IEEE/ASME Trans Mech* 8(1):56–65
99. Kelly R, Moreno J (2001) Learning PID structures in an introductory course of automatic control. *IEEE Trans Edu* 44(4):373–376
100. Zhang G, Furusho J (2000) Speed control of two-inertia system by PI/PID control. *IEEE Trans Ind Electr* 47(3):603–609
101. Angel L, Viola J (2015) Design and statistical robustness analysis of FOPID, IOPID and SIMC PID controllers applied to a motor-generator system. *IEEE Lat Am Trans* 13(12):3724–3734
102. Jung J-W, Leu VQ, Do TD, Kim E-K, Choi HH (2014) Adaptive PID speed control design for permanent magnet synchronous motor drives. *IEEE Trans Power Electr* 30(2):900–908
103. Viola J, Angel L, Sebastian JM (2017) Design and robust performance evaluation of a fractional order PID controller applied to a dc motor. *IEEE/CAA J Automatica Sinica* 4(2):304–314
104. Hekimoğlu B (2019) Optimal tuning of fractional order PID controller for DC motor speed control via chaotic atom search optimization algorithm. *IEEE Access* 7:38100–38114
105. Gaing Z-L (2004) A particle swarm optimization approach for optimum design of PID controller in AVR system. *IEEE Trans Energy Convers* 19(2):384–391
106. Kim K, Rao P, Burnworth JA (2010) Self-tuning of the PID controller for a digital excitation control system. *IEEE Trans Ind Appl* 46(4):1518–1524
107. Hasanien HM (2012) Design optimization of PID controller in automatic voltage regulator system using taguchi combined genetic algorithm method. *IEEE Syst J* 7(4):825–831
108. Kapat S, Krein PT (2011) Formulation of PID control for DC-DC converters based on capacitor current: a geometric context. *IEEE Trans Power Electr* 27(3):1424–1432
109. Seo S-W, Choi HH (2019) Digital implementation of fractional order PID-type controller for boost DC-DC converter. *IEEE Access* 7:142652–142662
110. Natarajan K (2005) Robust PID controller design for hydroturbines. *IEEE Trans Energy Convers* 20(3):661–667
111. Behera A, Panigrahi TK, Ray PK, Sahoo AK (2019) A novel cascaded PID controller for automatic generation control analysis with renewable sources. *IEEE/CAA J Automatica Sinica* 6(6):1438–1451
112. Osinski C, Leandro GV, Henrique G Oliveira (2019) Fuzzy PID controller design for lfc in electric power systems. *IEEE Lat Am Trans* 17(01):147–154
113. Glickman S, Kulesky R, Nudelman G (2004) Identification-based PID control tuning for power station processes. *IEEE Trans Contr Syst Technol* 12(1):123–132
114. Slate JB, Sheppard LC (1982) Automatic control of blood pressure by drug infusion. *IEE Proc A Phys Sci Meas Instrum Manag Edu Rev* 129(9):639–645

115. Isaka S, Sebald AV (1993) Control strategies for arterial blood pressure regulation. *IEEE Trans Biomed Eng* 40(4):353–363
116. Denai M, Linkens DA, Asbury AJ, MacLeod AD, Gray WM (1990) Self-tuning PID control of atracurium-induced muscle relaxation in surgical patients. In: *IEE Proceedings D (Control Theory and Applications)*, vol 137. pp 261–272. IET
117. Veltink PH, Chizeck HJ, Crago PE, El-Bialy A (1992) Nonlinear joint angle control for artificially stimulated muscle. *IEEE Trans Biomed Eng* 39(4):368–380
118. Chee F, Fernando TL, Savkin AV, Van Heeden V (2003) Expert PID control system for blood glucose control in critically ill patients. *IEEE Trans Inf Technol Biomed* 7(4):419–425
119. Marchetti G, Barolo M, Jovanovic L, Zisser H, Seborg DE (2008) An improved PID switching control strategy for type 1 diabetes. *IEEE Trans Biomed Eng* 55(3):857–865
120. O'Hara DA, Hexem JG, Derbyshire GJ, Overdyk FJ, Chen B, Henthorn TK, Li JK-J (1997) The use of a PID controller to model vecuronium pharmacokinetics and pharmacodynamics during liver transplantation. *IEEE Trans Biomed Eng* 44(7):610–619
121. Van Heusden K, Dumont GA, Soltesz K, Petersen CL, Umedaly A, West N, Mark Ansermino J (2013) Design and clinical evaluation of robust PID control of propofol anesthesia in children. *IEEE Trans Contr Syst Technol* 22(2):491–501
122. Marttinen A, Virkkunen JOUKO, Salminen RT (1990) Control study with a pilot crane. *IEEE Trans Edu* 33(3):298–305
123. Homberg D, Weiss W (2006) PID control of laser surface hardening of steel. *IEEE Trans Contr Syst Technol* 14(5):896–904
124. Juang J-G, Huang M-T, Liu W-K (2008) PID control using pre-searched genetic algorithms for a MIMO system. *IEEE Trans Syst Man Cybern Part C Appl Rev* 38(5):716–727
125. Romero JG, Ortega R, Donaire A (2016) Energy shaping of mechanical systems via PID control and extension to constant speed tracking. *IEEE Trans Autom Contr* 61(11):3551–3556
126. Wei C, Söffker D (2015) Optimization strategy for PID-controller design of amb rotor systems. *IEEE Trans Contr Syst Technol* 24(3):788–803
127. Paul S, Morales-Menendez R (2018) Active control of chatter in milling process using intelligent PD/PID control. *IEEE Access* 6:72698–72713
128. Ortiz JP, Minchala LI, Reinoso MJ (2016) Nonlinear robust H-infinity PID controller for the multivariable system quadrotor. *IEEE Lat Am Trans* 14(3):1176–1183
129. Wai R-J, Lee J-D, Chuang K-L (2010) Real-time PID control strategy for maglev transportation system via particle swarm optimization. *IEEE Trans Ind Electr* 58(2):629–646
130. Chen Q, Tan Y, Li J, Mareels I (2017) Decentralized PID control design for magnetic levitation systems using extremum seeking. *IEEE Access* 6:3059–3067
131. Duan X-G, Deng H, Li H-X (2012) A saturation-based tuning method for fuzzy PID controller. *IEEE Trans Ind Electr* 60(11):5177–5185
132. Meng F, Liu S, Liu K (2020) Design of an optimal fractional order PID for constant tension control system. *IEEE Access* 8:58933–58939. <https://doi.org/10.1109/ACCESS.2020.2983059>