

ILLUSTRATIVE SAMPLE - NOT AN OFFICIAL DOCUMENT

Written for the Layer 0 proof of concept. It was not issued by the Syracuse Regional Airport Authority, and its content is invented for demonstration.

ADDENDUM NO. 1

Request for Proposals - Switchgear Procurement, RFP Reference # 2023-20

Syracuse Regional Airport Authority

Date of Addendum: September 5, 2023

This addendum modifies the Request for Proposals as follows. Page numbers refer to the RFP document. Specification means 22186.00-SPC-E01, Specification for Metal Clad Switchgear.

A. MODIFICATIONS

1. Section 1.9, Submission Due Date, page 5: replace "09/15/2023 by 4:00PM" with "09/29/2023 by 4:00PM".

2. Specification Section 1.1.E.1, page 55: replace "eighteen (18) 15kV vacuum circuit breaker positions" with "twenty (20) 15kV vacuum circuit breaker positions".

B. ADDITIONS

3. Specification Section 1.1.E, page 56: add the following as item 11. "The switchgear lineup shall be seismically qualified for the site, and the MANUFACTURER shall provide the seismic qualification report with the submittals."

4. Specification Part 1, after Section 1.6: add the following as Section 1.7, Warranty. "The MANUFACTURER shall warrant the switchgear lineup against defects in materials and workmanship for sixty (60) months from the date of energization."

C. DELETIONS

5. Specification Section 1.1.D.3, page 55: the sentence "In addition to other Submittal requirements, final drawings shall be submitted as AutoCAD format files." is deleted in its entirety.

D. QUESTIONS AND ANSWERS

6. Question: Is arc-resistant Type 2B construction required? Answer: Yes, arc-resistant Type 2B construction is required as specified in Section 1.1.E.2; no change.

E. GENERAL

Please acknowledge receipt of this addendum on the proposal form.

All other terms and conditions of the RFP remain unchanged.