Energy Storage in Remote Australia: conniptions and kerfuffles

Phil Maker <philip.maker@gmail.com>

ACEP/Powerwater Remote Operations

March 2014

Abstract

A review of energy storage in hybrid systems in Remote Australia including the messy bits (well a wee bit at least).

Where: Australia

*"I keep six honest serving men,
They taught me all I knew,
Their names are What and
Why and When And How and
Where and Who."* – *Kipling*

Where: Australia

*"I keep six honest serving men,
They taught me all I knew,
Their names are What and
Why and When And How and
Where and Who."* – Kipling

- *Energy storage in
  NT/WA.*

Where: Australia

*"I keep six honest serving men,
They taught me all I knew,
Their names are What and
Why and When And How and
Where and Who."* – Kipling

- *Energy storage in NT/WA.*

- *And the conniptions and kerfuffles (see handbook).*

Where: Australia



"I keep six honest serving men, They taught me all I knew, Their names are What and Why and When And How and Where and Who." – Kipling

- *Energy storage in NT/WA.*
- *And the conniptions and kerfuffles (see handbook).*
- *Feel free to interrupt or redirect me.*

Northern Territory/Powerwater

- Early SMA systems for delaying gen switch up (20y lifetime).
- Small ($\approx$ 50kW) PV/Wind systems.
- Concentrated PV with limited smoothing.
- Ti Tree, Kalkarindji and Lake Nash ($\approx$ 1MW total PV, 80% peak penetration).
- ASIM and Solar Diesel Handbook.
- Medium Pen Rollout.
- High Pen Diesel off systems.

Western Australia/Horizon Power, Verve Energy

In the past:

Western Australia/Horizon Power, Verve Energy

In the past:

- ▶ Wind Diesel systems using Enercon, Vestas and Vergnet WTGS.

Western Australia/Horizon Power, Verve Energy

In the past:

- Wind Diesel systems using Enercon, Vestas and Vergnet WTGS.
- Low Load Diesels: 12L/hr at 7% load for 320kW generator which gives us 280kW of spinning reserve and 190kW of step load.

Western Australia/Horizon Power, Verve Energy

In the past:

- Wind Diesel systems using Enercon, Vestas and Vergnet WTGS.

- Low Load Diesels: 12L/hr at 7% load for 320kW generator which gives us 280kW of spinning reserve and 190kW of step load.

- Flywheel Energy Storage: 18MWs at 500kW so 36s at rated which is enough to start and synchronise a diesel.

Western Australia/Horizon Power, Verve Energy

In the past:

- Wind Diesel systems using Enercon, Vestas and Vergnet WTGS.

- Low Load Diesels: 12L/hr at 7% load for 320kW generator which gives us 280kW of spinning reserve and 190kW of step load.

- Flywheel Energy Storage: 18MWs at 500kW so 36s at rated which is enough to start and synchronise a diesel.

Western Australia/Horizon Power, Verve Energy

In the past:

- Wind Diesel systems using Enercon, Vestas and Vergnet WTGS.
- Low Load Diesels: 12L/hr at 7% load for 320kW generator which gives us 280kW of spinning reserve and 190kW of step load.
- Flywheel Energy Storage: 18MWs at 500kW so 36s at rated which is enough to start and synchronise a diesel.

Currently:

- PV with hosting capacity limits and mandatory battery smoothing.

Western Australia/Horizon Power, Verve Energy

In the past:

- Wind Diesel systems using Enercon, Vestas and Vergnet WTGS.
- Low Load Diesels: 12L/hr at 7% load for 320kW generator which gives us 280kW of spinning reserve and 190kW of step load.
- Flywheel Energy Storage: 18MWs at 500kW so 36s at rated which is enough to start and synchronise a diesel.

Currently:

- PV with hosting capacity limits and mandatory battery smoothing.
- Its very hard to get some of them away from Low Load diesels :-).

Western Australia/Horizon Power, Verve Energy

In the past:

- Wind Diesel systems using Enercon, Vestas and Vergnet WTGS.
- Low Load Diesels: 12L/hr at 7% load for 320kW generator which gives us 280kW of spinning reserve and 190kW of step load.
- Flywheel Energy Storage: 18MWs at 500kW so 36s at rated which is enough to start and synchronise a diesel.

Currently:

- PV with hosting capacity limits and mandatory battery smoothing.
- Its very hard to get some of them away from Low Load diesels :-).
- But I'm sure something will happen.

Some obvious facts?

- A standby loss of $x > k$ kW is a show stopper!

Some obvious facts?

- A standby loss of $x > k$ kW is a show stopper!
  For example a 500kW for 36s flywheel is useless because its
  standby losses might be 15kW.

Some obvious facts?

- A standby loss of $x > k$ kW is a show stopper!
  For example a 500kW for 36s flywheel is useless because its standby losses might be 15kW.
  Complete piffle: just resize your PV array by 30kW ($<$10%) and have a a brandy, its not the standby loss, its the CAPEX/Engineering

Some obvious facts?

- A standby loss of $x > k$ kW is a show stopper!
  For example a 500kW for 36s flywheel is useless because its standby losses might be 15kW.
  Complete piffle: just resize your PV array by 30kW ($<$10%) and have a a brandy, its not the standby loss, its the CAPEX/Engineering

- Round trip efficiency is important.

Some obvious facts?

- A standby loss of $x > k$ kW is a show stopper!
  For example a 500kW for 36s flywheel is useless because its standby losses might be 15kW.
  Complete piffle: just resize your PV array by 30kW ($<$10%) and have a a brandy, its not the standby loss, its the CAPEX/Engineering

- Round trip efficiency is important.Well perhaps but if you can give me a cheap 500kW solution with 50% round trip efficiency I'm going to buy it.

Some obvious facts?

- A standby loss of $x > k$ kW is a show stopper!
  For example a 500kW for 36s flywheel is useless because its standby losses might be 15kW.
  Complete piffle: just resize your PV array by 30kW ($<$10%) and have a a brandy, its not the standby loss, its the CAPEX/Engineering

- Round trip efficiency is important.Well perhaps but if you can give me a cheap 500kW solution with 50% round trip efficiency I'm going to buy it.

- Its about energy and load shifting.

Some obvious facts?

- A standby loss of $x > k$ kW is a show stopper!
  For example a 500kW for 36s flywheel is useless because its
  standby losses might be 15kW.
  **Complete piffle: just resize your PV array by 30kW
  ($<$10%) and have a a brandy, its not the standby loss,
  its the CAPEX/Engineering**

- Round trip efficiency is important.Well perhaps but if you can
  give me a cheap 500kW solution with 50% round trip
  efficiency I'm going to buy it.

- Its about energy and load shifting.A bit, it turns out that
  most of our NT work will be power limited using East/West
  arrays (or tracking).

Our Past Mistakes

So what have your mob got wrong:

Our Past Mistakes

So what have your mob got wrong:

- TKLN - an award winning design that flogs batteries for no real reason.

Our Past Mistakes

So what have your mob got wrong:

- TKLN - an award winning design that flogs batteries for no real reason.
  Well we do not use the diesel spinning reserve as a resource.

Our Past Mistakes

So what have your mob got wrong:

- TKLN - an award winning design that flogs batteries for no real reason.
  Well we do not use the diesel spinning reserve as a resource.
- Concentrated Solar that is not intergrated in the power system.

Our Past Mistakes

So what have your mob got wrong:

- ▶ TKLN - an award winning design that flogs batteries for no real reason.
  Well we do not use the diesel spinning reserve as a resource.

- ▶ Concentrated Solar that is not intergrated in the power system.

- ▶ No Low Load Diesels.

Our Past Mistakes

So what have your mob got wrong:

- ▶ TKLN - an award winning design that flogs batteries for no real reason.
  Well we do not use the diesel spinning reserve as a resource.

- ▶ Concentrated Solar that is not intergrated in the power system.

- ▶ No Low Load Diesels.
  Note that running diesels at low load is impossible and anyone who suggests it is a liar and a coward.

Our Past Mistakes

So what have your mob got wrong:

- ▶ TKLN - an award winning design that flogs batteries for no real reason.
  Well we do not use the diesel spinning reserve as a resource.

- ▶ Concentrated Solar that is not intergrated in the power system.

- ▶ No Low Load Diesels.
  Note that running diesels at low load is impossible and anyone who suggests it is a liar and a coward.

- ▶ And difficulties in sizing sets for loads.

Our Future Mistakes

So our cunning plans are:

- ▶ We've done a few design studies and a wee bit of modelling.

Our Future Mistakes

So our cunning plans are:

- We've done a few design studies and a wee bit of modelling.
- Expecting to use a 30m..2h Li Ion battery system with diesel off capability.

Our Future Mistakes

So our cunning plans are:

- We've done a few design studies and a wee bit of modelling.
- Expecting to use a 30m..2h Li Ion battery system with diesel off capability. That is we need a power battery, we are not doing load shifting.

Our Future Mistakes

So our cunning plans are:

- We've done a few design studies and a wee bit of modelling.
- Expecting to use a 30m..2h Li Ion battery system with diesel off capability. That is we need a power battery, we are not doing load shifting.
- Roll out medium penetration first and prove to our operations people that high penetration can work.

Our Future Mistakes

So our cunning plans are:

- We've done a few design studies and a wee bit of modelling.
- Expecting to use a 30m..2h Li Ion battery system with diesel off capability. That is we need a power battery, we are not doing load shifting.
- Roll out medium penetration first and prove to our operations people that high penetration can work.
- Continue working on a variety of projects in order to improve system performance.

So what!

- Share our lessons learnt in a frank fashion.

So what!

- ▶ Share our lessons learnt in a frank fashion.
- ▶ Chemistry is difficult.

So what!

- ► Share our lessons learnt in a frank fashion.
- ► Chemistry is difficult.
- ► Its not just the technology.

So what!

- ▶ Share our lessons learnt in a frank fashion.
- ▶ Chemistry is difficult.
- ▶ Its not just the technology.
- ▶ Don't look at the problem just from your interests, e.g. in my case control systems.

So what!

- Share our lessons learnt in a frank fashion.
- Chemistry is difficult.
- Its not just the technology.
- Don't look at the problem just from your interests, e.g. in my case control systems.
- Try to replicate projects/share risks,

So what!

- Share our lessons learnt in a frank fashion.
- Chemistry is difficult.
- Its not just the technology.
- Don't look at the problem just from your interests, e.g. in my case control systems.
- Try to replicate projects/share risks,particularly with remote battery chemistry.

"Learning is not compulsory...

So what!

- Share our lessons learnt in a frank fashion.
- Chemistry is difficult.
- Its not just the technology.
- Don't look at the problem just from your interests, e.g. in my case control systems.
- Try to replicate projects/share risks,particularly with remote battery chemistry.

"Learning is not compulsory...
neither is survival" – W. Edwards Deming