

Inspection Packs for Am(S)

ID	Fluid Category	Enhanced Inspection	Notes
3	Innocuous	Visual inspection is to be completed to the extent to satisfy the examiner that B31.3 conformance is met.\n\nLesser of 5 psig or 25% of Design Pressure snoop test of random mechanical joints for vapour / gas commodities. 5% MT for carbon steel pipe \n\n5% PT for stainless steel pipe	In service visual inspection to be completed during initial commissioning of lines.