

HYDRAULIC PARTICULARS HNSS MAIN CANAL FROM KM 115.350 TO 125.000

SL. No	Reach No	Reach In KM			Hydraulic Particulars										Loss (m)			Bed Level		Full Supply Level		Remarks	
		From	TO	Distance (IN Mts)	Required Discharge (Cumecs)	Bed Width (In Mts)	F.S.D (IN Mts)	Surface Fall	Side Slopes	A(m2)	P(m)	R(m)	R=2/3	Velocity M/Sec	Designed Discharge (Cumecs)	Due To Bed Fall	DueTo CM & CD Structures	Total	AT Start (M)	AT End (M)	AT Start (M)		AT End (M)
		2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
	3	115.350	125.000	9650	95.460	9.5.	4.70.	1:8500	1.50:1	77.79	26.446	2.941.	2.053.	1.237.	96.221.	1.135	0.000.	1.135	446.183.	445.047.	450.883.	449.747.	ALL SOILS

