

GROUP HOUSING

UBBL Delhi 2016 · Annexure VI (MPD-2021) · Amendments up to Feb 2020

KEY DEVELOPMENT CONTROLS

Parameter	Value / Norm	Remarks
Minimum plot size	3,000 sq.m	1,670 sq.m for redevelopment/rehabilitation areas on 7.5 m ROW
Maximum ground coverage	33.3%	Up to 40% for low-rise high-density housing (without lifts)
Maximum FAR	200	15% additional FAR for EWS/CSP over and above 200 FAR
Maximum height	No restriction (NR)	Subject to clearance from AAI / Delhi Fire Service and other statutory bodies
Max density	200 DUs/ha (900 persons/ha)	EWS/JJ clusters/resettlement colonies: up to 900 DUs/ha
Min road width (fronting)	18 m ROW	7.5 m ROW for redevelopment/rehabilitation/special area/Lal Dora
Community facilities	Min 400 sq.m OR 0.6% of FAR (free from FAR)	For community hall, crèche, library, senior citizen room, society office
EWS requirement	Min 15% of proposed FAR for EWS	Over and above 200 FAR; 50% retained by developer for CSP housing
Basement	Excluded from FAR	Only if used for parking, utilities & services
Stilts	Excluded from FAR; counted in height	Non-habitable stilt for parking/landscaping

MINIMUM SETBACKS (Table 17.1)

Plot Size (sq.m)	Front (m)	Rear (m)	Side-1 (m)	Side-2 (m)
Up to 60	0	0	—	—
Above 60–150	3	1.5 avg	—	—
Above 150–300	4	2 avg	—	—
Above 300–500	4	3	3	—
Above 500–2,000	6	3	3	3
Above 2,000–10,000	9	6	6	6
Above 10,000	15	12	12	12

i Effective setbacks for Group Housing (min plot 3,000 sq.m): Front 9 m | Rear 6 m | Side-1 6 m | Side-2 6 m

PARKING NORMS

Category	Parking Standard	Space: Open	Space: Covered	Space: Basement
General housing units	2.0 ECS per 100 sq.m built-up area	23 sq.m/ECS	28 sq.m/ECS	32 sq.m/ECS
EWS / Service personnel	0.5 ECS per 100 sq.m built-up area	23 sq.m/ECS	28 sq.m/ECS	32 sq.m/ECS