

# Optimal coordination of neutral function of directional overcurrent protections for interconnected electric power systems

P. M. De Oliveira-De Jesus *Senior Member, IEEE*, E. Sorrentino, J. S. Abello, O. Archilla, C. A. Alza, D. F. Celeita *Senior Member, IEEE*, G. A. Ramos *Senior Member, IEEE*, A. J. Urdaneta *Senior Member, IEEE*

**Abstract**—The problem of coordination of directional overcurrent protections (DOCP) in interconnected power systems has been widely treated in literature. All existing procedures are focused on phase 67P function and network models based upon typical positive sequence models. However, other DOCP functions such as 67N (neutral) should be also coordinated accounting the effects of high-impedance phase to earth faults. The optimal coordination of the neutral function of DOCP has been completely overlooked in literature. In this paper, we investigate the impact of high-impedance single-phase to earth faults in the clearing times and selectivity of the 67N function of DOCP whose time dial settings were selected using a standard optimization technique. The multiphase-multiground (4-wire) network model developed by EPRI for the OpenDSS platform is used to determine the exact fault current distribution across phases, neutrals and the ground path. As a key contribution, we determine the effect of a range of pickup settings and fault resistances on speed, selectivity and voltage profile. The results show that for a range of pickup settings the optimal operation time decreases as the fault impedance increases until the calculated time dial setting stagnates at the minimum value. Beyond this point, the clearing times reach a minimum and deteriorate as far the fault impedance increases.

**Index Terms**—directional overcurrent relays coordination, high-impedance faults, single phase faults

## I. INTRODUCTION

The optimal coordination of directional overcurrent protections (DOCP) in interconnected power systems is still a challenging problem. The first optimization approach to coordinate DOCP was introduced in 1988 by [1] using a linear-programming approach. The original method was applied to coordinate directional overcurrent function 67 (phase). In this approach optimal relay time dial settings are determined for solid three-phase to ground short-circuit currents [2]. In the last thirty years a large number of contributions have been proposed to tackle problem resorting to different linear and nonlinear optimization procedures based on 67 phase function and standard positive sequence models.

The coordination on 67 neutral function DOCP protections have gained great interest since under the smart grid paradigm

[3], [4]. Single-phase faults are very common in medium voltage sub-transmission and distribution systems. These kind of networks are being operated under weakly-meshed schemes in order to improve the power system reliability. So, traditional radial-based operation supported in unidirectional overcurrent protection relays are not longer suitable. The use of directional overcurrent relays to protect meshed networks might be a cost effective alternative.

However, the 67N function should be also coordinated accounting the effects of high-impedance phase to earth faults. The optimal coordination of neutral/earth function of DOCP power systems has been completely overlooked in literature. To do so, we need to determine the magnitude of the asymmetrical faults seen by the 67N function to setup the optimization procedure. A fundamental shortcoming of the short current calculation lies on the use of traditional sequence models disregarding important effects such as mutual couplings, current division at neutral/grounding path and the effect of high-impedance faults. On account of the existence of several short-circuit calculation tools based on multiphase-multiground network models such as the OpenDSS [5], it is now possible to determine precisely how different fault impedance magnitudes change the fault currents and therefore the response of the protection system whose settings were optimized assuming fault currents associated with solid faults. This detailed network model overcomes the limitations of symmetrical components by including the effect of unbalanced loads, neutral grounding through earth resistances and fault impedances on short-circuit currents passing through all relays of the system.

The effect of high impedance faults are critical to ensure speed and selectivity objectives. Existing optimization procedures cannot answer how high-impedance single-phase to neutral faults affect the optimal clearing time, the selectivity and, the corresponding optimal relay settings.

To fulfill the research gap, this paper investigates how different magnitudes of high-impedance faults affect the performance of the protection system. To do so, the proposal is illustrated with the well-known three bus test system introduced by [1] redefined now as a multiphase-multigrounded network system.

The paper is organized as follows. Background is discussed in Section II. The method is presented in Section III. The case-study is defined in Section IV. Results are discussed in Section V. Conclusions are drawn in Section VI.

Manuscript received November XX, 20XX

J. S. Abello, O. Archilla, C. A. Alza, D. Celeita, G. A. Ramos, and P. M. De Oliveira-De Jesus are with the Department of Electrical and Electronic Engineering, Universidad de Los Andes, Bogotá, Colombia. E-mail: pm.deoliveiradejes@uniandes.edu.co. A. J. Urdaneta is with Simon Bolivar University, Venezuela. E-mail: alberto@usb.ve, E. Sorrentino is with Carlos III University, Madrid, Spain. E-mail: elmer.sorrentino@uc3m.es

Digital Object Identifier

## II. BACKGROUND

Comprehensive reviews of existing optimization procedures can be found in [6], [7] listing around 80 relevant papers on optimal coordination of DOCP from 1988 to 2014. Recently, [8] presented an updated review with 23 new papers published between 2014 and 2020. These review papers classify existing contributions by optimization technique used: linear programming, nonlinear programming and evolutionary optimization. None of them deal with the problem of how to coordinate the DOCP 67N function and what is the effect of the single phase to ground fault resistance on speed and selectivity. In Table I we include the reviews of 2005, 2014 and 2020 as well as a number of recent contributions on optimal coordination of DOCP not included in previous lists.

TABLE I  
SUMMARY OF EXISTING DOCP OPTIMIZATION PROCEDURES

Reference	year	Relay function		Network model		
		67P	67N	+ seq.	3phase	4wire
Review paper [6]	2005	○		○		
Review paper [7]	2014	○		○		
Review paper [8]	2020	○		○		
[9]	2020	○		○		
[10]	2020	○		○		
[11]	2020	○		○		
[12]	2020	○		○		
[13]	2020	○		○		
[14]	2020	○		○		
[15]	2020	○		○		
[16]	2020	○		○		
[17]	2020	○		○		
[18]	2020	○		○		
[19]	2020	○		○		
[20]	2020	○		○		
[21]	2020	○		○		
[22]	2020	○		○		
[23]	2020	○		○		
[24]	2020	○		○		
[25]	2020	○		○		
[26]	2020	○		○		
[27]	2020	○		○		
[28]	2020	○		○		
[29]	2020	○			○	
<b>This paper</b>	-		○			○

In general, the coordination of 67 function at transmission level uses the positive sequence model [30]–[22]. Notice that [23]–[29] describe some applications in distribution systems. However, despite the distribution system is general untransposed with asymmetrical primitive matrices, the coordination of the 67 phase function is carried out using positive network sequence models. It is interesting to mention that [29] solves the problem of coordination of 67P relays by means of a real-time platform based upon a three-phase model. In this review, no evidence of optimal coordination of neutral DOCP with multi-phase multi-ground network model has been found.

## III. METHOD

The original optimization problem was written to coordinate 67 phase relays considering solid three-phase faults [1]. This method is now adapted to perform optimal coordination of 67N relays in meshed systems when different fault impedances (not only solid faults) occurs in the system affecting speed and selectivity.

### A. Assumptions

Real-world power systems are complex and for the sake of simplicity the following assumptions and limitations are considered in the formulation of the optimization problem.

- 1) The optimization problem is posed by assuming that the magnitude of the fault impedance is the same for all possible "relevant" faults located at near and end terminal of each line, just as the standard model [1] assumes that all relevant faults are solid, that is  $R_F=0$ . The use of a unique fault impedance magnitude for all faults of the model is debatable in account of its stochastic nature. It is clear that the coordination problem must be solved for the expected fault impedance magnitude and the corresponding variances. However, if we account the fault impedance magnitude as a probability function, the approach turns the model into a stochastic optimization problem. The stochastic view of this problem is matter of further research.
- 2) All asymmetrical phase-to-neutral faults were produced at same phase. In this case we select phase  $c$  (the nearest to ground).
- 3) Transient configurations are not included in the optimization problem formulation. In real-world the relaying system does not operate at the same time. Thus, the short circuit current magnitude seen by each relay adopts different values owing to topology changes. Despite this problem has been solved in [9], [31], this aspect has been overlooked in all existing DOCP optimization. The main consequence of disregard transient configurations lies on increased sensitivity problems in backup relays due to unrealistic low fault currents.
- 4) The use of the OpenDSS tool to determine fault currents include prefault conditions. However, in this paper we neglect load currents, neither balanced nor unbalanced.
- 5) We assume that the sensitivity problem is solved. In this paper we assume all relays are adjusted with the same pick-up currents of the 67N function. In general this value is set between 10 % of the current transformer capacity and 80 % of minimum short circuit current.
- 6) Short-circuit current magnitudes are assumed as invariant values over time. The effect of decrement factors are not included.
- 7) Only time-delayed relays are considered. The coordination time is unique for all primary-backup pairs. The effect of time-definite adjusts are out of scope.
- 8) Circuit breaker operation times are not included in the model.
- 9) Only standard curves are considered, and all the relays are assumed to be with the same curve.
- 10) Equivalent impedances at source buses are assumed the same at peak and off-peak load. Thus, the fault currents do not change along the time.
- 11) Resistance of all ground mats at substations are equal to zero.
- 12) The optimization model is built considering that near-end and far-end Faults occur at substations.
- 13) Influence of stability constraints is not considered.




Fig. 1. Primary-backup relays

### B. Problem formulation

Consider a meshed power system with  $k=1, \dots, n_l$  three-phase transmission lines. The set of transmission lines is defined as  $k \in \mathbb{N}$  with  $n_l = \dim(\mathbb{N})$ . Each line has two overcurrent 67N relays. Thus, a total of  $r=1, \dots, n_r=2n_l$  relays are installed in the system. The set of relays is defined as  $r \in \mathbb{R}$  with  $n_r = \dim(\mathbb{R})$ . Each relay  $r \in \mathbb{R}$  is characterized by the following manner. Current-time curve parameters for each relay are fixed and defined by three parameters:  $\alpha_{r1} \in \alpha$ ,  $\alpha_{r2} \in \alpha$  and  $\alpha_{r3} \in \alpha$ . Pick-up currents  $I_{pr} \in P$  depend on maximum unbalanced currents that may flow by the line, and the time dial setting  $D_r \in D$  are defined by the protection engineer according to a coordination criteria.

Figure 1 shows a faulted line  $k \in \mathbb{N}$ . Line  $k$  is protected by two primary 67N overcurrent relays  $i \in \mathbb{R}$  and  $q \in \mathbb{R}$ . Depending on the network topology, we can identify a number of relays pairs (primary relay  $i \in \mathbb{R}$  and backup relay  $j \in \mathbb{R}$ ) that must be coordinated. The set of "relevant" faults is defined as  $h \in \mathbb{H}$  with  $n_f = \dim(\mathbb{H})$  the number of faults under consideration. We identify two relevant faults per line  $k$ ,  $\mathbb{H}=\{1, 2\}$ . Thus,  $n_f=2$ . A near-end fault ( $h=1$ ) whose location is closer to relay  $i$  and a near-far fault ( $h=2$ ) adjacent to relay  $q$ . Given a fault  $h \in \mathbb{H}$  over the line  $k$ , if a primary relay  $i$  does not clear the fault, another adjacent (backup) relay  $j$  (located in other adjacent line) should clear the fault. All relays of the system can operate as primary or backup depending on whether the fault is located in its own line or the fault is located in adjacent line.

Figure 1 shows the situation when both primary relays  $i$  and  $q$  operate successfully when a fault  $h$  occurs in line  $k$ . In this case, each primary-backup relay-pair  $i-j$  must fulfill the following inequality time operation constraint:

$$T_{jkh} - T_{ikh} \geq C \quad i, j \in \mathbb{R}, k \in \mathbb{N}, h \in \mathbb{H} \quad (1)$$

where  $T_{ikh}$  is a primary operating time (for a relay  $i$  located in the line  $k$  with fault  $h$ ),  $T_{jkh}$  is a backup operating time (for a relay  $j$  located in an adjacent line of the line  $k$  with fault  $h$ , not in the same line), and  $C$  is a known value, the coordination time specified by the protection engineer for all primary-backup pairs.

The operation time for the primary relay  $i$  when the fault  $h$  occurs at line  $k$  is expressed as:

$$T_{ikh} = \frac{\alpha_{i1} D_i}{\left(\frac{I_{ikh}}{I_{pi}}\right)^{\alpha_{i2}} + \alpha_{i3}} = \beta_{ikh} D_i \quad (2)$$

where single-phase short-circuit current contribution seen by a relay  $i$  due to fault  $h$  at line  $k$  ( $I_{ikh}$ ) must be determined using the primitive admittance matrix  $Y_{BUS}$  with all breakers of the system closed. The maximum multiplier allowed is  $M^{max} = \frac{I_{ikh}}{I_{pi}} = 30$ . For short-circuit  $I_{ikh}$  currents higher than  $30I_{pi}$ , the operation time is constant  $T_{ikh} = \frac{\alpha_{i1} D_i}{30^{\alpha_{i2}} + \alpha_{i3}}$ .

Likewise, the operation time for the backup relay  $j$  when the fault  $h$  occurs at line  $k$  is expressed as:

$$T_{jkh} = \frac{\alpha_{j1} D_j}{\left(\frac{I_{jkh}}{I_{pj}}\right)^{\alpha_{j2}} + \alpha_{j3}} = \beta_{jkh} D_j \quad (3)$$

where single-phase short-circuit current contribution seen by a relay  $j$  due to fault  $h$  at line  $k$  ( $I_{jkh}$ ) must be determined using the primitive admittance matrix  $Y_{BUS}$  with all breakers of the system closed. Thus, given a fault  $h$  at line  $k$  both adjacent relay operation times can be expressed as a function of relay curve parameters and pick-up currents. Primary operation time  $T_{ikh} = \beta_{ikh} D_i$  where  $\beta_{ikh} = \alpha_{i1}^{-1} \left[ \left( \frac{I_{ikh}}{I_{pi}} \right)^{\alpha_{i2}} + \alpha_{i3} \right]$  must be lower than the backup operation time  $T_{jkh} = \beta_{jkh} D_j$  where  $\beta_{jkh} = \alpha_{j1}^{-1} \left[ \left( \frac{I_{jkh}}{I_{pj}} \right)^{\alpha_{j2}} + \alpha_{j3} \right]$ . Therefore, Eq. 1 can be rewritten as:

$$\beta_{jkh} D_j - \beta_{ikh} D_i \geq C \quad i, j \in \mathbb{R}, k \in \mathbb{N}, \mathbb{H} = \{1, 2\} \quad (4)$$

where  $C$  is the predefined coordination time. Normal load and short circuit currents are sensed by neutral directional overcurrent functions 67N through the sum of three phase currents measured by current transformers at phases or a by a separate current transformer for grounded neutrals at each substation.

Linear factors  $\beta_{ikh}$  and  $\beta_{jkh}$  should be determined considering two feasible single-phase faults located at near-end ( $h=1$ ) and far-end of line  $k=1, \dots, n_l$ . In many cases the use on near-end and near-far fault locations as relevant faults are sufficient to ensure complete selectivity. However, if transient configurations during the clearing time process are duly considered, the set of relevant faults that ensure complete selectivity must be previously determined in order to formulate an optimization model that assures full selectivity. The inclusion of transient configurations is out of scope of this paper.

It is important to stress out that  $\beta_{ikh}$  factors depend on single-phase to neutral short circuit magnitudes  $I_{ikh}$  whose magnitudes are strongly dependent upon the grounding path. Fault current  $I_{ikh}$  can be determined using a detailed network model such as EPRI's NEV OpenDSS platform.

Optimization problem constraints can be now defined for a generalized system with  $n_l$  lines,  $n_r$  relays and  $n_f=2$  feasible fault locations. A total of  $n_b$  feasible primary-backup pair constraints must be identified and grouped in this compact form:

$$\mathbf{B} \cdot \mathbf{D} \geq C \mathbf{u} \quad (5)$$

where  $\mathbf{D}$  is the  $n_r$  dimension vector with the time dial of each relay and  $\mathbf{B}$  is the coordination matrix that depends on linear factors  $\beta_{ikh}$  and  $\beta_{jkh}$  for  $h=1, 2$ . The coordination matrix  $\mathbf{B}$  has  $n_r$  columns and  $n_b$  rows. The number of rows

will depend on the number of effective primary-backup pairs. Entry  $\mathbf{u}$  is a  $n_b$  row unit vector and  $C$  is the specified coordination time between primary and backup relays.

The objective function (OF) of the optimization problem is defined as the average sum of operating times of all the primary relays for the two faults ( $n_f=2$ ), near-end and far-end faults under consideration:

$$OF = \frac{1}{n_f} \sum_{h=1}^{n_f} \sum_{k=1}^{n_l} \sum_{i=1}^{n_r} m_{ik} T_{ikh} \quad (6)$$

where  $m_{ik}$  is equal to 1 if the primary relay  $i$  is located at line  $k$ , otherwise  $m_{ik}=0$ .

Finally, once the objective function and the corresponding constraints are duly defined, the optimization problem is stated as follows. For a given the system data (primitive admittance matrix) and relay data (current-time parameters and pickup currents) determine the best set of time dial settings ( $\mathbf{D}^*$ ) that minimizes the overall system primary relay operation time (OF) considering selectivity constraints.

$$\min_{\mathbf{D}^*} OF = \frac{1}{n_f} \sum_{h=1}^{n_f} \sum_{k=1}^{n_l} \sum_{i=1}^{n_r} m_{ik} T_{ikh} \quad (7)$$

subject to :

$$\mathbf{B} \cdot \mathbf{D} \geq C\mathbf{u} \quad (8)$$

$$\mathbf{D} \leq \mathbf{D}^{\max} \quad (9)$$

$$\mathbf{D} \geq \mathbf{D}^{\min} \quad (10)$$

where  $\mathbf{D}^{\min}$  and  $\mathbf{D}^{\max}$  are the dial limits vectors. The optimization problem has  $n_r$  unknowns. The maximum number of inequality restrictions will be  $4n_l$  if all pairs primary-backup relays are able to detect the magnitude and/or direction of the fault. The above stated optimization problem is suitable to be solved using any linear programming tool, such as Matlab's LinProg.

In this paper, we investigate how the objective function (OF) and the optimal settings ( $\mathbf{D}$ ) are affected when the coordination matrix ( $\mathbf{B}$ ) is calculated using different high-impedance phase to neutral fault conditions. To do so, single-phase short-circuit currents  $I_{ikh}$  and  $I_{jkh}$  are calculated using a multiphase-multiground model considering different fault resistances  $R_f$ .

#### IV. TEST SYSTEM

The classic formulation was originally applied over the test-system depicted in Fig. 2 considering three-phase faults and the coordination of six relays 67P. The original test system comprises three substations, three generators with reactance  $X_1^+ = X_1^- = X_1^0 = 20\%$  (100 MVA),  $X_2^+ = X_2^- = X_2^0 = 12\%$  (25 MVA) and  $X_3^+ = X_3^- = X_3^0 = 18\%$  (50 MVA). Positive sequence series impedance of the three lines are:  $Z_1^+ = 5.5 + j 22.85 \Omega$  (50km),  $Z_2^+ = 4.4 + j 18.00 \Omega$  (40km) and  $Z_3^+ = 7.6 + j 27.00 \Omega$  (60km). The system has no loads. 67N phase relay parameters are  $\alpha_{i1} = 0.14$ ,  $\alpha_{i2} = 0.02$ ,  $\alpha_{i3} = -1$  for  $i = 1, \dots, 6$  (standard inverse curve). All pick-up currents were set 50A.




Fig. 2. Test system - One-line diagram and fault locations [1]

TABLE II  
TOWER/POLE GEOMETRY SKETCH

Line	$d$ (ft)	$b$ (ft)	$h$ (ft)	Phase conductor	Neutral
1-2	7.85	6.0	40	500MCM Conlay AA	ACSR 4/0 6/1
2-3	9.70	5.0	40	605MCM 54/7 ACSR	ACSR 4/0 6/1
3-1	10.6	5.5	40	605MCM 54/7 ACSR	ACSR 4/0 6/1

Positive sequence impedance parameters for lines and generators are given above in order to determine three-phase short-circuit currents required by 67 (phase) relays to operate. However, in order investigate how to optimize the coordination of 67N (neutral) relays we need to determine exact short-circuit currents for single phase  $c$  to neutral faults. To do so, we must build an equivalent 4-wire model for the original positive sequence model provided in [1] by scripting a new multi-phase multi-ground model under the OpenDSS platform [5].

Figure 3 shows the multiphase diagram equivalent for the one-line diagram depicted in Fig. 2. The OpenDSS tool provides an explicit network representation for all system elements. Besides three-phases represented in blue color, system neutrals (shield wires) and ground resistances  $R_T$  are highlighted in red color and green colors, respectively. Single-phase to neutral faults are represented by  $R_F$ . For instance, a single-phase  $c$  to neutral fault with  $R_F=100 \Omega$  in line 1 is coded as: `New fault.1 Bus1= n4.3 Bus2=n4.4 r=100.`

Primitive impedance matrices for lines and generators must be provided. Transmission lines primitive matrices are get from the tower sketch shown in Fig. 3 with dimensions provided in Table II. Phase conductor characteristics are given in Table III. Transmission line positive sequence impedances for the tower structure depicted in Fig. 3 coincides with the ones specified in the original three-bus test case [1].

The case-study shown in Fig. 3 has six buses. Buses 1, 2 and 3 correspond to generating substations and buses 4, 5 and 6 correspond to a faulted point at given distance from substation  $k$ , for  $k=1,2,3$ . In this paper, we only use near-end and near-far faults as seen in Fig. 2. Thus, the distance of all faults from substations is set equal to 1 meter.

The six bus system depicted in 3 was scripted in OpenDSS. Short-circuit impedances of generators are provided under a three-phase base coinciding with the original ones.






Fig. 3. Test system - Multi-phase Multi-ground diagram and tower sketch

TABLE III  
PHASE & NEUTRAL CONDUCTOR CHARACTERISTICS

Type	Size	Resistance (ohm/mile)	GMR (ft)
ACSR 6/1	4/0 AWG	0.5920	0.00814
AA Conlay	500 MCM	0.2023	0.02600
ACSR 54/7	605 MCM	0.1756	0.03210

## V. RESULTS

The problem solution approach is described in detail so that the interested reader can easily replicate the results with the script included in the following GitHub page: <https://github.com/pmdeoliveiradejesus/Optimal-67N-DOCR-coordination>. All Simulations were performed in Matlab with the LinProg optimization tool. Fault currents were acquired from the OpenDSS using the COM interface. Specific cases were also coded and solved with MS Excel's solver tool for illustrative purposes.

The proposed optimization model was applied to the case-study described in Section IV. The case study has  $n_l = 3$ ,  $N = \{1, 2, 3\}$ , lines and  $n_r = 6$  relays,  $R = \{1, 2, 3, 4, 5, 6\}$ . Two faults ( $n_f = 2$ ) are modelled.

Two scenarios are analyzed:

- 1) Case 1: Faults at near-end and far-end of all lines with  $R_F = 0 \Omega$
- 2) Case 2: Faults at near-end and far-end of all lines with  $R_F = 10.0 \Omega$

Finally a sensitivity analysis is carried out varying  $R_F$  from  $0 \Omega$  to  $50 \Omega$  when the optimization problem becomes not-well defined due to low currents make the relay system insensible.

A total of  $n_b = 12$  primary-backup ( $ikh-jkh$ ) pairs are identified. The fault currents ( $I_{ikh}$  and  $I_{jkh}$ ) determined using the OpenDSS 4-wire model and the corresponding  $\beta$ -factors ( $\beta_{ikh}$  and  $\beta_{jkh}$ ) for both scenarios can be found in [4]. Notice that some primary-backup ( $ikh-jkh$ ) pairs have currents with opposite directions (631-231, 112-512, 532-332). In case 1 and case 2 some  $\beta$ -factors are negative. This means the existence of short-circuit contributions lower than the selected pick-up currents (50A). In case 1 all short-circuit contributions are greater than the selected pick-up currents except primary-backup ( $ikh-jkh$ ) pairs 211-411 and 112-512. In case 2,

primary-backup ( $ikh-jkh$ ) pairs 211-411, 421-621, 631-231 do not operate for near-end faults and relay pairs 112-512, 322-122, 532-332 do not operate for far-end faults. It is clear that as in case 2  $R_F$  is not solid some loss of sensitivity is observed.

The general optimization model is given by the minimization of sum of all primary times when the fault occurs at near-end and near-far of each line of the system constrained to the coordination equation and corresponding time delay setting limits as follows:

$$\min_{D^*} \beta_{111}D_1 + \beta_{212}D_2 + \beta_{321}D_3 + \beta_{422}D_4 + \beta_{531}D_5 + \beta_{632}D_6 \quad (11)$$

subject to :

$$\begin{bmatrix} -\beta_{111} & 0 & 0 & 0 & \beta_{511} & 0 \\ \beta_{121} & 0 & -\beta_{321} & 0 & 0 & 0 \\ 0 & 0 & \beta_{331} & 0 & -\beta_{531} & 0 \\ 0 & -\beta_{211} & 0 & \beta_{411} & 0 & 0 \\ 0 & 0 & 0 & -\beta_{421} & 0 & \beta_{621} \\ 0 & \beta_{231} & 0 & 0 & 0 & -\beta_{621} \\ -\beta_{112} & 0 & 0 & 0 & \beta_{512} & 0 \\ \beta_{122} & 0 & -\beta_{322} & 0 & 0 & 0 \\ 0 & 0 & \beta_{332} & 0 & -\beta_{532} & 0 \\ 0 & -\beta_{212} & 0 & \beta_{412} & 0 & 0 \\ 0 & 0 & 0 & -\beta_{422} & 0 & \beta_{622} \\ 0 & \beta_{232} & 0 & 0 & 0 & -\beta_{622} \end{bmatrix} \begin{bmatrix} D_1 \\ D_2 \\ D_3 \\ D_4 \\ D_5 \\ D_6 \end{bmatrix} \geq \begin{bmatrix} C \\ C \\ C \\ C \\ C \\ C \end{bmatrix} \quad (12)$$

$$0.1 \leq D_i \quad i = 1 \dots 6$$

The coordination matrix  $\mathbf{B}$  is given by Eq. 5. As some primary-backup ( $ikh-jkh$ ) pairs do not operate due to selectivity and sensitivity problems, the size of  $\mathbf{B}$  changes since rows corresponding to conflictive primary-backup pairs should be eliminated.

### A. Case 1: solid fault

According to the calculated fault currents and linear factors [4] and the formulation given in Eq. 12, the resulting optimization model for solid faults (with  $R_F = 0$ ) is:

$$\min_{D^*} 2.30D_1 + 2.45D_2 + 2.30D_3 + 2.25D_4 + 2.54D_5 + 2.43D_6$$




Fig. 4. Test system - speed and selectivity in Cases 1 and 2

subject to :

$$\begin{bmatrix} -1.99 & 0.00 & 0.00 & 0.00 & 3.10 & 0.00 \\ 2.63 & 0.00 & -1.99 & 0.00 & 0.00 & 0.00 \\ 0.00 & 0.00 & 2.62 & 0.00 & -1.99 & 0.00 \\ 0.00 & 0.00 & 0.00 & -2.53 & 0.00 & 31.45 \\ 8.74 & 0.00 & -2.62 & 0.00 & 0.00 & 0.00 \\ 0.00 & -1.99 & 0.00 & 2.53 & 0.00 & 0.00 \\ 0.00 & 0.00 & 0.00 & -1.99 & 0.00 & 2.89 \\ 0.00 & 2.92 & 0.00 & 0.00 & 0.00 & -1.99 \end{bmatrix} \begin{bmatrix} D_1 \\ D_2 \\ D_3 \\ D_4 \\ D_5 \\ D_6 \end{bmatrix} \geq \begin{bmatrix} 0.2 \\ 0.2 \\ 0.2 \\ 0.2 \\ 0.2 \\ 0.2 \end{bmatrix}$$

$D_i \geq 0.1 \quad i = 1 \dots 6$

The solution for the optimal clearing time for faults with  $R_F=0$  is  $OF=3.6551s$ . The resulting optimal time dial settings are  $D_1=0.2711$ ,  $D_2=0.2427$ ,  $D_3=0.2579$ ,  $D_4=0.2703$ ,  $D_5=0.2387$  and,  $D_6=0.2553$ . It is worth to note that separation times (given by  $B \cdot D$ ) are equal to the prescribed coordination time (0.2s) with two exceptions in rows 4 and 5 of the coordination matrix:  $-2.53D_4+31.45D_6=7.34s$  and  $8.74D_1-2.62D_4=1.69s$ .

Figure 4(a) shows a histogram with the resulting operation times for 5000 random generated faults. The mean primary operation time calculated with the resulting optimal time dial settings is 3.3511s with standard deviation 0.0780s. In order to verify the appropriateness of the optimal settings obtained, we analyze if the selectivity criteria stills valid when the faults occur in other locations different to near-end or near-far of each line. To do so, we determine the separation times (given by  $B \cdot D$ ) for 5000 random generated faults. Results of the selectivity simulation are showed in the histogram shown in Fig. 4(b). Observe that no calculated separation time is below the coordination time interval  $C=200ms$  predefined by the protection engineer. A histogram with voltage profile for the faulted and non-faulted phases is depicted in Fig. 5(a).

#### B. Case 2: $R_F = 10 \Omega$

The resulting optimization model for a non-solid fault,  $R_F = 10 \Omega$  is given by:

$$\min_{D^*} \quad 2.01D_1 + 2.23D_2 + 2.25D_3 + 2.17D_4 + 2.14D_5 + 2.67D_6$$




Fig. 5. Test system - Temporary overvoltages in Cases 1 and 2

subject to :

$$\begin{bmatrix} -1.99 & 0.00 & 0.00 & 0.00 & 4.18 & 0.00 \\ 3.03 & 0.00 & -1.99 & 0.00 & 0.00 & 0.00 \\ 0.00 & 0.00 & 3.07 & 0.00 & -1.99 & 0.00 \\ 16.71 & 0.00 & -3.07 & 0.00 & 0.00 & 0.00 \\ 0.00 & -1.99 & 0.00 & 2.89 & 0.00 & 0.00 \\ 0.00 & 0.00 & 0.00 & -1.99 & 0.00 & 3.46 \\ 0.00 & 3.86 & 0.00 & 0.00 & 0.00 & -1.99 \end{bmatrix} \begin{bmatrix} D_1 \\ D_2 \\ D_3 \\ D_4 \\ D_5 \\ D_6 \end{bmatrix} \geq \begin{bmatrix} 0.2 \\ 0.2 \\ 0.2 \\ 0.2 \\ 0.2 \\ 0.2 \end{bmatrix}$$

$D_i \geq 0.1 \quad i = 1 \dots 6$

Notice that only seven relays are capable to detect the fault current. Three rows coordination matrix should be also removed since some backup fault currents are going in the opposite direction and two rows correspond to a negative operation time.

The optimal clearing time obtained 2.3222s. Notice that this time is lower than the one obtained in previous case 1 and the optimal settings are:  $D_1=0.1617$ ,  $D_2=0.1282$ ,  $D_3=0.1457$ ,  $D_4=0.1572$ ,  $D_5=0.1247$ , and  $D_6=0.1484$ . All separation times (given by  $B \cdot D$ ) are equal to the prescribed coordination time (0.2s). As done in case 1 we insert 5000 random faults with the resulting optimal primary operation times for dial settings of case 2. The histogram shown in Fig. 4(c) indicates that the mean operation time calculated is 2.0353s with standard deviation 0.0589s. Notice that for a fault of  $10 \Omega$ , the objective function is lower than the one obtained for solid faults. In few words, speed associated with settings of case 2 with  $R_F=10 \Omega$  is faster than speed associated with settings of case 1 with  $R_F=0 \Omega$ . If in real-world the majority of faults have resistance  $10 \Omega$  and the settings are fixed with the traditional approach (solid faults case 1) the actual operation time will not be optimal and far to the best result given by case 2. This result is similar for any fault resistance different than zero. Results of the selectivity simulation are depicted in the histogram shown in Fig. 4(d). In this case we also observe full selectivity. A histogram with voltage profile for the faulted and non-faulted phases is depicted in Fig. 5(b). Note that residual voltages are higher than the ones observed in case 1 (Fig. 5(a)). As a matter of fact, phases *a* and *b* show a temporary overvoltage lower than 1.2 for all simulated faults.




Fig. 6. Optimal clearing times for  $0 \leq R_F \leq 50 \Omega$  and  $30A \leq I_p \leq 50A$

### C. Verification with non-solid faults

One aspect that we can verify is what happens with speed and selectivity solutions if we setup the TDS of all relays with the optimal settings reported in case 1, but the actual fault magnitude is different than zero as simulated in case 2 ( $R_F=10 \Omega$ ). In this case, after simulate 5000 random locations for faults with  $R_F=10 \Omega$  and a pickup setting of 50A in all relays we observe average operational times larger than the optimal ones reported in case 2. In this case, optimal TD settings for solid faults yield a non-optimal solution when the actual fault impedance magnitude is different than zero. However, selectivity is not affected since separation times are greater than the coordination interval in all feasible primary-backup pairs. This result must not be considered a general case and further elaboration is required.

### D. Sensitivity analysis

When comparing cases 1 and 2 discussed above we can observe a decrease on both the objective function and time dial settings. Thus, if the fault impedance is steadily increased from 0 ohms we can expect to find an impedance value that yield a minimum operation time. A sensitivity analysis was carried out to verify this behavior by setting five pickup settings from 30A to 50A in steps of 5A, and by producing faults in a range between 0 ohms and  $R_F=50 \Omega$  in steps of 0.1  $\Omega$ . Thus, 2500 optimization problems were solved. Figures 6 and 7 display the optimal operation time and the optimal relay time dial settings required to get minimum clearing times, respectively.

Figure 6 highlights the solutions reported in case 1 ( $R_F=0 \Omega$ ,  $I_p=50A$ ) and case 2 ( $R_F=10 \Omega$ ,  $I_p=50A$ ). The minimum value of the OF for  $I_p=50A$  is reached when  $R_F=14.9 \Omega$  (OF = 2.005s). As seen in Fig. 6 this minimum value occurs when  $D_2=D_5=0.1$ .

If we continue increasing  $R_F$  from 15  $\Omega$  ( $I_p=50A$ ) to 50  $\Omega$  ( $I_p=50A$ ), the operation times (OF) steadily increases up to reach a maximum (4.22s for  $R_F=50 \Omega$ ) with invariant optimal time dial settings). The fact that optimal time dial settings do not change from 17.5 up to 50  $\Omega$  implies that separation times will increase as far as the fault impedance also increases. For  $R_F > 50.0 \Omega$  the optimization problem is not well defined due to sensitivity problems in some relay pairs and no efficient relay coordination is attainable.




Fig. 7. Optimal TDS for  $0 \leq R_F \leq 50 \Omega$  and  $30A \leq I_p \leq 50A$

Previous discussion was made on the assumption that the pickup current is set in 50A. If we reduce the pickups from 50 to 30A, we can observe that the optimal operation times (OF, from Fig. 6) and the time dials (TDSs from Fig. 7) must higher to address full selectivity. As a result, larger fault resistances are required to get the minimum objective function when the TDSs reach its minimum values. Beyond this point, when all TDSs are 0.1, the operation time (OF) deteriorates for all pickups.

## VI. CONCLUSIONS AND FURTHER RESEARCH

In this paper we analyze how optimal operation times and selectivity regarded to optimal coordination of neutral directional overcurrent relays are affected considering different impedance fault magnitudes.

Results show how the optimal operation time decreases as far as the fault impedance magnitude increases regardless the magnitude of pickup settings chosen by the protection engineer. When the fault impedance rises, the optimized time dial settings also decreases stagnating at their minimum values. Beyond this point, the time dials are bounded and the clearing times deteriorate as far the fault impedance also increases. In this example, for a pickup of 50A in all relays, the change of trend, namely the lowest operation time occurs when the fault impedance is around 15  $\Omega$ .

We also find in this example that if the TDSs are specified by the protection engineer considering solid faults but the actual fault type is non-solid, simulations show a non-optimal solution (larger operation times than the ones expected by the optimization problem. This means that current practice based on solid faults may produce suboptimal solutions from operation speed viewpoint.

The main limitation of this work lies on the deterministic representation of the fault resistance. Future work must pose this problem as a stochastic optimization problem where all settings, time dial and pickup settings, are included in the mathematical model. Further efforts would be devoted to solve this problem considering a more realistic condition accounting transient configurations during the clearing time process. In this case, the use of near-end and far-end faults to setup the optimization model should not be enough to assure full selectivity

## REFERENCES

- [1] A. J. Urdaneta, R. Nadira, and L. G. Perez Jimenez, "Optimal coordination of directional overcurrent relays in interconnected power systems," *IEEE Trans. Power Del.*, vol. 3, no. 3, pp. 903–911, July 1988.
- [2] M. Ezzeddine, R. Kaczmarek, and M. Iftikhar, "Coordination of directional overcurrent relays using a novel method to select their settings," *IET Gen., Trans. & Dist.*, vol. 5, no. 7, pp. 743–750, 2011.
- [3] D. Jones and J. J. Kumm, "Future distribution feeder protection using directional overcurrent elements," *IEEE Trans. Ind. Appl.*, vol. 50, no. 2, pp. 1385–1390, 2013.
- [4] P. M. De-Oliveira-De Jesus, E. Sorrentino, J. Abello, O. Archilla, C. A. Alza, D. F. Celeita, G. Ramos, and A. J. Urdaneta, "Optimal coordination of directional earth fault overcurrent relays 67N in interconnected electric power systems."
- [5] R. Dugan and D. Montenegro, "The open distribution system simulator (opendss) - reference guide," *Electric Power Research Institute*, 2020.
- [6] D. Birla, R. P. Maheshwari, and H. O. Gupta, "Time-overcurrent relay coordination: A review," *International Journal of Emerging Electric Power Systems*, vol. 2, no. 2, 2005.
- [7] S. Raza, T. Mahmood, and S. Bukhari, "optimum overcurrent relay coordination: A review," *The Nucleus*, vol. 51, no. 1, pp. 37–49, 2014.
- [8] S. D. Godwal, K. S. Pandya, V. N. Rajput, and S. C. Vora, "A review on approaches employed for solving directional overcurrent relays' coordination problem," in *Advances in Electric Power and Energy Infrastructure*. Springer, 2020, pp. 35–51.
- [9] E. Sorrentino and J. V. Rodríguez, "A novel and simpler way to include transient configurations in optimal coordination of directional overcurrent protections," *Elect. Pow. Syst. Res.*, vol. 180, p. 106127, 2020.
- [10] M. Ghotbi-Maleki, R. M. Chabanloo, M. A. Ebadi, and M. Savaghebi, "Determination of optimal breakpoint set of overcurrent relays using modified depth-first search and mixed-integer linear programming," *IET Gen., Trans. & Dist.*, 2020.
- [11] M. Sulaiman, M. Sulaman, A. Hamdi, and Z. H. Hussain, "The plant propagation algorithm for the optimal operation of directional overcurrent relays in electrical engineering," *Mehran Univ. Res. Jour. of Eng. and Tech.*, vol. 39, no. 2, pp. 223–236, 2020.
- [12] J. Shah, N. Khristi, V. N. Rajput, and K. S. Pandya, "A new objective function for optimal coordination of directional over-current relays," in *Advances in Electric Power and Energy Infrastructure*. Springer, 2020, pp. 1–11.
- [13] S. Gupta and K. Deep, "Optimal coordination of overcurrent relays using improved leadership-based grey wolf optimizer," *Arabian Journal for Science and Engineering*, vol. 45, no. 3, pp. 2081–2091, 2020.
- [14] A. Korashy, S. Kamel, T. Alquthami, and F. Jurado, "Optimal coordination of standard and non-standard direction overcurrent relays using an improved moth-flame optimization," *IEEE Access*, vol. 8, pp. 87 378–87 392, 2020.
- [15] A. Darabi, M. Bagheri, and G. Gharehpetian, "Dual feasible direction-finding nonlinear programming combined with metaheuristic approaches for exact overcurrent relay coordination," *International Journal of Electrical Power & Energy Systems*, vol. 114, p. 105420, 2020.
- [16] R. M. S. Dawood, M. Al-Greer, A. Gailani, and G. Pillai, "Optimum time coordination of directional overcurrent relays using cvx, gams and genetic algorithm," in *10th International Conference on Power Electronics, Machines and Drives*. IET, 2020.
- [17] A. Mahboubkhah, V. Talavat, and M. Beiraghi, "Modified multi-objective pso for coordination of directional overcurrent relays in interconnected networks," *Journal of Energy Management and Technology*, vol. 5, no. 1, pp. 43–50.
- [18] A. Mokhtarpour, A. Pashaei, and S. Pournaji, "Performance of pso algorithm in coordination of directional overcurrent relays considering fault current direction," *International Journal on Technical and Physical Problems of Engineering*, no. 42, pp. 105–109.
- [19] S. S. Fatemi and H. Samet, "Considering dgs voltage protection in optimal coordination of directional overcurrent relays to minimize the energy not supplied," *IEEE Systems Journal*, 2020.
- [20] S. Kamel, A. Korashy, A.-R. Youssef, and F. Jurado, "Development and application of an efficient optimizer for optimal coordination of directional overcurrent relays," *Neural Computing and Applications*, vol. 32, no. 12, pp. 8561–8583, 2020.
- [21] Y. Damchi and M. Dolatabadi, "Hybrid vns-lp algorithm for online optimal coordination of directional overcurrent relays," *IET Gen., Trans. & Dist.*, 2020.
- [22] A. A. Kida, A. E. L. Rivas, and L. A. Gallego, "An improved simulated annealing-linear programming hybrid algorithm applied to the optimal coordination of directional overcurrent relays," *Elect. Pow. Syst. Res.*, vol. 181, p. 106197, 2020.
- [23] A. Samadi and R. M. Chabanloo, "Adaptive coordination of overcurrent relays in active distribution networks based on independent change of relays' setting groups," *International Journal of Electrical Power & Energy Systems*, vol. 120, p. 106026, 2020.
- [24] P. Alaei and T. Amraee, "Optimal coordination of directional overcurrent relays in meshed active distribution network using imperialistic competition algorithm," *Journal of Mod. Pow. Syst. and Clean Ener.*, 2020.
- [25] S. D. Saldarriaga-Zuluaga, J. M. López-Lezama, and N. Muñoz-Galeano, "Optimal coordination of overcurrent relays in microgrids considering a non-standard characteristic," *Energies*, vol. 13, no. 4, p. 922, 2020.
- [26] M. H. Sadeghi, A. Dastfan, and Y. Damchi, "Optimal coordination of directional overcurrent relays in distribution systems with dgs and fcls considering voltage sag energy index," *Elect. Pow. Syst. Res.*, vol. 191, p. 106884.
- [27] K. Sarwagya, P. K. Nayak, and S. Ranjan, "Optimal coordination of directional overcurrent relays in complex distribution networks using sine cosine algorithm," *Elect. Pow. Syst. Res.*, vol. 187, p. 106435, 2020.
- [28] E. Sorrentino and J. V. Rodríguez, "An efficient method to include the effect of radial feeders on optimal coordination of directional overcurrent protections," *Elect. Pow. Syst. Res.*, vol. 191, p. 106858.
- [29] A. Mahboubkhah, V. Talavat, and M. Beiraghi, "Considering transient state in interconnected networks during fault for coordination of directional overcurrent relays," *Elect. Pow. Syst. Res.*, vol. 186, p. 106413, 2020.
- [30] N. El Naily, S. M. Saad, S. Abeid, and H. Saleh, "Improved over-current coordination using artificial intelligence in benghazi mv-distribution network case study," in *Proceedings of the 6th International Conference on Engineering & MIS 2020*, 2020, pp. 1–6.
- [31] A. J. Urdaneta, L. G. Pérez, and H. Restrepo, "Optimal coordination of directional overcurrent relays considering dynamic changes in the network topology," *IEEE Trans. Power Del.*, vol. 12, no. 4, pp. 1458–1464, 1997.

**P. M. De Oliveira De Jesus** (M'03 - SM'14) received the M.Sc. and the Electrical Engineering (5 year course) degree in 2002 and 1995 from Universidad Simón Bolívar (USB), Caracas, Venezuela, and Ph.D. (2008) degree from Oporto University, Portugal. Postdoctoral research at Coimbra University, Portugal in 2014-2015. Former head of the USB's Energy Institute. Associate professor 2007-2014. Full professor 2014-2016. Currently he is visiting professor with the Department of Electrical Engineering, School of Engineering, Universidad de Los Andes, Colombia. His research interests include technical and economic issues of electric power and energy systems.

**E. Sorrentino** received his Electrical Engineer (Cum Laude, 1984) and M.Sc. (Honors, 1986) degrees from Universidad Simón Bolívar (USB, Caracas, Venezuela), and his Ph.D. degree (Cum Laude, 2014) from Universidad Carlos III de Madrid (Spain). Since 1984, he has been a professor and a consulting engineer for several companies. His research interests include power system protection, power system analysis, and electrical machines.

**J.S. Abello** is electrical engineer degree from the Universidad de los Andes (2019).

**O. Archilla** is electrical engineer degree from the Universidad de los Andes (2019).

**C. Alza** is electrical engineer degree from the Universidad de los Andes (2019).

**D. F. Celeita** (SM'2019) received the degree in Electronic Engineering (2011) from Universidad Distrital Francisco Jos de Caldas, Bogotá, Colombia and M.Sc. (2014) and Ph.D (2018) in Electrical Engineering from Universidad de los Andes, Bogotá, Colombia. He worked as an automation engineer in low and medium voltage applications for a few years. He was a visiting researcher at Georgia Institute of Technology and he served as a postdoctoral researcher at CentraleSuplec with an industry partner in France. He is currently a Postdoctoral Research Associate at Universidad de los Andes. His research interest includes Protective - Relaying Control, Smart Grids, Advanced Distribution Automation, Fault Location, and Real-Time Simulation.

**G.A. Ramos** (M'04 - SM'13) received the degree in Electrical Engineering (1997) from Universidad Nacional, Manizales, Colombia, and M.Sc. (1999) and PhD (2008) in Electrical Engineering from Universidad de Los Andes, Bogotá, Colombia. He is currently an Associate Professor with the Department of Electrical Engineering at School of Engineering, Universidad de Los Andes, Colombia where is involved in teaching courses on power electronics, fundamentals of power systems, power quality, distribution, and industrial systems design. His research interests include power quality and transients in grounding systems.

**A. J. Urdaneta** (SM'90) received the Elect. Eng. (Hons.) degree from the Universidad Simón Bolívar, Caracas, Venezuela, in 1979, the M.Sc. degree in electrical engineering and applied physics in 1983, and the Ph.D. degree in systems engineering in 1986, both from Case Western Reserve University, Cleveland, OH. Retired Professor of electrical engineering, Department of Energy Conversion and Delivery, Universidad Simón Bolívar. He has been responsible for a number of projects and studies performed for local industries. He is the former Dean of Professional Studies and former Chairman of the IEEE Venezuelan Section. Former president of Venezuelan electricity regulatory board Fundelec. His research interests are in the area of power system analysis and optimization.