

Technical Report

on

Geotechnical Investigation

for

Proposed Mono Pole

SITE ID - IN- 3154999

SITE NAME.- Open Plot of Mrs Gangaben Dathji Devda, Gamtal Plot No 227, At Moje Samarvada village, Taluka Dhanera, District Banaskantha, State Gujarat, Picode 385310, Police station

SITE ADD.- Open Plot of Mrs Gangaben Dathji Devda, Gamtal Plot No 227, At Moje Samarvada village, Taluka Dhanera, District Banaskantha, State Gujarat, Picode 385310, Police station
Samarvada

Name of Client

INDUS TOWER LIMITED

Name of Consultant

M/s Multi Project Consulting Engineering



VISHWAS GEOTECH
PRIVATE LIMITED

VISHWAS GEOTECH PVT LTD.

ISO - 9001 CERTIFIED LABORATORY

Reg. Office

C-2, Vardhmannagar, Nr. Arjun Tower,
Ghatlodia, Ahmedabad-61

Work Office

A-14, CP Nagar Part-2,

Opp. Arjun Tower,
Ghatlodia, Ahmedabad-61

E-mail : vishwasgeotech@gmail.com

Phone No.- +91 9925965217



Ref. No.: VGPL/ 22-23 / M-0503

Date : 28/11/2022

To,
INDUS TOWER LIMITED

Sub. : Soil Investigation work for the Proposed

Proposed Mono Pole

i Devda, Gamtal Plot No 227, At Moje Samarvada village, Taluka Dhanera, District Banaskantha, State

SITE ADD.- Open Plot of Mrs Gangaben Dathji Devda, Gamtal Plot No 227, At Moje Samarvada village, Taluka Dhanera, District Banaskantha, State Gujarat, Picode 385310, Police station Samarvada

Dear Sir,

The soil investigation report is presented herewith alongwith the properties of sub soil investigation, analysis of strength characteristics, conclusion & recommendation for designing the foundation of proposed structure.

We are enclosing one copies of Test Report.

Thanking you, we remain,

Yours truly,

For **Vishwas Geotech Pvt.Ltd.**



Sign



INDEX

Sr. No.	Contents
01	Introduction
02	Field Investigation
03	Laboratory Investigation
04	Results
05	Soil Stratifications
06	Typical Calculation for S.B.C
07	Summary
08	Conclusion & Recommendation
09	Appendix
	a. Tables
	b. Figures



GEOTECHNICAL INVESTIGATION REPORT

1 Introduction:

For foundation analysis of the structure on the site, it is necessary

- 1 To determine soil profile of the site.
- 2 To know physical properties and strength characteristics of soil at various depths.
- 3 To determine the Pile Load Capacity of the soil at different depths for the different dia of footings for the test point.
- 4 To locate the presence of ground water level.
- 5 To give conclusion and recommendation.

The soil exploration work was carried out at the project site / location given by the client.

The following points were decided:

- 1 Bore hole - 1
- 2 Depth of Borehole **10.45** meters

Based on the above points the detailed Geotechnical Program includes

A Field Investigation

- 1 Drilling of Bore hole
- 2 Collection of soil samples (Disturbed & Undisturbed)
- 3 Conducting standard penetration test

B Laboratory Investigation

- 1 Bulk density and moisture contents
- 2 Grain size analysis
- 3 Index properties
- 4 Shear tests

C Recommendations

Based on the above investigations, the results are to be obtained. The findings would be based on interpretation of results, analysis and computations as per relevant Indian standards.



2 Field Investigation

2.1 Boring

Bore Hole No.	Location	Depth Investigation (m)
1	<i>SITE NAME.- Open Plot of Mrs Gangaben Dathji Devda, Gamtal Plot No 227, At Moje</i> <i>SITE ADD.- Open Plot of Mrs Gangaben Dathji Devda, Gamtal Plot No 227, At Moje Samarvada village, Taluka Dhanera, District Banaskantha, State Gujarat, Picode 385310, Police station Samarvada</i>	10.45

The exploratory boreholes of 100/150 mm diameter were drilled by Machine Drilling method / Handauger Drilling method The depth of the test bore at the proposed location is **10.45** Meter

2.2 Sampling

2.2.1 Disturbed samples

Disturbed samples were collected during boring and also from the split spoon sampler. The samples collected were logged, labeled and placed in polyethylene bags and sent to laboratory for testing.

2.2.2 Undisturbed samples

Undisturbed samples were collected in thin walled Shelby tubes, sealed with wax, labeled and transported to laboratory for testing.

2.2.3 Standard Penetration Test

The standard penetration tests were conducted in accordance with IS 2131-1981. The test gives N – Value, which is the number of blows of last 30cms penetration of split spoon sampler with 65Kg. hammer free fall from 75cms height.



3 Laboratory Investigation

The following laboratory tests were conducted on undisturbed and disturbed soil samples collected from various depths to find physical properties and strength characteristics. To measure the soil properties in the laboratory, following tests were conducted.

Sr. No.	Tests	Recommended Procedures	Type Samples
1	Sample Preparation	IS 2720 Pt. I	DS / UDS
2	Moisture Contents	IS 2720 Pt. II	DS / UDS
3	Dry Unit Weight	LAMBE	UDS
4	Specific Gravity	IS 2720 Pt. III	DS
5	Liquid Limit	IS 2720	DS
6	Plastic Limit	IS 2720 Pt. V	DS
7	Grain Size Analysis	IS 2720 Pt. IV	DS
8	Soil Classification	IS 1498	DS / UDS
9	Direct Shear Test	IS 2720 Pt. XIII	UDS

4 Results

- 1 P.L.C.C. are shown in Summary.
- 2 The laboratory test results of borehole are shown in Table No. 1.
- 3 The Borelog details of borehole are shown in Table No.-2
- 4 The Location plan of borehole is shown in Figure No.1

5 Soil Stratification

Borehole No.	Depth (meter)	Description
BH - 01	0.00 to 10.45	Non Plastic Silty Sand

5B Water Chemical

Type of Test	Units	Depth (meter)	Remark
		NA	
PH		NA	
Chloride Content	in ppm	NA	
Sulphate Content (So3)	in ppm	NA	

5C Soil Chemical

Type of Test	Units	Depth (meter)	Remark
		3.0 mtr	
PH		7.2	
Chloride Content	in ppm	60	
Sulphate Content (So3)	in ppm	15	



6 Typical Calculation for Net Safe Bearing Capacity of soil based on field & laboratory test results:

(A) Typical Calculation for Net Safe Bearing Capacity (As per IS 6403 – 1981) based on Shear Parameter Criteria:

On the basis of available structural details and load on foundation, following assumptions/adoptions are made for the bearing capacity. Computation for Bore No. 1 at 3.00 m below ground level as per I.S. : 6403 - 1981.

1.Width of foundation	=	4.000 m footing	
2.Depth of foundation	=	3.000 m.	
3.Cohesion ©	=	0.000 kg/cm ²	= 0.000 t/m ²
4.Field Dry density (FDD)	=	1.600 gm/cc	= 1.600 t/m ³
5.Field Moisture Content (FMC)	=	2.500 %	
6.Specific Gravity	=	2.640	
7.Angle of internal friction (Ø)	=	30.00 °	
8.Soil Strata	=	--	

Typical calculation:

(1) Size of footing:

Width of footing (B)	=	4.000 m
Length of footing(L)	=	4.000 m
Depth of foundation	=	
GL - FL	=	3.000 m.

(2) Shape factor:

Shape of foundation	=	Square
Sc	=	1.30
Sq	=	1.20
Sr	=	0.80

(3) Depth factor:

$$d_c = 1 + 0.2 \times \frac{D_f}{B} \sqrt{N \phi}$$

where,

$$\sqrt{N \phi} = \tan \left(45 + \frac{30}{2} \right)$$

$$= 1.73$$

$$d_c = \mathbf{1.26}$$

$$d_q = d_r = 1 + 0.1 \times \frac{D_f}{B} \sqrt{N \phi}$$

For $\phi > 10^\circ$

$$d_q = d_r = \mathbf{1.13}$$

(4) Inclination Factor:

Angle of inclination	=	0.000
ic = iq	=	1.000
ir	=	1.000

(5) Bulk Unit Wt. of Foundation Soil:

$$Y = y_d (1 + W/100)$$

$$= \mathbf{1.640} \quad \text{t/m}^3$$

(6) Effective surcharge:

$$\begin{aligned} q &= Y \times D_f \\ &= \gamma_d (1 + w/100) \times D_f \\ &= \mathbf{2.982} \quad \text{t/m}^2 \end{aligned}$$

(7) Correction factor for Water table:

Ground level	=	10.000	m
Water table	=	10.000	m
FL - WTL	=	-3.000	< 3
FL - WTL	<	D _f	
FL - WTL	0.500		

(8) Type of failure:

Initial void ratio

$$\begin{aligned} e_o &= \frac{\text{Specific gravity}}{\text{Dry density}} - 1 = \frac{2.64}{1.600} - 1 \\ &= 0.6500 > 0.55 \\ \therefore \quad \mathbf{Mix\ Shear\ Failure} \quad \mathbf{MSF} \end{aligned}$$

(9) Factors N_c, N_q, N_r from table :1, Pg. 8 of IS:6403-1981:

$$\begin{aligned} \text{Corrected } \phi &= 25.72^\circ & \text{Corrected } C &= \mathbf{0.000} \\ N_c &= \mathbf{21.82} & N_q &= \mathbf{11.52} & N_r &= \mathbf{12.08} \end{aligned}$$

With the use of above parameters, safe bearing capacity is calculated as below:

Net ultimate bearing capacity

$$\begin{aligned} 'q_d &= C N_c S_c d_{c,i_c} + q(N_q - 1) S_q d_{q,i_q} + 1/2 \times B \times Y N_r S_r d_{r,i_r} W' \\ &= 0.00 + 42.51 + 10.85 \\ q_d &= \mathbf{53.361} \quad \text{t/m}^2 \end{aligned}$$

SAFE BEARING CAPACITY:

$$SBC = \frac{\text{Net Ultimate Bearing capacity}}{\text{Factor of safety}}$$

$$SBC = \frac{53.36}{3}$$

$$SBC = 17.787 \quad \text{t/m}^2$$

$$\therefore \text{ Say } SBC = \mathbf{17.79} \quad \text{t/m}^2$$

(B) Allowable Bearing Pressure by Considering 50 mm Settlement.

1	Width of Foundation (B)	=	4.000	4.00	400	cm
2	Length of Foundation (L)	=	4.000	1.80	400	cm
3	Depth of Foundation (D)	=	3.000	m	300	cm
4	Field Dry Density (rd)	=	1.600	1.61	0.0016	kg/cm ³
5	Field Moisture Contents (w)	=	2.650	7.90		
6	Wet Density (rb)	=	1.642	2.63	0.0016424	kg/cm ³
7	Submerged Density (rsub)	=	0.992	30.00	0.00099163	kg/cm ³
7	Specific Gravity (G)	=	2.630			
8	Void Ratio (eo)	=	0.644			
9	Depth of Bore hole	=	10.00			
10	Depth of Water Table	=	3.000			

Average N Value between base of the footing and the depth equal to 1.5 times the width of footing
 $N_{avg} = 16$

Applying correction for overburden & dilatancy

(1) Overburden pressure below foundation $q = r \cdot D$

$$= 4.9272 \text{ t/m}^2$$

$$q' = 4.9272 \text{ t/m}^2$$

$$\text{Corection Factor} = CF = 1.24$$

$$N = 16$$

$$N' = CF \cdot N$$

$$N' = 19.82$$

$$N'' = 20$$

(2) Correction for Dilatancy

$$N'' = 15 + 0.50 (N' - 15)$$

$$N'' = 17.41$$

$$N'' = 17$$

Taking N- Value as 17 & width of footing as 4.000 m, total settlement for 1.00 kg/cm² pressure is 20 mm as per fig.-9 IS-8009(Part-1)

$$L/B = 1.000$$

$$D/_L/B = 0.750$$

$$_L/B/D = 1.333$$

$$\text{Depth Correction} = 0.780$$

$$\text{Rigidity Correction} = 1.00$$

$$\text{Water Table correction} = 0.50$$

$$\text{Corrected Settlement} = 31.20 \text{ mm for 1 Kg/cm}^2 \text{ pressure}$$

$$\text{Allowable Bearing Pressure for 50 mm Settlement} = 1.603 \text{ kg/cm}^2$$

$$\text{Say Allowable Bearing Pressure} = 16.03 \text{ t/m}^2$$

7 Summary

Analysis of S.B.C.						
Depth Below existing G.L. (meter)	Depth Below Natural G.L. (meter)	Type of Foundation	Foundation Size (mtr x mtr)	Net S.B.C. t/m ²		Recomm. Net S.B.C. t/m ²
				Shear Criterion C & Φ Value	Settlement Criteria (50mm)	
2.00	2.00	Square	2.00 x 2.00	11.69	>11.00	11.00
			3.00 x 3.00	12.00	>11.00	11.00
			4.00 x 4.00	12.56	>11.00	11.00
2.50	2.50	Square	2.00 x 2.00	14.66	>14.00	14.00
			3.00 x 3.00	14.71	>14.00	14.00
			4.00 x 4.00	15.13	>14.00	14.00
3.00	3.00	Square	2.00 x 2.00	17.81	>16.00	16.00
			3.00 x 3.00	17.53	>16.00	16.00
			4.00 x 4.00	17.79	16.03	16.00

8 Conclusion & Recommendations:

- The study of the soil investigation at the site at various depths indicates layers as shown in the general stratifications.
- Ground water table is not encountered at the time of investigation.
- Any variation in stratification in any of the foundation location shall be studied thoroughly before executing the foundation work.
- S.B.C. is recommended by considering all the parameters affecting to soil At the field as well as in the laboratory.
- **Side soil should be retained during execution of work.**

For Vishwas Geotech Pvt.Ltd.

Date - 28/11/2022

Sign



NOTATIONS

C	Cohesion
ϕ	Angle of internal friction of soil
DS	Disturbed Sample
UDS	Undisturbed Sample
SPT	Standard Penetration Test
NP	Non Plastic Soils
C_c	Compression Index
P_c	Pre Consolidation pressure
TUU	Unconsolidated undrained triaxial test
DUU	Unconsolidated undrained direct shear test
HWR	Highly Weathered Rock
MWR	Moderately Weathered Rock
FR	Fresh Rock
TCU	Consolidated Undrained triaxial test
DCU	Consolidated Undrained Directshear test

REFERENCE

Indain Standards	IS 2720 Pt. II, III, IV, V, XIII, XXXI, XXVI, XXV IS 1498, IS 6403, IS 1904, IS 2911 IS : 12070 - 1987, IS : 8009 - Pt- 1 - 1973, IS : 4453 - 1967
Murthy V.N.S.	Soil Mechanics and Foundation engineering (Dhanpat Rai and Sons Delhi)
Lambe T.W.	Soil testing or Engineers (Wilery Easter Ltd., New Delhi)
Peck. R.S. Hanson W.E.	Foundation Engineering (Asia Publishing House)
Nayak N.V.	Foundation Engineering Manual (Dhanpat Rai and Sons)
Kaniraj S.R.	Design aids in soil mechnaics and foundation Engineering (Tata Mc Graw Hill Publishing Co. Ltd.)
Alam Singh	Modern Geotechnical Eng. (IBT Publishing & Distrubutors Delhi.)



Vishwas Geotech Pvt.Ltd.						SUMMARY OF EXPLORATION DATA																TABLE - 1		
						Particle Size Analysis				Atterberg's Limit						Shear Parameters			Consolidation Test		Unconfined Comp. Strength kg/sq.cm		For Rock	
																Gravel % - 4.75 mm & above	Sand % - 0.075 to 4.75 mm	Silt % - 0.002 to 0.075 mm	Clay % - Less than 0.002 mm	Liquid Limit			Plastic Limit	Plasticity Index
Depth in mtr.	To	Sample No. & Type	Visual Description of Soil & Stratum No.	Hatching	IS Classification	7	8	9	10	11	12	13	14	15	16						17	18		
0.00	1.00	DS	Non Plastic Silty Sand		SM	0	81	19	22	N P	N P		3.30											
1.50	1.95	SPT			SM	0	83	17	24	N P	N P		3.00											
3.00	3.45	UDS			SM	0	82	18	24	N P	N P	1.60	2.50	0.64	0.00	30	DUU							
4.50	4.95	SPT			SM	10	74	16	23	N P	N P		2.30											
6.00	6.45	UDS			SM	11	62	27	22	N P	N P	1.61	2.20	2.64	0.00	31	DUU							
7.50	7.95	SPT			SM	10	77	13	21	N P	N P		2.10											
9.00	9.45	UDS			SM	12	75	13	20	N P	N P	1.62	2.00	2.64	0.00	32	DUU							
10.00	10.45	SPT			SM	10	75	15	19	N P	N P		1.90											




BORELOG

BORE HOLE NO : 1

Depth of Borehole : 10.45 mtr.

Method of Boring	Casing Bore Diameter	G.W.L.	Depth (M)	Thickness of Layer (M)	Hatching	VISUAL DESCRIPTION SOIL	PENETRATION TEST (N-VALUES)	S.P.T. No. of Blows			N- Value	Un Disturbed Sample	Disturbed Sample	Remark
								N1	N2	N3				
Hand Auger	Not Used	150 mm.	0.00	10.45		Non Plastic Silty Sand		5	6	7	13			
			1.00											
			2.00											
			3.00											
			4.00											
			5.00					6	7	9	16			
			6.00											
			7.00											
			8.00					7	9	10	19			
			9.00											
			10.00					10	12	13	25			





Site Photos



SITE ID - IN- 3154999

SITE NAME:- Open Plot of Mrs Gangaben Dathji Devda, Gamtal Plot No 227, At Moje Samarvada village, Taluka Dhanera, District Banaskantha, State Gujarat, Picode 385310, Police station Samarvada

SITE ADD.- Open Plot of Mrs Gangaben Dathji Devda, Gamtal Plot No 227, At Moje Samarvada village, Taluka Dhanera, District Banaskantha, State Gujarat, Picode 385310, Police station Samarvada

