NODAL POINT BILL CHECK

Duncanville ISD bill review

Prepared for **Marquies Scott, Purchasing Manager**. This is a plain-English check of the invoice, with the main question up front: **is the district being charged for more power than it actually used?**

WHAT NEEDS ATTENTION NOW

The bill shows a peak of 154 kW, but the district is being billed on 175 kW. That is the number to verify first.

AMOUNT DUE

$4,099.70

Due April 10, 2026

USAGE

39,000 kWh

31-day billing period

PEAK SHOWN ON BILL

154 kW

This is the highest level the meter shows

BILLED DEMAND

175 kW

This is the higher number being charged

PLAIN-ENGLISH SUMMARY

- The bill math looks clean. I do not see an obvious double charge or a broken total.
- The real issue is the jump from `154 kW` to `175 kW`.
- That usually means the utility is using a billing rule, a minimum, or a look-back rule from an earlier peak.
- If that rule is valid, the charge stands. If not, the district may be paying for capacity it did not use this month.

WHY THIS MATTERS

THE COST DRIVER

More than half of this bill is coming from utility delivery charges and peak-use charges, not the energy price itself. That means the biggest savings are likely in how the building is being billed, not just in the supply rate.

THE WARNING SIGN

The building is peaking hard instead of using power more evenly. That makes each unit of power more expensive.

QUICK FACTS

ENERGY PRICE	**4.727 cents/kWh**
MEASURED PEAK	**154 kW**
BILLED DEMAND	**175 kW**
GAP TO EXPLAIN	**21 kW**
BLENDED COST	**10.51 cents/kWh**

Short version: the invoice itself looks consistent, but the billed demand number deserves a quick challenge before the next bill closes.

WHAT TO ASK NEXT

The one question that matters

Ask where the 175 kW came from and whether it is a rule, a minimum, or a carryover from an earlier peak.

QUESTIONS TO PUT ON THE TABLE

- Why is the district billed for 175 kW when the bill shows a 154 kW peak?
- Is that number coming from a contract rule, a utility rule, or a minimum charge?
- Can we see the billing details that explain that number in writing?
- Is the current usage pattern causing the building to pay more than it should for peaks?

MY PLAIN-ENGLISH READ

BOTTOM LINE

The district is probably not being overcharged because of a math mistake. The real risk is that it is being charged for a higher power level than it actually hit this month. That is the kind of thing that can quietly add cost every month until someone asks the right question.

RECOMMENDED NEXT STEP

What Marquies should ask for

Keep it simple. Ask for the billing details that explain why 175 kW is being used when the bill shows a 154 kW peak.

WHAT TO SAY

SUGGESTED WORDING

“The bill math looks fine, but I want to understand why we are being charged on 175 kW when the bill shows a 154 kW peak. Please send the billing details that explain that number.”

WHY THIS MATTERS NEXT MONTH

IF THE NUMBER STAYS HIGH

The same cost pattern will likely repeat, and the district keeps paying for a higher level than it actually used.

IF THE NUMBER DROPS

That tells us the current charge was being driven by a rule that can be managed.

RECOMMENDED NEXT STEP

What leadership should see

The ask is simple: explain the 175 kW number in writing, or review it before the next bill lands.

WHAT I WOULD TELL LEADERSHIP

- The bill math is clean.
- The billed demand number is the issue.
- That number may be valid, but it should be explained in writing.
- If it cannot be explained, it deserves pushback now, not later.

WHAT TO WATCH NEXT

IF THE NUMBER STAYS HIGH

The same cost pattern will likely repeat, and the district keeps paying for a higher level than it actually used.

IF THE NUMBER DROPS

That tells us the current charge was being driven by a rule that can be managed.

This report is written to be easy to hand to a superintendent or supervisor. It stays simple and focuses on the one issue that could add cost every month.