

```
11 Desigo Fire Safety Modular "BDB DC-2" Local
  CAB-1 "CAB-1 Enclosure #1"
    11:249 PSC-12 "PSC-12 @ address 249"
```

```
|      |  |-- 11:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      |  |-- Inner Door
|      |  |-- 11:253 PMI-D "PMI-D @ address 253"
|-- 10 Desigo Fire Safety Modular "BDB TOWER A" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-2 "CAB-2 Enclosure #1"
|    |-- CC-5 "Card Cage 5 Slots"
|      |-- 10:1 XDLC "DLC @ address 1 E/W 1st FLOOR"
|        |-- 10:1-1 HTRI-R "A/L1/EC/1F/CM1/FIRE HYD SHAFT"
|          |-- Switch ""
|          |-- Relay
|            |-- 10:1-2 HTRI-S "A/L1/EC/1F/MM2/FIRE HYD SHAFT"
|              |-- 10:1-3 HMS-S/D/M/SA "A/L1/EC/1F/MCP3/LIFT LOBBY STR"
|                |-- 10:1-4 FDOT421 "A/L1/EC/1F/SD4/LIFT LOBBY"
|                  |-- 10:1-5 HTRI-R "A/L1/EC/1F/CM5/AHU ROOM"
|                    |-- Switch ""
|                    |-- Relay
|                      |-- 10:1-6 FDOT421 "A/L1/EC/1F/SD6/AHU ROOM"
|                        |-- 10:1-7 FDOT421 "A/L1/EC/1F/SD7/AHU ROOM"
|                          |-- 10:1-8 FDOT421 "A/L1/EC/1F/SD8/ELECTRICAL ROOM"
|                            |-- 10:1-9 HTRI-R "A/L1/WC/1F/CM9/FIRE HYD SHAFT"
|                              |-- Switch ""
|                              |-- Relay
|                                |-- 10:1-10 HTRI-S "A/L1/WC/1F/MM10/FIRE HYD SHAFT"
|                                  |-- 10:1-11 HMS-S/D/M/SA "A/L1/WC/1F/MCP11/FIRE ESCAPE STR"
|                                    |-- 10:1-13 FDOT421 "A/L1/WC/1F/SD13/LIFT LOBBY"
|                                      |-- 10:1-14 FDOT421 "A/L1/WC/1F/SD14/CORR NR L.L."
|                                        |-- 10:1-15 FDOT421 "A/L1/WC/1F/SD15/LOBBY NR AW1021"
|                                          |-- 10:1-16 FDOT421 "A/L1/WC/1F/SD16/ELE ROOM"
|                                            |-- 10:1-17 FDOT421 "A/L1/WC/1F/SD17/AHU ROOM"
|                                              |-- 10:1-18 HTRI-R "A/L1/WC/1F/CM18/AHU ROOM"
|                                                |-- Switch ""
|                                                |-- Relay
|                                                  |-- 10:1-41 XTRI-S "A/L1/1F/MM41/AW1010"
|                                                    |-- 10:1-42 XTRI-S "A/L1/1F/MM42/AW1022"
|                                                      |-- 10:1-43 XTRI-S "A/L1/1F/MM43/AW1021"
|                                                        |-- 10:1-44 XTRI-S "A/L1/1F/MM44/AW1031"
|                                                          |-- 10:1-45 HTRI-S "A/L1/1F/MM45/AE1010 1A"
|                                                            |-- 10:1-46 HTRI-S "A/L1/1F/MM46/AE1010 1B"
|                      |-- 10:2 XDLC "DLC @ address 2 E/W 2nd FLOOR"
|                        |-- 10:2-1 HTRI-R "A/L2/EC/2F/CM1/FIRE HYD SHAFT"
|                          |-- Switch ""
|                          |-- Relay
|                            |-- 10:2-2 HTRI-S "A/L2/EC/2F/MM2/FIRE HYD SHAFT"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:2 XDLC "DLC @ address 2 E/W 2nd FLOOR"

| | | |-- 10:2-3 HMS-S/D/M/SA "A/L2/EC/2F/MCP3/LIFT LOBBY STR"
| | | |-- 10:2-4 FDOT421 "A/L2/EC/2F/SD4/LIFT LOBBY"
| | | |-- 10:2-5 HTRI-R "A/L2/EC/2F/CM5/DOOR RELEASE U"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:2-6 HTRI-R "A/L2/EC/2F/CM6/AHU ROOM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:2-7 FDOT421 "A/L2/EC/2F/SD7/AHU ROOM"
| | | |-- 10:2-8 FDOT421 "A/L2/EC/2F/SD8/ELECTRICAL ROOM"
| | | |-- 10:2-9 FDOT421 "A/L2/EC/2F/SD9/AFC ELECT RM"
| | | |-- 10:2-10 FDOT421 "A/L2/EC/2F/SD10/OUTSIDE ELECT RM"
| | | |-- 10:2-11 FDOT421 "A/L2/EC/2F/SD11/AFC CORR AE2080"
| | | |-- 10:2-12 FDOT421 "A/L2/EC/2F/SD12/AFC CORR AE2/S02"
| | | |-- 10:2-13 FDOT421 "A/L2/EC/2F/SD13/CORR AE 2020A"
| | | |-- 10:2-14 FDOT421 "A/L2/EC/2F/SD14/CORRIDOR AE 2020"
| | | |-- 10:2-15 FDOT421 "A/L2/E/2F/SD15/AFC COR NRAE2020"
| | | |-- 10:2-16 HTRI-R "A/L2/EC/2F/CM16/CORR STR CASE"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:2-17 HMS-S/D/M/SA "A/L2/EC/2F/MCP17/CORR STR CASE"
| | | |-- 10:2-18 FDOT421 "A/L2/EC/2F/SD18/CORRIDOR AE 2031"
| | | |-- 10:2-19 FDOT421 "A/L2/EC/2F/SD19/AFC CORR AE2/S10"
| | | |-- 10:2-20 FDOT421 "A/L2/EC/2F/SD20/CORR AE2/S05"
| | | |-- 10:2-21 FDOT421 "A/L2/E/2F/SD21/CORR NrAW2/S09AFC"
| | | |-- 10:2-22 FDOT421 "A/L2/EC/2F/SD22/CORRIDOR AE 2044"
| | | |-- 10:2-23 FDOT421 "A/L2/WC/2F/SD23/OUTSIDE ELECT RM"
| | | |-- 10:2-24 HTRI-R "A/L2/WC/2F/CM24/OUTSIDE ELECT RM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:2-25 FDOT421 "A/L2/WC/2F/SD25/ELECTRICAL ROOM"
| | | |-- 10:2-26 HMS-S/D/M/SA "A/L2/WC/2F/MCP26/LIFT LOBBY STR"
| | | |-- 10:2-27 HTRI-R "A/L2/WC/2F/CM27/FIRE HYD SHAFT"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:2-28 HTRI-S "A/L2/WC/2F/MM28/FIRE HYD SHAFT"
| | | |-- 10:2-29 FDOT421 "A/L2/WC/2F/SD29/LIFT LOBBY"
| | | |-- 10:2-30 FDOT421 "A/L2/WC/2F/SD30/LIFT LOBBY"
| | | |-- 10:2-31 HTRI-R "A/L2/WC/2F/CM31/DOOR RELEASE U"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:2-32 HTRI-R "A/L2/WC/2F/CM32/AHU ROOM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:2-33 FDOT421 "A/L2/WC/2F/SD33/AHU ROOM"
| | | |-- 10:2-34 FDOT421 "A/L2/W/2F/SD34/CORRAW2/S07AFC"
| | | |-- 10:2-35 FDOT421 "A/L2/WC/2F/SD35/CORR AW2/S07"
| | | |-- 10:2-36 FDOT421 "A/L2/W/2F/SD36/CORRAW2022AFC"
| | | |-- 10:2-37 FDOT421 "A/L2/WC/2F/SD37/CORR AW2150"
| | | |-- 10:2-41 XTRI-S "A/L2/2F/MM41/AE2011"

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:2 XDLC "DLC @ address 2 E/W 2nd FLOOR"

				--	10:2-43	XTRI-S	"A/L2/2F/MM43/AE2080"
				--	10:2-44	XTRI-S	"A/L2/2F/MM44/AE2013"
				--	10:2-46	XTRI-S	"A/L2/2F/MM46/AE2020A"
				--	10:2-51	XTRI-S	"A/L2/2F/MM51/AE2031"
				--	10:2-52	XTRI-S	"A/L2/2F/MM52/AE2041"
				--	10:2-53	XTRI-S	"A/L2/2F/MM53/AE2053"
				--	10:2-54	XTRI-S	"A/L2/2F/MM54/AE2042"
				--	10:2-56	XTRI-S	"A/L2/2F/MM56/AE2043"
				--	10:2-57	XTRI-S	"A/L2/2F/MM57/AE2044"
				--	10:2-58	XTRI-S	"A/L2/2F/MM58/AE2051"
				--	10:2-60	XTRI-S	"A/L2/2F/MM60/AW2160"
				--	10:2-61	XTRI-S	"A/L2/2F/MM61/AW2022/23"
				--	10:2-62	XTRI-S	"A/L2/2F/MM62/AW2150"
				--	10:2-63	HFP-11	"A/L2/AE2020/SD63/Main cabin"
				--	10:2-64	HFP-11	"A/L2/AE2020/SD64/Assorter Room"
				--	10:2-65	HFP-11	"A/L2/AE2020/SD65/Accounts cabin"
				--	10:2-66	HFPT-11	"A/L2/AE2020/HD66/Pantry Area"
				--	10:2-67	HFP-11	"A/L2/AE2020/SD67/Passage Area"
				--	10:2-68	HTRI-R	"A/L2/AE2020/CM68/Entry Door"
				--	Switch	"	
				--	Relay		
				--	10:2-69	HMS-S/D/M/SA	"A/L2/AE2020/MCP69/Entry Door"
				--	10:2-70	HFP-11	"A/L2/AE2032/SD70/Main cabin-1"
				--	10:2-71	HFP-11	"A/L2/AE2032/SD71/Main cabin-2"
				--	10:2-72	HFP-11	"A/L2/AE2032/SD72/Passage Area"
				--	10:2-73	HTRI-R	"A/L2/AE2032/CM73/Entry Door"
				--	Switch	"	
				--	Relay		
				--	10:2-74	HMS-S/D/M/SA	"A/L2/AE2032/MCP74/Entry Door"
				--	10:2-94	HFP-11	"A/L2/AW2021/SD94/Main Cab1"
				--	10:2-95	HFP-11	"A/L2/AW2021/SD95/Main Cab2"
				--	10:2-96	HFP-11	"A/L2/AW2021/SD96/Main Cab2"
				--	10:2-97	HFP-11	"A/L2/AW2021/SD97/Account cab"
				--	10:2-98	HFP-11	"A/L2/AW2021/SD98/Assorter Cab"
				--	10:2-99	HFP-11	"A/L2/AW2021/SD99/Reception Area"
				--	10:2-100	HFPT-11	"A/L2/AW2021/HD100/Pantry"
				--	10:2-101	HTRI-R	"A/L2/AW2021/CM101/Entry Door Psg"
				--	Switch	"	
				--	Relay		
				--	10:2-102	HMS-S/D/M/SA	"A/L2/AW2021/MCP102/Entry Door"
				--	10:2-80	HTRI-S	"A/L2/2F/MM80/AE2060"
				--	10:3	XDLC	"DLC @ address 3 E/W 3rd FLOOR"
				--	10:3-1	HTRI-R	"A/L3/EC/3F/CM1/FIRE HYD SHAFT"
				--	Switch	"	
				--	Relay		
				--	10:3-2	HTRI-S	"A/L3/EC/3F/MM2/FIRE HYD HAFT"
				--	10:3-3	HMS-S/D/M/SA	"A/L3/EC/3F/MCP3/LIFT LOBBY STR"
				--	10:3-4	FDOT421	"A/L3/EC/3F/SD4/LIFT LOBBY"
				--	10:3-5	HTRI-R	"A/L3/EC/3F/CM5/DOOR RELEASE U"
				--	Switch	"	

```

10 Desigo Fire Safety Modular "BDB TOWER A" Local
    CAB-2 "CAB-2 Enclosure #1"
        CC-5 "Card Cage 5 Slots"
            10:3 XDLC "DLC @ address 3 E/W 3rd FLOOR"
                10:3-5 HTRI-R "A/L3/EC/3F/CM5/DOOR RELEASE U"

```

```
| | | Relay
| | | |-- 10:3-6 HTRI-R "A/L3/EC/3F/CM6/AHU ROOM"
| | | |   |-- Switch ""
| | | |   |-- Relay
| | | |-- 10:3-7 FDOT421 "A/L3/EC/3F/SD7/AHU ROOM"
| | | |-- 10:3-8 FDOT421 "A/L3/EC/3F/SD8/ELECTRICAL ROOM"
| | | |-- 10:3-9 FDOT421 "A/L3/EC/3F/SD9/AFC CORR AE3100"
| | | |-- 10:3-10 FDOT421 "A/L3/EC/3F/SD10/CORR AE3100"
| | | |-- 10:3-11 FDOT421 "A/L3/EC/3F/SD11/AFC CORR AE3/S02"
| | | |-- 10:3-12 FDOT421 "A/L3/EC/3F/SD12/CORRIDOR AE3/S02"
| | | |-- 10:3-13 FDOT421 "A/L3/EC/3F/SD13/CORRIDOR AE3021"
| | | |-- 10:3-14 FDOT421 "A/L3/EC/3F/SD14/AFC CORR AE 3080"
| | | |-- 10:3-15 FDOT421 "A/L3/EC/3F/SD15/CORRIDOR AE 3022"
| | | |-- 10:3-16 HTRI-R "A/L3/EC/3F/CM16/CORR STR CASE"
| | | |   |-- Switch ""
| | | |   |-- Relay
| | | |-- 10:3-17 HMS-S/D/M/SA "A/L3/EC/3F/MCP17/CORR STR CASE"
| | | |-- 10:3-18 FDOT421 "A/L3/EC/3F/SD18/AFC CORR AE/S04"
| | | |-- 10:3-19 FDOT421 "A/L3/EC/3F/SD19/CORRIDOR AE3/S04"
| | | |-- 10:3-20 FDOT421 "A/L3/EC/3F/SD20/CORRIDOR AE 3040"
| | | |-- 10:3-21 FDOT421 "A/L3/EC/3F/SD21/AFC CORR AE 3060"
| | | |-- 10:3-22 FDOT421 "A/L3/EC/3F/SD22/COAR NR AE3050"
| | | |-- 10:3-23 FDOT421 "A/L3/EC/3F/SD23/CORR AW3/S09AFC"
| | | |-- 10:3-24 FDOT421 "A/L3/EC/3F/SD24/CORR NR ELE RM"
| | | |-- 10:3-25 HTRI-R "A/L3/WC/3F/CM25/OUTSIDE ELECT RM"
| | | |   |-- Switch ""
| | | |   |-- Relay
| | | |-- 10:3-26 FDOT421 "A/L3/WC/3F/SD26/AW ELECTRIC ROOM"
| | | |-- 10:3-27 HMS-S/D/M/SA "A/L3/WC/3F/MCP27/LIFT LOBBY STR"
| | | |-- 10:3-28 HTRI-R "A/L3/WC/3F/CM28/FIRE HYD SHAFT"
| | | |   |-- Switch ""
| | | |   |-- Relay
| | | |-- 10:3-29 HTRI-S "A/L3/WC/3F/MM29/FIRE HYD SHAFT"
| | | |-- 10:3-30 FDOT421 "A/L3/WC/3F/SD30/LIFT LOBBY"
| | | |-- 10:3-31 FDOT421 "A/L3/WC/3F/SD31/LIFT LOBBY"
| | | |-- 10:3-32 HTRI-R "A/L3/WC/3F/CM32/DOOR RELEASE U"
| | | |   |-- Switch ""
| | | |   |-- Relay
| | | |-- 10:3-33 HTRI-R "A/L3/WC/3F/CM33/AHU ROOM"
| | | |   |-- Switch ""
| | | |   |-- Relay
| | | |-- 10:3-34 FDOT421 "A/L3/EC/3F/SD32/CORR NR AE3050"
| | | |-- 10:3-35 FDOT421 "A/L3/WC/3F/SD35/AFC CORR AHU RM"
| | | |-- 10:3-36 FDOT421 "A/L3/WC/3F/SD36/CORR AW3/S07"
| | | |-- 10:3-37 FDOT421 "A/L3/WC/3F/SD37/CORR NRAW3021"
| | | |-- 10:3-41 XTRI-S "A/L3/3F/MM41/AE3100"
| | | |-- 10:3-43 XTRI-S "A/L3/3F/MM43/AE3092"
| | | |-- 10:3-46 XTRI-S "A/L3/3F/MM46/AE3080"
| | | |-- 10:3-48 XTRI-S "A/L3/3F/MM48/AE3031"
| | | |-- 10:3-51 XTRI-S "A/L3/3F/MM51/AE3032"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:3 XDLC "DLC @ address 3 E/W 3rd FLOOR"

			-- 10:3-52 XTRI-S	"A/L3/3F/MM52/AE3040"
			-- 10:3-53 XTRI-S	"A/L3/3F/MM53/AE3060"
			-- 10:3-54 XTRI-S	"A/L3/3F/MM54/AE3050"
			-- 10:3-56 XTRI-S	"A/L3/3F/MM56/AW3120"
			-- 10:3-57 XTRI-S	"A/L3/3F/MM57/AW3021"
			-- 10:3-59 HFP-11	"A/L3/AW3110/SD59/Main Cabin"
			-- 10:3-60 HFP-11	"A/L3/AW3110/SD60/Passage Area"
			-- 10:3-61 HFP-11	"A/L3/AW3110/SD61/AFC Cab 1"
			-- 10:3-116 HFP-11	"A/L3/WC/SD116/AW3110/Entry Door"
			-- 10:3-62 HTRI-R	"A/L3/AW3110/CM62/Entry Door"
				-- Switch ""
				-- Relay
			-- 10:3-108 HMS-S/D/M/SA	"A/L3/AW3110/MCP108/Entry Door"
			-- 10:3-63 HFP-11	"A/L3/AW3010/SD63/Main Cabin"
			-- 10:3-64 HFP-11	"A/L3/AW3010/SD64/Assorter Room"
			-- 10:3-65 HFP-11	"A/L3/AW3010/SD65/Accounts Cabin"
			-- 10:3-66 HFP-11	"A/L3/AW3010/SD66/Passage Area"
			-- 10:3-67 HFP-11	"A/L3/AW3010/SD67/Pantry""
			-- 10:3-68 HTRI-R	"A/L3/AW3010/CM68/Entry Door"
				-- Switch ""
				-- Relay
			-- 10:3-69 HMS-S/D/M/SA	"A/L3/AW3010/MCP69/Entry Door"
			-- 10:3-70 HFP-11	"A/L3/AE3071/SD70/Main cabin-1"
			-- 10:3-71 HFP-11	"A/L3/AE3071/SD71/Main cabin-2"
			-- 10:3-72 HFP-11	"A/L3/AE3071/SD72/Assorter Room"
			-- 10:3-73 HFP-11	"A/L3/AE3071/SD73/Pantry Area"
			-- 10:3-74 HFP-11	"A/L3/AE3071/SD74/Passage Area"
			-- 10:3-75 XTRI-R	"A/L3/AE3071/CM75/Entry Door"
				-- Switch ""
				-- Relay
			-- 10:3-76 HMS-S/D/M/SA	"A/L3/AE3071/MCP76/Entry Door"
			-- 10:3-77 HFP-11	"A/L3/AE3010/SD77/Entry Door"
			-- 10:3-78 HFP-11	"A/L3/AE3010/SD78/Passage Area"
			-- 10:3-79 HFP-11	"A/L3/AE3010/SD79/Cabin 1"
			-- 10:3-81 HFP-11	"A/L3/AE3010/SD81/Cabin 2"
			-- 10:3-82 HFP-11	"A/L3/AE3010/SD82/Cabin 3"
			-- 10:3-83 HFP-11	"A/L3/AE3010/SD83/Cabin 4"
			-- 10:3-84 HFP-11	"A/L3/AE3010/SD84/Cabin 5"
			-- 10:3-85 HTRI-R	"A/L3/AE3010/CM85/Entry Door"
				-- Switch ""
				-- Relay
			-- 10:3-86 HMS-S/D/M/SA	"A/L3/AE3010/MCP86/Entry Door"
			-- 10:3-87 HFP-11	"A/L3/AE3021/SD87/Account cab "
			-- 10:3-88 HFP-11	"A/L3/AE3021/SD88/Assorter cab "
			-- 10:3-89 HFP-11	"A/L3/AE3021/SD89/Main cab "
			-- 10:3-90 HFP-11	"A/L3/AE3021/SD90/Conference rm"
			-- 10:3-91 HFP-11	"A/L3/AE3021/SD91/Boss cab"
			-- 10:3-92 HFP-11	"A/L3/AE3021/SD92/Angadia cab"
			-- 10:3-93 HFP-11	"A/L3/AE3021/SD93/Pantry"
			-- 10:3-95 HFP-11	"A/L3/AE3021/SD95/Reception psq"

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:3 XDLC "DLC @ address 3 E/W 3rd FLOOR"

```
|      |      |      |-- 10:3-96 HTRI-R "A/L3/AE3021/CM96/Entry dr psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:3-97 HMS-S/D/M/SA "A/L3/AE3021/MCP97/Entry dr psg"
|      |      |      |-- 10:3-115 HTRI-S "A/L3/3F/MM115/AE3090"
|      |      |      |-- 10:3-109 HFP-11 "A/L3/AE3022/SD109/Mani Cab"
|      |      |      |-- 10:3-110 HFP-11 "A/L3/AE3022/SD110/Assotors Cab"
|      |      |      |-- 10:3-111 HFP-11 "A/L3/AE3022/SD111/Psg Nr. Pantry"
|      |      |      |-- 10:3-112 HFPT-11 "A/L3/AE3022/HD112/Pantry"
|      |      |      |-- 10:3-113 HTRI-R "A/L3/AE3022/CM113/Assortor Cab A"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:3-114 HMS-S/D/M/SA "A/L3/AE3022/SD114/Entry DR Psg"
|      |      |      |-- 10:3-98 HFP-11 "A/L3/AE3071/SD98/DINNING CABIN "
|      |      |      |-- 10:3-80 HFP-11 "A/L3/AE3010/SD80/Watting Area"
|      |      |      |-- 10:4 XDLC "DLC @ address 4 E/W 4th FLOOR"
|      |      |      |-- 10:4-1 HTRI-R "A/L4/EC/4F/CM1/FIRE HYD SHAFT"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:4-2 HTRI-S "A/L4/EC/4F/MM2/FIRE HYD SHAFT"
|      |      |      |-- 10:4-3 HMS-S/D/M/SA "A/L4/EC/4F/MCP3/LIFT LOBBY STR"
|      |      |      |-- 10:4-4 FDOT421 "A/L4/EC/4F/SD4/LIFT LOBBY"
|      |      |      |-- 10:4-5 HTRI-R "A/L4/EC/4F/CM5/DOOR RELEASE U"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:4-6 HTRI-R "A/L4/EC/4F/CM6/AHU ROOM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:4-7 FDOT421 "A/L4/EC/4F/SD7/AHU ROOM"
|      |      |      |-- 10:4-8 FDOT421 "A/L4/EC/4F/SD8/ELECTRICAL ROOM"
|      |      |      |-- 10:4-9 FDOT421 "A/L4/EC/4F/SD9/AFC COR NR AE4070"
|      |      |      |-- 10:4-10 FDOT421 "A/L4/EC/4F/SD10/COR NR AE4070"
|      |      |      |-- 10:4-11 FDOT421 "A/L4/EC/4F/SD11/AFC CORR AE4011"
|      |      |      |-- 10:4-12 FDOT421 "A/L4/EC/4F/SD12/CORRIDOR AE2/S02"
|      |      |      |-- 10:4-13 FDOT421 "A/L4/EC/4F/SD13/CORR NR AE4012"
|      |      |      |-- 10:4-14 FDOT421 "A/L4/EC/4F/SD14/CORR NR AE4020"
|      |      |      |-- 10:4-15 HTRI-R "A/L4/EC/4F/CM15/CORR STR CASE"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:4-16 HMS-S/D/M/SA "A/L4/EC/4F/MCP16/CORR STR CASE"
|      |      |      |-- 10:4-17 FDOT421 "A/L4/E/4F/SD17/AFC CORNrAE4 S/10"
|      |      |      |-- 10:4-18 FDOT421 "A/L4/EC/4F/SD18/CORRIDOR AE4032A"
|      |      |      |-- 10:4-19 FDOT421 "A/L4/EC/4F/SD19/AFC COR NR AE404"
|      |      |      |-- 10:4-20 FDOT421 "A/L4/EC/4F/SD20/CORRIDOR AE4032C"
|      |      |      |-- 10:4-21 FDOT421 "A/L4/EC/4F/SD21/AFC COR AE S/09"
|      |      |      |-- 10:4-22 FDOT421 "A/L4/EC/4F/SD22/CORRIDOR AE4032D"
|      |      |      |-- 10:4-23 FDOT421 "A/L4/WC/4F/SD23/AFC COR ELE RM"
|      |      |      |-- 10:4-24 FDOT421 "A/L4/WC/4F/SD24/OUTSIDE ELECT RM"
|      |      |      |-- 10:4-25 HTRI-R "A/L4/WC/4F/CM25/DOOR RELEASE U"
|      |      |      |  |-- Switch ""
```

```

10 Desigo Fire Safety Modular "BDB TOWER A" Local
    CAB-2 "CAB-2 Enclosure #1"
        CC-5 "Card Cage 5 Slots"
            10:4 XDLC "DLC @ address 4 E/W 4th FLOOR"
                10:4-25 HTRI-R "A/L4/WC/4F/CM25/DOOR RELEASE U"

```

[illegible]

```

| | | Switch ""
| | | |-- Relay
| | | |-- 10:4-72 HMS-S/D/M/SA "A/L4/AE4041/MCP72/Entry Door"
| | | |-- 10:4-83 HFP-11 "A/L4/AE4070/SD83/Main cabin"
| | | |-- 10:4-84 HFP-11 "A/L4/AE4070/SD84/Pantry"
| | | |-- 10:4-85 HTRI-R "A/L4/AE4070/CM85/Entry Door"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 10:4-86 HMS-S/D/M/SA "A/L4/AE4070/MCP86/Entry Door"
| | | |-- 10:4-51 HTRI-S "A/L4/P1/4F/MM51/AE4042A""
| | |-- 10:5 XDLC "DLC @ address 5 E/W 5th FLOOR"
| | | |-- 10:5-1 HTRI-R "A/L5/EC/5F/CM1/FIRE HYD SHAFT"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:5-2 XTRI-S "A/L5/EC/5F/MM2/FIRE HYD SHAFT"
| | | |-- 10:5-3 HMS-S/D/M/SA "A/L5/EC/5F/MCP3/LIFT LOBBY STR"
| | | |-- 10:5-4 FDOT421 "A/L5/EC/5F/SD4/LIFT LOBBY"
| | | |-- 10:5-5 HTRI-R "A/L5/EC/5F/CM5/DOOR RELEASE U"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:5-6 HTRI-R "A/L5/EC/5F/CM6/AHU ROOM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:5-7 FDOT421 "A/L5/EC/5F/SD7/AHU ROOM"
| | | |-- 10:5-8 FDOT421 "A/L5/EC/5F/SD8/ELECTRICAL ROOM"
| | | |-- 10:5-9 FDOT421 "A/L5/EC/5F/SD9/AFC CORR AE5021 "
| | | |-- 10:5-10 FDOT421 "A/L5/EC/5F/SD10/CORRIDOR AE 5010"
| | | |-- 10:5-11 FDOT421 "A/L5/EC/5F/SD11/CORR AE5/S02"
| | | |-- 10:5-12 FDOT421 "A/L5/EC/5F/SD12/CORRIDOR AE5030"
| | | |-- 10:5-13 FDOT421 "A/L5/EC/5F/SD13/AFC CORR AE 5030"
| | | |-- 10:5-14 FDOT421 "A/L5/EC/5F/SD14/CORR NR STR CASE"
| | | |-- 10:5-15 HTRI-R "A/L5/EC/5F/CM15/CORR NR STR CASE"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:5-16 HMS-S/D/M/SA "A/L5/EC/5F/MCP16/CORR STR CASE"
| | | |-- 10:5-17 FDOT421 "A/L5/EC/5F/SD17/AFC CORR AE5050"
| | | |-- 10:5-18 FDOT421 "A/L5/EC/5F/SD18/CORRIDOR AE 5040"
| | | |-- 10:5-19 FDOT421 "A/L5/EC/5F/SD19/CORRIDOR AE 5080"
| | | |-- 10:5-20 FDOT421 "A/L5/EC/5F/SD20/AFC CORR AE5070"
| | | |-- 10:5-21 FDOT421 "A/L5/EC/5F/SD21/CORR NR ELE RM"
| | | |-- 10:5-22 FDOT421 "A/L5/WC/5F/SD22/ELECTRICAL ROOM"
| | | |-- 10:5-23 HTRI-R "A/L5/WC/5F/CM23/DOOR RELEASE U"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:5-24 HMS-S/D/M/SA "A/L5/WC/5F/MCP24/LIFT LOBBY STR"
| | | |-- 10:5-25 HTRI-R "A/L5/WC/5F/CM25/FIRE HYD SHAFT"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 10:5-26 XTRI-S "A/L5/WC/5F/MM26/FIRE HYD SHAFT"
| | | |-- 10:5-27 FDOT421 "A/L5/WC/5F/SD27/LIFT LOBBY"

```


10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:5 XDLC "DLC @ address 5 E/W 5th FLOOR"

```
|      |      |-- 10:5-28 FDOT421 "A/L5/WC/5F/SD28/LIFT LOBBY"
|      |      |-- 10:5-29 HTRI-R "A/L5/WC/5F/CM29/DOOR RELEASE U"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:5-30 HTRI-R "A/L5/WC/5F/CM30/AHU ROOM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:5-31 FDOT421 "A/L5/WC/5F/SD31/AHU ROOM"
|      |      |-- 10:5-32 FDOT421 "A/L5/WC/5F/SD32/CORR AW5130AFC"
|      |      |-- 10:5-33 FDOT421 "A/L5/WC/5F/SD33/CORR AW5130"
|      |      |-- 10:5-34 FDOT421 "A/L5/WC/5F/SD34/AFC CORR AW5020"
|      |      |-- 10:5-35 FDOT421 "A/L5/WC/5F/SD35/CORRIDOR AW5020"
|      |      |-- 10:5-36 HTRI-S "A/L5/5F/MM36/AW5130"
|      |      |-- 10:5-42 HTRI-S "A/L5/5F/MM42/AE5021"
|      |      |-- 10:5-43 HTRI-S "A/L5/5F/MM43/AE5110"
|      |      |-- 10:5-44 HTRI-S "A/L5/5F/MM44/AE5030A"
|      |      |-- 10:5-46 HTRI-S "A/L5/5F/MM46/AE5100"
|      |      |-- 10:5-47 HTRI-S "A/L5/5F/MM47/AE5040"
|      |      |-- 10:5-49 HTRI-S "A/L5/5F/MM49/AE5050"
|      |      |-- 10:5-50 HTRI-S "A/L5/5F/MM50/AE5080"
|      |      |-- 10:5-51 HTRI-S "A/L5/5F/MM51/AE5060"
|      |      |-- 10:5-52 HTRI-S "A/L5/5F/MM52/AE5070"
|      |      |-- 10:5-53 HTRI-S "A/L5/5F/MM53/AW5010"
|      |      |-- 10:5-55 HTRI-S "A/L5/5F/MM55/AW5122"
|      |      |-- 10:5-56 HTRI-S "A/L5/5F/MM56/AW5121"
|      |      |-- 10:5-57 HTRI-S "A/L5/5F/MM57/AW5020"
|      |      |-- 10:5-59 HTRI-S "A/L5/5F/MM59/AE5010"
|      |      |-- 10:5-60 HFP-11 "A/L5/AW5030/SD60/Main cabin"
|      |      |-- 10:5-61 HFP-11 "A/L5/AW5030/SD61/Store Room"
|      |      |-- 10:5-62 HFP-11 "A/L5/AW5030/SD62/Conference room"
|      |      |-- 10:5-63 HFP-11 "A/L5/AW5030/SD63/Account Departm"
|      |      |-- 10:5-64 HFP-11 "A/L5/AW5030/SD64/Tiffin room"
|      |      |-- 10:5-65 HFP-11 "A/L5/AW5030/SD65/Reception"
|      |      |-- 10:5-66 HTRI-R "A/L5/AW5030/CM66/Entry Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:5-67 HMS-S/D/M/SA "A/L5/AW5030/MCP67/Entry Door"
|      |      |-- 10:5-68 HFP-11 "A/L5/AW5030/SD68/Pantry"
|      |      |-- 10:5-69 FDOT421 "A/L5/AE5030/SD69/Passage Area"
|      |      |-- 10:5-70 HFPT-11 "A/L5/AE5030/HD70/Pantry "
|      |      |-- 10:5-71 HFP-11 "A/L5/AE5030/SD71/Assorter Room 1"
|      |      |-- 10:5-72 HFP-11 "A/L5/AE5030/SD72/Assorter Room 2"
|      |      |-- 10:5-73 HFP-11 "A/L5/AE5030/SD73/Assorter Room 3"
|      |      |-- 10:5-74 HFP-11 "A/L5/AE5030/SD74/Assorter Room 4"
|      |      |-- 10:5-75 HFP-11 "A/L5/AE5030/SD75/Assorter Room 5"
|      |      |-- 10:5-76 HFP-11 "A/L5/AE5030/SD76/Locker Room"
|      |      |-- 10:5-77 HFP-11 "A/L5/AE5030/SD77/Main Cabin"
|      |      |-- 10:5-78 HTRI-R "A/L5/AE5030/CM78/Entry Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:5 XDLC "DLC @ address 5 E/W 5th FLOOR"

```
|      |      |-- 10:5-79 HMS-S/D/M/SA "A/L5/AE5030/MCP79/Entry Door"
|      |      |-- 10:5-84 HFP-11 "A/L5/AE5090/SD84/Pantry Area"
|      |      |-- 10:5-85 HFP-11 "A/L5/AE5090/SD85/Passage Area"
|      |      |-- 10:5-86 HFP-11 "A/L5/AE5090/SD86/Main cabin"
|      |      |-- 10:5-87 HFP-11 "A/L5/AE5090/SD87/Cabin 1"
|      |      |-- 10:5-88 HTRI-R "A/L5/AE5090/CM88/Entry Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:5-89 HMS-S/D/M/SA "A/L5/AE5090/MCP89/Entry Door"
|      |-- CC-5 "Card Cage 5 Slots"
|      |      |-- 10:6 XDLC "DLC @ address 6 E/W 6th FLOOR"
|      |      |  |-- 10:6-1 HTRI-R "A/L6/EC/6F/CM1/FIRE HYD SHAFT"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 10:6-2 HTRI-S "A/L6/EC/6F/MM2/FIRE HYD SHAFT"
|      |      |  |-- 10:6-3 HMS-S/D/M/SA "A/L6/EC/6F/MCP3/LIFT LOBBY STR"
|      |      |  |-- 10:6-4 FDOT421 "A/L6/EC/6F/SD4/LIFT LOBBY"
|      |      |  |-- 10:6-5 HTRI-R "A/L6/EC/6F/CM5/DOOR RELEASE U"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 10:6-6 HTRI-R "A/L6/EC/6F/CM6/AHU ROOM"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 10:6-7 FDOT421 "A/L6/EC/6F/SD7/AHU ROOM"
|      |      |  |-- 10:6-8 FDOT421 "A/L6/EC/6F/SD8/ELECTRICAL ROOM"
|      |      |  |-- 10:6-9 FDOT421 "A/L6/EC/6F/SD9/AFC CORR NR AHU R"
|      |      |  |-- 10:6-10 FDOT421 "A/L6/EC/6F/SD10/CORR NR AHU RM"
|      |      |  |-- 10:6-11 FDOT421 "A/L6/WC/6F/SD11/AFC COR AW6/S03"
|      |      |  |-- 10:6-12 FDOT421 "A/L6/WC/6F/SD12/COR AW6/03"
|      |      |  |-- 10:6-13 FDOT421 "A/L6/WC/6F/SD13/AFC CORR AW6060"
|      |      |  |-- 10:6-14 FDOT421 "A/L6/WC/6F/SD14/CORRIDOR AW 6060"
|      |      |  |-- 10:6-15 HTRI-R "A/L6/WC/6F/CM15/CORR STR CASE"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 10:6-16 HMS-S/D/M/SA "A/L6/WC/6F/MCP16/CORR STR CASE"
|      |      |  |-- 10:6-17 FDOT421 "A/L6/WC/6F/SD17/CORRIDOR AW 6071"
|      |      |  |-- 10:6-18 FDOT421 "A/L6/WC/6F/SD18/AFC COR AW 6080"
|      |      |  |-- 10:6-19 FDOT421 "A/L6/WC/6F/SD19/CORRIDOR AW6/S05"
|      |      |  |-- 10:6-20 FDOT421 "A/L6/WC/6F/SD20/AFC CORR AW6020"
|      |      |  |-- 10:6-21 FDOT421 "A/L6/WC/6F/SD21/CORR AW6/S09"
|      |      |  |-- 10:6-22 HTRI-R "A/L6/WC/6F/CM22/DOOR RELEASE U"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 10:6-23 FDOT421 "A/L6/WC/6F/SD23/ELECTRICAL ROOM"
|      |      |  |-- 10:6-24 HMS-S/D/M/SA "A/L6/WC/6F/MCP24/LIFT LOBBY STR"
|      |      |  |-- 10:6-25 HTRI-R "A/L6/WC/6F/CM25/FIRE HYD SHAFT"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 10:6-26 HTRI-S "A/L6/WC/6F/MM26/FIRE HYD SHAFT"
|      |      |  |-- 10:6-27 FDOT421 "A/L6/WC/6F/SD27/LIFT LOBBY"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:6 XDLC "DLC @ address 6 E/W 6th FLOOR"

```
|      |      |      |-- 10:6-28 FDOT421 "A/L6/WC/6F/SD28/LIFT LOBBY"
|      |      |      |-- 10:6-29 XTRI-R "A/L6/WC/6F/CM29/DOOR RELEASE U"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:6-30 HTRI-R "A/L6/WC/6F/CM30/AHU ROOM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:6-31 FDOT421 "A/L6/WC/6F/SD31/AHU ROOM"
|      |      |      |-- 10:6-32 FDOT421 "A/L6/WC/6F/SD32/AFC CORR AW6252"
|      |      |      |-- 10:6-33 FDOT421 "A/L6/WC/6F/SD33/CORRIDOR AW6252"
|      |      |      |-- 10:6-34 FDOT421 "A/L6/WC/6F/SD34/AFC COR AW6251"
|      |      |      |-- 10:6-35 FDOT421 "A/L6/WC/6F/SD35/CORRIDOR AW6251"
|      |      |      |-- 10:6-41 HTRI-S "A/L6/6F/MM41/AW6053"
|      |      |      |-- 10:6-42 XTRI-S "A/L6/6F/MM42/AW6052"
|      |      |      |-- 10:6-44 HTRI-S "A/L6/6F/MM44/AW6040"
|      |      |      |-- 10:6-46 HTRI-S "A/L6/6F/MM46/AW6071"
|      |      |      |-- 10:6-48 HTRI-S "A/L6/6F/MM48/AW6030"
|      |      |      |-- 10:6-50 HTRI-S "A/L6/6F/MM50/AW6090"
|      |      |      |-- 10:6-52 HTRI-S "A/L6/6F/MM52/AW6010"
|      |      |      |-- 10:6-53 HTRI-S "A/L6/6F/MM53/AW6100"
|      |      |      |-- 10:6-54 HTRI-S "A/L6/6F/MM54/AW6110"
|      |      |      |-- 10:6-57 HTRI-S "A/L6/6F/MM57/AW6251"
|      |      |      |-- 10:6-58 HTRI-S "A/L6/6F/MM58/AE6011"
|      |      |      |-- 10:6-59 HFP-11 "A/L6/AW6080/SD59/MAIN CABIN"
|      |      |      |-- 10:6-60 HFP-11 "A/L6/AW6080/SD60/ACCOUNT CAB"
|      |      |      |-- 10:6-61 HFP-11 "A/L6/AW6080/SD61/PASSASGE AREA"
|      |      |      |-- 10:6-62 HFP-11 "A/L6/AW6080/SD62/PANTRY AREA"
|      |      |      |-- 10:6-63 HMS-S/D/M/SA "A/L6/AW6080/MCP63/PASSAGE AREA"
|      |      |      |-- 10:6-64 HTRI-R "A/L6/AW6080/CM64/PASSAGE AREA"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:6-65 HFP-11 "A/L6/AW6240/SD65/Accounts Cab"
|      |      |      |-- 10:6-66 HFP-11 "A/L6/AW6240/SD66/Main cab"
|      |      |      |-- 10:6-67 HFP-11 "A/L6/AW6240/SD67/Assorter cab"
|      |      |      |-- 10:6-68 HFP-11 "A/L6/AW6240/SD68/Assorter cab"
|      |      |      |-- 10:6-69 HFP-11 "A/L6/AW6240/SD69/Pantry"
|      |      |      |-- 10:6-70 HTRI-R "A/L6/AW6240/CM70/Psg nr Entry do"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:6-71 HMS-S/D/M/SA "A/L6/AW6240/MCP71/Psg nr Entry d"
|      |      |      |-- 10:6-72 HFP-11 "A/L6/AW6240/SD72/Psg nr Entry do"
|      |      |      |-- 10:6-73 HFP-11 "A/L6/AW6252/SD73/Main cab"
|      |      |      |-- 10:6-74 HFP-11 "A/L6/AW6252/SD74/Manager cab"
|      |      |      |-- 10:6-75 FDOT421 "A/L6/AW6252/SD75/Psg nr Main cab"
|      |      |      |-- 10:6-76 FDOT421 "A/L6/AW6252/SD76/Psg nr Entrance"
|      |      |      |-- 10:6-77 HMS-S/D/M/SA "A/L6/AW6252/MCP77/Psg nr Entry D"
|      |      |      |-- 10:6-78 HTRI-R "A/L6/AW6252/CM78/Psg nr Entry Do"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:6-82 HMS-S/D/M/SA "A/L6/AW6020/MCP82/Psg nr ent"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:6 XDLC "DLC @ address 6 E/W 6th FLOOR"

```
|      |      |      |-- 10:6-83 HFP-11 "A/L6/AW6260/SD83/PAS NR ENTRY"
|      |      |      |-- 10:6-84 HFP-11 "A/L6/AW6260/SD84/ASSORTER CAB"
|      |      |      |-- 10:6-85 HMS-S/D/M/SA "A/L6/AW6260/MCP85/Passage Near E"
|      |      |      |-- 10:6-86 HTRI-R "A/L6/AW6260/CM86/Passage Near En"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:6-90 HFP-11 "A/L6/AW6060/SD90/Pantry"
|      |      |      |-- 10:6-91 HFP-11 "A/L6/AW6060/SD91/ASSORTER CAB"
|      |      |      |-- 10:6-92 HFP-11 "A/L6/AW6060/SD92/ASSORTER CAB"
|      |      |      |-- 10:6-93 HTRI-R "A/L6/AW6060/CM93/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:6-94 HMS-S/D/M/SA "A/L6/AW6060/MCP94/Entry dr Psg"
|      |      |      |-- 10:6-40 XTRI-S "A/L6/6F/MM40/AW6020"
|      |      |  |-- 10:7 XDLC "DLC @ address 7 E/W 7th FLOOR"
|      |      |      |-- 10:7-1 HTRI-R "A/L7/EC/7F/CM1/FIRE HYD SHAFT"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:7-2 HTRI-S "A/L7/EC/7F/MM2/FIRE HYD SHAFT"
|      |      |      |-- 10:7-3 HMS-S/D/M/SA "A/L7/EC/7F/MCP3/LIFT LOBBY STR"
|      |      |      |-- 10:7-4 FDOT421 "A/L7/EC/7F/SD4/LIFT LOBBY"
|      |      |      |-- 10:7-5 HTRI-R "A/L7/EC/7F/CM5/DOOR RELEASE U"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:7-6 HTRI-R "A/L7/EC/7F/CM6/AHU ROOM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:7-7 FDOT421 "A/L7/EC/7F/SD7/AHU ROOM"
|      |      |      |-- 10:7-8 FDOT421 "A/L7/EC/7F/SD8/ELECTRICAL ROOM"
|      |      |      |-- 10:7-9 FDOT421 "A/L7/EC/7F/SD9/NR ELEC RM"
|      |      |      |-- 10:7-10 FDOT421 "A/L7/EC/7F/SD10/AFC CORR NR ELE "
|      |      |      |-- 10:7-11 FDOT421 "A/L7/EC/7F/SD11/CORRIDOR AE7/S12"
|      |      |      |-- 10:7-12 FDOT421 "A/L7/EC/7F/SD12/AFC CORR AE7093"
|      |      |      |-- 10:7-13 FDOT421 "A/L7/EC/7F/SD13/CORRIDOR AE 7021"
|      |      |      |-- 10:7-14 FDOT421 "A/L7/EC/7F/SD14/AFC AE7/S11"
|      |      |      |-- 10:7-15 FDOT421 "A/L7/EC/7F/SD15/CORRIDOR AE7030"
|      |      |      |-- 10:7-16 HTRI-R "A/L7/EC/7F/CM16/CORR STR CASE"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:7-17 HMS-S/D/M/SA "A/L7/EC/7F/MCP17/CORR STR CASE"
|      |      |      |-- 10:7-18 FDOT421 "A/L7/EC/7F/SD18/CORRIDOR AE 7040"
|      |      |      |-- 10:7-19 FDOT421 "A/L7/EC/7F/SD19/CORRIDOR AE 7060"
|      |      |      |-- 10:7-20 FDOT421 "A/L7/EC/7F/SD20/AFC CORR AE 7080"
|      |      |      |-- 10:7-21 FDOT421 "A/L7/EC/7F/SD21/AFC CORR AE7/S09"
|      |      |      |-- 10:7-22 FDOT421 "A/L7/EC/7F/SD22/CORRIDOR AE 7070"
|      |      |      |-- 10:7-23 FDOT421 "A/L7/WC/7F/SD23/ELECTRICAL ROOM"
|      |      |      |-- 10:7-24 HTRI-R "A/L7/WC/7F/CM24/DOOR RELEASE U"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:7-25 HMS-S/D/M/SA "A/L7/WC/7F/MCP25/LIFT LOBBY STR"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:7 XDLC "DLC @ address 7 E/W 7th FLOOR"

```
|      |      |      |  -- 10:7-26 HTRI-R "A/L7/WC/7F/CM26/FIRE HYD SHAFT"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 10:7-27 HTRI-S "A/L7/WC/7F/MM27/FIRE HYD SHAFT"
|      |      |      |  -- 10:7-28 FDOT421 "A/L7/WC/7F/SD28/LIFT LOBBY"
|      |      |      |  -- 10:7-29 FDOT421 "A/L7/WC/7F/SD29/LIFT LOBBY"
|      |      |      |  -- 10:7-30 HTRI-R "A/L7/WC/7F/CM30/AHU ROOM"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 10:7-31 FDOT421 "A/L7/WC/7F/SD31/AHU ROOM"
|      |      |      |  -- 10:7-32 FDOT421 "A/L7/WC/TERCE/SD32/LIFT MACHINE "
|      |      |      |  -- 10:7-33 FDOT421 "A/L7/WC/TERCE/SD33/LIFT MACHINE "
|      |      |      |  -- 10:7-34 HTRI-R "A/L7/WC/7F/CM34/AW TERRACE"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 10:7-41 HTRI-S "A/L7/7F/MM41/AE7093"
|      |      |      |  -- 10:7-42 HTRI-S "A/L7/7F/MM42/AE7010"
|      |      |      |  -- 10:7-43 HTRI-S "A/L7/7F/MM43/AE7021"
|      |      |      |  -- 10:7-44 XTRI-S "A/L7/7F/MM44/AE7022"
|      |      |      |  -- 10:7-45 HTRI-S "A/L7/7F/MM45/AE7092"
|      |      |      |  -- 10:7-46 HTRI-S "A/L7/7F/MM46/AE7030"
|      |      |      |  -- 10:7-47 HTRI-S "A/L7/7F/MM47/AE7091"
|      |      |      |  -- 10:7-49 HTRI-S "A/L7/7F/MM49/AE7050"
|      |      |      |  -- 10:7-50 HTRI-S "A/L7/7F/MM50/AE7060"
|      |      |      |  -- 10:7-51 HTRI-S "A/L7/7F/MM51/AE7080"
|      |      |      |  -- 10:7-52 HTRI-S "A/L7/7F/MM52/AE7070"
|      |      |      |  -- 10:7-53 HTRI-S "A/L7/7F/MM53/AW7010"
|      |      |      |  -- 10:7-55 HFP-11 "A/L7/AE7040/SD55/Main Cabin"
|      |      |      |  -- 10:7-56 HFP-11 "A/L7/AE7040/SD56/Assorter Room"
|      |      |      |  -- 10:7-57 HFP-11 "A/L7/AE7040/SD57/Passage nr Asst"
|      |      |      |  -- 10:7-58 HFP-11 "A/L7/AE7040/SD58/Assorter Cab2"
|      |      |      |  -- 10:7-59 HTRI-R "A/L7/AE7040/CM59/Entry Door"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 10:7-60 HMS-S/D/M/SA "A/L7/AE7040/MCP60/Entry Door"
|      |      |      |  -- 10:7-61 HFP-11 "A/L7/AW7020/SD61/Cabin 1""
|      |      |      |  -- 10:7-62 HFP-11 "A/L7/AW7020/SD62/Passage Area""
|      |      |      |  -- 10:7-63 HFP-11 "A/L7/AW7020/SD63/ASSORTER CAB"
|      |      |      |  -- 10:7-64 HTRI-R "A/L7/AW7020/CM64/Entry Door""
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 10:7-65 HMS-S/D/M/SA "A/L7/AW7020/MCP65/ENTRY PSG."
|      |      |      |  -- 10:8 XDLC "DLC @ address 8 E/W GND FLOOR"
|      |      |      |  -- 10:8-1 FDOT421 "A/L8/EC/GF/SD1/AFC LIFT LOBBY"
|      |      |      |  -- 10:8-2 FDOT421 "A/L8/EC/GF/SD2/INSIDE TICKET COU"
|      |      |      |  -- 10:8-3 FDOT421 "A/L8/EC/GF/SD3/LIFT LOBBY"
|      |      |      |  -- 10:8-4 HTRI-S "A/L8/EC/GF/MM4/AFC LL SHAFT"
|      |      |      |  -- 10:8-5 HTRI-R "A/L8/EC/GF/CM5/AFC LL SHAFT"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:8 XDLC "DLC @ address 8 E/W GND FLOOR"

| | | |-- 10:8-6 HMS-S/D/M/SA "A/L8/EC/GF/MCP6/LIFT LOBBY"
| | | |-- 10:8-7 FDOT421 "A/L8/EC/GF/SD7/AHU ROOM"
| | | |-- 10:8-8 HTRI-R "A/L8/EC/GF/CM8/AHU ROOM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **10:8-9 FDOT421 "A/L8/EC/GF/SD9/ELECT ROOM"**
| | | |-- 10:8-10 FDOT421 "A/L8/EC/GF/SD10/LIFT LOBBY"
| | | |-- 10:8-12 FDOT421 "A/L8/WC/GF/SD12/LIFT LOBBY"
| | | |-- 10:8-13 FDOT421 "A/L8/WC/GF/SD13/LIFT LOBBY"
| | | |-- 10:8-14 FDOT421 "A/L8/WC/GF/SD14/LIFT LOBBY"
| | | |-- 10:8-15 FDOT421 "A/L8/WC/GF/SD15/LIFT LOBBY"
| | | |-- 10:8-16 HMS-S/D/M/SA "A/L8/WC/GF/MCP16/LIFT LOBBY"
| | | |-- 10:8-17 FDOT421 "A/L8/WC/GF/SD17/ELECT ROOM"
| | | |-- 10:8-18 FDOT421 "A/L8/WC/GF/SD18/AHU ROOM"
| | | |-- 10:8-19 HTRI-R "A/L8/WC/GF/CM19/AHU ROOM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **10:8-20 HTRI-R "A/L8/WC/GF/AFC LL CM20/FOR HTR"**
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **10:8-22 HTRI-S "A/L8/WC/GF/AFC LL MM22/SHAFT"**
| | | |-- 10:8-23 FDOT421 "A/L8/WC/GF/SD23/SECUR CABIN LL"
| | | |-- 10:8-50 HFPT-11 "A/A/L8/AE/GF/HD50/FOOD COUNTER 1"
| | | |-- 10:8-51 HFPT-11 "A/L8/AE/GF/HD51/FOOD COUNTER 2"
| | | |-- 10:8-52 HFPT-11 "A/L8/AE/GF/HD52/FOOD COUNTER 3"
| | | |-- 10:8-53 HFPT-11 "A/L8/AE/GF/HD53/FOOD COUNTER 4"
| | | |-- 10:8-54 FDOT421 "A/L8/AE/GF/SD54/Psg FOOD COUNT 2"
| | | |-- 10:8-55 FDOT421 "A/L8/AE/GF/SD55/Psg FOOD COUNT 1"
| | | |-- 10:8-56 XTTRI-R "A/L8/AE/GF/CM56/FoodCont Ent Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **10:8-57 HMS-S/D/M/SA "A/L8/AE/GF/MCP57/FoodCont Ent Ps"**
| | | |-- 10:8-101 HTRI-R "A/L8/EC/UB/CM101/LIFT ROOM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **10:8-102 FDOT421 "A/L8/EC/UB/SD102/LIFT ROOM"**
| | | |-- 10:8-103 FDOT421 "A/L8/EC/UB/SD103/LIFT ROOM"
| | | |-- 10:8-104 FDOT421 "A/L8/EC/UB/SD104/BMS ROOM"
| | | |-- 10:8-105 FDOT421 "A/L8/EC/UB/SD105/ELEC ROOM"
| | | |-- 10:8-106 HTRI-R "A/L8/EC/UB/CM106/ELEC ROOM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **10:8-107 FDOT421 "A/L8/EC/UB/SD107/DMS RM"**
| | | |-- 10:8-108 FDOT421 "A/L8/AE/UB/SD108/DMS RM"
| | | |-- 10:8-110 HMS-S/D/M/SA "A/L8/WC/UB/MCP110/STAIRCASE"
| | | |-- 10:8-111 HTRI-R "A/L8/WC/UB/CM111/STAIRCASE"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **10:8-112 HTRI-S "A/L8/WC/UB/MM112/STAIRCASE"**
| | | |-- 10:8-113 HMS-S/D/M/SA "A/L8/EC/UB/MCP113/STAIRCASE 5"

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:8 XDLC "DLC @ address 8 E/W GND FLOOR"

```
|      |      |      |-- 10:8-114 HTRI-R "A/L8/EC/UB/CM114/STAIRCASE 5"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-116 FDOT421 "A/L8/EC/UB/SD116/NR LIFT RM"
|      |      |      |-- 10:8-117 FDOT421 "A/L8/WC/UB/SD117/ELEC RM"
|      |      |      |-- 10:8-118 HTRI-R "A/L8/WC/UB/CM118/ELEC RM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-119 FDOT421 "A/L8/WC/UB/SD119/DRIVER ROOM"
|      |      |      |-- 10:8-120 FDOT421 "A/L8/WC/UB/SD120/FAN ROOM"
|      |      |      |-- 10:8-121 HMS-S/D/M/SA "A/L8/EC/UB/MCP121/NR. DMS ROOM"
|      |      |      |-- 10:8-122 HTRI-R "A/L8/EC/UB/CM122/NR. DMS ROOM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-124 HFP-11 "A/L8/EC/UB/SD124/NR. DMS ROOM"
|      |      |      |-- 10:8-151 HMS-S/D/M/SA "A/L8/WC/LB/MCP151/ST NR FAN RM 1"
|      |      |      |-- 10:8-152 HTRI-R "A/L8/WC/LB/CM152/ST NR FAN RM 1"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-153 HMS-S/D/M/SA "A/L8//WC/LB/MCP153/ST NR FAN RM "
|      |      |      |-- 10:8-154 HTRI-R "A/L8/WC/LB/CM154/ST NR FAN RM 2"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-155 HMS-S/D/M/SA "A/L8/WC/LB/MCP155/ST NR FAN RM 3"
|      |      |      |-- 10:8-156 HTRI-R "A/L8/WC/LB/CM156/ST NR FAN RM 3"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-157 HMS-S/D/M/SA "A/L8/WC/LB/MCP157/RAMP NO. 1"
|      |      |      |-- 10:8-158 HTRI-R "A/L8/WC/LB/CM158/RAMP NO. 1"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-159 HTRI-S "A/L8/EC/LB/MM159/FAN ROOM"
|      |      |      |-- 10:8-160 HMS-S/D/M/SA "A/L8/EC/LB/MCP160/BK OFF. FIRE E"
|      |      |      |-- 10:8-161 HTRI-R "A/L8/EC/LB/CM161/BK OFF. FIRE EX"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-162 FDOT421 "A/L8/EC/LB/SD162/FAN ROOM"
|      |      |      |-- 10:8-163 FDOT421 "A/L8/EC/LB/SD163/FAN ROOM"
|      |      |      |-- 10:8-164 FDOT421 "A/L8/EC/LB/SD164/FAN ROOM"
|      |      |      |-- 10:8-165 HMS-S/D/M/SA "A/L8/WC/LB/MCP165/NR FAN ROOM"
|      |      |      |-- 10:8-166 HTRI-R "A/L8/WC/LB/CM166/NR FAN ROOM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-167 HMS-S/D/M/SA "A/L8/WC/LB/MCP167/EXIT PARK AREA"
|      |      |      |-- 10:8-168 XTRI-R "A/L8/WC/LB/CM168/EXIT PARK AREA "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-169 FDOT421 "A/L8/WC/LB/SD169/FAN ROOM"
|      |      |      |-- 10:8-171 HMS-S/D/M/SA "A/L8/UB/MCP171/DMS RM"
|      |      |      |-- 10:8-172 FDOT421 "A/L8/UB/SD172/DMS RM"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:8 XDLC "DLC @ address 8 E/W GND FLOOR"

```
|      |      |  |-- 10:8-173 FDOT421 "A/L8/UB/SD173/DMS RM"
|      |      |  |-- 10:8-174 FDOT421 "A/L8/UB/SD174/DMS RM"
|      |      |  |-- 10:8-175 FDOT421 "A/L8/UB/SD175/DMS RM"
|      |      |  |-- 10:8-176 FDOT421 "A/L8/UB/SD176/DMS RM"
|      |      |  |-- 10:8-177 FDOT421 "A/L8/UB/SD177/DMS RM"
|      |      |  |-- 10:8-178 HMS-S/D/M/SA "A/L8/UB/MCP178/DMS RM"
|      |      |  |-- 10:8-179 FDOT421 "A/L8/UB/SD179/DMS RM"
|      |      |  |-- 10:8-180 FDOT421 "A/L8/UB/SD180/DMS RM"
|      |      |  |-- 10:8-181 FDOT421 "A/L8/UB/SD181/DMS RM"
|      |      |  |-- 10:8-182 FDOT421 "A/L8/UB/SD182/DMS RM"
|      |      |  |-- 10:8-183 FDOT421 "A/L8/UB/SD183/DMS RM"
|      |      |  |-- 10:8-184 FDOT421 "A/L8/UB/SD184/DMS RM"
|      |      |  |-- 10:8-185 FDOT421 "A/L8/UB/SD185/DMS RM"
|      |      |  |-- 10:8-186 HTRI-R "A/L8/UB/CM186/DMS RM Entry"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 10:8-187 FDOT421 "A/L8/UB/SD187/DMS RM"
|      |      |  |-- 10:8-170 FDOT421 "A/L8/WC/LB/SD170/DMS RM"
|      |      |  |-- 10:8-24 HTRI-S "A/L8/WC/GND/MM24/NR AHU Room AFC"
|      |      |  |-- 10:8-188 FDOT421 "A/L8/UB/SD188/DMS RM"
|      |      |  |-- 10:8-189 FDOT421 "A/L8/UB/SD189/DMS RM"
|      |  |-- 10:9 NIC-C(XNet) "NIC_Xnet @ address 9"
|      |  |-- 10:10 XDLC "L10/A/UB/BACK OFFICE"
|      |      |-- 10:10-3 FDOT421 "A/L10/UB/SD03/RECEPTION"
|      |      |-- 10:10-4 FDOT421 "A/L10/UB/SD04/AFC/RECEPTION"
|      |      |-- 10:10-5 HFPT-11 "A/L10/UB/HD05/CONFERANCE PANTRY"
|      |      |-- 10:10-7 FDOT421 "A/L10/UB/SD07/CONFERANCE RM"
|      |      |-- 10:10-9 HMS-S/D/M/SA "A/L10/UB/MCP09/ENT. RECEPT"
|      |      |-- 10:10-10 HTRI-R "A/L10/UB/CM10/ENT. RECEPT"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-11 FDOT421 "A/L10/UB/SD11/PRAKASH SIR CAB"
|      |      |-- 10:10-12 FDOT421 "A/L10/UB/SD12/LEGAL MET RM "
|      |      |-- 10:10-13 FDOT421 "A/L10/UB/SD13/AFC LEGAL MET RM "
|      |      |-- 10:10-14 FDOT421 "A/L10/UB/SD14/LAGAL HOD CABIN"
|      |      |-- 10:10-15 FDOT421 "A/L10/UB/SD15/FOOD FACILITY"
|      |      |-- 10:10-16 FDOT421 "A/L10/UB/SD16/AFC FOOD FACILITY"
|      |      |-- 10:10-17 FDOT421 "A/L10/UB/SD17/LAGAL"
|      |      |-- 10:10-18 FDOT421 "A/L10/UB/SD18/AFC-IT"
|      |      |-- 10:10-19 FDOT421 "A/L10/UB/SD19/ADMIN"
|      |      |-- 10:10-20 FDOT421 "A/L10/UB/SD20/AFC IT-LOBBY"
|      |      |-- 10:10-21 FDOT421 "A/L10/UB/SD21/IT-LOBBY"
|      |      |-- 10:10-22 FDOT421 "A/L10/UB/SD22/PEUN-DESK"
|      |      |-- 10:10-23 FDOT421 "A/L10/UB/SD23/LOBBY STORA"
|      |      |-- 10:10-24 FDOT421 "A/L10/UB/SD24/AFC PRINTER STN "
|      |      |-- 10:10-25 HMS-S/D/M/SA "A/L10/UB/MCP25/FIRE EXIT-UB"
|      |      |-- 10:10-26 HTRI-R "A/L10/UB/CM26/FIRE EXIT-UB"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-27 FDOT421 "A/L10/UB/SD27/LOOBY-NR TOILET"
```


10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:10 XDLC "L10/A/UB/BACK OFFICE"

```
|      |      |-- 10:10-28 FDOT421 "A/L10/UB/SD28/AFC LOOBY-NR TOILE"
|      |      |-- 10:10-29 FDOT421 "A/L10/UB/SD29/PANTRY"
|      |      |-- 10:10-30 FDOT421 "A/L10/UB/SD30/TRAINING RM 1"
|      |      |-- 10:10-31 FDOT421 "A/L10/UB/SD31/AFC TRAINING RM "
|      |      |-- 10:10-32 FDOT421 "A/L10/UB/SD32/TRAINING RM 3"
|      |      |-- 10:10-33 FDOT421 "A/L10/UB/SD33/LOBBY-NR ACCOUNTS"
|      |      |-- 10:10-34 FDOT421 "A/L10/UB/SD34/AFC LOBBY-NR ACCOU"
|      |      |-- 10:10-35 FDOT421 "A/L10/UB/SD35/ACCOUNT HOD CAB"
|      |      |-- 10:10-36 FDOT421 "A/L10/UB/SD36/HR"
|      |      |-- 10:10-37 FDOT421 "A/L10/UB/SD37/AFC PURCHASE DEPT"
|      |      |-- 10:10-38 FDOT421 "A/L10/UB/SD38/PURCHASE DEPT"
|      |      |-- 10:10-39 FDOT421 "A/L10/UB/SD39/MINI CONFERENCE"
|      |      |-- 10:10-40 FDOT421 "A/L10/UB/SD/40/DGM CAB"
|      |      |-- 10:10-41 FDOT421 "A/L10/UB/SD/41/MANAGING COMMITTE"
|      |      |-- 10:10-42 FDOT421 "A/L10/UB/SD42/DH-SECURITY"
|      |      |-- 10:10-43 FDOT421 "A/L10/UB/SD43/NR WAIT RM ENT DR "
|      |      |-- 10:10-44 FDOT421 "A/L10/UB/SD44/NR WAIT RM ENT.DR"
|      |      |-- 10:10-45 HMS-S/D/M/SA "A/L10/UB/MCP45/NR WAIT RM ENT.DR"
|      |      |-- 10:10-46 XTRI-R "A/L10/UB/CM46/NR WAIT RM ENT.DR"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-47 FDOT421 "A/L10/UB/SD47/AFC WATING ROOM  "
|      |      |-- 10:10-48 FDOT421 "A/L10/UB/SD48/WAITING ROOM"
|      |      |-- 10:10-49 FDOT421 "A/L10/LB/SD49/BACK DR CAB 1"
|      |      |-- 10:10-50 FDOT421 "A/L10/LB/SD50/BACK DR CAB 1"
|      |      |-- 10:10-51 FDOT421 "A/L10/LB/SD51/BACK DR CAB 2"
|      |      |-- 10:10-52 HMS-S/D/M/SA "A/L10/LB/MCP52/BACK DR CAB1 ENT"
|      |      |-- 10:10-54 FDOT421 "A/L10/LB/SD54/LOBBY ELECTRIC RM"
|      |      |-- 10:10-55 FDOT421 "A/L10/LB/SD55/ELECTRIC RM"
|      |      |-- 10:10-56 FDOT421 "A/L10/LB/SD56/SERVER RM"
|      |      |-- 10:10-57 FDOT421 "A/L10/LB/SD57/AFC LOBBY HVAC "
|      |      |-- 10:10-58 FDOT421 "A/L10/LB/SD58/LOBBY HVAC "
|      |      |-- 10:10-59 FDOT421 "A/L10/LB/SD59/ELECTRIC DEPT"
|      |      |-- 10:10-60 FDOT421 "A/L10/LB/SD60/AFC ELECTRICAL "
|      |      |-- 10:10-61 FDOT421 "A/L10/LB/SD61/PLUMBING DEPT"
|      |      |-- 10:10-62 FDOT421 "A/L10/LB/SD62/AFC CIVIL "
|      |      |-- 10:10-63 FDOT421 "A/L10/LB/SD63/HK DEPT"
|      |      |-- 10:10-64 FDOT421 "A/L10/LB/SD64/GM CAB"
|      |      |-- 10:10-65 FDOT421 "A/L10/LB/SD65/PRINTER STATION"
|      |      |-- 10:10-66 FDOT421 "A/L10/LB/SD66/CABIN 2"
|      |      |-- 10:10-67 FDOT421 "A/L10/LB/SD67/NR AGM CAB"
|      |      |-- 10:10-68 FDOT421 "A/L10/LB/SD68/AFC LOBBY AGM CAB"
|      |      |-- 10:10-69 HMS-S/D/M/SA "A/L10/LB/MCP69/LOBBY-AGM"
|      |      |-- 10:10-70 HTRI-R "A/L10/LB/CM70/LOBBY-AGM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-71 FDOT421 "A/L10/LB/SD71/ CAB NR HK DEPT"
|      |      |-- 10:10-72 FDOT421 "A/L10/LB/SD72/LOBBY NR PANTRY"
|      |      |-- 10:10-73 FDOT421 "A/L10/LB/SD73/AFC NR PANTRY"
|      |      |-- 10:10-74 FDOT421 "A/L10/LB/SD74/NR XEROX MACHINE"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:10 XDLC "L10/A/UB/BACK OFFICE"

```
|      |      |-- 10:10-75 FDOT421 "A/L10/LB/SD75/AFC NR XEROX MACHI"
|      |      |-- 10:10-77 FDOT421 "A/L10/LB/SD77/PANTRY"
|      |      |-- 10:10-78 HMS-S/D/M/SA "A/L10/LB/MCP78/LOBBY-ENTRANCE 2"
|      |      |-- 10:10-79 HTRI-R "A/L10/LB/CM79/LOBBY-ENTRANCE 2"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 10:10-80 FDOT421 "A/L10/LB/SD80/PANTRY"
|      |      |-- 10:10-83 FDOT421 "A/L10/LB/SD83/LOBBY-MEETING RM 4"
|      |      |-- 10:10-84 FDOT421 "A/L10/LB/SD84/AFC LOBBY-MEETING "
|      |      |-- 10:10-85 FDOT421 "A/L10/LB/SD85/MEETING RM 4"
|      |      |-- 10:10-86 FDOT421 "A/L10/LB/SD86/RECEPTION-LB "
|      |      |-- 10:10-87 FDOT421 "A/L10/LB/SD87/AFC RECEPTION-LB"
|      |      |-- 10:10-88 FDOT421 "A/L10/LB/SD88/MEETING RM 3"
|      |      |-- 10:10-89 FDOT421 "A/L10/LB/SD89/SECURITY HOD"
|      |      |-- 10:10-90 FDOT421 "A/L10/LB/SD90/STORES"
|      |      |-- 10:10-91 FDOT421 "A/L10/LB/SD91/REST RM"
|      |      |-- 10:10-92 FDOT421 "A/L10/LB/SD92/CAB NR WASH RM"
|      |      |-- 10:10-93 HTRI-R "A/L10/LB/CM93/LOBBY-ENTRANCE 2"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 10:10-94 HMS-S/D/M/SA "A/L10/LB/MCP94/LOBBY-ENTRANCE 2"
|      |      |-- 10:10-95 HTRI-R "A/L10/LB/CM95/RECEPTION-LB"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 10:10-96 HMS-S/D/M/SA "A/L10/LB/MCP96/RECEPTION-LB"
|      |      |-- 10:10-97 FDOT421 "A/L10/SD97/Admin LB DOC RM Nr Re"
|      |-- 10:249 PSC-12 "PSC-12 @ address 1"
|      |      |-- 10:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      |      |-- 10:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      |      |-- 10:249-3 Relay "Relay @ address 249-3"
|      |      |-- 10:249-4 Relay "Relay @ address 249-4"
|      |-- Inner Door
|      |      |-- 10:253 PMI-D "PMI-D @ address 253"
|-- 12 Management Station "Management System @ address12"
```