

2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local

CAB-1 "CAB-1 Enclosure #1"

CC-5 "Card Cage 5 Slots"

2:1 DLC "DLC @LOOP 1"

2:1-124 HTRI-R "DC1/L2/PW-CM GSS CYL 1-124"

```
|      | | | |-- Relay
|      | | | |-- 2:1-125 HTRI-R "DC1/L2/PW-CM GSS CYL 1-125"
|      | | | |-- Switch ""
|      | | | |-- Relay
|      | | | |-- 2:2 NIC-C(XNet) "NIC_Xnet @ address 2"
|      | | | |-- 2:249 PSC-12 "POWER SUPPLY"
|      | | | |-- 2:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      | | | |-- 2:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      | | | |-- Inner Door
|      | | | |-- 2:253 PMI-D "PMI-D @ address 253"
|-- 4 Desigo Fire Safety Modular "BDB TOWER B" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-2 "CAB-2 Enclosure #1"
|      |-- CC-5 "Card Cage 5 Slots"
|          |-- 4:1 DLC "DLC @ address 1 L1 "
|              |-- 4:1-1 FDOT421 "B/L1/CC/1F/SD4/LIFT LOBBY"
|              |-- 4:1-2 FDOT421 "B/L1/CC/1F/SD2/COR NR BC1010AFC"
|              |-- 4:1-3 FDOT421 "B/L1/CC/1F/SD3/CORR BC-1010"
|              |-- 4:1-4 FDOT421 "B/L1/CC/1F/SD4/LIFT LOBBY"
|              |-- 4:1-5 FDOT421 "B/L1/CC/1F/SD5/LIFT LOBBY"
|              |-- 4:1-6 HMS-S/D/M/SA "B/L1/CC/1F/MCP6/LIFT LOBBY STR"
|              |-- 4:1-7 HTRI-R "B/L1/CC/1F/CM7/FIRE HYD SHAFT"
|              | | | |-- Switch ""
|              | | | |-- Relay
|              | | | |-- 4:1-8 HTRI-S "B/L1/CC/1F/MM8/FIRE HYD SHAFT"
|              | | | |-- 4:1-9 HTRI-R "B/L1/CC/1F/CM9/DOOR RELEASE UNIT"
|              | | | |-- Switch ""
|              | | | |-- Relay
|              | | | |-- 4:1-10 FDOT421 "B/L1/BC/1F/SD10/AFC Cor Nr AHURM"
|              | | | |-- 4:1-11 FDOT421 "B/L1/EC/1F/SD11/CORR Nr BE1100"
|              | | | |-- 4:1-12 FDOT421 "B/L1/EC/1F/SD12/CORR Nr BE 1110 "
|              | | | |-- 4:1-13 FDOT421 "B/L1/EC/1F/SD13/CorrNr BE1120AFC"
|              | | | |-- 4:1-14 FDOT421 "B/L1/EC/1F/SD14/CORR Nr BE1120"
|              | | | |-- 4:1-15 FDOT421 "B/L1/EC/1F/SD15/CORR NR BE1130"
|              | | | |-- 4:1-16 FDOT421 "B/L1/EC/1F/SD16/CorrNrElectRmAfc"
|              | | | |-- 4:1-17 FDOT421 "B/L1/EC/1F/SD17/ELECT RM"
|              | | | |-- 4:1-18 FDOT421 "B/L1/EC/1F/SD18/AHU RM"
|              | | | |-- 4:1-19 HTRI-R "B/L1/EC/1F/CM19/AHU RM"
|              | | | |-- Switch ""
|              | | | |-- Relay
|              | | | |-- 4:1-20 HTRI-R "B/L1/EC/1F/CM20/DOOR RELEASE UN"
|              | | | |-- Switch ""
|              | | | |-- Relay
|              | | | |-- 4:1-21 FDOT421 "B/L1/EC/1F/SD21/LIFT LOBBY"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:1 DLC "DLC @ address 1 L1 "

```
|      |      |      |-- 4:1-22 HMS-S/D/M/SA "B/L1/EC/1F/MCP22/FIRE ESCAPE ST"
|      |      |      |-- 4:1-23 HTRI-R "B/L1/EC/1F/CM23/FIRE HYD SHAFT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:1-24 HTRI-S "B/L1/EC/1F/MM24/FIRE HYD SHAFT"
|      |      |      |-- 4:1-27 HMS-S/D/M/SA "B/L1/EC/GND/MCP27/LIFT LOBBY"
|      |      |      |-- 4:1-28 HTRI-R "B/L1/EC/GND/CM28/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:1-29 HTRI-S "B/L1/EC/GND/MM29/LIFT LOBBY"
|      |      |      |-- 4:1-30 FDOT421 "B/L1/EC/GND/SD30/ELECT RM"
|      |      |      |-- 4:1-31 FDOT421 "B/L1/EC/GND/SD31/LIFT LOBBY"
|      |      |      |-- 4:1-32 FDOT421 "B/L1/EC/GND/SD32/LIFT LOBBY"
|      |      |      |-- 4:1-33 HTRI-R "B/L1/EC/GND/CM33/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:1-34 FDOT421 "B/L1/EC/GND/SD34/AHU RM"
|      |      |      |-- 4:1-35 HMS-S/D/M/SA "B/L1/CC/GND/MCP35/LIFT LOBBY"
|      |      |      |-- 4:1-36 HTRI-R "B/L1/CC/GND/CM36/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:1-37 HTRI-S "B/L1/CC/GND/MM37/LIFT LOBBY"
|      |      |      |-- 4:1-38 FDOT421 "B/L1/CC/GND/SD38/ELECT RM"
|      |      |      |-- 4:1-39 FDOT421 "B/L1/CC/GND/SD39/LIFT LOBBY"
|      |      |      |-- 4:1-40 FDOT421 "B/L1/CC/GND/SD40/LIFT LOBBY"
|      |      |      |-- 4:1-41 HTRI-R "B/L1/CC/GND/CM41/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:1-42 FDOT421 "B/L1/CC/GND/SD42/B DTC AHU RM"
|      |      |      |-- 4:1-43 HMS-S/D/M/SA "B/L1/WC/GND/MCP43/LIFT LOBBY"
|      |      |      |-- 4:1-44 HTRI-R "B/L1/WC/GND/CM44/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:1-45 HTRI-S "B/L1/WC/GND/MM45/LIFT LOBBY"
|      |      |      |-- 4:1-46 FDOT421 "B/L1/WC/GND/SD46/ELECTRIC RM"
|      |      |      |-- 4:1-47 FDOT421 "B/L1/WC/GND/SD47/LIFT LOBBY"
|      |      |      |-- 4:1-48 FDOT421 "B/L1/WC/GND/SD48/BW SECURITY Cab"
|      |      |      |-- 4:1-49 FDOT421 "B/L1/WC/GND/SD49/LIFT LOBBY"
|      |      |      |-- 4:1-50 FDOT421 "B/L1/WC/GND/SD50/LIFT LOBBY"
|      |      |      |-- 4:1-51 FDOT421 "B/L1/WC/GND/SD51/LIFT LOBBY"
|      |      |      |-- 4:1-52 HTRI-R "B/L1/WC/GND/CM52/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:1-53 FDOT421 "B/L1/WC/GND/SD53/AHU RM"
|      |      |      |-- 4:1-55 HTRI-R "B/L1/CC/1F/CM55/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:1-56 FDOT421 "B/L1/CC/1F/SD56/AHU RM"
|      |      |      |-- 4:1-75 HTRI-S "B/L1/1F/MM75/BE1010"
|      |      |      |-- 4:1-77 HTRI-S "B/L1/1F/MM77/BE1130"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:1 DLC "DLC @ address 1 L1 "

```
|      |      |  |-- 4:1-78 HTRI-S "B/L1/1F/MM78/BE1120"
|      |      |  |-- 4:1-79 HTRI-S "B/L1/1F/MM79/BE1110"
|      |      |  |-- 4:1-81 HTRI-S "B/L1/1F/MM81/BE1090"
|      |      |  |-- 4:1-82 HTRI-S "B/L1/1F/MM82/BE1080"
|      |      |  |-- 4:1-83 HTRI-S "B/L1/1F/MM83/BC1010"
|      |      |  |-- 4:1-101 HTRI-S "B/L1/CC/UB/MM101/ELEC ROOM"
|      |      |  |-- 4:1-102 HTRI-S "B/L1/WC/UB/MM102/ELEC ROOM"
|      |      |  |-- 4:1-103 HTRI-R "B/L1/WC/UB/CM103/STAIRCASE"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-104 HMS-S/D/M/SA "B/L1/WC/UB/MCP104/STAIRCASE"
|      |      |  |-- 4:1-105 HTRI-R "B/L1/WC/UB/CM105/STAIRCASE"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-106 HMS-S/D/M/SA "B/L1/WC/UB/MCP106/STAIRCASE"
|      |      |  |-- 4:1-107 HMS-S/D/M/SA "B/L1/WC/UB/MCP107/RAMP NO. 2"
|      |      |  |-- 4:1-108 HTRI-R "B/L1/WC/UB/CM108/RAMP NO. 2"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-109 HTRI-R "B/L1/CC/UB/CM109/COLUMN NO. 156"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-110 HTRI-R "B/L1/CC/UB/CM110/COLUMN NO. 156"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-111 FDOT421 "B/L1/CC/UB/SD111/ELEC ROOM"
|      |      |  |-- 4:1-114 FDOT421 "B/L1/WC/UB/SD114/FAN ROOM"
|      |      |  |-- 4:1-115 FDOT421 "B/L1/CC/UB/SD115/O/S BMS ROOM"
|      |      |  |-- 4:1-116 FDOT421 "B/L1/CC/UB/SD116/BMS ROOM"
|      |      |  |-- 4:1-117 FDOT421 "B/L1/CC/UB/SD117/ELEC RM BW"
|      |      |  |-- 4:1-118 FDOT421 "B/L1/EC/UB/SD118/ELEC ROOM"
|      |      |  |-- 4:1-119 FDOT421 "B/L1/EC/UB/SD119/Legal Record rm"
|      |      |  |-- 4:1-120 FDOT421 "B/L1/EC/UB/SD120/Legal Record rm"
|      |      |  |-- 4:1-121 FDOT421 "B/L1/EC/UB/SD121/Electric Store "
|      |      |  |-- 4:1-122 HTRI-R "B/L1/EC/UB/CM122/"NR BC ELE RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-123 HMS-S/D/M/SA "B/L1/EC/UB/MCP123/NR BC ELE RM"
|      |      |  |-- 4:1-124 HMS-S/D/M/SA "B/L1/EC/UB/MCP124/NR BC ELE RM"
|      |      |  |-- 4:1-125 HTRI-S "B/L1/EC/UB/MM125/BE ELE RM"
|      |      |  |-- 4:1-126 FDOT421 "B/L1/B-DTC/SD-126/Cabin1"
|      |      |  |-- 4:1-127 FDOT421 "B/L1/B-DTC/SD-127/Cabin2"
|      |      |  |-- 4:1-128 FDOT421 "B/L1/B-DTC/SD-128/Cabin3"
|      |      |  |-- 4:1-129 FDOT421 "B/L1/B-DTC/SD-129/Cabin4"
|      |      |  |-- 4:1-130 FDOT421 "B/L1/B-DTC/SD-130/Cabin5"
|      |      |  |-- 4:1-131 FDOT421 "B/L1/B-DTC/SD-131/Cabin6"
|      |      |  |-- 4:1-132 FDOT421 "B/L1/B-DTC/SD-132/Cabin7"
|      |      |  |-- 4:1-133 FDOT421 "B/L1/B-DTC/SD-133/Cabin8"
|      |      |  |-- 4:1-134 FDOT421 "B/L1/B-DTC/SD-134/Cabin9"
|      |      |  |-- 4:1-135 FDOT421 "B/L1/B-DTC/SD-135/Cabin10"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:1 DLC "DLC @ address 1 L1 "

			-- 4:1-136 FDOT421 "B/L1/B-DTC/SD-136/Cabin11"
			-- 4:1-137 FDOT421 "B/L1/B-DTC/SD-137/Cabin12"
			-- 4:1-138 FDOT421 "B/L1/B-DTC/SD-138/Cabin13"
			-- 4:1-139 FDOT421 "B/L1/B-DTC/SD-139/Cabin14"
			-- 4:1-140 FDOT421 "B/L1/B-DTC/SD-140/Cabin15"
			-- 4:1-141 FDOT421 "B/L1/B-DTC/SD-141/Cabin16"
			-- 4:1-142 FDOT421 "B/L1/B-DTC/SD-142/Cabin17"
			-- 4:1-143 FDOT421 "B/L1/B-DTC/SD-143/Cabin19"
			-- 4:1-144 FDOT421 "B/L1/B-DTC/SD-144/Cabin19"
			-- 4:1-145 FDOT421 "B/L1/B-DTC/SD-145/Cabin20"
			-- 4:1-146 FDOT421 "B/L1/B-DTC/SD-146/Cabin21"
			-- 4:1-147 FDOT421 "B/L1/B-DTC/SD-147/Cabin22"
			-- 4:1-148 FDOT421 "B/L1/B-DTC/SD-148/Cabin23"
			-- 4:1-149 FDOT421 "B/L1/B-DTC/SD-149/Cabin24"
			-- 4:1-150 FDOT421 "B/L1/B-DTC/SD-150/Cabin25"
			-- 4:1-151 FDOT421 "B/L1/B-DTC/SD-151/Cabin26"
			-- 4:1-152 FDOT421 "B/L1/B-DTC/SD-152/Cabin27"
			-- 4:1-153 FDOT421 "B/L1/B-DTC/SD-153/Cabin28"
			-- 4:1-154 FDOT421 "B/L1/B-DTC/SD-154/Cabin29"
			-- 4:1-155 FDOT421 "B/L1/B-DTC/SD-155/Security Recep"
			-- 4:1-156 FDOT421 "B/L1/B-DTC/SD-156/Psg nr Cabin 1"
			-- 4:1-157 FDOT421 "B/L1/B-DTC/SD-157/Psg nr cabin 5"
			-- 4:1-158 FDOT421 "B/L1/B-DTC/SD-158/Psg nr Cabin 9"
			-- 4:1-159 FDOT421 "B/L1/B-DTC/SD-159/Psg nr Cabin11"
			-- 4:1-160 FDOT421 "B/L1/B-DTC/SD-160/Psg nr cabin14"
			-- 4:1-161 FDOT421 "B/L1/B-DTC/SD-161/Psg nr cabin15"
			-- 4:1-162 FDOT421 "BL1/B-DTC/SD-162/Psg nr cabin16"
			-- 4:1-163 FDOT421 "B/L1/B-DTC/SD-163/Psg nr cabin24"
			-- 4:1-164 FDOT421 "B/L1/B-DTC/SD-164/Psg nr cabin21"
			-- 4:1-165 FDOT421 "B/L1/B-DTC/SD-165/Psg nr cabin27"
			-- 4:1-166 FDOT421 "B/L1/B-DTC/SD-166/Psg nr cabin29"
			-- 4:1-167 FDOT421 "B/L1/B-DTC/SD-167/Psg nr Pantry"
			-- 4:1-168 FDOT421 "B/L1/B-DTC/SD-168/AHU Room"
			-- 4:1-170 HMS-S/D/M/SA "B/L1/B-DTC/MCP-170/Psg NrCabin8 "
			-- 4:1-171 HMS-S/D/M/SA "B/L1/B-DTC/MCP-171/PsgNrCabin17 "
			-- 4:1-172 HMS-S/D/M/SA "B/L1/B-DTC/MCP-172/PsgNrCabin19"
			-- 4:1-173 HMS-S/D/M/SA "B/L1/B-DTC/MCP-173/PsgNrCabin24 "
			-- 4:1-174 HMS-S/D/M/SA "B/L1/B-DTC/MCP-174/Psg Nr Cabin "
			-- 4:1-175 HTRI-R "B/L1/B-DTC/CM-175/Psg nr Cab 27"
			-- Switch ""
			-- Relay
			-- 4:1-177 HTRI-R "B/L1/B-DTC/CM-177/PsgNrCab19"
			-- Switch ""
			-- Relay
			-- 4:1-178 HTRI-R "B/L1/B-DTC/CM-178/PsgNrCab17"
			-- Switch ""
			-- Relay
			-- 4:1-179 FDOT421 "B/L1/B-DTC/SD-179/AFC Psg Nr Cab"
			-- 4:1-180 FDOT421 "B/L1/B-DTC/SD-180/AFC PsgNrCab29"
			-- 4:1-181 FDOT421 "B/L1/B-DTC/SD-181/AFC PsgNrCab15"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:1 DLC "DLC @ address 1 L1 "

				--	4:1-182	FDOT421	"B/L1/B-DTC/SD-182/AFC	PsgNrCab14"
				--	4:1-185	FDOT421	"B/L1/B-DTC/SD-185/AFC	PsgNrCab25"
				--	4:1-186	HTRI-R	"B/L1/B-DTC/CM-186/AFC	PsgNrCab24"
					--	Switch	"	
					--	Relay		
				--	4:1-187	FDOT421	"B/L1/B-DTC/SD-187/AFC	Psg WashRm"
				--	4:1-188	FDOT421	"B/L1/B-DTC/SD-188/AFC	PsgNrCab13"
				--	4:1-189	FDOT421	"B/L1/B-DTC/SD-189/AFC	PsgNrCab7"
				--	4:1-191	FDOT421	"B/L1/B-DTC/SD-191/AFC	PsgNrCab9"
				--	4:1-192	FDOT421	"B/L1/B-DTC/SD-192/AFC	PsgNrAHU R"
				--	4:1-193	FDOT421	"B/L1/B-DTC/SD-193/AFC	PsgNrCab4"
				--	4:1-194	FDOT421	"B/L1/B-DTC/SD-194/AFC	Reception "
				--	4:1-195	FDOT421	"B/L1/B-DTC/SD-195/AFC	Cab 1"
				--	4:1-196	FDOT421	"B/L1/B-DTC/SD-196/AFC	Cab 2"
				--	4:1-197	FDOT421	"B/L1/B-DTC/SD-198/AFC	Cab 4"
				--	4:1-198	FDOT421	"B/L1/B-DTC/SD-198/AFC	Cab 4"
				--	4:1-199	FDOT421	"B/L1/B-DTC/SD-199/AFC	Cab 5"
				--	4:1-200	FDOT421	"B/L1/B-DTC/SD-200/AFC	Cab 6"
				--	4:1-201	FDOT421	"B/L1/B-DTC/SD-201/AFC	Cab 7"
				--	4:1-202	FDOT421	"B/L1/B-DTC/SD-202/AFC	Cab 8"
				--	4:1-203	FDOT421	"B/L1/B-DTC/SD-203/AFC	Cab 9"
				--	4:1-204	FDOT421	"B/L1/B-DTC/SD-204/AFC	Cab 10"
				--	4:1-205	FDOT421	"B/L1/B-DTC/SD-205/AFC	Cab 11"
				--	4:1-206	FDOT421	"B/L1/B-DTC/SD-206/AFC	Cab 12"
				--	4:1-207	FDOT421	"B/L1/B-DTC/SD-207/AFC	Cab 13"
				--	4:1-208	FDOT421	"B/L1/B-DTC/SD-208/AFC	Cab 14"
				--	4:1-209	FDOT421	"B/L1/B-DTC/SD-209/AFC	Cab 15"
				--	4:1-210	FDOT421	"B/L1/B-DTC/SD-210/AFC	Cab 16"
				--	4:1-211	FDOT421	"B/L1/B-DTC/SD-211/AFC	Cab 17"
				--	4:1-212	FDOT421	"B/L1/B-DTC/SD-212/AFC	Cab 18"
				--	4:1-213	FDOT421	"B/L1/B-DTC/SD-213/AFC	Cab 19"
				--	4:1-215	FDOT421	"B/L1/B-DTC/SD-215/AFC	Cab 21"
				--	4:1-216	FDOT421	"B/L1/B-DTC/SD-216/AFC	Cab 22"
				--	4:1-217	FDOT421	"B/L1/B-DTC/SD-217/AFC	Cab 23"
				--	4:1-218	FDOT421	"B/L1/B-DTC/SD-218/AFC	Cab 24"
				--	4:1-219	FDOT421	"B/L1/EC/UB/SD119/Legal	Record RM"
				--	4:1-220	FDOT421	"B/L1/EC/UB/SD120/Legal	Record RM"
				--	4:1-221	FDOT421	"B/L1/EC/UB/SD121/Elect	Store"
				--	4:1-222	HFP-11	"B/L1/BE1100/SD222/Cabin	1"
				--	4:1-223	HFP-11	"B/L1/BE1100/SD223/Cabin	2"
				--	4:1-224	HFP-11	"B/L1/BE1100/SD224/Cabin	3"
				--	4:1-225	HFP-11	"B/L1/BE1100/SD225/Cabin	4"
				--	4:1-226	HFP-11	"B/L1/BE1100/SD226/Psg	near Cabin"
				--	4:1-227	HMS-S/D/M/SA	"B/L1/BE1100/MCP227/Entry	Dr"
				--	4:1-228	HTRI-R	"B/L1/BE1100/CM228/Entry	Dr"
					--	Switch	"	
					--	Relay		
				--	4:1-229	HFP-11	"B/L1/BE1140/SD229/Pantry"	
				--	4:1-230	HFP-11	"B/L1/BE1140/SD230/Accounts	cabin"
				--	4:1-231	HFP-11	"B/L1/BE1140/SD231/Buyer	cabin"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:1 DLC "DLC @ address 1 L1 "

```
|      |      |      |-- 4:1-232 HFP-11 "B/L1/BE1140/SD232/Main cabin"
|      |      |      |-- 4:1-233 HFP-11 "B/L1/BE1140/SD233/Psg near Main "
|      |      |      |-- 4:1-234 HMS-S/D/M/SA "B/L1/BE1140/MCP234/Psg near Entr"
|      |      |      |-- 4:1-235 HTRI-R "B/L1/BE1140/CM235/Psg near Entry"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:1-236 FDOT421 "B/L1/B-DTC/SD-236/AFC Cab 28"
|      |      |      |-- 4:1-237 FDOT421 "B/L1/B-DTC/SD-237/AFC Cab 29"
|      |      |      |-- 4:1-176 FDOT421 "B/L1/B-DTC/SD-176/Cabin 20"
|      |      |      |-- 4:2 DLC "DLC @ address 2 L2"
|      |      |      |-- 4:2-1 FDOT421 "B/L2/WC/1F/SD1/CORR NR BW1110"
|      |      |      |-- 4:2-2 FDOT421 "B/L2/WC/1F/SD2/CorrNr BW1110 AFC"
|      |      |      |-- 4:2-3 FDOT421 "B/L2/WC/1F/SD3/CORR NR BW1070"
|      |      |      |-- 4:2-4 FDOT421 "B/L2/WC/1F/SD4/CORR NR AHU RM"
|      |      |      |-- 4:2-5 FDOT421 "B/L2/WC/1F/SD5/CorrNr AHU AFC"
|      |      |      |-- 4:2-6 FDOT421 "B/L2/WC/1F/SD6/AHU ROOM SD"
|      |      |      |-- 4:2-7 HTRI-R "B/L2/WC/1F/CM7/AHU ROOM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:2-8 FDOT421 "B/L2/WC/1F/SD8/CorrNr BW1/S18AFC"
|      |      |      |-- 4:2-10 FDOT421 "B/L2/WC/1F/SD10/CORR NR BW 1160"
|      |      |      |-- 4:2-11 FDOT421 "B/L2/WC/1F/SD11/CorrNrBW1/S19AFC"
|      |      |      |-- 4:2-12 HTRI-R "B/L2/WC/1F/CM12/DOOR RELESE CM N"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:2-13 FDOT421 "B/L2/WC/1F/SD13/LIFT LOBBY SD"
|      |      |      |-- 4:2-14 FDOT421 "B/L2/WC/1F/SD14/LIFT LOBBY SD"
|      |      |      |-- 4:2-15 FDOT421 "B/L2/WC/1F/SD15/ELECTRICAL ROOM "
|      |      |      |-- 4:2-16 FDOT421 "B/L2/WC/1F/SD16/AFC SD Nr BW1010"
|      |      |      |-- 4:2-17 FDOT421 "B/L2/WC/1F/SD17/CORR NR BW1010"
|      |      |      |-- 4:2-18 FDOT421 "B/L2/WC/1F/SD18/CORR NR BW 1020"
|      |      |      |-- 4:2-19 FDOT421 "B/L2/WC/1F/SD19/CorrNr BW1030AFC"
|      |      |      |-- 4:2-20 FDOT421 "B/L2/WC/1F/SD20/CORR NR BW 1040"
|      |      |      |-- 4:2-21 HMS-S/D/M/SA "B/L2/WC/1F/MCP21/StrCaseNrBW1040"
|      |      |      |-- 4:2-22 HTRI-R "B/L2/WC/1F/CM22/STR NR BW1040"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:2-23 FDOT421 "B/L2/WC/1F/SD23/AFC CorrNrBW1060"
|      |      |      |-- 4:2-24 FDOT421 "B/L2/WC/1F/SD24/CORR NR BW 1050"
|      |      |      |-- 4:2-25 FDOT421 "B/L2/WC/2F/SD25/ELECTRICAL ROOM "
|      |      |      |-- 4:2-26 FDOT421 "B/L2/WC/2F/SD26/CORR NR AW 2100"
|      |      |      |-- 4:2-27 FDOT421 "B/L2/WC/2F/SD27/COR NR AW2100AFC"
|      |      |      |-- 4:2-28 FDOT421 "B/L2/WC/2F/SD28/CORR NR AW 2070"
|      |      |      |-- 4:2-29 FDOT421 "B/L2/WC/2F/SD29/CorrNr AW2120AFC"
|      |      |      |-- 4:2-30 FDOT421 "B/L2/WC/2F/SD30/CORR NR AW 2120"
|      |      |      |-- 4:2-31 FDOT421 "B/L2/WC/2F/SD31/CORR NR BW2/S09"
|      |      |      |-- 4:2-32 FDOT421 "B/L2/WC/2F/SD32/LIFT LOBBY SD"
|      |      |      |-- 4:2-33 FDOT421 "B/L2/WC/2F/SD33/LIFT LOBBY SD"
|      |      |      |-- 4:2-34 FDOT421 "B/L2/WC/2F/SD34/CORR NR BW2251 A"
|      |      |      |-- 4:2-35 FDOT421 "B/L2/WC/2F/SD35/CORR NR BW 2251"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:2 DLC "DLC @ address 2 L2"

				--	4:2-37	FDOT421	"B/L2/WC/2F/SD37/AFC CorrNrBW2230"
				--	4:2-38	FDOT421	"B/L2/WC/2F/SD38/CORR NR BW 2230"
				--	4:2-39	FDOT421	"B/L2/WC/2F/SD39/CORR NR BW 2010"
				--	4:2-40	FDOT421	"B/L2/WC/2F/SD40/CorrNr BW2200AFC"
				--	4:2-41	FDOT421	"B/L2/WC/2F/SD41/CORR NR BW 2200"
				--	4:2-42	FDOT421	"B/L2/WC/2F/SD42/CORR NR BW 2060"
				--	4:2-43	FDOT421	"B/L2/WC/2F/SD43/CorrNr BW2070AFC"
				--	4:2-44	FDOT421	"B/L2/WC/2F/SD44/CORR NR BW 2070"
				--	4:2-45	FDOT421	"B/L2/WC/2F/SD45/CORR NR BW 2080"
				--	4:2-46	FDOT421	"B/L2/WC/2F/SD46/AHU ROOM SD"
				--	4:2-47	HTRI-R	"B/L2/WC/2F/CM47/AHU ROOM CM"
					--	Switch	" "
					--	Relay	
				--	4:2-48	HMS-S/D/M/SA	"B/L2/WC/2F/MCP48/STR NR BW 2060"
				--	4:2-49	HTRI-R	"B/L2/WC/2F/CM49/STR NR BW 2060"
					--	Switch	" "
					--	Relay	
				--	4:2-50	HTRI-R	"B/L2/WC/2F/CM50/DOOR R CM NR AHU"
					--	Switch	" "
					--	Relay	
				--	4:2-51	HMS-S/D/M/SA	"B/L2/WC/2F/MCP51/FIRE SHAFT L.L."
				--	4:2-52	HTRI-R	"B/L2/WC/2F/CM52/FIRE SHAFT L.L."
					--	Switch	" "
					--	Relay	
				--	4:2-53	HTRI-S	"B/L2/WC/2F/MM53/FIRE SHAFT L.L."
				--	4:2-54	HTRI-R	"B/L2/WC/2F/CM54/DOOR RELESE NR E"
					--	Switch	" "
					--	Relay	
				--	4:2-55	HTRI-R	"B/L2/WC/2F/CM55/STR NR AW 2023"
					--	Switch	" "
					--	Relay	
				--	4:2-56	HMS-S/D/M/SA	"B/L2/WC/2F/MCP56/STR NR AW 2023"
				--	4:2-57	HMS-S/D/M/SA	"B/L2/WC/1F/MCP57/FIRE SHAFT NR L"
				--	4:2-58	HTRI-R	"B/L2/WC/1F/CM58/FIRE SHAFT NR L."
					--	Switch	" "
					--	Relay	
				--	4:2-59	HTRI-S	"B/L2/WC/1F/MM59/FIRE SHAFT NR L."
				--	4:2-64	HFP-11	"B/L2/BW2080/SD64/Cab 1"
				--	4:2-65	HFP-11	"B/L2/BW2080/SD65/Cab 1"
				--	4:2-66	HFP-11	"B/L2/BW2080/SD66/Cab 2"
				--	4:2-67	HFP-11	"B/L2/BW2080/SD67/Psg nr ent"
				--	4:2-68	HTRI-R	"B/L2/BW2080/CM68/Psg nr ent"
					--	Switch	" "
					--	Relay	
				--	4:2-69	HMS-S/D/M/SA	"B/L2/BW2080/MCP69/Psg nr ent"
				--	4:2-75	HTRI-S	"B/L2/1F/MM75/BW1100"
				--	4:2-77	HTRI-S	"B/L2/1F/MM77/BW1090"
				--	4:2-78	HTRI-S	"B/L2/1F/MM78/BW1121"
				--	4:2-80	HTRI-S	"B/L2/1F/MM80/BW1080"
				--	4:2-83	HTRI-S	"B/L2/1F/MM83/BW1130"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:2 DLC "DLC @ address 2 L2"

			-- 4:2-84 HTRI-S "B/L2/1F/MM84/BW1140"
			-- 4:2-88 HTRI-S "B/L2/1F/MM88/BW1060"
			-- 4:2-90 HTRI-S "B/L2/1F/MM90/BW1010"
			-- 4:2-92 HTRI-S "B/L2/1F/MM92/BW1030"
			-- 4:2-94 HTRI-S "B/L2/1F/MM94/BW1040"
			-- 4:2-95 HTRI-S "B/L2/2F/MM95/AW2140"
			-- 4:2-96 HTRI-S "B/L2/2F/MM96/AW2023"
			-- 4:2-97 HTRI-S "B/L2/2F/MM97/AW/2030"
			-- 4:2-98 HTRI-S "B/L2/2F/MM98/AW2130"
			-- 4:2-99 HTRI-S "B/L2/2F/MM99/AW2040"
			-- 4:2-103 HTRI-S "B/L2/2F/MM103/AW2112"
			-- 4:2-104 HTRI-S "B/L2/2F/MM104/AW2070"
			-- 4:2-107 HTRI-S "B/L2/2F/MM107/AW2111"
			-- 4:2-108 HTRI-S "B/L2/2F/MM108/AW2100"
			-- 4:2-111 HTRI-S "B/L2/2F/MM111/BW2230"
			-- 4:2-112 HTRI-S "B/L2/2F/MM112/BW2220"
			-- 4:2-113 HTRI-S "B/L2/2F/MM113/BW2010"
			-- 4:2-115 HTRI-S "B/L2/2F/MM115/BW2210"
			-- 4:2-119 HTRI-S "B/L2/2F/MM119/BW2050"
			-- 4:2-121 HTRI-S "B/L2/2F/MM121/BW2060"
			-- 4:2-123 HTRI-S "B/L2/2F/MM123/BW2180"
			-- 4:2-124 HFP-11 "B/L2/AW2120/SD124/Main Cabin"
			-- 4:2-125 HFP-11 "B/L2/AW2120/SD125/Accounts Depar"
			-- 4:2-126 HFP-11 "B/L2/AW2120/SD126/Passage Area"
			-- 4:2-127 HTRI-R "B/L2/AW2120/CM127/Passage Area"
			-- Switch ""
			-- Relay
			-- 4:2-128 HMS-S/D/M/SA "B/L2/AW2120/MCP128/Entry Door"
			-- 4:2-129 HFP-11 "B/L2/AW2060/SD129/Main Cabin"
			-- 4:2-130 HFP-11 "B/L2/AW2060/SD130/Accounts Depar"
			-- 4:2-131 HFP-11 "B/L2/AW2060/SD131/Store Room"
			-- 4:2-132 HFP-11 "B/L2/AW2060/SD132/Passage Area"
			-- 4:2-133 HFPT-11 "B/L2/AW2060/SD133/Pantry"
			-- 4:2-134 HMS-S/D/M/SA "B/L2/AW2060/MCP134/Entry Door"
			-- 4:2-135 HTRI-R "B/L2/AW2060/CM135/Entry Door"
			-- Switch ""
			-- Relay
			-- 4:2-136 HFP-11 "B/L2/AW2090/SD136/Main Cabin"
			-- 4:2-137 HFP-11 "B/L2/AW2090/SD137/Buyers Cabin"
			-- 4:2-138 HFP-11 "B/L2/AW2090/SD138/Passage Area"
			-- 4:2-139 HFP-11 "B/L2/AW2090/SD139/Pantry"
			-- 4:2-140 HMS-S/D/M/SA "B/L2/AW2090/MCP140/Entry Door"
			-- 4:2-142 HFP-11 "B/L2/AW2080/SD142/Pantry Area"
			-- 4:2-143 HFP-11 "B/L2/AW2080/SD143/Passage Area"
			-- 4:2-144 HFP-11 "B/L2/AW2080/SD144/Cabin 1"
			-- 4:2-145 HFP-11 "B/L2/AW2080/SD145/Cabin 2"
			-- 4:2-146 HTRI-R "B/L2/AW2080/CM146/Entry Door"
			-- Switch ""
			-- Relay
			-- 4:2-147 HMS-S/D/M/SA "B/L2/AW2080/MCP147/Entry Door"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:2 DLC "DLC @ address 2 L2"

			-- 4:2-148 HFP-11 "B/L2/BW 2251/SD148/Psg near Pant"
			-- 4:2-149 HFP-11 "B/L2/BW 2251/SD149/Pantry "
			-- 4:2-150 HFP-11 "B/L2/BW 2251/SD150/Cabin 3"
			-- 4:2-151 HFP-11 "B/L2/BW 2251/SD151/Main cabin"
			-- 4:2-152 HFP-11 "B/L2/BW 2251/SD152/Main cabin"
			-- 4:2-153 HFP-11 "B/L2/BW 2251/SD153/Conference Ro"
			-- 4:2-154 HMS-S/D/M/SA "B/L2/BW 2251/MCP154/Main Entranc"
			-- 4:2-155 HTRI-R "B/L2/BW 2251/CM155/Entrance door"
			-- Switch ""
			-- Relay
			-- 4:2-156 HFP-11 "B/L2/BW 1110/SD156/Main cabin"
			-- 4:2-157 HFP-11 "B/L2/BW 1110/SD157/Main cabin"
			-- 4:2-158 HTRI-R "B/L2/BW 1110/CM158/Entrance door"
			-- Switch ""
			-- Relay
			-- 4:2-159 HMS-S/D/M/SA "B/L2/BW 1110/MCP159/Main Entranc"
			-- 4:2-160 HFP-11 "B/L2/BW 1130 A/SD160/Psg near En"
			-- 4:2-161 HFP-11 "B/L2/BW 1130 A/SD161/Cabin 1"
			-- 4:2-162 HFP-11 "B/L2/BW 1130 A/SD162/Cabin 2"
			-- 4:2-173 HFP-11 "B/L2/BW 1150/SD173/Cab 4"
			-- 4:2-174 HMS-S/D/M/SA "B/L2/BW 1150/MCP174/Entry Dr"
			-- 4:2-175 HFP-11 "B/L2/BW 1170/SD175/Psg near Pant"
			-- 4:2-176 HFPT-11 "B/L2/BW1170/HD176/Pantry"
			-- 4:2-177 HFP-11 "B/L2/BW 1170/SD177/Cab 1"
			-- 4:2-178 HFP-11 "B/L2/BW 1170/SD178/Cab 2"
			-- 4:2-179 HFP-11 "B/L2/BW 1170/SD179/Cab 3"
			-- 4:2-180 HMS-S/D/M/SA "B/L2/BW 1170/MCP180/Main Entry"
			-- 4:2-181 HTRI-R "B/L2/BW 1170/CM181/Main Entry"
			-- Switch ""
			-- Relay
			-- 4:2-182 HFP-11 "B/L2/BW 2200/SD182/Psg near Entr"
			-- 4:2-183 HFP-11 "B/L2/BW 2200/SD183/Cab 1"
			-- 4:2-184 HFP-11 "B/L2/BW 2200/SD184/Cab 2"
			-- 4:2-185 HMS-S/D/M/SA "B/L2/BW 2200/MCP185/Entry Dr"
			-- 4:2-186 HTRI-R "B/L2/BW 2200/CM186/ Entry Dr"
			-- Switch ""
			-- Relay
			-- 4:2-187 HTRI-R "B/L2/BW 1130 A/CM187/Psg near En"
			-- Switch ""
			-- Relay
			-- 4:2-188 HMS-S/D/M/SA "B/L2/BW 1130 A/MCP188/Psg near E"
			-- 4:2-189 HTRI-R "B/L2/BW 1150/CM189/Entry Dr"
			-- Switch ""
			-- Relay
			-- 4:2-190 HFP-11 "B/L2/BW 2190/SD190/Cab 1"
			-- 4:2-191 HFP-11 "B/L2/BW 2190/SD191/Cab 2"
			-- 4:2-192 HFP-11 "B/L2/BW 2190/SD192/Cab 3"
			-- 4:2-193 HFP-11 "B/L2/BW 2190/SD193/Cab 4"
			-- 4:2-194 HTRI-R "B/L2/BW 2190/CM194/Entry Dr"
			-- Switch ""

```
| | | | | Relay
```

```
| | | | |
```

```
| | | | | |-- 4:2-195 HMS-S/D/M/SA "B/L2/BW 2190/MCP195/Entry Dr"
```

```
| | | | | |-- 4:2-196 HTRI-R "B/L2/AW2090/CM196/Entry Door"
```

```
| | | | | | | |-- Switch ""
```

```
| | | | | | | |-- Relay
```

```
| | | | | |-- 4:2-197 HFPT-11 "B/L2/BW 2040/HD197/Pantry"
```

```
| | | | | |-- 4:2-198 HFP-11 "B/L2/BW 2040/SD198/Psg near Pant"
```

```
| | | | | |-- 4:2-199 HFP-11 "B/L2/BW 2040/SD199/Cab 1"
```

```
| | | | | |-- 4:2-200 HFP-11 "B/L2/BW 2040/SD200/Cab 1"
```

```
| | | | | |-- 4:2-201 HMS-S/D/M/SA "B/L2/BW 2040/MCP201/Entry Dr"
```

```
| | | | | |-- 4:2-202 HTRI-R "B/L2/BW 2040/CM202/Entry Dr"
```

```
| | | | | | | |-- Switch ""
```

```
| | | | | | | |-- Relay
```

```
| | | | | |-- 4:2-210 HFP-11 "B/L2/BW 1020/SD210/Pantry"
```

```
| | | | | |-- 4:2-211 HFP-11 "B/L2/BW 1020/SD211/Main Cab"
```

```
| | | | | |-- 4:2-212 HFP-11 "B/L2/BW 1020/SD212/Cab 1"
```

```
| | | | | |-- 4:2-213 HTRI-R "B/L2/BW 1020/CM213/Entry Dr"
```

```
| | | | | | | |-- Switch ""
```

```
| | | | | | | |-- Relay
```

```
| | | | | |-- 4:2-214 HMS-S/D/M/SA "B/L2/BW 1020/MCP214/Entry Dr"
```

```
| | | | | |-- 4:2-215 HFP-11 "B/L2/BW 1122/SD215/Cab 3"
```

```
| | | | | |-- 4:2-216 HFP-11 "B/L2/BW 1122/SD216/Cab 2"
```

```
| | | | | |-- 4:2-217 HFP-11 "B/L2/BW 1122/SD217/Cab 1"
```

```
| | | | | |-- 4:2-218 HFP-11 "B/L2/BW 1122/SD218/Psg near Cab "
```

```
| | | | | |-- 4:2-219 HTRI-R "B/L2/BW 1122/CM219/Entry Dr"
```

```
| | | | | | | |-- Switch ""
```

```
| | | | | | | |-- Relay
```

```
| | | | | |-- 4:2-220 HMS-S/D/M/SA "B/L2/BW 1122/MCP220/Entry Dr"
```

```
| | | | | |-- 4:2-221 HFP-11 "B/L2/BW2240/SD221/Psg near confe"
```

```
| | | | | |-- 4:2-222 HFP-11 "B/L2/BW2240/SD222/Conference Roo"
```

```
| | | | | |-- 4:2-223 HFP-11 "B/L2/BW2240/SD223/Main cabin"
```

```
| | | | | |-- 4:2-224 HFP-11 "B/L2/BW2240/SD224/Psg near Main "
```

```
| | | | | |-- 4:2-225 HFP-11 "B/L2/BW2240/SD225/Pantry"
```

```
| | | | | |-- 4:2-226 HTRI-R "B/L2/BW2240/CM226/Entry Door"
```

```
| | | | | | | |-- Switch ""
```

```
| | | | | | | |-- Relay
```

```
| | | | | |-- 4:2-227 HMS-S/D/M/SA "B/L2/BW2240/MCP227/Entry Door"
```

```
| | | | | |-- 4:2-228 HFP-11 "B/L2/BW2251/SD228//Reception""
```

```
| | | | | |-- 4:2-229 HFP-11 "B/L2/BW 2251/SD229/Psg near Rece"
```

```
| | | | | |-- 4:2-230 HFP-11 "B/L2/BW 2251/SD230/Account Cabin"
```

```
| | | | | |-- 4:2-231 HFP-11 "B/L2/BW 2251/SD231/Assorter cabi"
```

```
| | | | | |-- 4:2-232 HFP-11 "B/L2/BW 2251/SD232/Assorter cabi"
```

```
| | | | | |-- 4:2-233 HFP-11 "B/L2/BW 2251/SD233/Cabin 1"
```

```
| | | | | |-- 4:2-234 HFP-11 "B/L2/BW 2251/SD234/Pantry"
```

```
| | | | | |-- 4:2-235 HFP-11 "B/L2/BW 2070/SD235/Main Cab"
```

```
| | | | | |-- 4:2-236 HFP-11 "B/L2/BW 2070/SD236/Cab 1"
```

```
| | | | | |-- 4:2-237 HFP-11 "B/L2/BW 2070/SD237/Psg near Cab"
```

```
| | | | | |-- 4:2-238 HFP-11 "B/L2/BW 2070/SD238/Entry Dr "
```

```
| | | | | |-- 4:2-239 HFP-11 "B/L2/BW 2070/SD239/Pantry"
```

```
| | | | | |-- 4:2-240 HTRI-R "B/L2/BW 2070/CM240/Entry Dr"
```

4:2-240 HTRI-R "B/L2/BW 2070/CM240/Entry Dr"

```
| | | Switch ""
| | | |-- Relay
| | | |-- 4:2-241 HMS-S/D/M/SA "B/L2/BW 2070/MCP241/Entry Dr"
| | | |-- 4:2-243 HFP-11 "B/L2/BW 2020/SD243/Waiting Area"
| | | |-- 4:2-244 FDOT421 "B/L2/BW 2020/SD244/Psg nr waitin"
| | | |-- 4:2-245 HFP-11 "B/L2/BW 2020/SD245/Psg near Acct"
| | | |-- 4:2-246 HFP-11 "B/L2/BW 2020/SD246/Assts Room"
| | | |-- 4:2-247 HFP-11 "B/L2/BW 2020/SD247/Executive Cab"
| | | |-- 4:2-248 HFP-11 "B/L2/BW 2020/SD248/Main Cab"
| | | |-- 4:2-249 FDOT421 "B/L2/BW 2020/SD249/SalesCab"
| | | |-- 4:2-250 HFP-11 "B/L2/BW1110/SD250/Pantry"
| | | |-- 4:2-81 HTRI-S "B/L2/1F/MM81/BW1070"
| | | |-- 4:2-163 HFP-11 "B/L2/BW2240/SD163/Entry Psg"
| | | |-- 4:2-60 HFP-11 "B/L2/BW 2020/SD60/Account cab"
| | | |-- 4:2-61 HMS-S/D/M/SA "B/L2/BW 2020/MCP61/Entry Door"
| | | |-- 4:2-251 HFP-11 "B/L2/BW 2020/SD251/Conferece rm"
| | | |-- 4:2-252 HTRI-R "B/L2/BW 2020/CM252/Entry DoorAFC"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:2-82 HTRI-S "B/L2/1F/MM82/BW1160"
| | |-- 4:3 DLC "DLC @ address 3 L3"
| | | |-- 4:3-1 FDOT421 "B/L3/CC/3F/SD1/ELECT RM"
| | | |-- 4:3-2 FDOT421 "B/L3/CC/3F/SD2/OutsideElectRmAFC"
| | | |-- 4:3-3 FDOT421 "B/L3/CC/3F/SD3/OUTSIDE ELECT RM"
| | | |-- 4:3-4 FDOT421 "B/L3/CC/3F/SD4/CORR BC 3012"
| | | |-- 4:3-5 FDOT421 "B/L3/CC/3F/SD5/CORR BC 3021AFC"
| | | |-- 4:3-6 FDOT421 "B/L3/CC/3F/SD6/CORR BC 3021"
| | | |-- 4:3-7 FDOT421 "B/L3/CC/3F/SD7/LIFT LOBBY"
| | | |-- 4:3-8 FDOT421 "B/L3/CC/3F/SD8/LIFT LOBBY"
| | | |-- 4:3-9 HMS-S/D/M/SA "B/L3/CC/3F/MCP9/FIRE ESCAPE STR "
| | | |-- 4:3-10 HTRI-R "B/L3/CC/3F/CM10/FIRE HYD SHAFT"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:3-11 HTRI-S "B/L3/CC/3F/MM11/FIRE HYD SHAFT"
| | | |-- 4:3-12 HTRI-R "B/L3/CC/3F/CM12/DOOR RELEASE UNI"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:3-13 FDOT421 "B/L3/CC/3F/SD13/PsgNr AFC AHU RM"
| | | |-- 4:3-14 FDOT421 "B/L3/CC/3F/SD14/PSG NR AHU RM"
| | | |-- 4:3-15 FDOT421 "B/L3/EC/3F/SD15/AFC CorrNrELE RM"
| | | |-- 4:3-16 FDOT421 "B/L3/EC/3F/SD16/CORR NR ELE RM"
| | | |-- 4:3-17 FDOT421 "B/L3/EC/3F/SD17/AHU RM"
| | | |-- 4:3-18 HTRI-R "B/L3/EC/3F/CM18/AHU RM"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:3-19 FDOT421 "B/L3/EC/3F/SD19/ELECT RM"
| | | |-- 4:3-20 FDOT421 "B/L3/EC/3F/SD20/LIFT LOBBY"
| | | |-- 4:3-21 HMS-S/D/M/SA "B/L3/EC/3F/MCP21/FIRE ESCAPE STA"
| | | |-- 4:3-22 HTRI-R "B/L3/BE/3F/CM22/FIRE HYD SHAFT"
| | | |-- Switch ""
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:3 DLC "DLC @ address 3 L3"

4:3-22 HTRI-R "B/L3/BE/3F/CM22/FIRE HYD SHAFT"

```
|      |      |      |      |-- Relay
|      |      |      |-- 4:3-23 HTRI-S "B/L3/EC/3F/MM23/FIRE HYD SHAFT"
|      |      |      |-- 4:3-24 HMS-S/D/M/SA "B/L3/3F/MCP24/BC FIRE STR"
|      |      |      |-- 4:3-25 FDOT421 "B/L3/CC/2F/SD25/ELECT RM"
|      |      |      |-- 4:3-26 FDOT421 "B/L3/CC/2F/SD26/CorrNrElectRMAFC"
|      |      |      |-- 4:3-27 FDOT421 "B/L3/CC/2F/SD27/CORR NR ELECT RM"
|      |      |      |-- 4:3-28 FDOT421 "B/L3/CC/2F/SD28/CORR BC 2010"
|      |      |      |-- 4:3-29 FDOT421 "B/L3/CC/2F/SD29/CORR BC2031 AFC"
|      |      |      |-- 4:3-30 FDOT421 "B/L3/CC/2F/SD30/CORR BC 2031"
|      |      |      |-- 4:3-31 FDOT421 "B/L3/CC/2F/SD31/CORR NR BC 2050"
|      |      |      |-- 4:3-32 FDOT421 "B/L3/CC/2F/SD32/CORR BC2042AFC"
|      |      |      |-- 4:3-33 FDOT421 "B/L3/CC/2F/SD33/CORR BC2/S20"
|      |      |      |-- 4:3-34 FDOT421 "B/L3/CC/2F/SD34/CORR NR BC 2041"
|      |      |      |-- 4:3-35 FDOT421 "B/L3/CC/2F/SD35/CORR NR BC-2S/20"
|      |      |      |-- 4:3-36 FDOT421 "B/L3/CC/2F/SD36/CORR BC-2S/20A"
|      |      |      |-- 4:3-37 HMS-S/D/M/SA "B/L3/CC/2F/MCP37/FIRE ESCAPE STR"
|      |      |      |-- 4:3-38 HTRI-R "B/L3/CC/2F/CM38/FIRE ESCAPE STR "
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:3-39 HMS-S/D/M/SA "B/L3/CC/2F/MCP39/FIRE ESCAPE STR"
|      |      |      |-- 4:3-40 HTRI-R "B/L3/CC/2F/CM40/FIRE HYD SHAFT"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:3-41 HTRI-S "B/L3/CC/2F/MM41/FIRE HYD SHAFT"
|      |      |      |-- 4:3-42 FDOT421 "B/L3/CC/2F/SD42/LIFT LOBBY"
|      |      |      |-- 4:3-43 FDOT421 "B/L3/CC/2F/SD43/LIFT LOBBY"
|      |      |      |-- 4:3-44 FDOT421 "B/L3/CC/2F/SD44/CorrNrBC2091AFC"
|      |      |      |-- 4:3-45 FDOT421 "B/L3/CC/2F/SD45/CORR NR BC 2091"
|      |      |      |-- 4:3-46 FDOT421 "B/L3/EC/2F/SD46/AFC CORNR AHU RM"
|      |      |      |-- 4:3-48 FDOT421 "B/L3/EC/2F/SD48/ELECT RM"
|      |      |      |-- 4:3-49 FDOT421 "B/L3/EC/2F/SD49/AHU RM"
|      |      |      |-- 4:3-50 HTRI-R "B/L3/2F/CM50/BE AHU RM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:3-51 FDOT421 "B/L3/EC/2F/SD51/LIFT LOBBY"
|      |      |      |-- 4:3-52 HMS-S/D/M/SA "B/L3/EC/2F/MCP52/LIFT LOBBY"
|      |      |      |-- 4:3-53 HTRI-R "B/L3/EC/2F/CM53/FIRE HYD SHAFT"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:3-54 HTRI-S "B/L3/EC/2F/MM54/FIRE HYD SHAFT"
|      |      |      |-- 4:3-55 HTRI-R "B/L3/CC/3F/CM55/FIRE STR"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:3-57 HTRI-R "B/L3/CC/2F/CM57/AHU RM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:3-58 FDOT421 "B/L3/CC/2F/SD58/AHU RM"
|      |      |      |-- 4:3-75 HTRI-S "B/L3/2F/MM75/BC2033"
|      |      |      |-- 4:3-76 HTRI-S "B/L3/2F/MM76/BC2041"
|      |      |      |-- 4:3-77 HTRI-S "B/L3/2F/MM77/BC2042"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:3 DLC "DLC @ address 3 L3"

			-- 4:3-78 HTRI-S "B/L3/2F/MM78/BC2050"
			-- 4:3-79 HTRI-S "B/L3/2F/MM79/BC2032"
			-- 4:3-80 HTRI-S "B/L3/2F/MM80/BC2031"
			-- 4:3-83 HTRI-S "B/L3/2F/MM83/BC2010"
			-- 4:3-84 HTRI-S "B/L3/2F/MM84/BC2071"
			-- 4:3-86 HTRI-S "B/L3/2F/MM86/BC2091"
			-- 4:3-87 HTRI-S "B/L3/2F/MM87/BC2090"
			-- 4:3-92 HTRI-S "B/L3/3F/MM92/BC3022"
			-- 4:3-94 HTRI-S "B/L3/3F/MM94/BC3012"
			-- 4:3-96 HTRI-S "B/L3/3F/MM96/BC3050"
			-- 4:3-97 HTRI-S "B/L3/3F/MM97/BC3040"
			-- 4:3-98 HTRI-S "B/L3/2F/MM98/BE2010"
			-- 4:3-100 HTRI-S "B/L3/3F/MM100/BE3011"
			-- 4:3-109 HFP-11 "B/L3/BC3030/SD109/Waiting Area"
			-- 4:3-110 HFP-11 "B/L3/BC3030/SD110/Pantry"
			-- 4:3-111 HFP-11 "B/L3/BC3030/SD111/Psg near Pantr"
			-- 4:3-112 HFP-11 "B/L3/BC3030/SD112/Main Cab"
			-- 4:3-113 HFP-11 "B/L3/BC3030/SD113/Cab 1"
			-- 4:3-114 HFP-11 "B/L3/BC3030/SD114/Cab 2"
			-- 4:3-115 HFP-11 "B/L3/BC3030/SD115/Cab 3"
			-- 4:3-116 HFP-11 "B/L3/BC3030/SD116/Asst Cab"
			-- 4:3-117 HFP-11 "B/L3/BC3030/SD117/Weighting corn"
			-- 4:3-118 HFP-11 "B/L3/BC3030/SD118/Accts Cab"
			-- 4:3-119 HFP-11 "B/L3/BC3030/SD119/Cab 4"
			-- 4:3-120 HFP-11 "B/L3/BC3030/SD120/Psg near Cab 4"
			-- 4:3-121 HTRI-R "B/L3/BC3030/CM121/Entry Dr"
			-- Switch ""
			-- Relay
			-- 4:3-122 HMS-S/D/M/SA "B/L3/BC3030/MCP122/Entry Dr"
			-- 4:3-123 HFP-11 "B/L3/BW3010/SD123/Cab13"
			-- 4:3-124 HFP-11 "B/L3/BW3010/SD124/Cab 11"
			-- 4:3-125 HFP-11 "B/L3/BW3010/SD125/Cab 11"
			-- 4:3-126 HFP-11 "B/L3/BW3010/SD126/Cab 10"
			-- 4:3-127 HFP-11 "B/L3/BW3010/SD127/Cab 12"
			-- 4:3-128 HFP-11 "B/L3/BW3010/SD128/cab 9"
			-- 4:3-129 HFP-11 "B/L3/BW3010/SD129/Psg nr Pantry"
			-- 4:3-130 HFP-11 "B/L3/BW3010/SD130/Pantry"
			-- 4:3-131 HMS-S/D/M/SA "B/L3/BW3010/MCP131/Psg nr Entry "
			-- 4:3-132 HFP-11 "B/L3/BW3010/SD132/Psg nr cab 12"
			-- 4:3-133 HFP-11 "B/L3/BW3010/SD133/cab 9"
			-- 4:3-134 HFP-11 "B/L3/BW3010/SD134/Psg nr Pantry "
			-- 4:3-135 HFP-11 "B/L3/BW3010/SD135/cab 7"
			-- 4:3-136 HFP-11 "B/L3/BW3010/SD136/cab 8"
			-- 4:3-137 HFP-11 "B/L3/BW3010/SD137/Cab 6"
			-- 4:3-138 HFP-11 "B/L3/BW3010/SD138/Psg nr Confere"
			-- 4:3-139 HFP-11 "B/L3/BW3010/SD139/Conference roo"
			-- 4:3-140 HFP-11 "B/L3/BW3010/SD140/Cab 5"
			-- 4:3-141 HFP-11 "B/L3/BW3010/SD141/Psg nr cab 5"
			-- 4:3-142 HFP-11 "B/L3/BW3010/SD142/Cab 1"
			-- 4:3-143 HFP-11 "B/L3/BW3010/SD143/Main cab"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:3 DLC "DLC @ address 3 L3"

```
|      |      |      |-- 4:3-144 HFP-11 "B/L3/BW3010/SD144/Main cab"
|      |      |      |-- 4:3-145 HFP-11 "B/L3/BW3010/SD145/Psg nr Main ca"
|      |      |      |-- 4:3-146 HFP-11 "B/L3/BW3010/SD146/Cab 2"
|      |      |      |-- 4:3-147 HFP-11 "B/L3/BW3010/SD147/Psg nr cab 3"
|      |      |      |-- 4:3-148 HFP-11 "B/L3/BW3010/SD148/Cab 4"
|      |      |      |-- 4:3-197 HFP-11 "B/L3/BW3010/SD197/Lunch room"
|      |      |      |-- 4:3-149 HTRI-R "B/L3/BW3010/CM149/Psg nr Entry D"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-150 HFP-11 "B/L3/BW3010/SD150/Reception"
|      |      |      |-- 4:3-151 HFP-11 "B/L3/BC2060/SD151/Assorter cab"
|      |      |      |-- 4:3-152 HFP-11 "B/L3/BC2060/SD152/Reception cab"
|      |      |      |-- 4:3-153 HFP-11 "B/L3/BC2060/SD153/Accounts cab"
|      |      |      |-- 4:3-154 HFP-11 "B/L3/BC2060/SD154/Main cab"
|      |      |      |-- 4:3-155 HFP-11 "B/L3/BC2060/SD155/Main cab"
|      |      |      |-- 4:3-156 HMS-S/D/M/SA "B/L3/BC2060/MCP156/Psg nr Entry "
|      |      |      |-- 4:3-157 HTRI-R "B/L3/BC2060/CM157/Psg nr Entry D"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-158 HFP-11 "B/L3/BC3011/SD158/cab 1"
|      |      |      |-- 4:3-159 HFP-11 "B/L3/BC3011/SD159/cab 2"
|      |      |      |-- 4:3-160 HFP-11 "B/L3/BC3011/SD160/cab 3"
|      |      |      |-- 4:3-161 HFP-11 "B/L3/BC3011/SD161/cab 4"
|      |      |      |-- 4:3-162 HFP-11 "B/L3/BC3011/SD162/cab 5"
|      |      |      |-- 4:3-165 HTRI-R "B/L3/BC3011/CM165/Psg nr Entry D"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-166 HMS-S/D/M/SA "B/L3/BC3011/MCP166/Psg nr Entry "
|      |      |      |-- 4:3-101 HFP-11 "B/L3/BC2080/SD101/Assorter cab"
|      |      |      |-- 4:3-102 HFP-11 "B/L3/BC2080/SD102/Main cab"
|      |      |      |-- 4:3-103 HFP-11 "B/L3/BC2080/SD103/Pantry"
|      |      |      |-- 4:3-104 HFP-11 "B/L3/BC2080/SD104/Entry psg"
|      |      |      |-- 4:3-105 HTRI-R "B/L3/BC2080/CM105/ Entry psg AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-106 HMS-S/D/M/SA "B/L3/BC2080/MCP106/ Entry psg"
|      |      |      |-- 4:3-167 HFP-11 "B/L3/BC3021/SD167/MAIN CABIN"
|      |      |      |-- 4:3-168 HFP-11 "B/L3/BC3021/SD168/ASSORTOR CABIN"
|      |      |      |-- 4:3-169 HFP-11 "B/L3/BC3021/SD169/PSG. NR.ASSORT"
|      |      |      |-- 4:3-170 HFPT-11 "B/L3/BC3021/HD170/PANTRY"
|      |      |      |-- 4:3-172 HMS-S/D/M/SA "B/L3/BC3021/MCP172/ENTRY PSG"
|      |      |      |-- 4:3-171 HTRI-R "B/L3/BC3021/CM171/ENTRY PSG AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-47 FDOT421 "B/L3/EC/2F/SD47/CORR BE 2010"
|      |      |      |-- 4:3-82 HTRI-S "B/L3/2F/MM82/BC2020"
|      |      |      |-- 4:3-81 HFPT-11 "B/L3/HD81/BC2060/Pantry"
|      |      |      |-- 4:3-59 FDOT421 "B/L3/CC/3F/SD59/AHU RM"
|      |      |      |-- 4:3-60 HTRI-R "B/L3/CC/3F/CM60/AHU RM"
|      |      |      |-- Switch ""
```

```
4 Desigo Fire Safety Modular "BDB TOWER B" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      4:3 DLC "DLC @ address 3 L3"
        4:3-60 HTRI-R "B/L3/CC/3F/CM60/AHU RM"
```

```
|      |      |      |-- Relay
|      |      |      |-- 4:4 DLC "DLC @ address 4 L4"
|      |      |      |-- 4:4-1 FDOT421 "B/L4/WC/3F/SD1/ELECT RM SD"
|      |      |      |-- 4:4-2 FDOT421 "B/L4/WC/3F/SD2/Corr Nr AW3061AFC"
|      |      |      |-- 4:4-3 FDOT421 "B/L4/WC/3F/SD3/CORR NR AW 3061"
|      |      |      |-- 4:4-4 FDOT421 "B/L4/WC/3F/SD4/CORR NR AW3041"
|      |      |      |-- 4:4-5 FDOT421 "B/L4/WC/3F/SD5/CorrNr AW3042 AFC"
|      |      |      |-- 4:4-6 FDOT421 "B/L4/WC/3F/SD6/CORR NR AW 3042"
|      |      |      |-- 4:4-7 FDOT421 "B/L4/WC/3F/SD7/CORR NR AW 3032"
|      |      |      |-- 4:4-8 FDOT421 "B/L4/WC/3F/SD8/CORR NR AW 3100"
|      |      |      |-- 4:4-9 FDOT421 "B/L4/WC/3F/SD9/CORR NR AW 3100"
|      |      |      |-- 4:4-10 FDOT421 "B/L4/WC/3F/SD10/LIFT LOBBY SD"
|      |      |      |-- 4:4-11 FDOT421 "B/L4/WC/3F/SD11/LIFT LOBBY SD"
|      |      |      |-- 4:4-12 FDOT421 "B/L4/WC/3F/SD12/CorrNrAHU RM"
|      |      |      |-- 4:4-13 FDOT421 "B/L4/WC/3F/SD13/CorrNrAHU RM"
|      |      |      |-- 4:4-14 FDOT421 "B/L4/WC/3F/SD14/CorrNr BW3022"
|      |      |      |-- 4:4-15 FDOT421 "B/L4/WC/3F/SD15/CORR NR BW 3022"
|      |      |      |-- 4:4-16 FDOT421 "B/L4/WC/3F/SD16/CORR NR BW 3032"
|      |      |      |-- 4:4-17 FDOT421 "B/L4/WC/3F/SD17/CORR NR BW 3050"
|      |      |      |-- 4:4-18 FDOT421 "B/L4/WC/3F/SD18/CORR NR BW 3050"
|      |      |      |-- 4:4-19 FDOT421 "B/L4/WC/3F/SD19/AHU RM SD"
|      |      |      |-- 4:4-20 HTRI-R "B/L4/WC/3F/CM20/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-21 HTRI-R "B/L4/WC/3F/CM21/STR NR BW 3050"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-22 HMS-S/D/M/SA "B/L4/WC/3F/MCP22/STR NR BW 3050"
|      |      |      |-- 4:4-23 HTRI-R "B/L4/WC/3F/CM23/DoorReleaseCmNrAH"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-24 HMS-S/D/M/SA "B/L4/WC/3F/MCP24/FIRE SHAFT NRL.L"
|      |      |      |-- 4:4-25 HTRI-R "B/L4/WC/3F/CM25/FIRE SHAFT NRL.L"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-26 HTRI-S "B/L4/WC/3F/MM26/FIRE SHAFT NRL.L"
|      |      |      |-- 4:4-27 HTRI-R "B/L4/WC/3F/CM27/DOOR RELESE CM N"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-28 HTRI-R "B/L4/WC/3F/CM28/STR NR AW 3100"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-29 HMS-S/D/M/SA "B/L4/WC/3F/MCP29/STR NR AW 3100"
|      |      |      |-- 4:4-30 FDOT421 "B/L4/WC/4F/SD30/BW ELECT RM"
|      |      |      |-- 4:4-31 FDOT421 "B/L4/WC/4F/SD31/CORR NR AW 4080"
|      |      |      |-- 4:4-32 FDOT421 "B/L4/WC/4F/SD32/CORR NR AW 4080"
|      |      |      |-- 4:4-33 FDOT421 "B/L4/WC/4F/SD33/CORR NR AW 4101"
|      |      |      |-- 4:4-34 FDOT421 "B/L4/WC/4F/SD34/CORR NR AW 4060"
|      |      |      |-- 4:4-35 FDOT421 "B/L4/WC/4F/SD35/CORR NR AW 4060"
|      |      |      |-- 4:4-36 FDOT421 "B/L4/WC/4F/SD36/CORR NR AW 4120"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 4:4-37 FDOT421 "B/L4/WC/4F/SD37/CORR NR AW 4130"
|      |      |      |-- 4:4-38 FDOT421 "B/L4/WC/4F/SD38/CORR NR AW 4130"
|      |      |      |-- 4:4-39 FDOT421 "B/L4/WC/4F/SD39/LIFT LOBBY SD"
|      |      |      |-- 4:4-40 FDOT421 "B/L4/WC/4F/SD40/LIFT LOBBY SD"
|      |      |      |-- 4:4-41 FDOT421 "B/L4/WC/4F/SD41/CORR NrBW4220AFC"
|      |      |      |-- 4:4-42 FDOT421 "B/L4/WC/4F/SD42/CORR NR BW 4210"
|      |      |      |-- 4:4-43 FDOT421 "B/L4/WC/4F/SD43/CORR NR BW 4/S18"
|      |      |      |-- 4:4-44 FDOT421 "B/L4/WC/4F/SD44/CORR NrBW4201AFC"
|      |      |      |-- 4:4-45 FDOT421 "B/L4/WC/4F/SD45/CORR NR BW 4201"
|      |      |      |-- 4:4-46 FDOT421 "B/L4/WC/4F/SD46/CORR NR BW 4011"
|      |      |      |-- 4:4-47 FDOT421 "B/L4/WC/4F/SD47/CORR NrBW4180AFC"
|      |      |      |-- 4:4-48 FDOT421 "B/L4/WC/4F/SD48/CORR NR BW 4180"
|      |      |      |-- 4:4-49 FDOT421 "B/L4/WC/4F/SD49/CORR NR BW 4170"
|      |      |      |-- 4:4-50 FDOT421 "B/L4/WC/4F/SD50/CORR NrBW4051AFC"
|      |      |      |-- 4:4-51 FDOT421 "B/L4/WC/4F/SD51/CORR NR BW 4051"
|      |      |      |-- 4:4-52 HTRI-R "B/L4/WC/4F/CM52/STR NR BW 4051"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-53 HMS-S/D/M/SA "B/L4/WC/4F/MCP53/STR NR BW 4051"
|      |      |      |-- 4:4-54 FDOT421 "B/L4/WC/4F/SD54/AHU RM SD"
|      |      |      |-- 4:4-55 HTRI-R "B/L4/WC/4F/CM55/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-56 HTRI-R "B/L4/WC/4F/CM56/DOOR RELESE CM N"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-57 HMS-S/D/M/SA "B/L4/WC/4F/MCP57/FIRE SHAFT NRL."
|      |      |      |-- 4:4-58 HTRI-S "B/L4/WC/4F/MM58/FIRE SHAFT NRL.L"
|      |      |      |-- 4:4-59 HTRI-R "B/L4/WC/4F/CM59/FIRE SHAFT NRL.L"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-60 HTRI-R "B/L4/WC/4F/CM60/DOOR RELESE CM N"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-61 HTRI-R "B/L4/WC/4F/CM61/STR NR AW 4130"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-62 HMS-S/D/M/SA "B/L4/WC/4F/MCP62/STR NR AW 4130"
|      |      |      |-- 4:4-75 HTRI-S "B/L4/4F/MM75/BW3062"
|      |      |      |-- 4:4-76 HTRI-S "B/L4/4F/MM76/BW3130"
|      |      |      |-- 4:4-77 HTRI-S "B/L4/4F/MM77/BW3061"
|      |      |      |-- 4:4-82 HTRI-S "B/L4/4F/MM82/BW3150"
|      |      |      |-- 4:4-83 HTRI-S "B/L4/4F/MM83/BW3160"
|      |      |      |-- 4:4-85 HTRI-S "B/L4/4F/MM85/BW3170"
|      |      |      |-- 4:4-88 HTRI-S "B/L4/4F/MM88/BW3182"
|      |      |      |-- 4:4-90 HTRI-S "B/L4/4F/MM90/AW3062"
|      |      |      |-- 4:4-91 HTRI-S "B/L4/4F/MM91/AW3061"
|      |      |      |-- 4:4-93 HTRI-S "B/L4/4F/MM93/AW3051"
|      |      |      |-- 4:4-95 HTRI-S "B/L4/4F/MM95/AW3070"
|      |      |      |-- 4:4-97 HTRI-S "B/L4/4F/MM97/AW3080"
```


4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 4:4-98 HTRI-S "B/L4/4F/MM98/AW3032"
|      |      |      |-- 4:4-100 HTRI-S "B/L4/4F/MM100/AW3031"
|      |      |      |-- 4:4-103 HTRI-S "B/L4/4F/MM103/AW4023"
|      |      |      |-- 4:4-104 HTRI-S "B/L4/4F/MM104/AW4130"
|      |      |      |-- 4:4-107 HTRI-S "B/L4/4F/MM107/AW4040"
|      |      |      |-- 4:4-108 HTRI-S "B/L4/4F/MM108/AW4110"
|      |      |      |-- 4:4-109 HTRI-S "B/L4/4F/MM109/AW4050"
|      |      |      |-- 4:4-110 HTRI-S "B/L4/4F/MM110/AW4060"
|      |      |      |-- 4:4-111 HTRI-S "B/L4/4F/MM111/AW4102"
|      |      |      |-- 4:4-112 HTRI-S "B/L4/4F/MM112/AW4101"
|      |      |      |-- 4:4-113 HTRI-S "B/L4/4F/MM113/AW4070"
|      |      |      |-- 4:4-114 HTRI-S "B/L4/4F/MM114/AW4080"
|      |      |      |-- 4:4-117 HTRI-S "B/L4/4F/MM117/BW4220"
|      |      |      |-- 4:4-118 HTRI-S "B/L4/4F/MM118/BW4210"
|      |      |      |-- 4:4-120 HTRI-S "B/L4/4F/MM120/BW4201"
|      |      |      |-- 4:4-121 HTRI-S "B/L4/4F/MM121/BW4011"
|      |      |      |-- 4:4-124 HTRI-S "B/L4/4F/MM124/BW4021"
|      |      |      |-- 4:4-125 HTRI-S "B/L4/4F/MM125/BW4180"
|      |      |      |-- 4:4-126 HTRI-S "B/L4/4F/MM126/BW4022"
|      |      |      |-- 4:4-127 HTRI-S "B/L4/4F/MM127/BW4030"
|      |      |      |-- 4:4-128 HTRI-S "B/L4/4F/MM128/BW4170"
|      |      |      |-- 4:4-131 HTRI-S "B/L4/4F/MM131/BW4160"
|      |      |      |-- 4:4-132 HTRI-S "B/L4/4F/MM132/BW4052"
|      |      |      |-- 4:4-133 HFP-11 "B/L4/AW4030/SD133/Account Depart"
|      |      |      |-- 4:4-134 HFP-11 "B/L4/AW4030/SD134/Main cabin"
|      |      |      |-- 4:4-135 HFP-11 "B/L4/AW4030/SD135/Passage Area"
|      |      |      |-- 4:4-136 HTRI-R "B/L4/AW4030/CM136/Passage Area"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-137 HMS-S/D/M/SA "B/L4/AW4030/MCP137/Entry Door"
|      |      |      |-- 4:4-138 HFP-11 "B/L4/AW4120/SD138/Main Cabin"
|      |      |      |-- 4:4-139 HFP-11 "B/L4/AW4120/SD139/Passage Area"
|      |      |      |-- 4:4-140 HFP-11 "B/L4/AW4120/SD140/Account Depart"
|      |      |      |-- 4:4-141 HFP-11 "B/L4/AW4120/SD141/Pantry"
|      |      |      |-- 4:4-142 HMS-S/D/M/SA "B/L4/AW4120/MCP142/Entry Door"
|      |      |      |-- 4:4-143 HTRI-R "B/L4/AW4120/CM143/Entry Door"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-144 HFP-11 "B/L4/AW4090/SD144/Main Cabin"
|      |      |      |-- 4:4-145 HFP-11 "B/L4/AW4090/SD145/Managers Cabin"
|      |      |      |-- 4:4-146 HFP-11 "B/L4/AW4090/SD146/Assorter Room"
|      |      |      |-- 4:4-147 HFP-11 "B/L4/AW4090/SD147/Account Cabin"
|      |      |      |-- 4:4-148 HFP-11 "B/L4/AW4090/SD148/Passage Area"
|      |      |      |-- 4:4-149 HFP-11 "B/L4/AW4090/SD149/Pantry"
|      |      |      |-- 4:4-150 HTRI-R "B/L4/AW4090/CM150/Entry Door"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-151 HMS-S/D/M/SA "B/L4/AW4090/MCP151/Entry Door"
|      |      |      |-- 4:4-152 HFP-11 "B/L4/AW3090/SD152/Main Cabin"
|      |      |      |-- 4:4-153 HFP-11 "B/L4/AW3090/SD153/Assorter Room"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 4:4-154 HFP-11 "B/L4/AW3090/SD154/Pantry"
|      |      |      |-- 4:4-155 HTRI-R "B/L4/AW3090/CM155/Entry door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-156 HMS-S/D/M/SA "B/L4/AW3090/MCP156/Entry door"
|      |      |      |-- 4:4-157 HFP-11 "B/L4/AW3022/SD157/Pantry Area"
|      |      |      |-- 4:4-158 HFP-11 "B/L4/AW3022/SD158/Passage Area"
|      |      |      |-- 4:4-159 HFP-11 "B/L4/AW3022/SD159/Cabin 1 "
|      |      |      |-- 4:4-160 HFP-11 "B/L4/AW3022/SD160/Cabin 2"
|      |      |      |-- 4:4-161 HTRI-R "B/L4/AW3022/CM161/Entry Door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-162 HMS-S/D/M/SA "B/L4/AW3022/MCP162/Entry Door"
|      |      |      |-- 4:4-163 HFP-11 "B/L4/AW3100/SD163/Passage Area"
|      |      |      |-- 4:4-164 HFPT-11 "B/L4/AW3100/SD164/Pantry Area"
|      |      |      |-- 4:4-165 HFP-11 "B/L4/AW3100/SD165/Assorter Cabin"
|      |      |      |-- 4:4-166 HFP-11 "B/L4/AW3100/SD166/Buyer Cabin"
|      |      |      |-- 4:4-167 HFP-11 "B/L4/AW3100/SD167/Main Cabin"
|      |      |      |-- 4:4-168 HTRI-R "B/L4/AW3100/CM168/Entry Door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-169 HMS-S/D/M/SA "B/L4/AW3100/MCP169/Entry Door"
|      |      |      |-- 4:4-170 HFP-11 "B/L4/BW3140/SD170/Pantry"
|      |      |      |-- 4:4-171 HFP-11 "B/L4/BW3140/SD171/Main Cab"
|      |      |      |-- 4:4-172 HFP-11 "B/L4/BW3140/SD172/Psg near Main "
|      |      |      |-- 4:4-173 HFP-11 "B/L4/BW3140/SD173/Cab 1"
|      |      |      |-- 4:4-174 HFP-11 "B/L4/BW3140/SD174/Cab 1"
|      |      |      |-- 4:4-175 HMS-S/D/M/SA "B/L4/BW3140/MCP175/Entry Dr"
|      |      |      |-- 4:4-176 HTRI-R "B/L4/BW3140/CM176/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-177 HFP-11 "B/L4/BW3050/SD177/Psg near Pantr"
|      |      |      |-- 4:4-178 HFP-11 "B/L4/BW3050/SD178/Pantry"
|      |      |      |-- 4:4-179 HFP-11 "B/L4/BW3050/SD179/Asst Cab"
|      |      |      |-- 4:4-180 HFP-11 "B/L4/BW3050/SD180/Cab 1"
|      |      |      |-- 4:4-181 HFP-11 "B/L4/BW3050/SD181/Cab 2"
|      |      |      |-- 4:4-182 HTRI-R "B/L4/BW3050/CM182/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-183 HMS-S/D/M/SA "B/L4/BW3050/MCP183/Entry Dr"
|      |      |      |-- 4:4-193 HFP-11 "B/L4/BW3040/SD193/Pantry"
|      |      |      |-- 4:4-194 HFP-11 "B/L4/BW3040/SD194/Cab 1"
|      |      |      |-- 4:4-195 HFP-11 "B/L4/BW3040/SD195/Asst Cab"
|      |      |      |-- 4:4-196 HFP-11 "B/L4/BW3040/SD196/Main Cab"
|      |      |      |-- 4:4-197 HFP-11 "B/L4/BW3040/SD197/Psg near Cab 1"
|      |      |      |-- 4:4-198 HTRI-R "B/L4/BW3040/CM198/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-199 HMS-S/D/M/SA "B/L4/BW3040/MCP199/Entry Dr"
|      |      |      |-- 4:4-200 HFP-11 "B/L4/BW3021/SD200/Pantry"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 4:4-201 HFP-11 "B/L4/BW3021/SD201/Cab 1"
|      |      |      |-- 4:4-202 HFP-11 "B/L4/BW3021/SD202/Cab 2"
|      |      |      |-- 4:4-203 HFP-11 "B/L4/BW3021/SD203/Cab 3"
|      |      |      |-- 4:4-204 HFP-11 "B/L4/BW3021/SD204/Psg near Cab 2"
|      |      |      |-- 4:4-205 HTRI-R "B/L4/BW3021/CM205/Entry Dr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-206 HMS-S/D/M/SA "B/L4/BW3021/MCP206/Entry Dr"
|      |      |      |-- 4:4-207 HFP-11 "B/L4/BW3031/SD207/Pantry "
|      |      |      |-- 4:4-208 HFP-11 "B/L4/BW3031/SD208/Cab 1"
|      |      |      |-- 4:4-209 HFP-11 "B/L4/BW3031/SD209/Cab 2"
|      |      |      |-- 4:4-210 HFP-11 "B/L4/BW3031/SD210/Cab 3"
|      |      |      |-- 4:4-211 HFP-11 "B/L4/BW3031/SD211/Cab 4"
|      |      |      |-- 4:4-212 HFP-11 "B/L4/BW3031/SD212/Cab 5"
|      |      |      |-- 4:4-213 HFP-11 "B/L4/BW3031/SD213/Recp"
|      |      |      |-- 4:4-214 HTRI-R "B/L4/BW3031/CM214/Entry Dr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-215 HMS-S/D/M/SA "B/L4/BW3031/MCP215/Entry Dr"
|      |      |      |-- 4:4-217 HFP-11 "B/L4/BW4190/SD217/Cab 2"
|      |      |      |-- 4:4-218 HFP-11 "B/L4/BW4190/SD218/Cab 1"
|      |      |      |-- 4:4-220 HTRI-R "B/L4/BW4190/CM220/Entry Dr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-221 HMS-S/D/M/SA "B/L4/BW4190/MCP221/Entry Dr"
|      |      |      |-- 4:4-222 HFP-11 "B/L4/BW3022/SD222/Pantry "
|      |      |      |-- 4:4-223 HFP-11 "B/L4/BW3022/SD223/Psg near Pantr"
|      |      |      |-- 4:4-224 HFP-11 "B/L4/BW3022/SD224/Director Cab"
|      |      |      |-- 4:4-225 HFP-11 "B/L4/BW3022/SD225/Psg near Accts"
|      |      |      |-- 4:4-226 HTRI-R "B/L4/BW3022/CM226/Entry Dr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-227 HMS-S/D/M/SA "B/L4/BW3022/MCP227/Entry Dr"
|      |      |      |-- 4:5 DLC "DLC @ address 5 L5"
|      |      |      |-- 4:5-1 FDOT421 "B/L5/CC/5F/SD1/ELECTRICAL RM"
|      |      |      |-- 4:5-2 FDOT421 "B/L5/CC/5F/SD2/AFC NR ELE RM"
|      |      |      |-- 4:5-3 FDOT421 "B/L5/CC/5F/SD3/CORR NR BC5025"
|      |      |      |-- 4:5-4 HMS-S/D/M/SA "B/L5/CC/5F/MCP4/FIRE ESCAPE STR"
|      |      |      |-- 4:5-5 HTRI-R "B/L5/CC/5F/CM5/FIRE HYD SHAFT"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:5-6 HTRI-S "B/L5/CC/5F/MM6/FIRE HYD SHAFT"
|      |      |      |-- 4:5-7 FDOT421 "B/L5/CC/5F/SD7/LIFT LOBBY"
|      |      |      |-- 4:5-8 FDOT421 "B/L5/CC/5F/SD8/LIFT LOBBY"
|      |      |      |-- 4:5-9 FDOT421 "B/L5/CC/5F/SD9/COR NR BC5022 AFC"
|      |      |      |-- 4:5-10 FDOT421 "B/L5/CC/5F/SD10/CORR NR BC5022"
|      |      |      |-- 4:5-11 FDOT421 "B/L5/EC/5F/SD11/CorrNr BE5021/22"
|      |      |      |-- 4:5-12 FDOT421 "B/L5/EC/5F/SD12/CorNr ELE RM AFC"
|      |      |      |-- 4:5-13 FDOT421 "B/L5/EC/5F/SD13/ELECTRICAL RM"
|      |      |      |-- 4:5-14 FDOT421 "B/L5/EC/5F/SD14/AHU RM"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:5 DLC "DLC @ address 5 L5"

```
|      |      |-- 4:5-15 HTRI-R "B/L5/EC/5F/CM15/AHU RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-16 FDOT421 "B/L5/EC/5F/SD16/LIFT LOBBY"
|      |      |-- 4:5-17 HMS-S/D/M/SA "B/L5/EC/5F/MCP17/FIRE ESCAPE STR"
|      |      |-- 4:5-18 HTRI-R "B/L5/EC/5F/CM18/FIRE HYD SHAFT"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-19 HTRI-S "B/L5/EC/5F/MM19/FIRE HYD SHAFT"
|      |      |-- 4:5-24 FDOT421 "B/L5/CC/4F/SD24/ELECTRICAL RM"
|      |      |-- 4:5-25 FDOT421 "B/L5/CC/4F/SD25/CorrNr BC4011AFC"
|      |      |-- 4:5-26 FDOT421 "B/L5/CC/4F/SD26/CORR NR BC 4011"
|      |      |-- 4:5-27 HTRI-R "B/L5/CC/4F/CM27/FIRE HYD SHAFT"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-28 HTRI-S "B/L5/CC/4F/MM28/FIRE HYD SHAFT"
|      |      |-- 4:5-29 HMS-S/D/M/SA "B/L5/CC/4F/MCP29/FIRE ESCAPE STR"
|      |      |-- 4:5-30 FDOT421 "B/L5/CC/4F/SD30/LIFT LOBBY"
|      |      |-- 4:5-31 FDOT421 "B/L5/CC/4F/SD31/LIFT LOBBY"
|      |      |-- 4:5-32 FDOT421 "B/L5/CC/4F/SD32/CorrNrBC4022bAFC"
|      |      |-- 4:5-33 FDOT421 "B/L5/CC/4F/SD33/CORR NR BC 4022B"
|      |      |-- 4:5-34 FDOT421 "B/L5/EC/4F/SD34/CORR NR BE AHU R"
|      |      |-- 4:5-35 FDOT421 "B/L5/EC/4F/SD35/CORR NR AHU RM"
|      |      |-- 4:5-36 FDOT421 "B/L5/EC/4F/SD36/AHU RM"
|      |      |-- 4:5-37 HTRI-R "B/L5/EC/4F/CM37/AHU RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-38 FDOT421 "B/L5/EC/4F/SD38/ELECTRICAL RM"
|      |      |-- 4:5-39 FDOT421 "B/L5/EC/4F/SD39/LIFT LOBBY"
|      |      |-- 4:5-40 HTRI-R "B/L5/EC/4F/CM40/FIRE HYD SHAFT L"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-41 FDOT421 "B/L5/CC/5F/SD41/BC AHU RM"
|      |      |-- 4:5-42 HTRI-S "B/L5/EC/4F/MM42/FIRE HYD SHAFT"
|      |      |-- 4:5-45 HTRI-R "B/L5/CC/4F/CM45/AHU RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-46 FDOT421 "B/L5/CC/4F/SD46/AHU RM"
|      |      |-- 4:5-63 HTRI-S "B/L5/4F/MM63/BC4011"
|      |      |-- 4:5-64 HTRI-S "B/L5/4F/MM64/BC4022B"
|      |      |-- 4:5-67 HTRI-S "B/L5/5F/MM67/BE5021"
|      |      |-- 4:5-68 HTRI-S "B/L5/5F/MM68/BE5010"
|      |      |-- 4:5-71 HTRI-S "B/L5/5F/MM71/BC5010"
|      |      |-- 4:5-72 HTRI-S "B/L5/5F/MM72/BC5025"
|      |      |-- 4:5-73 HFP-11 "B/L5/BC4012/SD73/Recp"
|      |      |-- 4:5-74 HFP-11 "B/L5/BC4012/SD74/Cab 2"
|      |      |-- 4:5-75 HFP-11 "B/L5/BC4012/SD75/Assorter Cab"
|      |      |-- 4:5-76 HFP-11 "B/L5/BC4012/SD76/Psg Nr Assorter"
|      |      |-- 4:5-77 HFP-11 "B/L5/BC4012/SD77/Main Cab"
|      |      |-- 4:5-80 HFP-11 "B/L5/BC4012/SD80/Pntry"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:5 DLC "DLC @ address 5 L5"

```
|      |      |-- 4:5-81 HTRI-R "B/L5/BC4012/CM81/Psg Nr En Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-82 HMS-S/D/M/SA "B/L5/BC4012/MCP82/Psg Nr En Door"
|      |      |-- 4:5-83 HFP-11 "B/L5/BE4011/SD83/Reception"
|      |      |-- 4:5-84 HFP-11 "B/L5/BE4011/SD84/Psg near cabin "
|      |      |-- 4:5-85 HFP-11 "B/L5/BE4011/SD85/Psg near cabin "
|      |      |-- 4:5-86 HFP-11 "B/L5/BE4011/SD86/Cabin 1"
|      |      |-- 4:5-87 HFP-11 "B/L5/BE4011/SD87/Cabin 2"
|      |      |-- 4:5-88 HFP-11 "B/L5/BE4011/SD88/Cabin 3"
|      |      |-- 4:5-89 HFP-11 "B/L5/BE4011/SD89/Sales cabin 1"
|      |      |-- 4:5-90 HFP-11 "B/L5/BE4011/SD90/Sales cabin 2"
|      |      |-- 4:5-91 HFP-11 "B/L5/BE4011/SD91/Sales cabin 3"
|      |      |-- 4:5-93 HFP-11 "B/L5/BE4011/SD93/Conference Room"
|      |      |-- 4:5-94 HFP-11 "B/L5/BE4011/SD94/Psg near confer"
|      |      |-- 4:5-95 HFP-11 "B/L5/BE4011/SD95/Cabin 4"
|      |      |-- 4:5-96 HFP-11 "B/L5/BE4011/SD96/Accounts cabin "
|      |      |-- 4:5-97 HFP-11 "B/L5/BE4011/SD97/stock cabin"
|      |      |-- 4:5-98 HFP-11 "B/L5/BE4011/SD98/cabin 5"
|      |      |-- 4:5-99 HFP-11 "B/L5/BE4011/SD99/Pantry 1"
|      |      |-- 4:5-100 HFP-11 "B/L5/BE4011/SD100/Pantry 2"
|      |      |-- 4:5-101 HFP-11 "B/L5/BE4011/SD101/Stock cabin 1"
|      |      |-- 4:5-102 FDOT421 "B/L5/BE4011/SD102/Stock Cabin 2"
|      |      |-- 4:5-103 HFP-11 "B/L5/BE4011/SD103/Assorters cabi"
|      |      |-- 4:5-104 HFP-11 "B/L5/BE4011/SD104/Assorter cabin"
|      |      |-- 4:5-105 HFP-11 "B/L5/BE4011/SD105/Psg near Pantr"
|      |      |-- 4:5-106 HFP-11 "B/L5/BE4011/SD106/BE Reception"
|      |      |-- 4:5-107 HFP-11 "B/L5/BE4011/SD107/Cabin 6"
|      |      |-- 4:5-108 HMS-S/D/M/SA "B/L5/BE4011/MCP108/BE Reception"
|      |      |-- 4:5-109 HMS-S/D/M/SA "B/L5/BE4011/MCP109/Psg near serv"
|      |      |-- 4:5-110 HTRI-R "B/L5/BE4011/SD110/Server rm AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-113 HFP-11 "B/L5/BC 5021/SD113/Guest Room"
|      |      |-- 4:5-114 HFP-11 "B/L5/BC 5021/SD114/Reception Are"
|      |      |-- 4:5-115 HFP-11 "B/L5/BC 5021/SD115/Pantry"
|      |      |-- 4:5-116 HFP-11 "B/L5/BC 5021/SD116/Polishing Dep"
|      |      |-- 4:5-117 HFP-11 "B/L5/BC 5021/SD117/Cabin 1"
|      |      |-- 4:5-118 HFP-11 "B/L5/BC 5021/SD118/Cabin 2"
|      |      |-- 4:5-119 HFP-11 "B/L5/BC 5021/SD119/Cabin 3"
|      |      |-- 4:5-120 HFP-11 "B/L5/BC 5021/SD120/Cabin 4"
|      |      |-- 4:5-121 HFP-11 "B/L5/BC 5021/SD121/Cabin 5"
|      |      |-- 4:5-122 HFP-11 "B/L5/BC 5021/SD122/Accounts Depa"
|      |      |-- 4:5-123 HFP-11 "B/L5/BC 5021/SD123/Store"
|      |      |-- 4:5-124 HFP-11 "B/L5/BC 5021/SD124/Cabin 6"
|      |      |-- 4:5-125 HTRI-R "B/L5/BC 5021/CM125/Entry Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-126 HMS-S/D/M/SA "B/L5/BC 5021/MCP126/Entry Door"
|      |      |-- 4:5-127 HFP-11 "B/L5/BE4011/SD127/Strong room"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:5 DLC "DLC @ address 5 L5"

```
|      |      |-- 4:5-128 HFP-11 "B/L5/BE4011/SD128/Account cab"
|      |      |-- 4:5-129 HFP-11 "B/L5/BE4011/SD129/Server room"
|      |      |-- 4:5-130 HFP-11 "B/L5/BE4011/SD130/psg nr Server "
|      |      |-- 4:5-131 HFP-11 "B/L5/BE4011/SD131/psg nr account"
|      |      |-- 4:5-132 HFP-11 "B/L5/BE4011/SD132/recep cab Entr"
|      |      |-- 4:5-133 HFP-11 "B/L5/BE4011/SD133/psg nr assorto"
|      |      |-- 4:5-134 HFP-11 "B/L5/BE4011/SD134/assortor cab"
|      |      |-- 4:5-70 HTRI-S "B/L5/5F/MM70/BC5022"
|      |      |-- 4:5-43 HMS-S/D/M/SA "B/L5/EC/4F/MCP43/LIFT LOBBY"
|      |      |-- 4:5-65 HTRI-S "B/L5/4F/MM65/BC4022A"
|      |      |-- 4:5-44 HTRI-R "B/L5/CC/5F/CM44/BC AHU RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 4:5-69 HTRI-S "B/L5/5F/MM69/BC5010-B2"
|      |  |-- CC-5 "Card Cage 5 Slots"
|      |  |-- 4:6 DLC "DLC @ address 6 L6"
|      |  |  |-- 4:6-1 FDOT421 "B/L6/WC/5F/SD1/ELECTRICAL RM SD"
|      |  |  |-- 4:6-2 FDOT421 "B/L6/WC/5F/SD2/CorrNr BW5/S08AFC"
|      |  |  |-- 4:6-3 FDOT421 "B/L6/WC/5F/SD3/CORR NR AW 5061"
|      |  |  |-- 4:6-4 FDOT421 "B/L6/WC/5F/SD4/CORR NR BW5/S08"
|      |  |  |-- 4:6-5 FDOT421 "B/L6/WC/5F/SD5/CORR NR AW5052AFC"
|      |  |  |-- 4:6-6 FDOT421 "B/L6/WC/5F/SD6/CORR NR AW5051/52"
|      |  |  |-- 4:6-7 FDOT421 "B/L6/WC/5F/SD7/CORR NR AW5/S09AF"
|      |  |  |-- 4:6-8 FDOT421 "B/L6/WC/5F/SD8/Corr.Nr AW5042"
|      |  |  |-- 4:6-9 FDOT421 "B/L6/WC/5F/SD9/Corr.Nr AW5110"
|      |  |  |-- 4:6-10 FDOT421 "B/L6/WC/5F/SD10/LIFT LOBBY SD"
|      |  |  |-- 4:6-11 FDOT421 "B/L6/WC/5F/SD11/LIFT LOBBY SD"
|      |  |  |-- 4:6-12 FDOT421 "B/L6/WC/5F/SD12/CorrNr BW5154AFC"
|      |  |  |-- 4:6-13 FDOT421 "B/L6/WC/5F/SD13/CORR NR BW 5154"
|      |  |  |-- 4:6-14 FDOT421 "B/L6/WC/5F/SD14/CORR NR BW 5151"
|      |  |  |-- 4:6-15 FDOT421 "B/L6/WC/5F/SD15/CorrNrBW5/S18AFC"
|      |  |  |-- 4:6-16 FDOT421 "B/L6/WC/5F/SD16/CORR NR BW5/S18"
|      |  |  |-- 4:6-17 FDOT421 "B/L6/WC/5F/SD17/COR NR AHU RM AF"
|      |  |  |-- 4:6-18 FDOT421 "B/L6/WC/5F/SD18/CORR NR AHU RM "
|      |  |  |-- 4:6-19 FDOT421 "L6/B/WC/5F/SD19/CORR NR BW5011AF"
|      |  |  |-- 4:6-20 FDOT421 "B/L6/WC/5F/SD20/CORR NR BW 5011"
|      |  |  |-- 4:6-21 FDOT421 "B/L6/WC/5F/SD21/CorrNr BW5130AFC"
|      |  |  |-- 4:6-22 FDOT421 "B/L6/WC/5F/SD22/CORR NR BW 5130"
|      |  |  |-- 4:6-23 FDOT421 "B/L6/WC/5F/SD23/Corr Nr BW5032"
|      |  |  |-- 4:6-24 FDOT421 "B/L6/WC/5F/SD24/CorrNr BW5032AFC"
|      |  |  |-- 4:6-25 FDOT421 "B/L6/WC/5F/SD25/Corr.Nr BW5051"
|      |  |  |-- 4:6-26 FDOT421 "B/L6/WC/5F/SD26/CorrNr BW5051AFC"
|      |  |  |-- 4:6-27 FDOT421 "B/L6/WC/5F/SD27/AHU RM SD"
|      |  |  |-- 4:6-28 HTRI-R "B/L6/WC/5F/CM28/AHU RM CM"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 4:6-29 HTRI-R "B/L6/WC/5F/CM29/DOOR R NR AHU RM"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 4:6-30 HMS-S/D/M/SA "B/L6/WC/5F/MCP30/FIRE SHAFT L.L."
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:6 DLC "DLC @ address 6 L6"

```
|      |      |      |-- 4:6-31 HTRI-R "B/L6/WC/5F/CM31/FIRE SHAFT L/L"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-32 HTRI-S "B/L6/WC/5F/MM32/FIRE SHAFT L.L."
|      |      |      |-- 4:6-33 HTRI-R "B/L6/WC/5F/CM33/DOOR R NR E.R."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-34 HMS-S/D/M/SA "B/L6/WC/5F/MCP34/STR NR AW 5030"
|      |      |      |-- 4:6-35 HTRI-R "B/L6/WC/5F/CM35/STR NR AW 5030"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-36 HMS-S/D/M/SA "B/L6/WC/5F/MCP36/STR NR BW5032"
|      |      |      |-- 4:6-37 HTRI-R "B/L6/WC/5F/CM37/STR NR BW5032"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-38 FDOT421 "B/L6/WC/6F/SD38/Electric room"
|      |      |      |-- 4:6-39 FDOT421 "B/L6/WC/6F/SD39/CorrNr AW6190AFC"
|      |      |      |-- 4:6-40 FDOT421 "B/L6/WC/6F/SD40/CORR NR AW 6190"
|      |      |      |-- 4:6-41 FDOT421 "B/L6/WC/6F/SD41/CorrNr A6/S11AFC"
|      |      |      |-- 4:6-42 FDOT421 "B/L6/WC/6F/SD42/CORR NR BW6/S11"
|      |      |      |-- 4:6-43 FDOT421 "B/L6/WC/6F/SD43/CORR NR AW6220"
|      |      |      |-- 4:6-44 FDOT421 "B/L6/WC/6F/SD44/CorrNr AW6220AFC"
|      |      |      |-- 4:6-45 FDOT421 "B/L6/WC/6F/SD45/CORR NR AW6240"
|      |      |      |-- 4:6-46 FDOT421 "B/L6/WC/6F/SD46/LIFT LOBBY SD"
|      |      |      |-- 4:6-47 FDOT421 "B/L6/WC/6F/SD47/LIFT LOBBY SD"
|      |      |      |-- 4:6-48 FDOT421 "B/L6/WC/6F/SD48/CORR NR BW S/19"
|      |      |      |-- 4:6-49 FDOT421 "B/L6/WC/6F/SD49/AFC SD Nr BW6081"
|      |      |      |-- 4:6-50 FDOT421 "B/L6/WC/6F/SD50/CORR NR BW6081"
|      |      |      |-- 4:6-51 FDOT421 "B/L6/WC/6F/SD51/CorrNrBW6/S18AFC"
|      |      |      |-- 4:6-52 FDOT421 "B/L6/WC/6F/SD52/Corr Nr BW6-S/18"
|      |      |      |-- 4:6-53 FDOT421 "B/L6/WC/6F/SD53/AFC CORR NR AHU "
|      |      |      |-- 4:6-54 FDOT421 "B/L6/WC/6F/SD54/CORR NR BW6070"
|      |      |      |-- 4:6-55 FDOT421 "B/L6/WC/6F/SD55/CORR NR BW6060"
|      |      |      |-- 4:6-56 FDOT421 "B/L6/WC/6F/SD56/CorrNr BW6040AFC"
|      |      |      |-- 4:6-57 FDOT421 "B/L6/WC/6F/SD57/CORR NR BW6040"
|      |      |      |-- 4:6-58 FDOT421 "B/L6/WC/6F/SD58/AHU RM SD"
|      |      |      |-- 4:6-59 HTRI-R "B/L6/WC/6F/CM59/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-60 HTRI-R "B/L6/WC/6F/CM60/DOOR R CM NR AHU"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-61 HMS-S/D/M/SA "B/L6/WC/6F/MCP61/FIRE SHAFT L.L."
|      |      |      |-- 4:6-62 HTRI-R "B/L6/WC/6F/CM62/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-63 HTRI-S "B/L6/WC/6F/MM63/FIRE SHAFT L.L."
|      |      |      |-- 4:6-64 HTRI-R "B/L6/WC/6F/CM64/DOOR R NR E.R. W"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:6 DLC "DLC @ address 6 L6"

```
|      |      |      |  -- 4:6-65 HMS-S/D/M/SA "B/L6/WC/6F/MCP65/STR NR AW6120"
|      |      |      |  -- 4:6-66 HTRI-R "B/L6/WC/6F/CM66/STR NR AW6120"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |      |  -- 4:6-67 HTRI-S "B/L6/5F/MM67/BC5010A"
|      |      |      |  -- 4:6-68 HTRI-S "B/L6/5F/MM68/BW5110"
|      |      |      |  -- 4:6-75 HTRI-S "B/L6/5F/MM75/BW5041"
|      |      |      |  -- 4:6-76 HTRI-S "B/L6/5F/MM76/BW5032"
|      |      |      |  -- 4:6-77 HTRI-S "B/L6/5F/MM77/BW5120"
|      |      |      |  -- 4:6-78 HTRI-S "B/L6/5F/MM78/BW5031"
|      |      |      |  -- 4:6-80 HTRI-S "B/L6/5F/MM80/BW5130"
|      |      |      |  -- 4:6-87 HTRI-S "B/L6/5F/MM87/BW5151"
|      |      |      |  -- 4:6-94 HTRI-S "B/L6/5F/MM94/AW5080"
|      |      |      |  -- 4:6-95 HTRI-S "B/L6/5F/MM95/AW5051/52"
|      |      |      |  -- 4:6-96 HTRI-S "B/L6/5F/MM96/AW5042"
|      |      |      |  -- 4:6-97 HTRI-S "B/L6/5F/MM97/AW5090"
|      |      |      |  -- 4:6-99 HTRI-S "B/L6/5F/MM99/AW5041"
|      |      |      |  -- 4:6-102 HTRI-S "B/L6/6F/MM102/AW6120"
|      |      |      |  -- 4:6-104 HTRI-S "B/L6/6F/MM104/AW6130"
|      |      |      |  -- 4:6-105 HTRI-S "B/L6/6F/MM105/AW6230"
|      |      |      |  -- 4:6-106 HTRI-S "B/L6/6F/MM106/AW6140"
|      |      |      |  -- 4:6-107 HTRI-S "B/L6/6F/MM107/AW6150"
|      |      |      |  -- 4:6-108 HTRI-S "B/L6/6F/MM108/AW6220"
|      |      |      |  -- 4:6-112 HTRI-S "B/L6/6F/MM112/AW6180"
|      |      |      |  -- 4:6-116 HTRI-S "B/L6/6F/MM116/BW6091"
|      |      |      |  -- 4:6-119 HTRI-S "B/L6/6F/MM119/BW6081"
|      |      |      |  -- 4:6-120 HTRI-S "B/L6/6F/MM120/BW6070"
|      |      |      |  -- 4:6-124 HTRI-S "B/L6/6F/MM124/BW6012"
|      |      |      |  -- 4:6-128 HTRI-S "B/L6/5F/MM128/BW5011"
|      |      |      |  -- 4:6-131 HFP-11 "B/L6/AW6210/SD131/Main cabin"
|      |      |      |  -- 4:6-132 HFP-11 "B/L6/AW6210/SD132/Passage Area"
|      |      |      |  -- 4:6-133 HFP-11 "B/L6/AW6210/SD133/Reception"
|      |      |      |  -- 4:6-134 HTRI-R "B/L6/AW6210/CM134/Passage Area"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |      |  -- 4:6-135 HMS-S/D/M/SA "B/L6/AW6210/MCP135/Passage Area"
|      |      |      |  -- 4:6-136 HFP-11 "B/L6/AW6190/SD136/Main cabin"
|      |      |      |  -- 4:6-137 HFP-11 "B/L6/AW6190/SD137/Account Depart"
|      |      |      |  -- 4:6-138 HFP-11 "B/L6/AW6190/SD138/Reception"
|      |      |      |  -- 4:6-139 HFP-11 "B/L6/AW6190/SD139/Pantry"
|      |      |      |  -- 4:6-140 HTRI-R "B/L6/AW6190/CM140/Passage Area"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |      |  -- 4:6-141 HMS-S/D/M/SA "B/L6/AW6190/MCP141/Passage Area"
|      |      |      |  -- 4:6-142 HFP-11 "B/L6/AW6200/SD142/Main cabin"
|      |      |      |  -- 4:6-143 HFP-11 "B/L6/AW6200/SD143/Account Depart"
|      |      |      |  -- 4:6-144 HFP-11 "B/L6/AW6200/SD144/Reception"
|      |      |      |  -- 4:6-145 HFP-11 "B/L6/AW6200/SD145/Pantry"
|      |      |      |  -- 4:6-146 HTRI-R "B/L6/AW6200/CM146/Passage Area"
|      |      |      |  -- Switch ""
```



```
| | | | | Relay
| | | | | 
| | | | | --- 4:6-147 HMS-S/D/M/SA "B/L6/AW6200/MCP147/Passage Area"
| | | | | --- 4:6-148 HFP-11 "B/L6/AW5061/SD148/Main cabin"
| | | | | --- 4:6-149 HFP-11 "B/L6/AW5061/SD149/Conference Roo"
| | | | | --- 4:6-150 HFP-11 "B/L6/AW5061/SD150/Store Room"
| | | | | --- 4:6-151 HFP-11 "B/L6/AW5061/SD151/Account Depart"
| | | | | --- 4:6-152 HFP-11 "B/L6/AW5061/SD152/Pantry"
| | | | | --- 4:6-153 HFP-11 "B/L6/AW5061/SD153/Passage Area"
| | | | | --- 4:6-154 HFP-11 "B/L6/AW5061/SD154/Reception"
| | | | | --- 4:6-155 HTRI-R "B/L6/AW5061/CM155/Passage Area"
| | | | |   |-- Switch ""
| | | | |   |-- Relay
| | | | | 
| | | | | --- 4:6-156 HMS-S/D/M/SA "B/L6/AW5061/MCP156/Entry door"
| | | | | --- 4:6-157 HFP-11 "B/L6/AW5100/SD157/Passage Area 1"
| | | | | --- 4:6-158 HFP-11 "B/L6/AW5100/SD158/Passage Area 2"
| | | | | --- 4:6-159 HFP-11 "B/L6/AW5100/SD159/Account Depart"
| | | | | --- 4:6-160 HFP-11 "B/L6/AW5100/SD160/Store Room"
| | | | | --- 4:6-161 HFP-11 "B/L6/AW5100/SD161/Main cabin"
| | | | | --- 4:6-162 HTRI-R "B/L6/AW5100/CM162/Entry Door"
| | | | |   |-- Switch ""
| | | | |   |-- Relay
| | | | | 
| | | | | --- 4:6-163 HMS-S/D/M/SA "B/L6/AW5100/MCP163/Entry Door"
| | | | | --- 4:6-164 HFP-11 "B/L6/AW5110/SD164/Main Cabin"
| | | | | --- 4:6-165 HFP-11 "B/L6/AW5110/SD165/Assorter Room"
| | | | | --- 4:6-166 HFP-11 "B/L6/AW5110/SD166/Pantry"
| | | | | --- 4:6-167 HTRI-R "B/L6/AW5110/CM167/Main Cabin"
| | | | |   |-- Switch ""
| | | | |   |-- Relay
| | | | | 
| | | | | --- 4:6-168 HMS-S/D/M/SA "B/L6/AW5110/MCP168/Main Cabin"
| | | | | --- 4:6-189 HFP-11 "B/L6/BW6040/SD189/Psg near Ptry"
| | | | | --- 4:6-190 HFP-11 "B/L6/BW6040/SD190/Cab 1"
| | | | | --- 4:6-191 HFP-11 "B/L6/BW6040/SD191/Cab 2"
| | | | | --- 4:6-192 HFP-11 "B/L6/BW6040/SD192/Cab 2"
| | | | | --- 4:6-193 HMS-S/D/M/SA "B/L6/BW6040/MCP193/Psg near Entr"
| | | | | --- 4:6-199 HFP-11 "B/L6/BW 6011/SD199/Psg Nr Assort"
| | | | | --- 4:6-200 HFP-11 "B/L6/BW 6011/SD200/Assortor Cab1"
| | | | | --- 4:6-201 HFP-11 "B/L6/BW 6011/SD201/Assortor Cab2"
| | | | | --- 4:6-202 HFP-11 "B/L6/BW 6011/SD202/Main Cab"
| | | | | --- 4:6-203 HTRI-R "B/L6/BW 6011/CM203/Entry Dr"
| | | | |   |-- Switch ""
| | | | |   |-- Relay
| | | | | 
| | | | | --- 4:6-204 HMS-S/D/M/SA "B/L6/BW 6011/MCP204/Entry Dr"
| | | | | --- 4:6-205 HTRI-R "B/L6/BW6040/CM205/Psg near Entry"
| | | | |   |-- Switch ""
| | | | |   |-- Relay
| | | | | 
| | | | | --- 4:6-215 HFP-11 "B/L6/BW6030B/SD215/Main cabin"
| | | | | --- 4:6-216 HFP-11 "B/L6/BW6030B/SD216/Main cabin"
| | | | | --- 4:6-217 HFP-11 "B/L6/BW6030B/SD217/Assorter cab"
| | | | | --- 4:6-218 HMS-S/D/M/SA "B/L6/BW6030B/MCP218/Psg nr Entry"
| | | | | --- 4:6-219 HTRI-R "B/L6/BW6030B/CM219/Psg nr Entry "
```

```
| | | Switch ""
| | | |-- Relay
| | | |-- 4:6-224 HFP-11 "B/L6/BW6060/SD224/Main cabin"
| | | |-- 4:6-225 HFP-11 "B/L6/BW6060/SD225/Assorter cabin"
| | | |-- 4:6-226 HFP-11 "B/L6/BW6060/SD226/Psg nr Entranc"
| | | |-- 4:6-227 HMS-S/D/M/SA "B/L6/BW6060/MCP227/Psg nr Entry "
| | | |-- 4:6-228 HTRI-R "B/L6/BW6060/CM228/Psg nr Entry "
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:6-229 HFP-11 "B/L6/BW6030B/SD229/AFC Entry dr "
| | | |-- 4:6-230 HFP-11 "B/L6/BW6030B/SD230/AFC Entry dr "
| | | |-- 4:6-231 HTRI-R "B/L6/BW6050/CM231/AFC Entry Psg"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:6-232 HMS-S/D/M/SA "B/L6/BW6050/MCP232/Entry Psg"
| | | |-- 4:6-233 HFP-11 "B/L6/BW6050/SD233/Main cabin"
| | | |-- 4:6-234 HFP-11 "B/L6/BW6050/SD234/Entry Psg"
| | | |-- 4:6-169 HFP-11 "B/L6/BW6092/SD169/STAFF CAB"
| | | |-- 4:6-170 HFP-11 "B/L6/SD170/BW6092/STAFF CAB"
| | | |-- 4:6-172 HMS-S/D/M/SA "B/L6/MCP172/BW6092/ENTRY DOOR PS"
| | | |-- 4:6-171 HTRI-R "B/L6/CM171/BW6092/AFC ENTRY PSG"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:6-130 HFP-11 "B/L6/BW6050/SD130/Assortor cabin"
| | | |-- 4:6-240 HFP-11 "B/L6/BW5141-42/SD240/Main CAB"
| | | |-- 4:6-241 HFP-11 "B/L6/BW5141-42/SD241/Main CAB"
| | | |-- 4:6-242 HFP-11 "B/L6/BW5141-42/SD242/Account CAB"
| | | |-- 4:6-243 HFP-11 "B/L6/BW5141-42/SD243/Psg NR Acco"
| | | |-- 4:6-244 HFP-11 "B/L6/BW5141-42/SD244/Buyer CAB"
| | | |-- 4:6-245 HFP-11 "B/L6/BW5141-42/SD245/Assortor Ca"
| | | |-- 4:6-246 HFP-11 "B/L6/BW5141-42/SD246/Pantry"
| | | |-- 4:6-247 HFP-11 "B/L6/BW5141-42/SD247/Enyrt Psg"
| | | |-- 4:6-248 HTRI-R "B/L6/BW5141-42/CM248/Enyrt Psg A"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:6-249 HMS-S/D/M/SA "B/L6/BW5141-42/MCP249/Enyrt Psg"
| | | |-- 4:6-117 HTRI-S "B/L6/6F/MM117/BW6020A"
| | |-- 4:7 DLC "DLC @ address 7 L7"
| | | |-- 4:7-1 FDOT421 "B/L7/CC/7F/SD1/ELECTRICAL RM SD"
| | | |-- 4:7-2 FDOT421 "B/L7/CC/7F/SD2/CORR NR BC 7012AF"
| | | |-- 4:7-3 FDOT421 "B/L7/CC/7F/SD3/CORR NR BC 7012"
| | | |-- 4:7-4 HTRI-R "B/L7/CC/7F/CM4/FIRE SHAFT L.L."
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:7-5 HTRI-S "B/L7/CC/7F/MM5/FIRE SHAFT L.L."
| | | |-- 4:7-6 HMS-S/D/M/SA "B/L7/CC/7F/MCP6/FIRE SHAFT L.L."
| | | |-- 4:7-7 FDOT421 "B/L7/CC/7F/SD7/LIFT LOBBY SD"
| | | |-- 4:7-8 FDOT421 "B/L7/CC/7F/SD8/LIFT LOBBY SD"
| | | |-- 4:7-9 FDOT421 "B/L7/EC/7F/SD9/CORR NR AHU AFC"
| | | |-- 4:7-10 FDOT421 "B/L7/EC/7F/SD10/CORR NR AHU"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:7 DLC "DLC @ address 7 L7"

```
|      |      |      |-- 4:7-11 FDOT421 "B/L7/EC/7F/SD11/ELECTRICAL RM SD"
|      |      |      |-- 4:7-12 FDOT421 "B/L7/EC/7F/SD12/AHU RM SD"
|      |      |      |-- 4:7-13 HTRI-R "B/L7/EC/7F/CM13/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-14 FDOT421 "B/L7/EC/7F/SD14/LIFT LOBBY SD"
|      |      |      |-- 4:7-15 HMS-S/D/M/SA "B/L7/EC/7F/MCP15/FIRE SHAFT L.L."
|      |      |      |-- 4:7-16 HTRI-R "B/L7/EC/7F/CM16/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-17 HTRI-S "B/L7/EC/7F/MM17/FIRE SHAFT L.L."
|      |      |      |-- 4:7-20 FDOT421 "B/L7/CC/6F/SD20/ELECTRICAL RM"
|      |      |      |-- 4:7-23 HTRI-R "B/L7/CC/6F/CM23/FIRE HYD SHAFT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-24 HTRI-S "B/L7/CC/6F/MM24/FIRE HYD SHAFT"
|      |      |      |-- 4:7-25 HMS-S/D/M/SA "B/L7/CC/6F/MCP25/FIRE ESCAPE STR"
|      |      |      |-- 4:7-26 FDOT421 "B/L7/CC/6F/SD26/LIFT LOBBY"
|      |      |      |-- 4:7-27 FDOT421 "B/L7/CC/6F/SD27/LIFT LOBBY"
|      |      |      |-- 4:7-29 FDOT421 "B/L7/CC/6F/SD29/AFC CorrNr AHU R"
|      |      |      |-- 4:7-30 FDOT421 "B/L7/CC/6F/SD30/ Corr NR AHU RM"
|      |      |      |-- 4:7-31 FDOT421 "B/L7/EC/6F/SD31/AFC CorrNr ELE R"
|      |      |      |-- 4:7-32 FDOT421 "B/L7/EC/6F/SD32/ Corr NR ELE RM"
|      |      |      |-- 4:7-33 FDOT421 "B/L7/EC/6F/SD33/ELECTRICAL RM"
|      |      |      |-- 4:7-34 FDOT421 "B/L7/EC/6F/SD34/AHU RM"
|      |      |      |-- 4:7-35 HTRI-R "B/L7/EC/6F/CM35/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-36 FDOT421 "B/L7/EC/6F/SD36/LIFT LOBBY"
|      |      |      |-- 4:7-37 HMS-S/D/M/SA "B/L7/EC/6F/MCP37/FIRE ESCAPE STR"
|      |      |      |-- 4:7-38 HTRI-R "B/L7/EC/6F/CM38/FIRE HYD SHAFT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-39 HTRI-S "B/L7/EC/6F/MM39/FIRE HYD SHAFT"
|      |      |      |-- 4:7-42 HTRI-R "B/L7/CC/6F/CM42/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-43 FDOT421 "B/L7/CC/6F/SD43/AHU RM"
|      |      |      |-- 4:7-46 HTRI-R "B/L7/CC/6F/CM46/Corr.Nr Fire Esc"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-56 HMS-S/D/M/SA "B/L7/CC/7F/MCP56/Corr.Nr Fire Es"
|      |      |      |-- 4:7-59 FDOT421 "B/L7/CC/7F/SD59/AHU RM SD"
|      |      |      |-- 4:7-60 HTRI-R "B/L7/CC/7F/CM60/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-72 HTRI-R "B/L7/EC/7F/CM72/FIRE ESCAPE STR "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:7-77 HTRI-S "B/L7/6F/MM77/BE6011"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:7 DLC "DLC @ address 7 L7"

				-- 4:7-79 HTRI-S "B/L7/6F/MM79/BC6021A"
				-- 4:7-98 HFP-11 "B/L7/BC7011/SD98/Psg nr Main Ent"
				-- 4:7-99 HFP-11 "B/L7/BC7011/SD99/AFC Conf 1"
				-- 4:7-100 HFP-11 "B/L7/BC7011/SD100/Export Dept"
				-- 4:7-101 HFP-11 "B/L7/BC7011/SD101/Bank Dept"
				-- 4:7-102 HFP-11 "B/L7/BC7011/SD102/AFC Bank Dept"
				-- 4:7-103 HFP-11 "B/L7/BC7011/SD103/Psg nr Export "
				-- 4:7-104 HFP-11 "B/L7/BC7011/SD104/AFC Export Dep"
				-- 4:7-105 HFP-11 "B/L7/BC7011/SD105/Psg nr Bank De"
				-- 4:7-106 HFP-11 "B/L7/BC7011/SD106/Accounts Dept"
				-- 4:7-107 HFP-11 "B/L7/BC7011/SD107/AFC Accounts D"
				-- 4:7-108 HFP-11 "B/L7/BC7011/SD108/Server Rm"
				-- 4:7-109 HFP-11 "B/L7/BC7011/SD109/AFC Server Rm"
				-- 4:7-110 HFP-11 "B/L7/BC7011/SD110/Asst cab1"
				-- 4:7-111 HFP-11 "B/L7/BC7011/SD111/AFC Asst cab 1"
				-- 4:7-112 HFP-11 "B/L7/BC7011/SD112/Psg nr Asst ca"
				-- 4:7-113 HFP-11 "B/L7/BC7011/SD113/Psg nr Asst ca"
				-- 4:7-114 HFP-11 "B/L7/BC7011/SD114/Psg near Pantr"
				-- 4:7-115 HFP-11 "B/L7/BC7011/SD115/Pantry"
				-- 4:7-116 HFP-11 "B/L7/BC7011/SD116/Pantry"
				-- 4:7-117 HFP-11 "B/L7/BC7011/SD117/AFC Pantry"
				-- 4:7-118 HTRI-R "B/L7/BC7011/CM118/AFC Recp Areal"
				-- Switch ""
				-- Relay
				-- 4:7-119 HFP-11 "B/L7/BC7011/SD119/Electric rm"
				-- 4:7-120 HFP-11 "B/L7/BC7011/SD120/Asst cab 2"
				-- 4:7-121 HFP-11 "B/L7/BC7011/SD121/AFC Asst cab 2"
				-- 4:7-122 FDOT421 "B/L7/BC7011/SD122/Secreatory sta"
				-- 4:7-123 HFP-11 "B/L7/BC7011/SD123/AFC secreatory"
				-- 4:7-124 HFP-11 "B/L7/BC7011/SD124/Audit cab"
				-- 4:7-125 HFP-11 "B/L7/BC7011/SD125/AFC Audit cab"
				-- 4:7-126 HFP-11 "B/L7/BC7011/SD126/CS Cab"
				-- 4:7-127 HFP-11 "B/L7/BC7011/SD127/AFC CS Cab"
				-- 4:7-128 HFP-11 "B/L7/BC7011/SD128/Manager cab"
				-- 4:7-129 HFP-11 "B/L7/BC7011/SD129/AFC Manger cab"
				-- 4:7-130 HFP-11 "B/L7/BC7011/SD130/Psg nr CS Cab"
				-- 4:7-131 HFP-11 "B/L7/BC7011/SD131/Psg nr Manager"
				-- 4:7-132 HFP-11 "B/L7/BC7011/SD132/Reception Area"
				-- 4:7-133 HFP-11 "B/L7/BC7011/SD133/Admin cab"
				-- 4:7-134 HFP-11 "B/L7/BC7011/SD134/AFC Admin cab"
				-- 4:7-135 HFP-11 "B/L7/BC7011/SD135/AFC Conf 1"
				-- 4:7-136 HFP-11 "B/L7/BC7011/SD136/Boiling Rm"
				-- 4:7-137 HFP-11 "B/L7/BC7011/SD137/Psg nr Entry D"
				-- 4:7-138 HFP-11 "B/L7/BC7011/SD138/Psg nr Assort "
				-- 4:7-139 HFP-11 "B/L7/BC7011/SD139/Asst cab 3"
				-- 4:7-140 HFP-11 "B/L7/BC7011/SD140/AFC Asst cab 3"
				-- 4:7-141 HFP-11 "B/L7/BC7011/SD141/Asst cab 4"
				-- 4:7-142 HFP-11 "B/L7/BC7011/SD142/AFC Asst cab 4"
				-- 4:7-143 HFP-11 "B/L7/BC7011/SD143/Boss cab 1"
				-- 4:7-144 HFP-11 "B/L7/BC7011/SD144/AFC Boss cab 1"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:7 DLC "DLC @ address 7 L7"

			-- 4:7-145 HFP-11 "B/L7/BC7011/SD145/Boss cab 2"
			-- 4:7-146 HFP-11 "B/L7/BC7011/SD146/Boss cab3"
			-- 4:7-147 HFP-11 "B/L7/BC7011/SD147/AFC Boss cab 3"
			-- 4:7-148 HFP-11 "B/L7/BC7011/SD148/Boss Cab 4"
			-- 4:7-149 HMS-S/D/M/SA "B/L7/BC 7011/MCP149/Main Entry A"
			-- 4:7-150 HFP-11 "B/L7/BC7011/SD150/Pantry 2"
			-- 4:7-151 HMS-S/D/M/SA "B/L7/BC 7011/MCP151/Staff Entry"
			-- 4:7-152 HFP-11 "B/L7/BC7011/SD152/Psg nr pantry "
			-- 4:7-153 HMS-S/D/M/SA "B/L7/BC 7011/MCP153/Recp Area 1"
			-- 4:7-156 HFP-11 "B/L7/BC6010/SD156/cab 1"
			-- 4:7-157 HFP-11 "B/L7/BC6010/SD157/cab 1"
			-- 4:7-158 HFP-11 "B/L7/BC6010/SD158/cab 1"
			-- 4:7-159 HFP-11 "B/L7/BC6010/SD159/cab 2"
			-- 4:7-160 HFP-11 "B/L7/BC6010/SD160/cab 3"
			-- 4:7-161 HFP-11 "B/L7/BC6010/SD161/cab 3"
			-- 4:7-162 HFP-11 "B/L7/BC6010/SD162/Psg near cab 3"
			-- 4:7-163 HFP-11 "B/L7/BC6010/SD163/cab 4"
			-- 4:7-164 HFP-11 "B/L7/BC6010/SD164/cab 4"
			-- 4:7-165 HFP-11 "B/L7/BC6010/SD165/cab 5"
			-- 4:7-166 HFP-11 "B/L7/BC6010/SD166/cab 6"
			-- 4:7-167 HFP-11 "B/L7/BC6010/SD167/cab 7"
			-- 4:7-168 HFP-11 "B/L7/BC6010/SD168/cab 7"
			-- 4:7-169 HFP-11 "B/L7/BC6010/SD169/Psg near cab 7"
			-- 4:7-170 HFP-11 "B/L7/BC6010/SD170/Psg near cab 8"
			-- 4:7-171 HFP-11 "B/L7/BC6010/SD171/cab 8"
			-- 4:7-172 HFP-11 "B/L7/BC6010/SD172/cab 8"
			-- 4:7-173 HFP-11 "B/L7/BC6010/SD173/Psg nr Kitchen"
			-- 4:7-174 HFP-11 "B/L7/BC6010/SD174/Cab 9"
			-- 4:7-175 HFP-11 "B/L7/BC6010/SD175/Cab 9"
			-- 4:7-176 HFP-11 "B/L7/BC6010/SD176/Psg near cabin"
			-- 4:7-177 HFP-11 "B/L7/BC6010/SD177/Psg near cabin"
			-- 4:7-178 HFP-11 "B/L7/BC6010/SD178/Cabin 16"
			-- 4:7-179 HFP-11 "B/L7/BC6010/SD179/Cabin 17"
			-- 4:7-180 HFP-11 "B/L7/BC6010/SD180/Psg near cab 1"
			-- 4:7-181 HFP-11 "B/L7/BC6010/SD181/cab 10"
			-- 4:7-182 HFP-11 "B/L7/BC6010/SD182/cab 11"
			-- 4:7-183 HFP-11 "B/L7/BC6010/SD183/cab 18"
			-- 4:7-184 HFP-11 "B/L7/BC6010/SD184/Psg near cab 1"
			-- 4:7-185 HFP-11 "B/L7/BC6010/SD185/cab 12"
			-- 4:7-186 HFP-11 "B/L7/BC6010/SD186/Psg near cab 1"
			-- 4:7-187 HFP-11 "B/L7/BC6010/SD187/cab 14"
			-- 4:7-188 HFP-11 "B/L7/BC6010/SD188/cab 15"
			-- 4:7-189 HFP-11 "B/L7/BC6010/SD189/Psg nr cab 15"
			-- 4:7-190 HFP-11 "B/L7/BC6010/SD190/Lunch room"
			-- 4:7-191 HFP-11 "B/L7/BC6010/SD191/Lunch room"
			-- 4:7-192 HFP-11 "B/L7/BC6010/SD192/cab 20"
			-- 4:7-193 HFP-11 "B/L7/BC6010/SD193/cab 20"
			-- 4:7-194 HFP-11 "B/L7/BC6010/SD194/cab 20"
			-- 4:7-195 HFP-11 "B/L7/BC6010/SD195/cab 21"
			-- 4:7-196 HFP-11 "B/L7/BC6010/SD196/cab 22"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:7 DLC "DLC @ address 7 L7"

```
|      |      |      |-- 4:7-197 HFP-11 "B/L7/BC6010/SD197/cab 23"
|      |      |      |-- 4:7-198 HFP-11 "B/L7/BC6010/SD198/cab 23"
|      |      |      |-- 4:7-199 HFP-11 "B/L7/BC6010/SD199/cab 23"
|      |      |      |-- 4:7-200 HFP-11 "B/L7/BC6010/SD200/Psg near cab 3"
|      |      |      |-- 4:7-201 HFP-11 "B/L7/BC6010/SD201/Psg near cab 3"
|      |      |      |-- 4:7-202 HFP-11 "B/L7/BC6010/SD202/cab 24"
|      |      |      |-- 4:7-203 HFP-11 "B/L7/BC6010/SD203/cab 24"
|      |      |      |-- 4:7-204 HFP-11 "B/L7/BC6010/SD204/cab 26"
|      |      |      |-- 4:7-205 HFP-11 "B/L7/BC6010/SD205/Psg near cab 5"
|      |      |      |-- 4:7-206 HFP-11 "B/L7/BC6010/SD206/cab 25"
|      |      |      |-- 4:7-207 HMS-S/D/M/SA "B/L7/BC6010/MCP207/Psg nr cab 15"
|      |      |      |-- 4:7-208 HMS-S/D/M/SA "B/L7/BC6010/MCP208/Psg nr cab 17"
|      |      |      |-- 4:7-209 HTRI-R "B/L7/BC6010/CM209/Psg near BC En"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:7-210 HFP-11 "B/L7/BC7011/SD210/Reception 2"
|      |      |      |-- 4:7-211 HFP-11 "B/L7/BC7011/SD211/AFC Reception "
|      |      |      |-- 4:7-212 HFP-11 "B/L7/BC7011/SD212/Reception 2"
|      |      |      |-- 4:7-213 HFP-11 "B/L7/BC7011/SD213/Conference 2"
|      |      |      |-- 4:7-214 HFP-11 "B/L7/BC7011/SD214/Aditya cab"
|      |      |      |-- 4:7-215 HFP-11 "B/L7/BC7011/SD215/AFC Aditya cab"
|      |      |      |-- 4:7-216 HFP-11 "B/L7/BC7011/SD216/AFC Reception "
|      |      |      |-- 4:7-217 HFP-11 "B/L7/BC7011/SD217/AFC Darpan cab"
|      |      |      |-- 4:7-218 HFP-11 "B/L7/BC7011/SD218/AFC Darpan cab"
|      |      |      |-- 4:7-219 HFP-11 "B/L7/BC7011/SD219/Shreyashbhai c"
|      |      |      |-- 4:7-220 HFP-11 "B/L7/BC7011/SD220/AFC Shreyasbha"
|      |      |      |-- 4:7-221 HFP-11 "B/L7/BC7011/SD221/File store"
|      |      |      |-- 4:7-222 HFP-11 "B/L7/BC7011/SD222/Psg nr File st"
|      |      |      |-- 4:7-223 HFP-11 "B/L7/BC7011/SD223/Psg AFC file s"
|      |      |      |-- 4:7-224 FDOT421 "B/L7/BC7011/SD224/Filling room"
|      |      |      |-- 4:7-225 FDOT421 "B/L7/BC7011/SD225/AFC filling ro"
|      |      |      |-- 4:7-226 HTRI-R "B/L7/BC6010/CM226/Psg nr BW Entr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:7-227 HMS-S/D/M/SA "B/L7/BC6010/MCP227/BC Entry"
|      |      |      |-- 4:7-228 HFPT-11 "B/L7/BC6010/HD228/BC Pantry"
|      |      |      |-- 4:7-229 HFP-11 "B/L7/BC6010/SD229/Psg nr BC Pant"
|      |      |      |-- 4:7-230 HFP-11 "B/L7/BC6010/SD230/BW Pantry"
|      |      |      |-- 4:7-231 HMS-S/D/M/SA "B/L7/BC6010/MCP231/BW Entry"
|      |      |      |-- 4:7-232 HFP-11 "B/L7/BC6010/SD232/BC Reception"
|      |      |      |-- 4:7-80 HTRI-S "B/L7/6F/MM80/BC6021B"
|      |      |      |-- 4:7-81 HTRI-S "B/L7/6F/MM81/BC6021C"
|      |      |      |-- 4:7-236 HMS-S/D/M/SA "B/L7/BC6010/MCP236/FIRE STR "
|      |      |      |-- 4:8 DLC "DLC @ address 8 L8"
|      |      |      |-- 4:8-1 FDOT421 "B/L8/WC/7F/SD1/ELECTRICAL RM"
|      |      |      |-- 4:8-2 FDOT421 "B/L8/WC/7F/SD2/CorrNr BW7030 AFC"
|      |      |      |-- 4:8-3 FDOT421 "B/L8/WC/7F/SD3/CorrNr BW7030"
|      |      |      |-- 4:8-4 FDOT421 "B/L8/WC/7F/SD4/CorrNr BW7012AFC"
|      |      |      |-- 4:8-5 FDOT421 "B/L8/WC/7F/SD5/CORR NR BW7012"
|      |      |      |-- 4:8-6 FDOT421 "B/L8/WC/7F/SD6/LIFT LOBBY SD"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:8 DLC "DLC @ address 8 L8"

			-- 4:8-7 FDOT421 "B/L8/WC/7F/SD7/LIFT LOBBY SD"
			-- 4:8-8 FDOT421 "B/L8/WC/7F/SD8/CorrNr BW9/S19AFC"
			-- 4:8-9 FDOT421 "B/L8/WC/7F/SD9/CORR NR BW7/S19"
			-- 4:8-10 FDOT421 "B/L8/WC/7F/SD10/CORR NR BW7/S18"
			-- 4:8-11 FDOT421 "B/L8/WC/7F/SD11/CORR NR DC2 AFC"
			-- 4:8-12 FDOT421 "B/L8/WC/7F/SD12/CORR NR AHU RM"
			-- 4:8-14 HTRI-S "B/L8/9F/MM14/BW9010"
			-- 4:8-15 FDOT421 "B/L8/WC/7F/SD15/AHU RM SD"
			-- 4:8-16 HTRI-R "B/L8/WC/7F/CM16/AHU RM CM"
			-- Switch ""
			-- Relay
			-- 4:8-17 HMS-S/D/M/SA "B/L8/WC/7F/MCP17/FIRE SHAFT L.L."
			-- 4:8-18 HTRI-R "B/L8/WC/7F/CM18/FIRE SHAFT L.L."
			-- Switch ""
			-- Relay
			-- 4:8-19 HTRI-S "B/L8/WC/7F/MM19/FIRE SHAFT L.L."
			-- 4:8-20 HTRI-R "B/L8/WC/7F/CM20/DOOR R NR L.L."
			-- Switch ""
			-- Relay
			-- 4:8-21 FDOT421 "B/L8/WC/8F/SD21/ELECTRICAL RM SD"
			-- 4:8-22 FDOT421 "B/L8/WC/8F/SD22/CorrNr BW8030AFC"
			-- 4:8-23 FDOT421 "B/L8/WC/8F/SD23/CORR NR BW8030"
			-- 4:8-24 FDOT421 "B/L8/WC/8F/SD24/LIFT LOBBY SD"
			-- 4:8-25 FDOT421 "B/L8/WC/8F/SD25/LIFT LOBBY SD"
			-- 4:8-26 FDOT421 "B/L8/WC/8F/SD26/CORR NR BW 8013"
			-- 4:8-27 FDOT421 "B/L8/WC/8F/SD27/CorrNr BW8012AFC"
			-- 4:8-28 FDOT421 "B/L8/WC/8F/SD28/AHU RM SD"
			-- 4:8-29 HTRI-R "B/L8/WC/8F/CM29/AHU RM CM"
			-- Switch ""
			-- Relay
			-- 4:8-30 HMS-S/D/M/SA "B/L8/WC/8F/MCP30/FIRE SHAFT L.L."
			-- 4:8-31 HTRI-R "B/L8/WC/8F/CM31/FIRE SHAFT L.L."
			-- Switch ""
			-- Relay
			-- 4:8-32 HTRI-S "B/L8/WC/8F/MM32/FIRE SHAFT L.L."
			-- 4:8-33 FDOT421 "B/L8/WC/9F/SD33/ELECTRICAL RM SD"
			-- 4:8-34 FDOT421 "B/L8/WC/9F/SD34/CorrNr BW9022AFC"
			-- 4:8-35 FDOT421 "B/L8/WC/9F/SD35/CORR NR BW9021"
			-- 4:8-36 FDOT421 "B/L8/WC/9F/SD36/LIFT LOBBY SD"
			-- 4:8-37 FDOT421 "B/L8/WC/9F/SD37/LIFT LOBBY SD"
			-- 4:8-38 HMS-S/D/M/SA "B/L8/WC/9F/MCP38/FIRE SHAFT L.L."
			-- 4:8-39 HTRI-R "B/L8/WC/9F/CM39/FIRE SHAFT L.L."
			-- Switch ""
			-- Relay
			-- 4:8-40 HTRI-S "B/L8/WC/9F/MM40/FIRE SHAFT L.L."
			-- 4:8-41 FDOT421 "B/L8/WC/9F/SD41/AHU RM SD"
			-- 4:8-42 HTRI-R "B/L8/WC/9F/CM42/AHU RM CM"
			-- Switch ""
			-- Relay
			-- 4:8-55 HTRI-S "B/L8/7F/MM55/BW7020A"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:8 DLC "DLC @ address 8 L8"

			-- 4:8-60	HTRI-S	"B/L8/7F/MM60/BW7030"
			-- 4:8-61	HTRI-S	"B/L8/8F/MM61/BW8012"
			-- 4:8-62	HTRI-S	"B/L8/8F/MM62/BW8013"
			-- 4:8-63	HTRI-S	"B/L8/8F/MM63/BW8011"
			-- 4:8-64	HTRI-S	"B/L8/8F/MM64/BW8030"
			-- 4:8-65	HTRI-S	"B/L8/8F/MM65/BW8020"
			-- 4:8-67	HTRI-S	"B/L8/9F/MM67/BW9022"
			-- 4:8-70	HFP-11	"B/L8/BW7012/SD70/Reception"
			-- 4:8-71	HFP-11	"B/L8/BW7012/SD71/Psg near Recept"
			-- 4:8-72	HFP-11	"B/L8/BW7012/SD72/Cab 1"
			-- 4:8-73	HFP-11	"B/L8/BW7012/SD73/Cab 2"
			-- 4:8-74	HFP-11	"B/L8/BW7012/SD74/Cab 3"
			-- 4:8-75	HFP-11	"B/L8/BW7012/SD75/Psg nr cab 2"
			-- 4:8-76	HFP-11	"B/L8/BW7012/SD76/Assorter cab 1"
			-- 4:8-77	HFP-11	"B/L8/BW7012/SD77/Assorter cab 2"
			-- 4:8-78	HFP-11	"B/L8/BW7012/SD78/Cab 4"
			-- 4:8-79	HFP-11	"B/L8/BW7012/SD79/Cab 5"
			-- 4:8-80	HFP-11	"B/L8/BW7012/SD80/Cab 6"
			-- 4:8-81	HFP-11	"B/L8/BW7012/SD81/Accounts cab"
			-- 4:8-82	HFP-11	"B/L8/BW7012/SD82/Cab 7"
			-- 4:8-83	HFP-11	"B/L8/BW7012/SD83/Psg nr cab 7"
			-- 4:8-84	HFP-11	"B/L8/BW7012/SD84/Psg nr cab 7"
			-- 4:8-85	HFP-11	"B/L8/BW7012/SD85/Cab 8"
			-- 4:8-86	HFP-11	"B/L8/BW7012/SD86/Conference rm 1"
			-- 4:8-87	HFP-11	"B/L8/BW7012/SD87/Conference rm 2"
			-- 4:8-88	HFP-11	"B/L8/BW7012/SD88/Pantry"
			-- 4:8-89	HFP-11	"B/L8/BW7012/SD89/Main cab 1"
			-- 4:8-90	HFP-11	"B/L8/BW7012/SD90/Main cab 2"
			-- 4:8-91	HFP-11	"B/L8/BW7012/SD91/Cab 9"
			-- 4:8-92	HMS-S/D/M/SA	"B/L8/BW7012/MCP92/Reception"
			-- 4:8-93	HMS-S/D/M/SA	"B/L8/BW7012/MCP93/Psg nr Account"
			-- 4:8-94	HTRI-R	"B/L8/BW7012/CM94/Psg nr Receptio"
			--	Switch	" "
			--	Relay	" "
			-- 4:8-105	HFP-11	"B/L8/BW7011/SD105/Recp Area"
			-- 4:8-106	HFP-11	"B/L8/BW7011/SD106/Accts Departme"
			-- 4:8-107	HFP-11	"B/L8/BW7011/SD107/Cab 1"
			-- 4:8-108	HFP-11	"B/L8/BW7011/SD108/Cab 2"
			-- 4:8-109	HFP-11	"B/L8/BW7011/SD109/Cab 3"
			-- 4:8-110	HFP-11	"B/L8/BW7011/SD110/Grad Del "
			-- 4:8-111	HFP-11	"B/L8/BW7011/SD111/Grad De 2"
			-- 4:8-112	HFP-11	"B/L8/BW7011/SD112/Grad De 3"
			-- 4:8-113	HFP-11	"B/L8/BW7011/SD113/Head Cab"
			-- 4:8-114	HFP-11	"B/L8/BW7011/SD114/Grading Depart"
			-- 4:8-115	HFP-11	"B/L8/BW7011/SD115/Cab 4"
			-- 4:8-116	HFP-11	"B/L8/BW7011/SD116/Main Cab 1"
			-- 4:8-117	HFP-11	"B/L8/BW7011/SD117/Main Cab 2"
			-- 4:8-118	HFP-11	"B/L8/BW7011/SD118/Conf Room"
			-- 4:8-119	HFP-11	"B/L8/BW7011/SD119/Conf Room"
			-- 4:8-120	HFP-11	"B/L8/BW7011/SD120/Psg nr entry"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:8 DLC "DLC @ address 8 L8"

```
|      |      |      |  -- 4:8-121 HTRI-R "B/L8/BW7011/CM121/Entry Dr"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:8-122 HMS-S/D/M/SA "B/L8/BW7011/MCP122/Entry Dr"
|      |      |      |  -- 4:8-123 HFP-11 "B/L8/BW9010A/SD123/Recp"
|      |      |      |  -- 4:8-124 HFP-11 "B/L8/BW9010A/SD124/Accts Cab"
|      |      |      |  -- 4:8-125 HFP-11 "B/L8/BW9010A/SD125/Main Cab"
|      |      |      |  -- 4:8-126 HFP-11 "B/L8/BW9010A/SD126/Main Cab"
|      |      |      |  -- 4:8-127 HFP-11 "B/L8/BW9010A/SD127/Cab 1"
|      |      |      |  -- 4:8-128 HFP-11 "B/L8/BW9010A/SD128/Asst Cab"
|      |      |      |  -- 4:8-129 HFP-11 "B/L8/BW9010A/SD129/Pantry"
|      |      |      |  -- 4:8-130 HFP-11 "B/L8/BW9010A/SD130/Cab 2"
|      |      |      |  -- 4:8-132 HTRI-R "B/L8/BW9010A/CM132/Entry Dr"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:8-133 HMS-S/D/M/SA "B/L8/BW9010A/MCP133/Entry Dr"
|      |      |      |  -- 4:8-134 HFP-11 "B/L8/BW9021/SD134/Recp"
|      |      |      |  -- 4:8-135 HFP-11 "B/L8/BW9021/SD135/Psg near Recp"
|      |      |      |  -- 4:8-136 HFP-11 "B/L8/BW9021/SD136/Cab 1"
|      |      |      |  -- 4:8-137 HFP-11 "B/L8/BW9021/SD137/Cab 2"
|      |      |      |  -- 4:8-138 HFP-11 "B/L8/BW9021/SD138/Cab 3"
|      |      |      |  -- 4:8-139 HFP-11 "B/L8/BW9021/SD139/Cab 4"
|      |      |      |  -- 4:8-140 HFP-11 "B/L8/BW9021/SD140/Psg near Cab 4"
|      |      |      |  -- 4:8-141 HFP-11 "B/L8/BW9021/SD141/Psg near Cab 1"
|      |      |      |  -- 4:8-142 HFP-11 "B/L8/BW9021/SD142/Pantry"
|      |      |      |  -- 4:8-143 HTRI-R "B/L8/BW9021/CM143/Entry Dr"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:8-144 HMS-S/D/M/SA "B/L8/BW9021/MCP144/Entry Dr"
|      |      |      |  -- 4:8-68 HTRI-S "B/L8/9F/MM68/BW9030"
|      |      |      |  -- 4:8-66 HTRI-S "B/L8/8F/MM66/BW8012"
|      |      |      |  -- 4:8-43 FDOT421 "B/L8/WC/SD43/TERACE LIFT RM BW"
|      |      |      |  -- 4:8-44 FDOT421 "B/L8/WC/SD44/TERACE LIFT RM BW"
|      |      |      |  -- 4:8-45 FDOT421 "B/L8/WC/SD45/TERACE LIFT RM BW"
|      |      |      |  -- 4:8-46 FDOT421 "B/L8/WC/SD46/TERACE LIFT RM BW"
|      |      |      |  -- 4:8-47 FDOT421 "B/L8/WC/SD47/TERACE LIFT RM BW"
|      |      |      |  -- 4:8-48 HTRI-R "B/L8/WC/CM48/TERACE LIFT RM BW"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:8-103 HFP-11 "B/L8/BW7011/SD103/Psg Nr Cab1"
|      |      |      |  -- 4:8-104 HFP-11 "B/L8/BW7011/SD104/Pantry Psg Are"
|      |      |      |  -- 4:8-151 HFP-11 "DC2/L8/SD151/SERVER RM"
|      |      |      |  -- 4:8-152 HFP-11 "DC2/L8/SD152/SERVER RM"
|      |      |      |  -- 4:8-153 HFP-11 "DC2/L8/SD153/SERVER RM"
|      |      |      |  -- 4:8-154 HFP-11 "DC2/L8/SD154/SERVER RM"
|      |      |      |  -- 4:8-155 HFP-11 "DC2/L8/SD155/SERVER RM/BFF"
|      |      |      |  -- 4:8-156 HFP-11 "DC2/L8/SD156/SERVER RM/BFF"
|      |      |      |  -- 4:8-157 HFP-11 "DC2/L8/SD157/SERVER RM/BFF"
|      |      |      |  -- 4:8-158 HFP-11 "DC2/L8/SD158/SERVER RM/BFF"
|      |      |      |  -- 4:8-159 HFP-11 "DC2/L8/SD159/NR MAIN ENTRANCE"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:8 DLC "DLC @ address 8 L8"

```
|      |      |      |-- 4:8-160 HFP-11 "DC2/L8/SD160/NOC RM"
|      |      |      |-- 4:8-161 HFP-11 "DC2/L8/SD161/ELECTRICAL RM"
|      |      |      |-- 4:8-162 HFP-11 "DC2/L8/SD162/ELECTRICAL RM"
|      |      |      |-- 4:8-163 HFP-11 "DC2/L8/SD163/ELECTRICAL RM"
|      |      |      |-- 4:8-164 HFP-11 "DC2/L8/SD164/ELECTRICAL RM/BFF"
|      |      |      |-- 4:8-165 HFP-11 "DC2/L8/SD165/ELECTRICAL RM/BFF"
|      |      |      |-- 4:8-166 HTRI-S "DC2/L8/MM166/BUILDING FAS INPUT"
|      |      |      |-- 4:8-167 HTRI-R "DC2/L8/CM167/ FAS INPUT TO BUILD"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:8-168 HTRI-R "DC2/L8/CM168/GSS/Z2"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:8-169 HTRI-S "DC2/L8/MM169/VESDA INPUT"
|      |      |      |-- 4:8-170 HTRI-R "DC2/L8/CM170/GSS/Z1"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:8-171 HTRI-R "DC2/L2/CM171/SERVER RM HOOTER"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:8-172 HMS-S/D/M/SA "DC2/L8/MCP172/SER RM/NR FIRE EXI"
|      |      |      |-- 4:9 DLC "DLC @ address 9 L9"
|      |      |      |-- 4:9-18 FDOT421 "B/L9/CC/8F/SD18/ELECT RM SD"
|      |      |      |-- 4:9-19 FDOT421 "B/L9/CC/8F/SD19/CORR NR E.R.AFC"
|      |      |      |-- 4:9-20 FDOT421 "B/L9/CC/8F/SD20/CORR NR E.R."
|      |      |      |-- 4:9-21 HTRI-R "B/L9/CC/8F/CM21/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:9-22 HTRI-S "B/L9/CC/8F/MM22/FIRE SHAFT L.L."
|      |      |      |-- 4:9-23 HMS-S/D/M/SA "B/L9/CC/8F/MCP23/FIRE SHAFT L.L."
|      |      |      |-- 4:9-24 FDOT421 "B/L9/CC/8F/SD24/LIFT LOBBY SD"
|      |      |      |-- 4:9-25 FDOT421 "B/L9/CC/8F/SD25/LIFT LOBBY SD"
|      |      |      |-- 4:9-26 FDOT421 "B/L9/CC/8F/SD26/CorrNrBC8/S04AFC"
|      |      |      |-- 4:9-27 FDOT421 "B/L9/CC/8F/SD27/CORR NR BC8/S04"
|      |      |      |-- 4:9-28 FDOT421 "B/L9/EC/8F/SD28/CORR NR BE8/S23"
|      |      |      |-- 4:9-29 FDOT421 "B/L9/EC/8F/SD29/CORR NR BE8/S23"
|      |      |      |-- 4:9-30 FDOT421 "B/L9/EC/8F/SD30/AHU RM SD"
|      |      |      |-- 4:9-31 HTRI-R "B/L9/EC/8F/CM31/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:9-32 FDOT421 "B/L9/EC/8F/SD32/ELECT RM SD"
|      |      |      |-- 4:9-33 FDOT421 "B/L9/EC/8F/SD33/LIFT LOBBY SD"
|      |      |      |-- 4:9-34 HMS-S/D/M/SA "B/L9/EC/8F/MCP34/FIRE SHAFT L.L."
|      |      |      |-- 4:9-35 HTRI-R "B/L9/EC/8F/CM35/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:9-36 HTRI-S "B/L9/EC/8F/MM36/FIRE SHAFT L.L."
|      |      |      |-- 4:9-37 HTRI-R "B/L9/CC/9F/CM37/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:9 DLC "DLC @ address 9 L9"

```
|      |      |      |-- 4:9-38 HTRI-S "B/L9/CC/9F/MM38/FIRE SHAFT L.L."
|      |      |      |-- 4:9-39 HMS-S/D/M/SA "B/L9/CC/9F/MCP39/FIRE SHAFT L.L."
|      |      |      |-- 4:9-40 FDOT421 "B/L9/CC/9F/SD40/CORR NR E.R.AFC"
|      |      |      |-- 4:9-41 FDOT421 "B/L9/CC/9F/SD41/CORR NR E.R."
|      |      |      |-- 4:9-42 FDOT421 "B/L9/CC/9F/SD42/ELECT RM SD"
|      |      |      |-- 4:9-43 FDOT421 "B/L9/CC/9F/SD43/LIFT LOBBY SD"
|      |      |      |-- 4:9-44 FDOT421 "B/L9/CC/9F/SD44/LIFT LOBBY SD"
|      |      |      |-- 4:9-45 FDOT421 "B/L9/CC/9F/SD45/AHU RM SD"
|      |      |      |-- 4:9-46 HTRI-R "B/L9/CC/9F/CM46/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-47 FDOT421 "B/L9/EC/9F/SD47/ELECT RM SD"
|      |      |      |-- 4:9-48 FDOT421 "B/L9/EC/9F/SD48/CORR NR E.R."
|      |      |      |-- 4:9-49 FDOT421 "B/L9/EC/9F/SD49/AHU RM SD"
|      |      |      |-- 4:9-50 HTRI-R "B/L9/EC/9F/CM50/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-51 FDOT421 "B/L9/EC/9F/SD51/LIFT LOBBY SD"
|      |      |      |-- 4:9-52 HMS-S/D/M/SA "B/L9/EC/9F/MCP52/FIRE SHAFT L.L."
|      |      |      |-- 4:9-53 HTRI-R "B/L9/EC/9F/CM53/FIRE SHAFT L.L."
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-54 HTRI-S "B/L9E/9F/MM 54/FIRE SHAFT "
|      |      |      |-- 4:9-55 HMS-S/D/M/SA "B/L9/EC/9F/MCP55/FIRE ESCP STR C"
|      |      |      |-- 4:9-56 FDOT421 "B/L9/CC/8F/SD56/AHU RM SD"
|      |      |      |-- 4:9-57 HTRI-R "B/L9/CC/8F/CM57/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-60 HTRI-S "B/L9/8F/MM60/BE8020"
|      |      |      |-- 4:9-61 HTRI-S "B/L9/8F/MM61/BE8030"
|      |      |      |-- 4:9-62 HTRI-S "B/L9/9F/MM62/BC9010"
|      |      |      |-- 4:9-64 FDOT421 "B/L9/BC/SD64/BC Lift RM Terrace"
|      |      |      |-- 4:9-65 FDOT421 "B/L9/BC/SD65/BC Lift RM Terrace"
|      |      |      |-- 4:9-66 FDOT421 "B/L9/BC/SD66/BC Lift RM Terrace"
|      |      |      |-- 4:9-67 HTRI-R "B/L9/BC/CM67/BC lift RM Terrace"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-68 FDOT421 "B/L9/BE/SD68/BE Lift RM Terrace"
|      |      |      |-- 4:9-69 HTRI-R "B/L9/BE/CM69/BE LIFT RM Terrace"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-70 HTRI-R "B/L9/EC/9F/CM70/FIRE ESCP STR CA"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-63 FDOT421 "B/L9/BC/SD63/BC Lift RM Terrace"
|      |      |      |-- 4:9-71 HTRI-S "B/L9/8F/MM71/BC8010 B/C"
|      |      |      |-- 4:10 NIC-C(XNet) "NIC_Xnet @ address 10"
|      |      |      |-- 4:249 PSC-12 "PSC-12 @ address 1"
|      |      |      |      |-- 4:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      |      |      |      |-- 4:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local
CAB-2 "CAB-2 Enclosure #1"

```
|      |-- Inner Door
|      |-- 4:253 PMI-D "PMI-D Tower B -4"
|
|-- 5 Desigo Fire Safety Modular "BDB TOWER C" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-2 "CAB-2 Enclosure #1"
|  |  |-- CC-5 "Card Cage 5 Slots"
|  |  |  |-- 5:1 DLC "DLC @ address 1 L1"
|  |  |  |  |-- 5:1-1 HMS-S/D/M/SA "C/L1/CE/GND/MCP1/LIFT LOBBY"
|  |  |  |  |-- 5:1-2 HTRI-R "C/L1/CE/GND/CM2/SHAFT"
|  |  |  |  |  |-- Switch ""
|  |  |  |  |  |-- Relay
|  |  |  |  |-- 5:1-3 HTRI-S "C/L1/CE/GND/MM3/SHAFT"
|  |  |  |  |-- 5:1-4 HFP-11 "C/L1/CE/GND/SD4/ELEC ROOM"
|  |  |  |  |-- 5:1-5 HFP-11 "C/L1/CE/SD 5/LIFT LOBBY"
|  |  |  |  |-- 5:1-6 HFP-11 "C/L1/CE/SD 6/LIFT LOBBY"
|  |  |  |  |-- 5:1-7 HFP-11 "C/L1/CE/SD 7/LIFT LOBBY"
|  |  |  |  |-- 5:1-8 HFP-11 "C/L1/CE/SD 8/LIFT LOBBY"
|  |  |  |  |-- 5:1-9 HFP-11 "C/L1/CE/SD 9/LIFT LOBBY"
|  |  |  |  |-- 5:1-10 HTRI-R "C/L1/CE/GND/CM10/AHU RM"
|  |  |  |  |  |-- Switch ""
|  |  |  |  |  |-- Relay
|  |  |  |  |-- 5:1-11 HFP-11 "C/L1/CE/GND/SD11/AHU RM"
|  |  |  |  |-- 5:1-12 HMS-S/D/M/SA "C/L1/CC/GND/MCP12/LIFT LOBBY"
|  |  |  |  |-- 5:1-13 HTRI-R "C/L1/CC/GND/CM13/SHAFT"
|  |  |  |  |  |-- Switch ""
|  |  |  |  |  |-- Relay
|  |  |  |  |-- 5:1-14 HTRI-S "C/L1/CC/GND/MM14/SHAFT"
|  |  |  |  |-- 5:1-15 HFP-11 "C/L1/CC/GND/SD15/ELEC ROOM"
|  |  |  |  |-- 5:1-16 HFP-11 "C/L1/CC/SD 16/LIFT LOBBY"
|  |  |  |  |-- 5:1-17 HFP-11 "C/L1/CC/SD 17/LIFT LOBBY"
|  |  |  |  |-- 5:1-18 HTRI-R "C/L1/CC/GND/CM18/AHU RM"
|  |  |  |  |  |-- Switch ""
|  |  |  |  |  |-- Relay
|  |  |  |  |-- 5:1-19 HFP-11 "C/L1/CC/GND/SD19/AHU RM"
|  |  |  |  |-- 5:1-20 HMS-S/D/M/SA "C/L1/CW/GND/MCP20/LIFT LOBBY"
|  |  |  |  |-- 5:1-21 HTRI-R "C/L1/CW/GND/CM21/SHAFT"
|  |  |  |  |  |-- Switch ""
|  |  |  |  |  |-- Relay
|  |  |  |  |-- 5:1-22 HTRI-S "C/L1/CW/GND/MM22/SHAFT"
|  |  |  |  |-- 5:1-23 HFP-11 "C/L1/CW/GND/SD23/ELEC ROOM"
|  |  |  |  |-- 5:1-24 HFP-11 "C/L1/CW/SD24/LIFT LOBBY"
|  |  |  |  |-- 5:1-25 HFP-11 "C/L1/CW/SD25/LIFT LOBBY"
|  |  |  |  |-- 5:1-26 HFP-11 "C/L1/CW/SD26/GND/LIFT LOBBY"
|  |  |  |  |-- 5:1-27 HTRI-R "C/L1/CW/GND/CM27/AHU RM"
```