

Project

```
|-- Global System Flags
|-- 3 Desigo Fire Safety Modular "BDB DC-1 GLOBAL PANEL" Local
|   |-- System Flags
|   |-- History Log
|   |-- Behavior
|   |-- Voice
|   |-- Maintenance
|   |-- Field Devices
|   |-- Miscellaneous
|   |-- CAB-1 "CAB-1 Enclosure #1"
|       |-- CC-5 "Card Cage 5 Slots"
|           |-- 3:1 NIC-C(XNet) "NIC_Xnet @ address 1"
|               |-- 3:249 PSC-12 "POWER SUPPLY"
|                   |-- 3:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|                   |-- 3:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|                   |-- 3:249-3 Relay "Relay -3"
|               |-- Inner Door
|                   |-- 3:253 PMI-D "PMI-D Global Panel -1"
|-- 2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local
|   |-- System Flags
|   |-- History Log
|   |-- Behavior
|   |-- Voice
|   |-- Maintenance
|   |-- Field Devices
|   |-- Miscellaneous
|   |-- CAB-1 "CAB-1 Enclosure #1"
|       |-- CC-5 "Card Cage 5 Slots"
|           |-- 2:1 DLC "DLC @LOOP 1"
|               |-- 2:1-1 HFP-11 "DC1/L1/PR-SD-AFC-1"
|               |-- 2:1-2 HFP-11 "DC1/L1/PR-SD-2"
|               |-- 2:1-3 HTRI-R "DC1/L1/PR-CM ACS-3"
|               |-- Switch ""
|               |-- Relay
|               |-- 2:1-4 HFP-11 "DC1/L1/PR-CM ACS-3"
|               |-- 2:1-5 HFP-11 "DC1/L1/OP-SD-5"
|               |-- 2:1-6 HFP-11 "DC1/L1/OP-SD-AFC-6"
|               |-- 2:1-7 HFP-11 "DC1/L1/OP-SD-AFC-7"
|               |-- 2:1-8 HFP-11 "DC1/L1/OP-SD-AFC-8"
|               |-- 2:1-9 HFP-11 "DC1/L1/ME-SD-AFC-9"
|               |-- 2:1-10 HFP-11 "DC1/L1/ME-SD-10"
|               |-- 2:1-11 HTRI-S "DC1/L2/RECP-MM "
|               |-- 2:1-12 HTRI-R "DC1/L2/RECP-CM HTR-12"
|               |-- Switch ""
|               |-- Relay
|               |-- 2:1-13 HMS-S/D/M/SA "DC1/L1/RECP-MCP-13"
|               |-- 2:1-14 HFP-11 "DC1/L1/RECP-SD-14"
|               |-- 2:1-15 HFP-11 "DC1/L1/RECP-SD-AFC-15"
|               |-- 2:1-16 HFP-11 "DC1/L1/TP-SD-16"
|               |-- 2:1-17 HFP-11 "DC1/L1/TP-SD-AFC-17"
|               |-- 2:1-18 HFP-11 "DC1/L1/PNTY-SD-18"
|               |-- 2:1-19 HFPT-11 "DC1/L1/PNTY-HD-19"
|               |-- 2:1-20 HTRI-S "DC1/PNTY-MM LSA-20"
```

2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local
CAB-1 "CAB-1 Enclosure #1"
CC-5 "Card Cage 5 Slots"
2:1 DLC "DLC @LOOP 1"

			-- 2:1-21 HFP-11 "DC1/L2/RR-SD-BFT-21"
			-- 2:1-22 HFP-11 "DC1/L1/PNTY-SD-AFC-22"
			-- 2:1-23 HMS-S/D/M/SA "DC1/L1/NOC R-MCP-23"
			-- 2:1-24 HTRI-R "DC1/L1/NOC R-CM HTR-24"
			-- Switch ""
			-- Relay
			-- 2:1-25 HFP-11 "DC1/L1/NOC R-SD-AFC-25"
			-- 2:1-26 HFP-11 "DC1/L1/INOC R-SD-26"
			-- 2:1-27 HFP-11 "DC1/L1/NOC R-SD-AFC-27"
			-- 2:1-28 HFP-11 "DC1/L1/RRP-SD-AFC-28"
			-- 2:1-29 HFP-11 "DC1/L1/IBMS R-SD-AFC-29"
			-- 2:1-30 HFP-11 "DC1/L1/IBMS R-SD-30"
			-- 2:1-31 HFP-11 "DC1/L1/RRP-SD-31"
			-- 2:1-33 HTRI-R "DC1/L1/ NOC R-CM ACS-33"
			-- Switch ""
			-- Relay
			-- 2:1-34 HTRI-R "DC1/L1/ IBMS R-CM ACS-34"
			-- Switch ""
			-- Relay
			-- 2:1-35 HTRI-R "DC1/L1/PNTY-CM ACS-35"
			-- Switch ""
			-- Relay
			-- 2:1-36 HTRI-R "DC1/L1/ME-CM ACS-36"
			-- Switch ""
			-- Relay
			-- 2:1-37 HFP-11 "DC1/L2/COMCP-SD-37"
			-- 2:1-38 HFP-11 "DC1/L2/COMCP-SD-38"
			-- 2:1-39 HMS-S/D/M/SA "DC1/L2/OER-MCP-39"
			-- 2:1-40 HTRI-R "DC1/L2/OER-CM-HTR-40"
			-- Switch ""
			-- Relay
			-- 2:1-41 HFP-11 "DC1/L2/ELE-SD-41"
			-- 2:1-42 HTRI-S "DC1/L2/ELE-MM LSA-42"
			-- 2:1-43 HTRI-R "DC1/L2/ELE-CM HTR-43"
			-- Switch ""
			-- Relay
			-- 2:1-44 HMS-S/D/M/SA "DC1/L2/ELE-MCP-44"
			-- 2:1-45 HMS-S/D/M/SA "DC1/L2/RRE-MCP-45"
			-- 2:1-46 HFP-11 "DC1/L2/RRE-SD-46"
			-- 2:1-47 HFP-11 "DC1/L2/RRE-SD-AFC-47"
			-- 2:1-48 HTRI-S "DC1/L2/RRE-MM LSA-48"
			-- 2:1-49 HTRI-R "DC1/L2/RR-CM HTR-49"
			-- Switch ""
			-- Relay
			-- 2:1-50 HFP-11 "DC1/L2/RR-SD-50"
			-- 2:1-51 HFP-11 "DC1/L2/RR-SD-AFC-51"
			-- 2:1-52 HMS-S/D/M/SA "DC1/L2/RR-MCP-52"
			-- 2:1-53 HTRI-R "DC1/L2/RR-CM HTR-53"
			-- Switch ""
			-- Relay

2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local
CAB-1 "CAB-1 Enclosure #1"
CC-5 "Card Cage 5 Slots"
2:1 DLC "DLC @LOOP 1"

			-- 2:1-54 HFP-11 "DC1/L2/RR-SD-54"
			-- 2:1-55 HFP-11 "DC1/L2/RR-SD-AFC-55"
			-- 2:1-56 HFP-11 "DC1/L2/RR-SD-BFT-56"
			-- 2:1-57 HFP-11 "DC1/L1/PNTY-SD-AFC-57"
			-- 2:1-58 HFP-11 "DC1/L2/RR-SD-BFT-58"
			-- 2:1-59 HFP-11 "DC1/L2/ELR-SD-BFT-59"
			-- 2:1-60 HFP-11 "DC1/L2/ELR-SD-BFT-60"
			-- 2:1-61 HFP-11 "DC1/L2/BTR-SD-BFT-61"
			-- 2:1-62 HFP-11 "DC1/L2/OMR-SD-BFT-62"
			-- 2:1-63 HFP-11 "DC1/L2.MR-SD-BFT-63"
			-- 2:1-64 HMS-S/D/M/SA "DC1/L2/MR-MCP-64"
			-- 2:1-65 HFP-11 "DC1/L2/MR-SD-65"
			-- 2:1-66 HFP-11 "DC1/L2/BTR-SD-66"
			-- 2:1-67 HMS-S/D/M/SA "DC1/L2/BTR-MCP-67"
			-- 2:1-68 HTRI-R "DC1/L2/O BTR-CM ASC-68"
			-- Switch ""
			-- Relay
			-- 2:1-69 HFP-11 "DC1/L2/0 BTR-SD-AFC-69"
			-- 2:1-70 HFP-11 "DC1/L2/ELR-SD-70"
			-- 2:1-71 HFP-11 "DC1/L2/ELR-SD-71"
			-- 2:1-72 HFP-11 "DC1/L2/AHU-SD-72"
			-- 2:1-73 HFP-11 "DC1/L2/AHU-SD-73"
			-- 2:1-74 HTRI-R "DC1/L2/AHU-CM AHU1 TRIP-74"
			-- Switch ""
			-- Relay
			-- 2:1-75 HTRI-R "DC1/L2/AHU-CM AHU2 TRIP-75"
			-- Switch ""
			-- Relay
			-- 2:1-76 HTRI-S "DC1/L2/AHU-MM LSA-76"
			-- 2:1-77 HMS-S/D/M/SA "DC1/L2/AHU-MCP-77"
			-- 2:1-78 HTRI-R "DC1/L2/AHU-CM HTR-78"
			-- Switch ""
			-- Relay
			-- 2:1-79 HFP-11 "DC1/L2/AHU-SD-79"
			-- 2:1-80 HFP-11 "DC1/L2/AHU-SD-80"
			-- 2:1-81 HTRI-R "DC1/L2/AHU-CM HTR-81"
			-- Switch ""
			-- Relay
			-- 2:1-82 HMS-S/D/M/SA "DC1/L2/AHU-MCP-82"
			-- 2:1-83 HTRI-R "DC1/L2/AHU-CM AHU3 TRIP-83"
			-- Switch ""
			-- Relay
			-- 2:1-84 HTRI-R "DC1/L2/AHU-CM AHU4 TRIP-84"
			-- Switch ""
			-- Relay
			-- 2:1-85 HTRI-S "DC1/L2/AHU-MM LSA-85"
			-- 2:1-86 HMS-S/D/M/SA "DC1/L2/AHU-MCP-86"
			-- 2:1-87 HTRI-R "DC1/L2/OMR-CM HTR-87"
			-- Switch ""
			-- Relay

2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local
CAB-1 "CAB-1 Enclosure #1"
CC-5 "Card Cage 5 Slots"
2:1 DLC "DLC @LOOP 1"

			-- 2:1-88 HFP-11 "DC1/L2/OMR-SD-88"
			-- 2:1-89 HFP-11 "DC1/L2/COMC-SD-89"
			-- 2:1-90 HFP-11 "DC1/L2/COMC-SD-AFC-90"
			-- 2:1-91 HTRI-S "DC1/L2/BE-MM LSA-91"
			-- 2:1-92 HFP-11 "DC1/L2/BE-SD-92"
			-- 2:1-93 HMS-S/D/M/SA "DC1/L2/COMC-MCP-93"
			-- 2:1-94 HTRI-R "DC1/L2/COMC-CM HTR-94"
			-- Switch ""
			-- Relay
			-- 2:1-95 HFP-11 "DC1/L2/COMC-SD-AFC-95"
			-- 2:1-96 HFP-11 "DC1/L2/COMC-SD-96"
			-- 2:1-97 HFP-11 "DC1/L2/COMC-SD-AFC-97"
			-- 2:1-98 HFP-11 "DC1/L2/COMC-SD-98"
			-- 2:1-99 HFP-11 "DC1/L2/COMC-SD-AFC-99"
			-- 2:1-100 HFP-11 "DC1/L2/COMC-SD-AFC-100"
			-- 2:1-101 HFP-11 "DC1/L2/COMC-SD-101"
			-- 2:1-102 HTRI-R "DC1/L2/COMC-CM HTR-102"
			-- Switch ""
			-- Relay
			-- 2:1-103 HFP-11 "DC1/L2/COMC-SD-AFC-103"
			-- 2:1-104 HFP-11 "DC1/L2/COMC-SD-104"
			-- 2:1-105 HMS-S/D/M/SA "DC1/L2/COMC-MCP-105"
			-- 2:1-106 HFP-11 "DC1/L2/COMC-SD-BFT-106"
			-- 2:1-107 HFP-11 "DC1/L2/COMC-SD-BFT-107"
			-- 2:1-108 HFP-11 "DC1/L2/COMC-SD-BFT-108"
			-- 2:1-109 HFP-11 "DC1/L2/COMC-SD-BFT-109"
			-- 2:1-110 HFP-11 "DC1/L2/COMC-SD-BFT-110"
			-- 2:1-111 HFP-11 "DC1/L2/COMC-SD-BFT-111"
			-- 2:1-112 HFP-11 "DC1/L2/COMC-SD-BFT-112"
			-- 2:1-113 HFP-11 "DC1/L2/IBMS R-SD-BFT-113"
			-- 2:1-114 HFP-11 "DC1/L2/INOC R-SD-BFT-114"
			-- 2:1-115 HFP-11 "DC1/L2/RPB-SD-BFT-115"
			-- 2:1-116 HFP-11 "DC1/L2/OBTR-SD-AFC-116"
			-- 2:1-117 HFP-11 "DC1/L2/OBTR-SD-117"
			-- 2:1-118 HTRI-R "DC1/L2/PW-CM GSS CYL 1-118"
			-- Switch ""
			-- Relay
			-- 2:1-119 HTRI-S "DC1/L2/PW-MM RACK RM VESDA-119"
			-- 2:1-120 HTRI-S "DC1/L2/PW-MM ELEC RM VESDA-120"
			-- 2:1-121 HTRI-R "DC1/L2/PW-CM GSS CLY 2-121"
			-- Switch ""
			-- Relay
			-- 2:1-122 HTRI-S "DC1/L2/PW-MM GSS CLY 2-122"
			-- 2:1-123 HTRI-S "DC1/L2/PW-MM GSS CLY 2-123"
			-- 2:1-124 HTRI-R "DC1/L2/PW-CM GSS CYL 1-124"
			-- Switch ""
			-- Relay
			-- 2:1-125 HTRI-R "DC1/L2/PW-CM GSS CYL 1-125"
			-- Switch ""
			-- Relay

```
2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local
  CAB-1 "CAB-1 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
```

```
|      |  |-- 2:2 NIC-C(XNet) "NIC_Xnet @ address 2"
|      |  |-- 2:249 PSC-12 "POWER SUPPLY"
|      |  |-- 2:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      |  |-- 2:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      |  |-- Inner Door
|      |  |-- 2:253 PMI-D "PMI-D @ address 253"
|-- 4 Desigo Fire Safety Modular "BDB TOWER B" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-2 "CAB-2 Enclosure #1"
|    |-- CC-5 "Card Cage 5 Slots"
|      |-- 4:1 DLC "DLC @ address 1 L1 "
|        |-- 4:1-1 FDOT421 "B/L1/CC/1F/SD4/LIFT LOBBY"
|        |-- 4:1-2 FDOT421 "B/L1/CC/1F/SD2/COR NR BC1010AFC"
|        |-- 4:1-3 FDOT421 "B/L1/CC/1F/SD3/CORR BC-1010"
|        |-- 4:1-4 FDOT421 "B/L1/CC/1F/SD4/LIFT LOBBY"
|        |-- 4:1-5 FDOT421 "B/L1/CC/1F/SD5/LIFT LOBBY"
|        |-- 4:1-6 HMS-S/D/M/SA "B/L1/CC/1F/MCP6/LIFT LOBBY STR"
|        |-- 4:1-7 HTRI-R "B/L1/CC/1F/CM7/FIRE HYD SHAFT"
|        |  |-- Switch ""
|        |  |-- Relay
|        |-- 4:1-8 HTRI-S "B/L1/CC/1F/MM8/FIRE HYD SHAFT"
|        |-- 4:1-9 HTRI-R "B/L1/CC/1F/CM9/DOOR RELEASE UNIT"
|        |  |-- Switch ""
|        |  |-- Relay
|        |-- 4:1-10 FDOT421 "B/L1/BC/1F/SD10/AFC Cor Nr AHURM"
|        |-- 4:1-11 FDOT421 "B/L1/EC/1F/SD11/CORR Nr BE1100"
|        |-- 4:1-12 FDOT421 "B/L1/EC/1F/SD12/CORR Nr BE 1110 "
|        |-- 4:1-13 FDOT421 "B/L1/EC/1F/SD13/CorrNr BE1120AFC"
|        |-- 4:1-14 FDOT421 "B/L1/EC/1F/SD14/CORR Nr BE1120"
|        |-- 4:1-15 FDOT421 "B/L1/EC/1F/SD15/CORR NR BE1130"
|        |-- 4:1-16 FDOT421 "B/L1/EC/1F/SD16/CorrNrElectRmAfc"
|        |-- 4:1-17 FDOT421 "B/L1/EC/1F/SD17/ELECT RM"
|        |-- 4:1-18 FDOT421 "B/L1/EC/1F/SD18/AHU RM"
|        |-- 4:1-19 HTRI-R "B/L1/EC/1F/CM19/AHU RM"
|        |  |-- Switch ""
|        |  |-- Relay
|        |-- 4:1-20 HTRI-R "B/L1/EC/1F/CM20/DOOR RELEASE UN"
|        |  |-- Switch ""
|        |  |-- Relay
|        |-- 4:1-21 FDOT421 "B/L1/EC/1F/SD21/LIFT LOBBY"
|        |-- 4:1-22 HMS-S/D/M/SA "B/L1/EC/1F/MCP22/FIRE ESCAPE ST"
|        |-- 4:1-23 HTRI-R "B/L1/EC/1F/CM23/FIRE HYD SHAFT"
|        |  |-- Switch ""
|        |  |-- Relay
```