

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:15 DLC "DLC LOOP 12"

```
|      |      |-- 6:15-150 HMS-S/D/M/SA "D/L12/DW2320/MCP150/Entry dr Psg"
|      |      |-- 6:15-151 HFP-11 "D/L12/DW1070/SD151/Cab 1"
|      |      |-- 6:15-152 HFP-11 "D/L12/DW1070/SD152/Reception are"
|      |      |-- 6:15-153 HFP-11 "D/L12/DW1070/SD153/Pantry"
|      |      |-- 6:15-154 HTRI-R "D/L12/DW1070/CM154/Entry dr psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-155 HMS-S/D/M/SA "D/L12/DW1070/MCP155/Entry dr psg"
|      |      |-- 6:15-156 HFP-11 "D/L12/DW4101/SD156/Main cab"
|      |      |-- 6:15-157 HFP-11 "D/L12/DW4101/SD157/Main cab"
|      |      |-- 6:15-158 HFP-11 "D/L12/DW4101/SD158/Assorter cab "
|      |      |-- 6:15-159 HFP-11 "D/L12/DW4101/SD159/Assorter cab "
|      |      |-- 6:15-160 HFP-11 "D/L12/DW4101/SD160/Assorter cab "
|      |      |-- 6:15-161 HFP-11 "D/L12/DW4101/SD161/Accounts cab"
|      |      |-- 6:15-162 HFP-11 "D/L12/DW4101/SD162/Psg nr Acc ca"
|      |      |-- 6:15-163 HFPT-11 "D/L12/DW4101/HD163/Pantry psg"
|      |      |-- 6:15-164 HTRI-R "D/L12/DW4101/CM164/Entry dr psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-165 HMS-S/D/M/SA "D/L12/DW4101/MCP165/Entry dr psg"
|      |      |-- 6:15-167 HFP-11 "D/L12/DW4112/SD167/Main cab"
|      |      |-- 6:15-168 HFP-11 "D/L12/DW4112/SD168/Assorter cab"
|      |      |-- 6:15-169 HFP-11 "D/L12/DW4112/SD169/Assorter cab"
|      |      |-- 6:15-170 HFPT-11 "D/L12/DW4112/HD170/Pantry"
|      |      |-- 6:15-171 HTRI-R "D/L12/DW4112/CM171/AFC Pantry"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-172 HMS-S/D/M/SA "D/L12/DW4112/MCP172/Psg nr pantr"
|      |      |-- 6:15-173 HFP-11 "D/L12/DW4260/SD173/Main cab"
|      |      |-- 6:15-174 HFP-11 "D/L12/DW4260/SD174/Assorter cab"
|      |      |-- 6:15-175 HFPT-11 "D/L12/DW4260/SD175/Psg nr Assort"
|      |      |-- 6:15-176 HTRI-R "D/L12/DW4260/CM176/AFC Entry dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-177 HMS-S/D/M/SA "D/L12/DW4260/MCP177/Entry dr psg"
|      |      |-- 6:15-178 HFP-11 "D/L12/DW3100/SD178/Psg.Nr.Pantry"
|      |      |-- 6:15-179 HFP-11 "D/L12/DW1060/SD179/Entry Psg."
|      |      |-- 6:15-180 HFP-11 "D/L12/DW3200/SD180/psgNrMain cab"
|      |-- 6:16 PSC-12 "PSC-12 @ address 12"
|      |      |-- 6:16-1 PSC Relay "Relay @ 012:001 - Common Alarm"
|      |      |-- 6:16-2 PSC Relay "Relay @ 012:002 - Common Trouble"
|-- 7 Desigo Fire Safety Modular "BDB TOWER E" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-2 "CAB-2 Enclosure #1"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"

```
| | |-- CC-5 "Card Cage 5 Slots"
| | | |-- 7:1 XDLC "DLC @ address 1 L1"
| | | | |-- 7:1-1 HFP-11 "E/L1/E-DTC/SD-1/Cab 1"
| | | | |-- 7:1-2 HFP-11 "E/L1/E-DTC/SD-2/Cab 2"
| | | | |-- 7:1-3 HFP-11 "E/L1/E-DTC/SD-3/Cab 3"
| | | | |-- 7:1-4 HFP-11 "E/L1/E-DTC/SD-4/Cab 4"
| | | | |-- 7:1-5 HFP-11 "E/L1/E-DTC/SD-5/Cab 5"
| | | | |-- 7:1-6 HFP-11 "E/L1/E-DTC/SD-6/Cab 6"
| | | | |-- 7:1-7 HFP-11 "E/L1/E-DTC/SD-7/Cab 7"
| | | | |-- 7:1-8 HFP-11 "E/L1/E-DTC/SD-8/Cab 8"
| | | | |-- 7:1-9 HFP-11 "E/L1/E-DTC/SD-9/Cab 9"
| | | | |-- 7:1-10 HFP-11 "E/L1/E-DTC/SD-10/Cab 10"
| | | | |-- 7:1-11 HFP-11 "E/L1/E-DTC/SD-11/Cab 11"
| | | | |-- 7:1-12 HFP-11 "E/L1/E-DTC/SD-12/Cab 12"
| | | | |-- 7:1-13 HFP-11 "E/L1/E-DTC/SD-13/Cab 13"
| | | | |-- 7:1-14 HFP-11 "E/L1/E-DTC/SD-14/Cab 14"
| | | | |-- 7:1-15 HFP-11 "E/L1/E-DTC/SD-15/Cab 15"
| | | | |-- 7:1-16 HFP-11 "E/L1/E-DTC/SD-16/Cab 16"
| | | | |-- 7:1-17 HFP-11 "E/L1/E-DTC/SD-17/Cab 17"
| | | | |-- 7:1-18 HFP-11 "E/L1/E-DTC/SD-18/Cab 18"
| | | | |-- 7:1-19 HFP-11 "E/L1/E-DTC/SD-19/Cab 19"
| | | | |-- 7:1-20 HFP-11 "E/L1/E-DTC/SD-20/Cab 20"
| | | | |-- 7:1-21 HFP-11 "E/L1/E-DTC/SD-21/Cab 21"
| | | | |-- 7:1-22 HFP-11 "E/L1/E-DTC/SD-22/Cab 22"
| | | | |-- 7:1-23 HFP-11 "E/L1/E-DTC/SD-23/Cab 23"
| | | | |-- 7:1-24 HFP-11 "E/L1/E-DTC/SD-24/Cab 24"
| | | | |-- 7:1-25 HFP-11 "E/L1/E-DTC/SD-25/Cab 25"
| | | | |-- 7:1-26 HFP-11 "E/L1/E-DTC/SD-26/Cab 26"
| | | | |-- 7:1-27 HFP-11 "E/L1/E-DTC/SD-27/Cab 27"
| | | | |-- 7:1-28 HFP-11 "E/L1/E-DTC/SD-28/Cab 28"
| | | | |-- 7:1-29 HFP-11 "E/L1/E-DTC/SD-29/Cab 29"
| | | | |-- 7:1-30 HFP-11 "E/L1/E-DTC/SD-30/Cab 30"
| | | | |-- 7:1-31 HFP-11 "E/L1/E-DTC/SD-31/Cab 31"
| | | | |-- 7:1-32 HFP-11 "E/L1/E-DTC/SD-32/Cab 32"
| | | | |-- 7:1-33 HFP-11 "E/L1/E-DTC/SD-33/Cab 33"
| | | | |-- 7:1-34 HFP-11 "E/L1/E-DTC/SD-34/Cab 34"
| | | | |-- 7:1-35 HFP-11 "E/L1/E-DTC/SD-35/Cab 35"
| | | | |-- 7:1-36 HFP-11 "E/L1/E-DTC/SD-36/Cab 36"
| | | | |-- 7:1-37 HFP-11 "E/L1/E-DTC/SD-37/Cab 37"
| | | | |-- 7:1-38 HFP-11 "E/L1/E-DTC/SD-38/Cab 38"
| | | | |-- 7:1-39 HFP-11 "E/L1/E-DTC/SD-39/Cab 39"
| | | | |-- 7:1-40 HFP-11 "E/L1/E-DTC/SD-40/Cab 40"
| | | | |-- 7:1-41 HFP-11 "E/L1/E-DTC/SD-41/Cab 41"
| | | | |-- 7:1-42 HFP-11 "E/L1/E-DTC/SD-42/Cab 42"
| | | | |-- 7:1-43 HFP-11 "E/L1/E-DTC/SD-43/Cab 43"
| | | | |-- 7:1-44 HFP-11 "E/L1/E-DTC/SD-44/Cab 44"
| | | | |-- 7:1-45 HFP-11 "E/L1/E-DTC/SD-45/Cab 45"
| | | | |-- 7:1-46 HFP-11 "E/L1/E-DTC/SD-46/Cab 46"
| | | | |-- 7:1-47 HFP-11 "E/L1/E-DTC/SD-47/Cab 47"
| | | | |-- 7:1-48 HFP-11 "E/L1/E-DTC/SD-48/Cab 48"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:1 XDLC "DLC @ address 1 L1"

					-- 7:1-49 HFP-11 "E/L1/E-DTC/SD-49/Cab 49"
					-- 7:1-50 HFP-11 "E/L1/E-DTC/SD-50/Cab 50"
					-- 7:1-51 HFP-11 "E/L1/E-DTC/SD-51/Cab 51"
					-- 7:1-52 HFP-11 "E/L1/E-DTC/SD-52/Cab 52"
					-- 7:1-53 HFP-11 "E/L1/E-DTC/SD-53/Cab 53"
					-- 7:1-54 HFP-11 "E/L1/E-DTC/SD-54/Cab 54"
					-- 7:1-55 HFP-11 "E/L1/E-DTC/SD-55/Cab 55"
					-- 7:1-56 HFP-11 "E/L1/E-DTC/SD-56/Cab 56"
					-- 7:1-57 HFP-11 "E/L1/E-DTC/SD-57/Cab 57"
					-- 7:1-58 HFP-11 "E/L1/E-DTC/SD-58/Cab 58"
					-- 7:1-59 HFP-11 "E/L1/E-DTC/SD-59/Cab 59"
					-- 7:1-60 HFP-11 "E/L1/E-DTC/SD-60/Cab 60"
					-- 7:1-61 HFP-11 "E/L1/E-DTC/SD-61/Cab 61"
					-- 7:1-62 HFP-11 "E/L1/E-DTC/SD-62/Cab 62"
					-- 7:1-63 HFP-11 "E/L1/E-DTC/SD-63/Cab 63"
					-- 7:1-64 HFP-11 "E/L1/E-DTC/SD-64/Cab 64"
					-- 7:1-65 HFP-11 "E/L1/E-DTC/SD-65/Cab 65"
					-- 7:1-66 HFP-11 "E/L1/E-DTC/SD-66/Cab 66"
					-- 7:1-67 HFP-11 "E/L1/E-DTC/SD-67/Cab 67"
					-- 7:1-68 HFP-11 "E/L1/E-DTC/SD-68/Cab 68"
					-- 7:1-69 HFP-11 "E/L1/E-DTC/SD-69/Cab 69"
					-- 7:1-70 HFP-11 "E/L1/E-DTC/SD-70/Cab 70"
					-- 7:1-71 HFP-11 "E/L1/E-DTC/SD-71/Cab 71"
					-- 7:1-72 HFP-11 "E/L1/E-DTC/SD-72/Cab 72"
					-- 7:1-73 HFP-11 "E/L1/E-DTC/SD-73/Cab 73"
					-- 7:1-74 HFP-11 "E/L1/E-DTC/SD-74/Cab 74"
					-- 7:1-75 HFP-11 "E/L1/E-DTC/SD-75/Cab 75"
					-- 7:1-76 HFP-11 "E/L1/E-DTC/SD-76/Cab 76"
					-- 7:1-77 HFP-11 "E/L1/E-DTC/SD-77/Cab 77"
					-- 7:1-78 HFP-11 "E/L1/E-DTC/SD-78/Cab 78"
					-- 7:1-79 HFP-11 "E/L1/E-DTC/SD-79/Cab 79"
					-- 7:1-80 HFP-11 "E/L1/E-DTC/SD-80/Cab 80"
					-- 7:1-81 HFP-11 "E/L1/E-DTC/SD-81/Cab 81"
					-- 7:1-82 HFP-11 "E/L1/E-DTC/SD-82/Cab 82"
					-- 7:1-83 HFP-11 "E/L1/E-DTC/SD-83/Reception Area"
					-- 7:1-84 FDOT421 "E/L1/E-DTC/SD-84/Psg Nr Cab 54"
					-- 7:1-85 FDOT421 "E/L1/E-DTC/SD-85/Psg Nr Cab 58 "
					-- 7:1-86 FDOT421 "E/L1/E-DTC/SD-86/Psg Nr Cab 79"
					-- 7:1-87 FDOT421 "E/L1/E-DTC/SD-87/Psg Nr Cab 81"
					-- 7:1-88 FDOT421 "E/L1/E-DTC/SD-88/Psg Nr Cab 68"
					-- 7:1-89 FDOT421 "E/L1/E-DTC/SD-89/Psg Nr Cab 62"
					-- 7:1-90 FDOT421 "E/L1/E-DTC/SD-90/Psg Nr Cab 44"
					-- 7:1-91 FDOT421 "E/L1/E-DTC/SD-91/Psg Nr Cab 42"
					-- 7:1-92 FDOT421 "E/L1/E-DTC/SD-92/Psg Nr Cab 40"
					-- 7:1-93 FDOT421 "E/L1/E-DTC/SD-93/Psg Nr Cab 36"
					-- 7:1-94 FDOT421 "E/L1/E-DTC/SD-94/Psg Nr Cab 22"
					-- 7:1-95 FDOT421 "E/L1/E-DTC/SD-95/Psg Nr Cab 11"
					-- 7:1-96 FDOT421 "E/L1/E-DTC/SD-96/Psg Nr Cab 05"
					-- 7:1-97 FDOT421 "E/L1/E-DTC/SD-97/Psg Nr Cab 16"
					-- 7:1-98 FDOT421 "E/L1/E-DTC/SD-98/Psg Nr Cab 14"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:1 XDLC "DLC @ address 1 L1"

					-- 7:1-99 FDOT421 "E/L1/E-DTC/SD-99/Psg Nr Cab 28"
					-- 7:1-100 FDOT421 "E/L1/E-DTC/SD-100/Psg Nr Cab 26"
					-- 7:1-101 FDOT421 "E/L1/E-DTC/SD-101/Psg Nr Cab 25"
					-- 7:1-103 HTRI-S "E/L1/CC/UB/MM103/ELEC ROOM"
					-- 7:1-104 HMS-S/D/M/SA "E/L1/EC/UB/MCP104/ELEC ROOM"
					-- 7:1-105 HTRI-R "E/L1/EC/UB/CM105/ELEC ROOM"
					-- Switch ""
					-- Relay
					-- 7:1-106 HTRI-S "E/L1/EC/GND/MM106/Lift Lobby "
					-- 7:1-107 FDOT421 "E/L1/EE/GND/SD-107/LL Security C"
					-- 7:1-108 HMS-S/D/M/SA "E/L1/WC/UB/MCP108/ST COLUMN E555"
					-- 7:1-109 HTRI-R "E/L1/WC/UB/CM109/ST COLUMN E555"
					-- Switch ""
					-- Relay
					-- 7:1-110 HMS-S/D/M/SA "E/L1/EE/GND/MCP-110/Lift Lobby"
					-- 7:1-111 HTRI-R "E/L1/WC/UB/CM111/NR RAMP NO. 4"
					-- Switch ""
					-- Relay
					-- 7:1-112 HTRI-R "E/L1/WC/UB/CM112/ NR RAMP 4 STP"
					-- Switch ""
					-- Relay
					-- 7:1-113 HMS-S/D/M/SA "E/L1/WC/UB/MCP113/NR RAMP 4 STP"
					-- 7:1-114 HTRI-R "E/L1/CC/UB/CM114/ST COLUMN E581"
					-- Switch ""
					-- Relay
					-- 7:1-115 HFP-11 "E/L1/EE/GND/SD115/Lift Lobby En"
					-- 7:1-116 HTRI-R "E/L1/EC/UB/CM116/ST COLUMN E523"
					-- Switch ""
					-- Relay
					-- 7:1-117 HMS-S/D/M/SA "E/L1/EC/UB/MCP117/ST COLUMN E523"
					-- 7:1-118 HTRI-S "E/L1/EC/UB/MM118/ELEC ROOM"
					-- 7:1-119 HTRI-S "E/L1/EC/UB/MM119/LIFT MC RM"
					-- 7:1-120 HFP-11 "E/L1/CC/UB/SD120/ELEC ROOM"
					-- 7:1-121 HFP-11 "E/L1/WC/UB/SD121/ELEC ROOM"
					-- 7:1-122 HFP-11 "E/L1/WC/UB/SD122/NR ELEC ROOM"
					-- 7:1-123 HTRI-R "E/L1/EE/GND/CM-123/Lift Lobby AF"
					-- Switch ""
					-- Relay
					-- 7:1-124 HFP-11 "E/L1/EE/GND/SD-124/Electric Room"
					-- 7:1-125 HFP-11 "E/L1/EC/UB/SD125/DRIVER ROOM"
					-- 7:1-126 HTRI-S "E/L1/EE/GND/MM-126/Lift Lobby AF"
					-- 7:1-127 HFP-11 "E/L1/CC/UB/SD127/BMS ROOM"
					-- 7:1-128 HTRI-R "E/L1/EE/GND/CM-128/LL AHU Room"
					-- Switch ""
					-- Relay
					-- 7:1-129 HFP-11 "E/L1/EC/UB/SD129/LIFT ROOM"
					-- 7:1-130 HFP-11 "E/L1EC/UB/SD130/ELEC ROOM"
					-- 7:1-131 HMS-S/D/M/SA "E/L1/E-DTC/MCP-131/Psg Nr Cab 59"
					-- 7:1-132 HMS-S/D/M/SA "E/L1/E-DTC/MCP-132/Psg Nr Cab 27"
					-- 7:1-133 HMS-S/D/M/SA "E/L1/E-DTC/MCP-133/Psg Nr Cab 03"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:1 XDLC "DLC @ address 1 L1"

					-- 7:1-134 HMS-S/D/M/SA "E/L1/E-DTC/MCP-134/Psg Nr Cab 22"
					-- 7:1-135 HMS-S/D/M/SA "E/L1/E-DTC/MCP-135/Psg Nr Cab 77"
					-- 7:1-136 HMS-S/D/M/SA "E/L1/E-DTC/MCP-136/Reception"
					-- 7:1-137 HMS-S/D/M/SA "E/L1/E-DTC/MCP-137/Psg Nr Cab 70"
					-- 7:1-138 HMS-S/D/M/SA "E/L1/E-DTC/MCP-138/Psg Nr Cab 49"
					-- 7:1-139 HMS-S/D/M/SA "E/L1/E-DTC/MCP-139/Psg Nr Cab 31"
					-- 7:1-140 HMS-S/D/M/SA "E/L1/E-DTC/MCP-140/Psg Nr Cab 67"
					-- 7:1-141 HMS-S/D/M/SA "E/L1/E-DTC/MCP-141/Psg Nr Cab 06"
					-- 7:1-142 HTRI-R "E/L1/C/GND/CM-142/Electric Room"
					-- Switch ""
					-- Relay
					-- 7:1-143 HFP-11 "E/L1/E-DTC/SD-143/Psg Nr Cab 47"
					-- 7:1-144 HFP-11 "E/L1/E-DTC/SD-144/Psg Nr Cab 61"
					-- 7:1-145 HFP-11 "E/L1/E-DTC/SD-145/Electric Room"
					-- 7:1-146 HFP-11 "E/L1/E-DTC/SD-146/Server Room"
					-- 7:1-147 HFP-11 "E/L1/E-DTC/SD-147/Psg AFC Cab 1"
					-- 7:1-148 HFP-11 "E/L1/E-DTC/SD-148/Psg AFC Cab 2"
					-- 7:1-149 HFP-11 "E/L1/E-DTC/SD-149/Psg AFC Cab 3"
					-- 7:1-150 HFP-11 "E/L1/E-DTC/SD-150/Psg AFC Cab 4"
					-- 7:1-151 HFP-11 "E/L1/E-DTC/SD-151/Psg AFC Cab 5"
					-- 7:1-152 HFP-11 "E/L1/E-DTC/SD-152/Psg AFC Cab 6"
					-- 7:1-153 HFP-11 "E/L1/E-DTC/SD-153/Psg AFC Cab 7"
					-- 7:1-154 HFP-11 "E/L1/E-DTC/SD-154/Psg AFC Cab 8"
					-- 7:1-155 HFP-11 "E/L1/E-DTC/SD-155/Psg AFC Cab 9"
					-- 7:1-156 HFP-11 "E/L1/E-DTC/SD-156/Psg AFC Cab 10"
					-- 7:1-157 HFP-11 "E/L1/E-DTC/SD-157/Psg AFC Cab 11"
					-- 7:1-158 HFP-11 "E/L1/E-DTC/SD-158/Psg AFC Cab 12"
					-- 7:1-159 HFP-11 "E/L1/E-DTC/SD-159/Psg AFC Cab 13"
					-- 7:1-160 HFP-11 "E/L1/E-DTC/SD-160/Psg AFC Cab 14"
					-- 7:1-161 HFP-11 "E/L1/E-DTC/SD-161/Psg AFC Cab 15"
					-- 7:1-162 HFP-11 "E/L1/E-DTC/SD-162/Psg AFC Cab 16"
					-- 7:1-163 HFP-11 "E/L1/E-DTC/SD-163/Psg AFC Cab 17"
					-- 7:1-164 HFP-11 "E/L1/E-DTC/SD-164/Psg AFC Cab 18"
					-- 7:1-165 HFP-11 "E/L1/E-DTC/SD-165/Psg AFC Cab 19"
					-- 7:1-166 HFP-11 "E/L1/E-DTC/SD-166/Psg AFC Cab 20"
					-- 7:1-167 HFP-11 "E/L1/E-DTC/SD-167/Psg AFC Cab 21"
					-- 7:1-168 HFP-11 "E/L1/E-DTC/SD-168/Psg AFC Cab 22"
					-- 7:1-169 HFP-11 "E/L1/E-DTC/SD-169/Psg AFC Cab 23"
					-- 7:1-170 HFP-11 "E/L1/E-DTC/SD-170/Psg AFC Cab 24"
					-- 7:1-171 HFP-11 "E/L1/E-DTC/SD-171/Psg AFC Cab 25"
					-- 7:1-172 HFP-11 "E/L1/E-DTC/SD-172/Psg AFC Cab 26"
					-- 7:1-173 HFP-11 "E/L1/E-DTC/SD-173/Psg AFC Cab 27"
					-- 7:1-174 HFP-11 "E/L1/E-DTC/SD-174/Psg AFC Cab 28"
					-- 7:1-175 HFP-11 "E/L1/E-DTC/SD-175/Psg AFC Cab 29"
					-- 7:1-176 HFP-11 "E/L1/E-DTC/SD-176/Psg AFC Cab 30"
					-- 7:1-177 HFP-11 "E/L1/E-DTC/SD-177/Psg AFC Cab 31"
					-- 7:1-178 HFP-11 "E/L1/E-DTC/SD-178/Psg AFC Cab 32"
					-- 7:1-179 HFP-11 "E/L1/E-DTC/SD-179/Psg AFC Cab 33"
					-- 7:1-180 HFP-11 "E/L1/E-DTC/SD-180/Psg AFC Cab 34"
					-- 7:1-181 HFP-11 "E/L1/E-DTC/SD-181/Psg AFC Cab 35"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:1 XDLC "DLC @ address 1 L1"

					--	7:1-182	HFP-11	"E/L1/E-DTC/SD-182/Psg	AFC	Cab	36"
					--	7:1-183	HFP-11	"E/L1/E-DTC/SD-183/Psg	AFC	Cab	37"
					--	7:1-184	HFP-11	"E/L1/E-DTC/SD-184/Psg	AFC	Cab	38"
					--	7:1-185	HFP-11	"E/L1/E-DTC/SD-185/Psg	AFC	Cab	39"
					--	7:1-186	HFP-11	"E/L1/E-DTC/SD-186/Psg	AFC	Cab	40"
					--	7:1-187	HFP-11	"E/L1/E-DTC/SD-187/Psg	AFC	Cab	41"
					--	7:1-188	HFP-11	"E/L1/E-DTC/SD-188/Psg	AFC	Cab	42"
					--	7:1-189	HFP-11	"E/L1/E-DTC/SD-189/Psg	AFC	Cab	43"
					--	7:1-190	HFP-11	"E/L1/E-DTC/SD-190/Psg	AFC	Cab	44"
					--	7:1-191	HFP-11	"E/L1/E-DTC/SD-191/Psg	AFC	Cab	45"
					--	7:1-192	HFP-11	"E/L1/E-DTC/SD-192/Psg	AFC	Cab	46"
					--	7:1-193	HFP-11	"E/L1/E-DTC/SD-193/Psg	AFC	Cab	47"
					--	7:1-194	HFP-11	"E/L1/E-DTC/SD-194/Psg	AFC	Cab	48"
					--	7:1-195	HFP-11	"E/L1/E-DTC/SD-195/Psg	AFC	Cab	49"
					--	7:1-196	HFP-11	"E/L1/E-DTC/SD-196/Psg	AFC	Cab	50"
					--	7:1-197	HFP-11	"E/L1/E-DTC/SD-197/Psg	AFC	Cab	51"
					--	7:1-198	HFP-11	"E/L1/E-DTC/SD-198/Psg	AFC	Cab	52"
					--	7:1-199	HFP-11	"E/L1/E-DTC/SD-199/Psg	AFC	Cab	53"
					--	7:1-200	HFP-11	"E/L1/E-DTC/SD-200/Psg	AFC	Cab	54"
					--	7:1-201	HFP-11	"E/L1/E-DTC/SD-201/Psg	AFC	Cab	55"
					--	7:1-202	HFP-11	"E/L1/E-DTC/SD-202/Psg	AFC	Cab	56"
					--	7:1-203	HFP-11	"E/L1/E-DTC/SD-203/Psg	AFC	Cab	57"
					--	7:1-204	HFP-11	"E/L1/E-DTC/SD-204/Psg	AFC	Cab	58"
					--	7:1-205	HFP-11	"E/L1/E-DTC/SD-205/Psg	AFC	Cab	59"
					--	7:1-206	HFP-11	"E/L1/E-DTC/SD-206/Psg	AFC	Cab	60"
					--	7:1-207	HFP-11	"E/L1/E-DTC/SD-207/Psg	AFC	Cab	61"
					--	7:1-208	HFP-11	"E/L1/E-DTC/SD-208/Psg	AFC	Cab	62"
					--	7:1-209	HFP-11	"E/L1/E-DTC/SD-209/Psg	AFC	Cab	63"
					--	7:1-210	HFP-11	"E/L1/E-DTC/SD-210/Psg	AFC	Cab	64"
					--	7:1-211	HFP-11	"E/L1/E-DTC/SD-211/Psg	AFC	Cab	65"
					--	7:1-212	HFP-11	"E/L1/E-DTC/SD-212/Psg	AFC	Cab	66"
					--	7:1-213	HFP-11	"E/L1/E-DTC/SD-213/Psg	AFC	Cab	67"
					--	7:1-214	HFP-11	"E/L1/E-DTC/SD-214/Psg	AFC	Cab	68"
					--	7:1-215	HFP-11	"E/L1/E-DTC/SD-215/Psg	AFC	Cab	69"
					--	7:1-216	HFP-11	"E/L1/E-DTC/SD-216/Psg	AFC	Cab	70"
					--	7:1-217	HFP-11	"E/L1/E-DTC/SD-217/Psg	AFC	Cab	71"
					--	7:1-218	HFP-11	"E/L1/E-DTC/SD-218/Psg	AFC	Cab	72"
					--	7:1-219	HFP-11	"E/L1/E-DTC/SD-219/Psg	AFC	Cab	73"
					--	7:1-220	HFP-11	"E/L1/E-DTC/SD-220/Psg	AFC	Cab	74"
					--	7:1-221	HFP-11	"E/L1/E-DTC/SD-221/Psg	AFC	Cab	75"
					--	7:1-222	HFP-11	"E/L1/E-DTC/SD-222/Psg	AFC	Cab	76"
					--	7:1-223	HFP-11	"E/L1/E-DTC/SD-223/Psg	AFC	Cab	77"
					--	7:1-224	HFP-11	"E/L1/E-DTC/SD-224/Psg	AFC	Cab	78"
					--	7:1-225	HFP-11	"E/L1/E-DTC/SD-225/Psg	AFC	Cab	79"
					--	7:1-226	HFP-11	"E/L1/E-DTC/SD-226/Psg	AFC	Cab	80"
					--	7:1-227	HFP-11	"E/L1/E-DTC/SD-227/Psg	AFC	Cab	81"
					--	7:1-228	HFP-11	"E/L1/E-DTC/SD-228/Psg	AFC	Cab	82"
					--	7:1-229	HFP-11	"E/L1/E-DTC/SD-229/Reception Area"			
					--	7:1-230	FDOT421	"E/L1/EE/GND/SD-230/LL AHU Room"			
					--	7:1-231	HFP-11	"E/L1/E-DTC/SD-231/Psg	AFC	58	Cab"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:1 XDLC "DLC @ address 1 L1"

					-- 7:1-232 HFP-11 "E/L1/E-DTC/SD-232/Psg AFC 79 Cab"
					-- 7:1-233 HFP-11 "E/L1/E-DTC/SD-233/Psg AFC 81 Cab"
					-- 7:1-236 HFP-11 "E/L1/E-DTC/SD-236/Psg AFC 44 Cab"
					-- 7:1-237 HFP-11 "E/L1/E-DTC/SD-237/Psg AFC 42 Cab"
					-- 7:1-238 HFP-11 "E/L1/E-DTC/SD-238/Psg AFC 40 Cab"
					-- 7:1-239 HFP-11 "E/L1/E-DTC/SD-239/Psg AFC 36 Cab"
					-- 7:1-240 HFP-11 "E/L1/E-DTC/SD-240/Psg AFC 22 Cab"
					-- 7:1-241 HFP-11 "E/L1/E-DTC/SD-241/Psg AFC 11 Cab"
					-- 7:1-242 HFP-11 "E/L1/E-DTC/SD-242/Psg AFC 05 Cab"
					-- 7:1-243 HFP-11 "E/L1/E-DTC/SD-243/Psg AFC 16 Cab"
					-- 7:1-244 HFP-11 "E/L1/E-DTC/SD-244/Psg AFC 14 Cab"
					-- 7:1-245 HFP-11 "E/L1/E-DTC/SD-245/Psg AFC 28 Cab"
					-- 7:1-246 HFP-11 "E/L1/E-DTC/SD-246/Psg AFC 26 Cab"
					-- 7:1-247 HFP-11 "E/L1/E-DTC/SD-247/Psg AFC 25 Cab"
					-- 7:1-248 HMS-S/D/M/SA "E/L1/EC/GND/MCP-248/Lift Lobby"
					-- 7:1-249 HTRI-R "E/L1/EC/GND/CM-249/Lift Lobby AF"
					-- Switch ""
					-- Relay
					-- 7:1-250 HTRI-S "E/L1/EC/GND/MM-250/Lift Lobby AF"
					-- 7:1-251 FDOT421 "E/L1/EC/GND/SD-251/Electric Room"
					-- 7:1-252 FDOT421 "E/L1/EC/GND/SD-252/Lift Lobby"
					-- 7:2 XDLC "DLC @ address 2 L2"
					-- 7:2-1 HTRI-R "E/L2/C/3F/CM1/DR REL NR EC3050"
					-- Switch ""
					-- Relay
					-- 7:2-2 HFP-11 "E/L2/C/3F/SD2/CORR NR EC3050"
					-- 7:2-3 HFP-11 "E/L2/E/3F/SD3/CORR NR EC3050"
					-- 7:2-4 HFP-11 "E/L2/C/3F/SD4/CORR NR EW3/S19"
					-- 7:2-5 HFP-11 "E/L2/C/3F/SD5/CORR NR EW3/219"
					-- 7:2-6 HFP-11 "E/L2/C/3F/SD6/CORR NR S07"
					-- 7:2-7 HFP-11 "E/L2/C/3F/SD7/CORR NR EC3"
					-- 7:2-8 HMS-S/D/M/SA "E/L2/C/3F/MCP8/FIRE ESC STR"
					-- 7:2-9 HTRI-R "E/L2/C/3F/CM9/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:2-10 HFP-11 "E/L2/C/3F/SD10/CORR NR S20"
					-- 7:2-11 HFP-11 "E/L2/C/3F/SD11/CORR NR EC3090"
					-- 7:2-12 HFP-11 "E/L2/C/3F/SD12/CORR NR EC3090"
					-- 7:2-13 HFP-11 "E/L2/C/3F/SD13/CORR NR E.R."
					-- 7:2-14 HFP-11 "E/L2/C/3F/SD14/CORR NR E.R."
					-- 7:2-15 HTRI-R "E/L2/C/3F/CM15/DR REL NR LL"
					-- Switch ""
					-- Relay
					-- 7:2-16 HFP-11 "E/L2/C/3F/SD16/LIFT LOBBY "
					-- 7:2-17 HFP-11 "E/L2/C/3F/SD17/LIFT LOBBY "
					-- 7:2-18 HMS-S/D/M/SA "E/L2/C/3F/MCP18/FIRE SHAFT L.L."
					-- 7:2-19 HTRI-R "E/L2/C/3F/CM19/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:2-20 HTRI-S "E/L2/C/3F/MM20/FIRE SHAFT L.L."

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:2 XDLC "DLC @ address 2 L2"

					-- 7:2-21 HFP-11 "E/L2/C/3F/SD21/ELECT RM "
					-- 7:2-22 HFP-11 "E/L2/C/3F/SD22/AHU RM "
					-- 7:2-23 HTRI-R "E/L2/C/3F/CM23/AHU RM "
					-- Switch ""
					-- Relay
					-- 7:2-24 HFP-11 "E/L2/C/3F/SD24/CORR NR EC3070"
					-- 7:2-25 HFP-11 "E/L2/C/3F/SD25/CORR NR EC3070"
					-- 7:2-26 HFP-11 "E/L2/C/3F/SD26/CORR NR EC3/S22"
					-- 7:2-27 HFP-11 "E/L2/C/3F/SD27/CORR NR EC3/S22"
					-- 7:2-28 HFP-11 "E/L2/3F/SD28/CORR NR EE3030"
					-- 7:2-29 HFP-11 "E/L2/3F/SD29/CORR NR EE3100"
					-- 7:2-30 HFP-11 "E/L2/3F/SD30/CORR NR EE3100"
					-- 7:2-31 HFP-11 "E/L2/3F/SD31/CORR NR EE3120"
					-- 7:2-32 HFP-11 "E/L2/3F/SD32/CORR NR EE3/S24"
					-- 7:2-33 HFP-11 "E/L2/3F/SD33/CORR NR EE3/S24"
					-- 7:2-34 HTRI-R "E/L2/3F/CM34DR RELESE CM NR L."
					-- Switch ""
					-- Relay
					-- 7:2-35 HFP-11 "E/L2/3F/SD35/ELECT RM "
					-- 7:2-36 HFP-11 "E/L2/3F/SD36/AHU RM "
					-- 7:2-37 HTRI-R "E/L2/3F/CM37/AHU RM "
					-- Switch ""
					-- Relay
					-- 7:2-38 HFP-11 "E/L2/3F/SD38/LIFT LOBBY "
					-- 7:2-39 HMS-S/D/M/SA "E/L2/3F/MCP39/FIRE SHAFT L.L."
					-- 7:2-40 XTRI-R "E/L2/3F/CM40/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:2-41 HTRI-S "E/L2/3F/MM41/FIRE SHAFT L.L."
					-- 7:2-42 HMS-S/D/M/SA "E/L2/2F/MCP42/FIRE ESC STR"
					-- 7:2-43 HTRI-R "E/L2/2F/CM43/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:2-44 HFP-11 "E/L2/C/2F/SD44/CORR NR ECS07"
					-- 7:2-45 HFP-11 "E/L2/C/2F/SD45/CORR NR ECS07"
					-- 7:2-46 HFP-11 "E/L2/C/2F/SD46/CORR NR EC2020"
					-- 7:2-47 HFP-11 "E/L2/C/2F/SD47/CORR NR EC2020"
					-- 7:2-48 HFP-11 "E/L2/C/2F/SD48/CORR NR EC2082"
					-- 7:2-49 HFP-11 "E/L2/C/2F/SD49/CORR NR E.R."
					-- 7:2-50 HFP-11 "E/L2/C/2F/SD50/CORR NR E.R."
					-- 7:2-51 HTRI-R "E/L2/C/2F/CM51/DR RELESE CM NR L"
					-- Switch ""
					-- Relay
					-- 7:2-52 HFP-11 "E/L2/C/2F/SD52/LIFT LOBBY "
					-- 7:2-53 HFP-11 "E/L2/C/2F/SD53/LIFT LOBBY "
					-- 7:2-54 HFP-11 "E/L2/C/2F/SD54/ELECT RM "
					-- 7:2-55 XTRI-R "E/L2/C/2F/CM55/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:2-56 HMS-S/D/M/SA "E/L2/C/2F/MCP56/FIRE SHAFT L.L."

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:2 XDLC "DLC @ address 2 L2"

					-- 7:2-57 HTRI-S "E/L2/C/2F/MM57/FIRE SHAFT L.L."
					-- 7:2-58 HTRI-R "E/L2/C/2F/CM58/DR RELESE NR LL"
					-- Switch ""
					-- Relay
					-- 7:2-59 HFP-11 "E/L2/C/2F/SD59/AHU RM "
					-- 7:2-60 HTRI-R "E/L2/2F/CM60/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:2-61 HFP-11 "E/L2/C/2F/SD61/CORR NR AHU "
					-- 7:2-62 HFP-11 "E/L2/C/2F/SD62/CORR NR EC2133"
					-- 7:2-63 HFP-11 "E/L2/C/2F/SD63/CORR NR EC2132"
					-- 7:2-64 HFP-11 "E/L2/C/2F/SD64/CORR NR EC2132"
					-- 7:2-65 HMS-S/D/M/SA "E/L2/2F/MCP65/IRE ESC STR"
					-- 7:2-66 HTRI-R "E/L2/2F/CM66/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:2-67 HFP-11 "E/L2/2F/SD67/ELECT RM SD"
					-- 7:2-68 HFP-11 "E/L2/2F/SD68/AHU RM SD"
					-- 7:2-69 HTRI-R "E/L2/2F/CM69/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:2-70 HFP-11 "E/L2/2F/SD70/LIFT LOBBY SD"
					-- 7:2-71 HMS-S/D/M/SA "E/L2/2F/MCP71/FIRE SHAFT L.L."
					-- 7:2-72 HTRI-R "E/L2/2F/CM72/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:2-73 HTRI-S "E/L2/2F/MM73/FIRE SHAFT L.L."
					-- 7:2-76 HTRI-R "E/L2/1F/CM76/DR RELESE NR EC1080"
					-- Switch ""
					-- Relay
					-- 7:2-77 HFP-11 "E/L2/1F/SD77/CORR NR EC 1080"
					-- 7:2-78 HFP-11 "E/L2/1F/SD78/CORR NR EC 1080"
					-- 7:2-79 HFP-11 "E/L2/1F/SD79/CORR NR EC 1050"
					-- 7:2-80 HFP-11 "E/L2/1F/SD80/CORR NR EC1/S07"
					-- 7:2-81 HFP-11 "E/L2/1F/SD81/CORR NR EC1/S07"
					-- 7:2-82 HTRI-R "E/L2/1F/CM82/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:2-83 HMS-S/D/M/SA "E/L2/1F/MCP83/FIRE ESC STR"
					-- 7:2-84 HFP-11 "E/L2/1F/SD84/CORR NR EC 1040"
					-- 7:2-85 HFP-11 "E/L2/1F/SD85/CORR NR EC1/S06"
					-- 7:2-86 HFP-11 "E/L2/1F/SD86/CORR NR EC 1010"
					-- 7:2-87 HFP-11 "E/L2/1F/SD87/CORR NR E.R."
					-- 7:2-88 HFP-11 "E/L2/1F/SD88/ELECT RM SD"
					-- 7:2-89 HTRI-R "E/L2/1F/CM89/DR RELESE CM NR E.R"
					-- Switch ""
					-- Relay
					-- 7:2-90 HFP-11 "E/L2/1F/SD90/CORR NR EC1/S21"
					-- 7:2-91 XTRI-R "E/L2/1F/CM91/FIRE SHAFT L.L.C/C"
					-- Switch ""

				-- Relay
				-- 7:2-92 HMS-S/D/M/SA "E/L2/1F/MCP92/FIRE SHAF L.L.C/C"
				-- 7:2-93 HTRI-S "E/L2/1F/MM93/FIRE SHAFT L.L.C/C"
				-- 7:2-94 HFP-11 "E/L2/1F/SD94/LIFT LOBBY SD C/C"
				-- 7:2-95 HFP-11 "E/L2/1F/SD95/LIFT LOBBY SD C/C"
				-- 7:2-97 HTRI-R "E/L2/1F/CM97/AHU RM CM C/C"
				-- Switch ""
				-- Relay
				-- 7:2-98 HFP-11 "E/L2/1F/SD98/AHU RM SD C/C"
				-- 7:2-101 HFP-11 "E/L2/1F/SD101/ELECT RM SD E/C"
				-- 7:2-102 HFP-11 "E/L2/1F/SD102/AHU RM SD E/C"
				-- 7:2-103 HTRI-R "E/L2/1F/CM103/AHU RM CM E/C"
				-- Switch ""
				-- Relay
				-- 7:2-104 HFP-11 "E/L2/1F/SD104/LIFT LOBBY SD E/C"
				-- 7:2-105 HTRI-R "E/L2/1F/CM105/FIRE SHAFT L.L.E/C"
				-- Switch ""
				-- Relay
				-- 7:2-106 HMS-S/D/M/SA "E/L2/1F/MCP106/FIRE SHAFT L.L.E/"
				-- 7:2-107 HTRI-S "E/L2/1F/MM107/FIRE SHAFT L.L.E/C"
				-- 7:2-108 HFP-11 "E/L2/1F/SD108/SMALL CORR "
				-- 7:2-110 HTRI-S "E/L2/3F/MM110/EC3080"
				-- 7:2-111 XTRI-S "E/L2/3F/MM111/EC3100"
				-- 7:2-115 HTRI-S "E/L2/2F/MM115/EC2200"
				-- 7:2-116 XTRI-S "E/L2/2F/MM116/EC2060"
				-- 7:2-119 XTRI-S "E/L2/2F/MM119/EC2040"
				-- 7:2-123 XTRI-S "E/L2/2F/MM123/EC2020"
				-- 7:2-124 XTRI-S "E/L2/2F/MM124/EC2010"
				-- 7:2-127 XTRI-S "E/L2/2F/MM127/EC2150"
				-- 7:2-128 XTRI-S "E/L2/2F/MM128/EC2140"
				-- 7:2-130 XTRI-S "E/L2/C//2F/MM130/EC2100"
				-- 7:2-131 HTRI-S "E/L2/2F/MM131/"
				-- 7:2-133 XTRI-S "E/L2/2F/MM133/EC2120"
				-- 7:2-139 HTRI-S "E/L2/1F/MM139/EC1160"
				-- 7:2-141 HTRI-S "E/L2/1F/MM141/EC1150"
				-- 7:2-142 HTRI-S "E/L2/1F/MM142/EC1030"
				-- 7:2-143 HTRI-S "E/L2/C/2F/MM143/EC1120"
				-- 7:2-145 HTRI-S "E/L2/1F/MM145/EC1130"
				-- 7:2-146 HTRI-S "E/L2/1F/MM146/EC1050-A"
				-- 7:2-148 HTRI-S "E/L2/1F/MM148/EC1050"
				-- 7:2-149 HTRI-S "E/L2/1F/MM149/EC1110"
				-- 7:2-150 HTRI-S "E/L2/1F/MM150/EC1060"
				-- 7:2-151 HTRI-S "E/L2/1F/MM151/EC1070"
				-- 7:2-152 HTRI-S "E/L2/1F/MM152/EC1100"
				-- 7:2-153 HTRI-S "E/L2/1F/MM153/EC1080"
				-- 7:2-154 HTRI-S "E/L2/1F/MM154/EC1090"
				-- 7:2-155 HTRI-S "E/L2/1F/MM155/EC1080-(A) "
				-- 7:2-158 HTRI-S "E/L2/2F/MM158/EE2010"
				-- 7:2-164 HTRI-S "E/L2/3F/MM164/EE3120"
				-- 7:2-166 HTRI-S "E/L2/3F/MM166/EC3050"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:2 XDLC "DLC @ address 2 L2"

					-- 7:2-171 HTRI-S "E/L2/3F/MM171/EE3070"
					-- 7:2-176 HMS-S/D/M/SA "E/L2/EW/GND/MCP-176/Lift Lobby"
					-- 7:2-177 HTRI-R "E/L2/EW/GND/CM-177/Lift Lobby AF"
					-- Switch ""
					-- Relay
					-- 7:2-178 HTRI-S "E/L2/EW/GND/MM-178/Lift Lobby AF"
					-- 7:2-179 FDOT421 "E/L2/EW/GND/SD-179/Electric Room"
					-- 7:2-180 FDOT421 "E/L2/EW/GND/SD-180/Lift Lobby En"
					-- 7:2-181 FDOT421 "E/L2/EW/GND/SD-181/LL security c"
					-- 7:2-182 FDOT421 "E/L2/EW/GND/SD-182/Lift Lobby "
					-- 7:2-183 FDOT421 "E/L2/EW/GND/SD-183/Lift Lobby "
					-- 7:2-184 FDOT421 "E/L2/EW/GND/SD-184/Lift Lobby En"
					-- 7:2-185 FDOT421 "E/L2/EW/GND/SD-185/Lift Lobby AH"
					-- 7:2-186 HTRI-R "E/L2/EW/GND/CM-186/Lift Lobby AH"
					-- Switch ""
					-- Relay
					-- 7:2-187 HFP-11 "E/L2/EC3010/SD187/Accounts cab"
					-- 7:2-188 HFP-11 "E/L2/EC3010/SD188/Assorter cab"
					-- 7:2-189 HFP-11 "E/L2/EC3010/SD189/Main cab"
					-- 7:2-190 HFP-11 "E/L2/EC3010/SD190/Pantry"
					-- 7:2-191 HFP-11 "E/L2/EC3010/SD191/Washroom area"
					-- 7:2-192 HFP-11 "E/L2/EC3010/SD192/Reception"
					-- 7:2-193 HTRI-R "E/L2/EC3010/CM193/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:2-194 HMS-S/D/M/SA "E/L2/EC3010/MCP194/Entry dr Psg"
					-- 7:2-195 HFP-11 "E/L2/EC3070/SD195/Reception"
					-- 7:2-196 HFPT-11 "E/L2/EC3070/HD196/Pantry"
					-- 7:2-197 HFP-11 "E/L2/EC3070/SD197/Meeting rm"
					-- 7:2-198 HFP-11 "E/L2/EC3070/SD198/Psg nr account"
					-- 7:2-199 HFP-11 "E/L2/EC3070/SD199/Account cab"
					-- 7:2-200 HFP-11 "E/L2/EC3070/SD200/Boss cab"
					-- 7:2-201 HFP-11 "E/L2/EC3070/SD201/Main cab"
					-- 7:2-202 HTRI-R "E/L2/EC3070/CM202/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:2-203 HMS-S/D/M/SA "E/L2/EC3070/MCP203/Entry dr Psg"
					-- 7:2-204 HFP-11 "E/L2/EC3060/SD204/Main cab1"
					-- 7:2-205 HFP-11 "E/L2/EC3060/SD205/Main cab2"
					-- 7:2-206 HFP-11 "E/L2/EC3060/SD206/Account cab"
					-- 7:2-207 HFP-11 "E/L2/EC3060/SD207/Account cab"
					-- 7:2-208 HFP-11 "E/L2/EC3060/SD208/Reception"
					-- 7:2-209 HFP-11 "E/L2/EC3060/SD209/Pantry"
					-- 7:2-210 HFP-11 "E/L2/EC3060/SD210/store rm"
					-- 7:2-211 XTRI-R "E/L2/EC3060/CM211/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:2-212 HMS-S/D/M/SA "E/L2/EC3060/MCP212/Entry dr Psg"
					-- 7:2-226 HFP-11 "E/L2/EE3060/SD226/Main cab"
					-- 7:2-227 HFP-11 "E/L2/EE3060/SD227/Assorter cab"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:2 XDLC "DLC @ address 2 L2"

```
| | | | |-- 7:2-228 HFP-11 "E/L2/EE3060/SD228/Psg nr Assorte"
| | | | |-- 7:2-229 HFP-11 "E/L2/EE3060/SD229/Accounts cab"
| | | | |-- 7:2-230 HFPT-11 "E/L2/EE3060/HD230/Pantry"
| | | | |-- 7:2-231 HTRI-R "E/L2/EE3060/CM231/Entry dr Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-232 HMS-S/D/M/SA "E/L2/EE3060/MCP232/Entry dr Psg"
| | | | |-- 7:2-233 HFP-11 "E/L2/EC1170/SD233/Assorter cab1"
| | | | |-- 7:2-234 HFP-11 "E/L2/EC1170/SD234/AFC Assorter c"
| | | | |-- 7:2-235 HFP-11 "E/L2/EC1170/SD235/Main cab"
| | | | |-- 7:2-236 HFP-11 "E/L2/EC1170/SD236/AFC Main cab"
| | | | |-- 7:2-237 HFP-11 "E/L2/EC1170/SD237/Entry Psg"
| | | | |-- 7:2-238 HFP-11 "E/L2/EC1170/SD238/Account cab"
| | | | |-- 7:2-239 HFP-11 "E/L2/EC1170/SD239/Assorter cab2"
| | | | |-- 7:2-240 HFP-11 "E/L2/EC1170/SD240/AFC Assorter c"
| | | | |-- 7:2-241 HTRI-R "E/L2/EC1170/CM241/Electric cupbo"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-242 HMS-S/D/M/SA "E/L2/EC1170/MCP242/Entry Psg"
| | | | |-- 7:2-74 HFP-11 "E/L2/EE1011/SD74/Main cabin"
| | | | |-- 7:2-75 HFP-11 "E/L2/EE1011/SD75/Assortor Cab 1"
| | | | |-- 7:2-100 HFP-11 "E/L2/EE1011/SD100/Assortor Cab 2"
| | | | |-- 7:2-112 HFP-11 "E/L2/EE1011/SD112/Assortor Cab 2"
| | | | |-- 7:2-113 HFP-11 "E/L2/EE1011/SD113/Lunch Cabin"
| | | | |-- 7:2-114 HFP-11 "E/L2/EE1011/SD114/Assortor Cab 3"
| | | | |-- 7:2-117 HFP-11 "E/L2/EE1011/SD117/Assortor Cab 3"
| | | | |-- 7:2-118 HFP-11 "E/L2/EE1011/SD118/Assortor Cab 3"
| | | | |-- 7:2-120 HFP-11 "E/L2/EE1011/SD120/Account Cabin"
| | | | |-- 7:2-122 HFP-11 "E/L2/EE1011/SD122/Director Cabin"
| | | | |-- 7:2-125 HFP-11 "E/L2/EE1011/SD125/Psg Nr. Pantry"
| | | | |-- 7:2-129 HFP-11 "E/L2/EE1011/SD129/Waiting Area P"
| | | | |-- 7:2-132 HFP-11 "E/L2/EE1011/SD132/Reception Psg"
| | | | |-- 7:2-99 HFP-11 "E/L2/EE1011/SD99/Assortor Cab 2"
| | | | |-- 7:2-136 HFPT-11 "E/L2/EE1011/HD136/Pantry"
| | | | |-- 7:2-137 HMS-S/D/M/SA "E/L2/EE1011/MCP137/Waiting Area "
| | | | |-- 7:2-138 HMS-S/D/M/SA "E/L2/EE1011/MCP138/Psg Nr.Main C"
| | | | |-- 7:2-161 HTRI-R "E/L2/EE1011/CM161/Waitting Psg A"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-163 HTRI-S "E/L2/1F/MM163/EE3110"
| | | | |-- 7:2-243 HFP-11 "E/L2/EC2160/SD243/main cab"
| | | | |-- 7:2-244 HFP-11 "E/L2/EC2160/SD244/Assoter cab"
| | | | |-- 7:2-245 HFP-11 "E/L2/EC2160/SD245/psg nr assoter"
| | | | |-- 7:2-246 HFP-11 "E/L2/EC2160/SD246/pantry"
| | | | |-- 7:2-248 HMS-S/D/M/SA "E/L2/EC2160/MCP248/Entry Psg"
| | | | |-- 7:2-247 HTRI-R "E/L2/EC2160/CM247/Entry psg afc"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-135 HFPT-11 "E/L2/EC3060/HD135/Pantry"
| | | | |-- 7:3 XDLC "DLC @ address 3 L3"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-1 HFP-11 "E/L3/WC/2F/SD1/CORR NR 2260"
					-- 7:3-2 HFP-11 "E/L3/WC/2F/SD2/CORR NR 2260"
					-- 7:3-3 HTRI-R "E/L3/WC/2F/CM3/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:3-4 HMS-S/D/M/SA "E/L3/WC/2F/MCP4/FIRE ESC STR"
					-- 7:3-5 HFP-11 "E/L3/WC/2F/SD5/CORR NR 2170"
					-- 7:3-6 HFP-11 "E/L3/WC/2F/SD6/CORR NR 2200"
					-- 7:3-7 HFP-11 "E/L3/WC/2F/SD7/CORR NR 2230"
					-- 7:3-8 HFP-11 "E/L3/WC/2F/SD8/CORR NR AHU"
					-- 7:3-9 HFP-11 "E/L3/WC/2F/SD9/CORR NR AHU"
					-- 7:3-10 HTRI-R "E/L3/WC/2F/CM10/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:3-11 HFP-11 "E/L3/WC/2F/SD11/AHU RM SD"
					-- 7:3-12 HTRI-R "E/L3/WC/2F/CM12/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 7:3-13 HFP-11 "E/L3/WC/2F/SD13/LIFT LOBBY SD"
					-- 7:3-14 HFP-11 "E/L3/WC/2F/SD14/LIFT LOBBY SD"
					-- 7:3-15 HTRI-R "E/L3/WC/2F/CM15/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:3-16 HMS-S/D/M/SA "E/L3/WC/2F/MCP16/FIRE SHAFT L.L."
					-- 7:3-17 HTRI-S "E/L3/WC/2F/MM17/FIRE SHAFT L.L."
					-- 7:3-18 HFP-11 "E/L3/WC/2F/SD18/ELECT RM SD"
					-- 7:3-19 HTRI-R "E/L3/WC/2F/CM19/DR RELESE NR E.R"
					-- Switch ""
					-- Relay
					-- 7:3-20 HFP-11 "E/L3/WC/2F/SD20/CORR NR 2020"
					-- 7:3-21 HFP-11 "E/L3/WC/2F/SD21/CORR NR 2200"
					-- 7:3-22 HFP-11 "E/L3/WC/2F/SD22/CORR NR 2050"
					-- 7:3-23 HFP-11 "E/L3/WC/2F/SD23/CORR NR 2180"
					-- 7:3-24 HFP-11 "E/L3/WC/2F/SD24/CORR NR 2070"
					-- 7:3-25 HFP-11 "E/L3/WC/1F/SD25/CORR NR 1200"
					-- 7:3-26 HFP-11 "E/L3/WC/1F/SD26/CORR NR 1230"
					-- 7:3-27 HFP-11 "E/L3/WC/1F/SD27/CORR NR 1230"
					-- 7:3-28 HFP-11 "E/L3/WC/1F/SD28/CORR NR 1170"
					-- 7:3-29 HFP-11 "E/L3/WC/1F/SD29/SMALL CORR "
					-- 7:3-30 HFP-11 "E/L3/WC/1F/SD30/SMALL CORR "
					-- 7:3-31 HTRI-R "E/L3/WC/1F/CM31/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:3-32 HFP-11 "E/L3/WC/1F/SD32/AHU RM SD"
					-- 7:3-33 HTRI-R "E/L3/WC/1F/CM33/DR RELESE CM AHU"
					-- Switch ""
					-- Relay
					-- 7:3-34 HFP-11 "E/L3/WC/1F/SD34/LIFT LOBBY SD"
					-- 7:3-35 HFP-11 "E/L3/WC/1F/SD35/LIFT LOBBY SD"
					-- 7:3-36 HTRI-R "E/L3/WC/1F/CM36/FIRE SHAFT L.L."

```

7 Desigo Fire Safety Modular "BDB TOWER E" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      7:3 XDLC "DLC @ address 3 L3"
        7:3-36 HTRI-R "E/L3/WC/1F/CM36/FIRE SHAFT L.L."

```

```
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:3-37 HMS-S/D/M/SA "E/L3/WC/1F/MCP37/FIRE SHAFT L.L."
| | | | | |-- 7:3-38 HTRI-S "E/L3/WC/1F/MM38/FIRE SHAFT L.L."
| | | | | |-- 7:3-39 HTRI-R "E/L3/WC/1F/CM39/DR RELESE CM "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:3-40 HFP-11 "E/L3/WC/1F/SD40/ELECT RM SD"
| | | | | |-- 7:3-41 HFP-11 "E/L3/WC/1F/SD41/CORR NR 1020"
| | | | | |-- 7:3-42 HFP-11 "E/L3/WC/1F/SD42/CORR NR 1020"
| | | | | |-- 7:3-43 HFP-11 "E/L3/WC/1F/SD43/CORR NR 1100"
| | | | | |-- 7:3-44 HFP-11 "E/L3/WC/1F/SD44/CORR NR 1070"
| | | | | |-- 7:3-45 HFP-11 "E/L3/WC/1F/SD45/CORR NR EW1070"
| | | | | |-- 7:3-55 HTRI-S "E/L3/2F/MM55/EW2170"
| | | | | |-- 7:3-56 HTRI-S "E/L3/2F/MM56/EW2200"
| | | | | |-- 7:3-60 HTRI-S "E/L3/2F/MM60/EW2040"
| | | | | |-- 7:3-61 HTRI-S "E/L3/2F/MM61/EW2200 (B) "
| | | | | |-- 7:3-62 HTRI-S "E/L3/2F/MM62/EW2030"
| | | | | |-- 7:3-63 HTRI-S "E/L3/2F/MM63/EW2020"
| | | | | |-- 7:3-64 HTRI-S "E/L3/2F/MM64/EW2010"
| | | | | |-- 7:3-65 HTRI-S "E/L3/2F/MM65/DW2220"
| | | | | |-- 7:3-67 HTRI-S "E/L3/2F/MM67/DW2200"
| | | | | |-- 7:3-80 HTRI-S "E/L3/1F/MM80/EW1050"
| | | | | |-- 7:3-81 HTRI-S "E/L3/1F/MM81/EW1090"
| | | | | |-- 7:3-82 HTRI-S "E/L3/1F/MM82/EW1100"
| | | | | |-- 7:3-85 HTRI-S "E/L3/1F/MM85/EW1110"
| | | | | |-- 7:3-86 HTRI-S "E/L3/1F/MM86/EW1120"
| | | | | |-- 7:3-88 HTRI-S "E/L3/1F/MM88/EW1130"
| | | | | |-- 7:3-90 HTRI-S "E/L3/1F/MM90/EW1011"
| | | | | |-- 7:3-91 HTRI-S "E/L3/1F/MM91/EW1140"
| | | | | |-- 7:3-92 HTRI-S "E/L3/1F/MM92/EW1150"
| | | | | |-- 7:3-96 HTRI-S "E/L3/1F/MM96/EW1220"
| | | | | |-- 7:3-98 HTRI-S "E/L3/1F/MM98/EW1180"
| | | | | |-- 7:3-100 HTRI-S "E/L3/1F/MM100/EW1200"
| | | | | |-- 7:3-102 HFP-11 "E/L3/DW2250/SD102/Account cab"
| | | | | |-- 7:3-103 HFP-11 "E/L3/DW2250/SD103/Main cab"
| | | | | |-- 7:3-104 HFP-11 "E/L3/DW2250/SD104/Psg nr Main ca"
| | | | | |-- 7:3-105 HFP-11 "E/L3/DW2250/SD105/Assorter cab"
| | | | | |-- 7:3-106 HTRI-R "E/L3/DW2250/CM106/Psg nr Entry"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:3-107 HMS-S/D/M/SA "E/L3/DW2250/MCP107/Psg nr Entry"
| | | | | |-- 7:3-108 HFP-11 "E/L3/DW2190/SD108/Pantry"
| | | | | |-- 7:3-109 HFP-11 "E/L3/DW2190/SD109/Managers cab 2"
| | | | | |-- 7:3-110 HFP-11 "E/L3/DW2190/SD110/Managers cab 1"
| | | | | |-- 7:3-111 HFP-11 "E/L3/DW2190/SD111/Directors cab"
| | | | | |-- 7:3-112 HTRI-R "E/L3/DW2190/CM112/Psg nr Entry"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:3-113 HMS-S/D/M/SA "E/L3/DW2190/MCP113/Psq nr Entry"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-114 HFP-11 "E/L3/DW2240/SD114/Pantry"
					-- 7:3-115 HFP-11 "E/L3/DW2240/SD115/Main cab"
					-- 7:3-116 HTRI-R "E/L3/DW2240/CM116/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 7:3-117 HMS-S/D/M/SA "E/L3/DW2240/MCP117/Psg nr Entry"
					-- 7:3-118 HFP-11 "E/L3/DW2230/SD118/Pantry"
					-- 7:3-119 HFP-11 "E/L3/DW2230/SD119/Main cab"
					-- 7:3-120 HTRI-R "E/L3/DW2230/CM120/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 7:3-121 HMS-S/D/M/SA "E/L3/DW2230/MCP121/Psg nr Entry"
					-- 7:3-122 HFP-11 "E/L3/DW2210/SD122/Cab 1"
					-- 7:3-123 HFP-11 "E/L3/DW2210/SD123/Cab 2"
					-- 7:3-125 HFP-11 "E/L3/DW2210/SD125/Main cab"
					-- 7:3-126 HFP-11 "E/L3/DW2210/SD126/Psg nr Cab 2"
					-- 7:3-127 HTRI-R "E/L3/DW2210/CM127/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 7:3-128 HMS-S/D/M/SA "E/L3/DW2210/MCP128/Psg nr Entry"
					-- 7:3-129 HFP-11 "E/L3/EW2050/SD129/Main cab"
					-- 7:3-130 HFP-11 "E/L3/EW2050/SD130/Assorter cab"
					-- 7:3-131 HFP-11 "E/L3/EW2050/SD131/Psg nr Assorte"
					-- 7:3-132 HFP-11 "E/L3/EW2050/SD132/Accounts cab"
					-- 7:3-133 HFPT-11 "E/L3/EW2050/HD133/Pantry"
					-- 7:3-134 HTRI-R "E/L3/EW2050/CM134/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-135 HMS-S/D/M/SA "E/L3/EW2050/MCP135/Entry dr Psg"
					-- 7:3-136 HFP-11 "E/L3/EW2190/SD136/Main cab"
					-- 7:3-137 HFP-11 "E/L3/EW2190/SD137/Account cab"
					-- 7:3-138 HFP-11 "E/L3/EW2190/SD138/Account cab Ps"
					-- 7:3-139 HTRI-R "E/L3/EW2190/CM139/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-140 HMS-S/D/M/SA "E/L3/EW2190/MCP140/Entry dr Psg"
					-- 7:3-146 HFP-11 "E/L3/EW1020/SD146/Main cab"
					-- 7:3-147 HFP-11 "E/L3/EW1020/SD147/Assorter cab"
					-- 7:3-148 HFP-11 "E/L3/EW1020/SD148/Account cab"
					-- 7:3-149 HFP-11 "E/L3/EW1020/SD149/Account cab ps"
					-- 7:3-150 HFP-11 "E/L3/EW1020/SD150/Pantry"
					-- 7:3-151 HTRI-R "E/L3/EW1020/CM151/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-152 HMS-S/D/M/SA "E/L3/EW1020/MCP152/Entry dr Psg"
					-- 7:3-153 HFP-11 "E/L3/EW1160/SD153/Entry Psg"
					-- 7:3-154 HFP-11 "E/L3/EW1160/SD154/Entry Psg"
					-- 7:3-155 HFP-11 "E/L3/EW1160/SD155/Pantry"
					-- 7:3-156 HFP-11 "E/L3/EW1160/SD156/Main cab1"
					-- 7:3-157 HFP-11 "E/L3/EW1160/SD157/Main cab2"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-158 HFP-11 "E/L3/EW1160/SD158/Assorter cab1"
					-- 7:3-159 HFP-11 "E/L3/EW1160/SD159/Assorter cab2"
					-- 7:3-160 HFP-11 "E/L3/EW1160/SD160/Accounts cab"
					-- 7:3-161 HTRI-R "E/L3/EW1160/CM161/Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:3-162 HMS-S/D/M/SA "E/L3/EW1160/MCP162/Entry Psg"
					-- 7:3-163 HFP-11 "E/L3/EW2060/SD163/Main cab"
					-- 7:3-164 HFP-11 "E/L3/EW2060/SD164/Assorter cab"
					-- 7:3-165 HFP-11 "E/L3/EW2060/SD165/Psg nr Assorte"
					-- 7:3-166 HFP-11 "E/L3/EW2060/SD166/Pantry"
					-- 7:3-167 HTRI-R "E/L3/EW2060/CM167/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-168 HMS-S/D/M/SA "E/L3/EW2060/MCP168/Entry dr Psg"
					-- 7:3-169 HFP-11 "E/L3/EW1190/SD169/Assorter cab"
					-- 7:3-170 HFP-11 "E/L3/EW1190/SD170/Main cab"
					-- 7:3-171 HFP-11 "E/L3/EW1190/SD171/Psg nr Main ca"
					-- 7:3-172 HTRI-R "E/L3/EW1190/CM172/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-173 HMS-S/D/M/SA "E/L3/EW1190/MCP173/Entry dr Psg"
					-- 7:3-174 HFP-11 "E/L3/EW2180/SD174/Main cab"
					-- 7:3-175 HFP-11 "E/L3/EW2180/SD175/Assorter cab"
					-- 7:3-176 HFP-11 "E/L3/EW2180/SD176/Entry Psg"
					-- 7:3-177 HTRI-R "E/L3/EW2180/CM177/Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:3-178 HMS-S/D/M/SA "E/L3/EW2180/MCP178/Entry Psg"
					-- 7:3-179 HFP-11 "E/L3/EW1030/SD179/Main cab"
					-- 7:3-180 HFP-11 "E/L3/EW1030/SD180/Assorter cab"
					-- 7:3-181 HFP-11 "E/L3/EW1030/SD181/Psg nr Assorte"
					-- 7:3-182 HFPT-11 "E/L3/EW1030/HD182/Pantry"
					-- 7:3-183 HTRI-R "E/L3/EW1030/CM183/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-184 HMS-S/D/M/SA "E/L3/EW1030/MCP184/Entry dr Psg"
					-- 7:3-185 HFP-11 "E/L3/EW1070/SD185/Main cab"
					-- 7:3-186 HFP-11 "E/L3/EW1070/SD186/Assorter cab"
					-- 7:3-187 FDOT421 "E/L3/EW1070/SD187/AFC Assorter c"
					-- 7:3-188 FDOT421 "E/L3/EW1070/SD188/Entry dr Psg"
					-- 7:3-189 HTRI-R "E/L3/EW1070/CM189/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-190 HMS-S/D/M/SA "E/L3/EW1070/MCP190/Entry dr Psg"
					-- 7:3-191 HFP-11 "E/L3/EW1170/SD191/Sales dept"
					-- 7:3-192 HFP-11 "E/L3/EW1170/SD192/Sales dept"
					-- 7:3-193 HFP-11 "E/L3/EW1170/SD193/Purchase dept"
					-- 7:3-194 HFPT-11 "E/L3/EW1170/HD194/Pantry"
					-- 7:3-195 HFP-11 "E/L3/EW1170/SD195/Psg nr Pantry"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-196 HFP-11 "E/L3/EW1170/SD196/Account dept"
					-- 7:3-197 HFP-11 "E/L3/EW1170/SD197/Cab nr Entry"
					-- 7:3-198 HFP-11 "E/L3/EW1170/SD198/Reception Psg"
					-- 7:3-199 HTRI-R "E/L3/EW1170/CM199/Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:3-200 HMS-S/D/M/SA "E/L3/EW1170/MCP200/Entry Psg"
					-- 7:3-201 HFP-11 "E/L3/EW2060/SD201/Cab 1"
					-- 7:3-202 HFP-11 "E/L3/EW2060/SD202/Cab 2"
					-- 7:3-203 HFP-11 "E/L3/EW2060/SD203/Cab 3"
					-- 7:3-204 HFP-11 "E/L3/EW2060/SD204/Cab 4"
					-- 7:3-205 HFP-11 "E/L3/EW2060/SD205/Pantry Psg"
					-- 7:3-206 HFP-11 "E/L3/EW2060/SD206/Pantry"
					-- 7:3-207 HFP-11 "E/L3/EW2060/SD207/Entry Psg"
					-- 7:3-210 HFP-11 "E/L3/EW1080/SD210/Main cab"
					-- 7:3-211 HFP-11 "E/L3/EW1080/SD211/Entry psg"
					-- 7:3-212 HTRI-R "E/L3/EW1080/CM212/Entry psg"
					-- Switch ""
					-- Relay
					-- 7:3-213 HMS-S/D/M/SA "E/L3/EW1080/MCP213/Entry psg"
					-- 7:3-243 HFP-11 "E/L3/EW1230/SD243/Main cab"
					-- 7:3-244 HFP-11 "E/L3/EW1230/SD244/Assorter cab"
					-- 7:3-245 HFP-11 "E/L3/EW1230/SD245/Assorter cab"
					-- 7:3-246 HFP-11 "E/L3/EW1230/SD246/Pantry"
					-- 7:3-247 HMS-S/D/M/SA "E/L3/EW1230/MCP247/Entry psg"
					-- 7:3-248 HTRI-R "E/L3/EW1230/CM248/AFC Pantry"
					-- Switch ""
					-- Relay
					-- 7:3-46 HTRI-S "E/L3/2F/MM46/DW2180"
					-- 7:3-47 HTRI-S "E/L3/2F/MM47/DW2170"
					-- 7:3-89 HTRI-S "E/L3/1F/MM89/EW1012"
					-- 7:3-49 HTRI-S "E/L3/2F/MM49/DW2260"
					-- 7:3-214 HFP-11 "E/L3/EW1170/SD214/psg Nr Assoter"
					-- 7:3-215 HFP-11 "E/L3/EW1060/SD215/Main Cabin"
					-- 7:3-216 HFP-11 "E/L3/EW1060/SD216/Account Cab"
					-- 7:3-217 HFP-11 "E/L3/EW1060/SD217/Assoter Cab"
					-- 7:3-219 HTRI-R "E/L3/EW1060/CM219/Afc Entry psg"
					-- Switch ""
					-- Relay
					-- 7:3-220 HMS-S/D/M/SA "E/L3/EW1060/MCP220/Entry Dr psg"
					-- 7:3-218 HFPT-11 "L3/EW1060/HD218/Pantry"
					-- 7:4 XDLC "DLC @ address 4 L4"
					-- 7:4-4 HFP-11 "E/L4/5F/SD4/CORR NR 5/S19"
					-- 7:4-5 HFP-11 "E/L4/5F/SD5/CORR NR 5183"
					-- 7:4-6 HFP-11 "E/L4/5F/SD6/CORR NR 5183"
					-- 7:4-9 HFP-11 "E/L4/5F/SD9/ELECT RM SD"
					-- 7:4-10 HMS-S/D/M/SA "E/L4/5F/MCP10/FIRE SHAFT L.L."
					-- 7:4-11 HTRI-R "E/L4/5F/CM11/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:4 XDLC "DLC @ address 4 L4"

					-- 7:4-12 HTRI-S "E/L4/5F/MM12/FIRE SHAFT L.L."
					-- 7:4-13 HFP-11 "E/L4/5F/SD13/AHU RM SD"
					-- 7:4-14 HTRI-R "E/L4/5F/CM14/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:4-17 HFP-11 "E/L4/5F/SD17/ELECT RM SD"
					-- 7:4-18 HFP-11 "E/L4/5F/SD18/AHU RM SD"
					-- 7:4-19 HTRI-R "E/L4/5F/CM19/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:4-20 HFP-11 "E/L4/5F/SD20/LIFT LOBBY SD "
					-- 7:4-21 HMS-S/D/M/SA "E/L4/5F/MCP21/FIRE SHAFT L.L."
					-- 7:4-22 HTRI-R "E/L4/5F/CM22/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:4-23 HTRI-S "E/L4/5F/MM23/FIRE SHAFT L.L."
					-- 7:4-24 HTRI-R "E/L4/4F/CM24/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 7:4-25 HFP-11 "E/L4/4F/SD25/CORR NR E.R."
					-- 7:4-26 HFP-11 "E/L4/4F/SD26/CORR NR E.R."
					-- 7:4-27 HFP-11 "E/L4/4F/SD27/CORR NR EC 4051"
					-- 7:4-28 HFP-11 "E/L4/4F/SD28/CORR NR EC 4051"
					-- 7:4-29 HFP-11 "E/L4/4F/SD29/CORR NR FIRE EXIT"
					-- 7:4-30 HMS-S/D/M/SA "E/L4/4F/MCP30/FIRE ESC STR"
					-- 7:4-31 HTRI-R "E/L4/4F/CM31/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:4-32 HFP-11 "E/L4/4F/SD32/CORR NR 4060"
					-- 7:4-33 HFP-11 "E/L4/4F/SD33/CORR NR EC4 S/20"
					-- 7:4-34 HFP-11 "E/L4/4F/SD34/CORR NR 4071"
					-- 7:4-35 HFP-11 "E/L4/4F/SD35/CORR NR 4072"
					-- 7:4-36 HFP-11 "E/L4/4F/SD36/CORR NR 4072"
					-- 7:4-37 HFP-11 "E/L4/4F/SD37/CORR NR 4080"
					-- 7:4-38 HTRI-R "E/L4/4F/CM38/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 7:4-39 HFP-11 "E/L4/4F/SD39/LIFT LOBBY SD"
					-- 7:4-40 HFP-11 "E/L4/4F/SD40/LIFT LOBBY SD"
					-- 7:4-41 HFP-11 "E/L4/4F/SD41/ELEC.RM"
					-- 7:4-42 HFP-11 "E/L4/4F/SD42/AHU RM SD"
					-- 7:4-43 HTRI-R "E/L4/4F/CM43/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:4-44 HFP-11 "E/L4/4F/SD44/CORR NR 4101"
					-- 7:4-45 HFP-11 "E/L4/4F/SD45/CORR NR 4101"
					-- 7:4-46 HFP-11 "E/L4/4F/SD46/CORR NR 4013"
					-- 7:4-47 HFP-11 "E/L4/4F/SD47/CORR NR 4013"
					-- 7:4-50 HFP-11 "E/L4/4F/SD50/ELECT RM SD"
					-- 7:4-51 HFP-11 "E/L4/4F/SD51/AHU RM SD"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:4 XDLC "DLC @ address 4 L4"

```
| | | | | |-- 7:4-52 HTRI-R "E/L4/4F/CM52/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:4-53 HFP-11 "E/L4/4F/SD53/LIFT LOBBY SD"
| | | | | |-- 7:4-54 HTRI-S "E/L4/4F/MM54/FIRE SHAFT L.L."
| | | | | |-- 7:4-55 XTRI-R "E/L4/4F/CM55/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:4-56 HMS-S/D/M/SA "E/L4/4F/MCP56/FIRE SHAFT L.L."
| | | | | |-- 7:4-57 HMS-S/D/M/SA "E/L4/4F/MCP57/FIRE SHAFT L.L."
| | | | | |-- 7:4-58 HTRI-R "E/L4/4F/CM58/FIRE SHATFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:4-59 HTRI-S "E/L4/4F/MM59/FIRE SHAFT L.L."
| | | | | |-- 7:4-60 HTRI-R "E/L4/4F/CM60/DR RELELSE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:4-70 HTRI-S "E/L4/5F/MM70/EC5021"
| | | | | |-- 7:4-72 HTRI-S "E/L4/5F/MM72/EC5010"
| | | | | |-- 7:4-75 HTRI-S "E/L4/4F/MM75/EC4016 ""
| | | | | |-- 7:4-77 HTRI-S "E/L4/4F/MM77/EC4013A"
| | | | | |-- 7:4-78 HTRI-S "E/L4/4F/MM78/EC4102 ""
| | | | | |-- 7:4-79 HTRI-S "E/L4/4F/MM79/EC4091"
| | | | | |-- 7:4-80 HTRI-S "E/L4/4F/MM80/EC4101"
| | | | | |-- 7:4-81 HTRI-S "E/L4/4F/MM81/EC4080B ""
| | | | | |-- 7:4-82 HTRI-S "E/L4/4F/MM82/EC4011"
| | | | | |-- 7:4-83 HTRI-S "E/L4/4F/MM83/EC4072"
| | | | | |-- 7:4-87 HTRI-S "E/L4/4F/MM87/EC4060"
| | | | | |-- 7:4-88 HTRI-S "E/L4/4F/MM88/EC4030"
| | | | | |-- 7:4-89 HTRI-S "E/L4/4F/MM89/EC4051"
| | | | | |-- 7:4-90 HTRI-S "E/L4/4F/MM90/EC4040"
| | | | | |-- 7:4-91 HTRI-S "E/L4/5F/MM91/EE5011"
| | | | | |-- 7:4-92 HTRI-S "E/L4/4F/MM92/EE4011"
| | | | | |-- 7:4-93 HFP-11 "E/L4/EC4012/SD93/Main cab"
| | | | | |-- 7:4-94 HFP-11 "E/L4/EC4012/SD94/Main cab"
| | | | | |-- 7:4-95 HFP-11 "E/L4/EC4012/SD95/Account cab"
| | | | | |-- 7:4-96 HFP-11 "E/L4/EC4012/SD96/Assorter cab"
| | | | | |-- 7:4-97 HFP-11 "E/L4/EC4012/SD97/Psg nr Account "
| | | | | |-- 7:4-98 HFP-11 "E/L4/EC4012/SD98/Pantry"
| | | | | |-- 7:4-99 HTRI-R "E/L4/EC4012/CM99/Entry dr Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:4-100 HMS-S/D/M/SA "E/L4/EC4012/MCP100/Entry dr Psg"
| | | | | |-- 7:4-101 HFP-11 "E/L4/EC4071/SD101/Assorter cab n"
| | | | | |-- 7:4-102 HFP-11 "E/L4/EC4071/SD102/Pantry"
| | | | | |-- 7:4-103 HFP-11 "E/L4/EC4071/SD103/Assorter cab"
| | | | | |-- 7:4-104 HFP-11 "E/L4/EC4071/SD104/Main cab1"
| | | | | |-- 7:4-105 HFP-11 "E/L4/EC4071/SD105/Main cab2"
| | | | | |-- 7:4-106 HFP-11 "E/L4/EC4071/SD106/Accounts cab"
| | | | | |-- 7:4-107 HTRI-R "E/L4/EC4071/CM107/AFC Entry dr P"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:4 XDLC "DLC @ address 4 L4"

7:4-107 HTRI-R "E/L4/EC4071/CM107/AFC Entry dr P"

```
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-108 HMS-S/D/M/SA "E/L4/EC4071/MCP108/Entry dr Psg"
| | | | |-- 7:4-109 HFP-11 "E/L4/EC4020/SD109/Reception"
| | | | |-- 7:4-110 HFP-11 "E/L4/EC4020/SD110/Assorter cab"
| | | | |-- 7:4-111 HFP-11 "E/L4/EC4020/SD111/Main cab"
| | | | |-- 7:4-112 HFP-11 "E/L4/EC4020/SD112/Main cab"
| | | | |-- 7:4-113 HFP-11 "E/L4/EC4020/SD113/Buyers cab1"
| | | | |-- 7:4-114 HFP-11 "E/L4/EC4020/SD114/Accounts cab"
| | | | |-- 7:4-115 HFPT-11 "E/L4/EC4020/HD115/Pantry"
| | | | |-- 7:4-116 HFP-11 "E/L4/EC4020/SD116/Buyers cab2"
| | | | |-- 7:4-117 HFP-11 "E/L4/EC4020/SD117/Psg nr Buyers "
| | | | |-- 7:4-118 HFP-11 "E/L4/EC4020/SD118/Entry Psg"
| | | | |-- 7:4-119 HTRI-R "E/L4/EC4020/CM119/Entry Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-120 HMS-S/D/M/SA "E/L4/EC4020/MCP120/Accounts cab"
| | | | |-- 7:4-121 HFP-11 "E/L4/EC4091/SD121/Main cab 1"
| | | | |-- 7:4-122 HFP-11 "E/L4/EC4091/SD122/Main cab 2"
| | | | |-- 7:4-123 HFP-11 "E/L4/EC4091/SD123/Main cab 3"
| | | | |-- 7:4-124 HFP-11 "E/L4/EC4091/SD124/Accounts cab"
| | | | |-- 7:4-125 HFP-11 "E/L4/EC4091/SD125/Assorter cab"
| | | | |-- 7:4-126 HFP-11 "E/L4/EC4091/SD126/Psg nr Assort."
| | | | |-- 7:4-127 HFP-11 "E/L4/EC4091/SD127/Psg nr Main ca"
| | | | |-- 7:4-128 HFP-11 "E/L4/EC4091/SD128/Accounts cab"
| | | | |-- 7:4-129 HFP-11 "E/L4/EC4091/SD129/Pantry"
| | | | |-- 7:4-130 HFP-11 "E/L4/EC4091/SD130/Entry psg"
| | | | |-- 7:4-131 HTRI-R "E/L4/EC4091/CM131/Entry psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-132 HMS-S/D/M/SA "E/L4/EC4091/MCP132/Entry psg"
| | | | |-- 7:4-71 HTRI-S "E/L4/4F/MM71/EE4014"
| | | | |-- 7:4-133 HFP-11 "E/L4/EC4071/SD133/ENTRY PSG"
| | | | |-- 7:4-134 HFP-11 "E/L4/EC4071/SD134/MAIN CABIN 2"
| | | | |-- 7:4-135 HTRI-S "E/L4/4F/MM135/EE4015"
| | | | |-- 7:5 XDLC "DLC @ address 5 L5"
| | | | |-- 7:5-1 HFP-11 "E/L5/WC/4F/SD1/CORR NR 4130"
| | | | |-- 7:5-2 HFP-11 "E/L5/WC/4F/SD2/CORR NR 4150"
| | | | |-- 7:5-3 HFP-11 "E/L5/WC/4F/SD3/CORR NR 4150"
| | | | |-- 7:5-4 HFP-11 "E/L5/WC/4F/SD4/CORR NR 4170"
| | | | |-- 7:5-5 HFP-11 "E/L5/WC/4F/SD5/CORR NR 4190"
| | | | |-- 7:5-6 HFP-11 "E/L5/WC/4F/SD6/CORR NR 4190"
| | | | |-- 7:5-7 HFP-11 "E/L5/WC/4F/SD7/CORR NR 4220"
| | | | |-- 7:5-8 HTRI-R "E/L5/WC/4F/CM8/DR RELESE 5 TO 4 "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:5-9 HMS-S/D/M/SA "E/L5/WC/4F/MCP9/FIRE SHAFT L.L."
| | | | |-- 7:5-10 HTRI-R "E/L5/WC/4F/CM10/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

			-- 7:5-11 HTRI-S "E/L5/WC/4F/MM11/FIRE SHAFT L.L."
			-- 7:5-12 HFP-11 "E/L5/WC/4F/SD12/LIFT LOBBY SD"
			-- 7:5-13 HFP-11 "E/L5/WC/4F/SD13/LIFT LOBBY SD"
			-- 7:5-14 HFP-11 "E/L5/WC/4F/SD14/ELECT RM SD"
			-- 7:5-15 HTRI-R "E/L5/WC/4F/CM15/DR RELEASE 5 TO 6"
			-- Switch ""
			-- Relay
			-- 7:5-16 HFP-11 "E/L5/WC/4F/SD16/CORR NR 4010"
			-- 7:5-17 HFP-11 "E/L5/WC/4F/SD17/CORR NR 4020"
			-- 7:5-18 HFP-11 "E/L5/WC/4F/SD18/CORR NR 4050"
			-- 7:5-19 HFP-11 "E/L5/WC/4F/SD19/CORR NR 4060"
			-- 7:5-20 HFP-11 "E/L5/WC/4F/SD20/CORR NR 4080"
			-- 7:5-21 HFP-11 "E/L5/WC/3F/SD21/CORR NR EW S/11"
			-- 7:5-22 HFP-11 "E/L5/WC/3F/SD22/CORR NR EW S/11"
			-- 7:5-23 HFP-11 "E/L5/WC/3F/SD23/CORR NR DW 3240"
			-- 7:5-24 HFP-11 "E/L5/WC/3F/SD24/CORR NR 3260"
			-- 7:5-25 HFP-11 "E/L5/WC/3F/SD25/CORR NR 3270"
			-- 7:5-26 HFP-11 "E/L5/WC/3F/SD26/CORR NR EW3/S13"
			-- 7:5-27 HFP-11 "E/L5/WC/3F/SD27/CORR NR 3301"
			-- 7:5-28 HFP-11 "E/L5/WC/3F/SD28/CORR NR DR"
			-- 7:5-29 HTRI-R "E/L5/WC/3F/CM29/DR RELEASE CM"
			-- Switch ""
			-- Relay
			-- 7:5-30 HMS-S/D/M/SA "E/L5/WC/3F/MCP30/FIRE SHAFT L.L."
			-- 7:5-31 HTRI-R "E/L5/WC/3F/CM31/FIRE SHAFT L.L."
			-- Switch ""
			-- Relay
			-- 7:5-32 HTRI-S "E/L5/WC/3F/MM32/FIRE SHAFT L.L."
			-- 7:5-33 HFP-11 "E/L5/WC/3F/SD33/LIFT LOBBY SD"
			-- 7:5-34 HFP-11 "E/L5/WC/3F/SD34/LIFT LOBBY SD"
			-- 7:5-35 HFP-11 "E/L5/WC/3F/SD35/ELECT RM SD"
			-- 7:5-36 HTRI-R "E/L5/WC/3F/CM36/DR RELEASE CM"
			-- Switch ""
			-- Relay
			-- 7:5-37 HFP-11 "E/L5/WC/3F/SD37/CORR NR "
			-- 7:5-38 HFP-11 "E/L5/WC/3F/SD38/CORR NR 3020"
			-- 7:5-39 HFP-11 "E/L5/WC/3F/SD39/CORR NR 3051"
			-- 7:5-40 HFP-11 "E/L5/WC/3F/SD40/CORR NR 3052"
			-- 7:5-41 HFP-11 "E/L5/WC/3F/SD41/CORR NR EW S/17"
			-- 7:5-42 HTRI-R "E/L5/WC/4F/CM42/FIRE SHAFT "
			-- Switch ""
			-- Relay
			-- 7:5-43 HMS-S/D/M/SA "E/L5/WC/4F/MCP43/FIRE STR"
			-- 7:5-44 HTRI-R "E/L5/WC/4F/CM44/AHU ROOM"
			-- Switch ""
			-- Relay
			-- 7:5-45 HFP-11 "E/L5/WC/4F/SD45/AHU ROOM "
			-- 7:5-46 HTRI-R "E/L5/WC/3F/CM46/FIRE STR."
			-- Switch ""
			-- Relay

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

```
| | | |-- 7:5-47 HMS-S/D/M/SA "E/L5/WC/3F/MCP47/FIRE STR"
| | | |-- 7:5-48 HTRI-R "E/L5/WC/3F/CM48/AHU ROOM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-49 HFP-11 "E/L5/WC/3F/SD49/AHU ROOM"
| | | |-- 7:5-50 HTRI-S "E/L5/4F/MM50/EW4080"
| | | |-- 7:5-52 HTRI-S "E/L5/4F/MM52/EW4070"
| | | |-- 7:5-53 HTRI-S "E/L5/4F/MM53/EW4060"
| | | |-- 7:5-54 HTRI-S "E/L5/4F/MM54/EW4180"
| | | |-- 7:5-55 HTRI-S "E/L5/4F/MM55/EW4050"
| | | |-- 7:5-57 HTRI-S "E/W/4F/MM57/EW4010"
| | | |-- 7:5-58 HTRI-S "E/L5/4F/MM58/EW4020"
| | | |-- 7:5-64 HTRI-S "E/L5/4F/MM64/DW4170"
| | | |-- 7:5-67 HTRI-S "E/L5/4F/MM67/DW4150"
| | | |-- 7:5-68 HTRI-S "E/L5/4F/MM68/DW4240"
| | | |-- 7:5-69 HTRI-S "E/L5/4F/MM69/DW4140"
| | | |-- 7:5-71 HTRI-S "E/L5/4F/MM71/DW4250"
| | | |-- 7:5-72 HTRI-S "E/L5/4F/MM72/DW4120"
| | | |-- 7:5-74 HTRI-S "E/L5/3F/MM74/DW3330"
| | | |-- 7:5-75 HTRI-S "E/L5/3F/MM75/DW3220"
| | | |-- 7:5-78 HTRI-S "E/L5/3F/MM78/DW3320"
| | | |-- 7:5-79 HTRI-S "E/L5/3F/MM79/DW3250"
| | | |-- 7:5-81 HTRI-S "E/L5/3F/MM81/DW3260"
| | | |-- 7:5-86 HTRI-S "E/L5/3F/MM86/DW3290"
| | | |-- 7:5-90 HTRI-S "E/L5/3F/MM90/EW3040"
| | | |-- 7:5-91 HTRI-S "E/L5/W/3F/MM91/EW3051/52"
| | | |-- 7:5-92 HTRI-S "E/L5/3F/MM92/EW3170"
| | | |-- 7:5-95 HFP-11 "E/L5/DW4160/SD95/Main cab"
| | | |-- 7:5-96 HFP-11 "E/L5/DW4160/SD96/Assorter cab"
| | | |-- 7:5-97 HFP-11 "E/L5/DW4160/SD97/Accounts cab"
| | | |-- 7:5-98 HFP-11 "E/L5/DW4160/SD98/Psg nr MC"
| | | |-- 7:5-99 HFP-11 "E/L5/DW4160/SD99/Pantry"
| | | |-- 7:5-100 HTRI-R "E/L5/DW4160/CM100/AFC Entry Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-101 HMS-S/D/M/SA "E/L5/DW4160/MCP101/Entry Psg"
| | | |-- 7:5-102 HFP-11 "E/L5/DW4130/SD102/Assorter cab"
| | | |-- 7:5-103 HFP-11 "E/L5/DW4130/SD103/Main Cab"
| | | |-- 7:5-104 HFP-11 "E/L5/DW4130/SD104/Account cab"
| | | |-- 7:5-105 HFPT-11 "E/L5/DW4130/HD105/Pantry""
| | | |-- 7:5-106 HTRI-R "E/L5/DW4130/CM106/Psg nr Entry d"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-107 HMS-S/D/M/SA "E/L5/DW4130/MCP107/Psg nr Entry "
| | | |-- 7:5-108 HFP-11 "E/L5/DW4230/SD108/Main cab"
| | | |-- 7:5-109 HFP-11 "E/L5/DW4230/SD109/Main cab"
| | | |-- 7:5-110 HFPT-11 "E/L5/DW4230/HD110/Pantry"
| | | |-- 7:5-111 HTRI-R "E/L5/DW4230/CM111/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

				-- 7:5-112 HMS-S/D/M/SA "E/L5/DW4230/MCP112/Psg nr Entry"
				-- 7:5-113 HFPT-11 "E/L5/DW4180/HD113/Pantry"
				-- 7:5-114 HFP-11 "E/L5/DW4180/SD114/Accounts cab"
				-- 7:5-115 HFP-11 "E/L5/DW4180/SD115/Assorter cab"
				-- 7:5-116 HFP-11 "E/L5/DW4180/SD116/Main cab"
				-- 7:5-117 HFP-11 "E/L5/DW4180/SD117/Psg nr Account"
				-- 7:5-118 HTRI-R "E/L5/DW4180/CM118/Psg nr Entry d"
				-- Switch ""
				-- Relay
				-- 7:5-119 HMS-S/D/M/SA "E/L5/DW4180/MCP119/Psg nr Entry "
				-- 7:5-120 HFP-11 "E/L5/DW4190/SD120/Main cab"
				-- 7:5-121 HFP-11 "E/L5/DW4190/SD121/Assorter cab"
				-- 7:5-122 HFP-11 "E/L5/DW4190/SD122/Account cab"
				-- 7:5-123 HFP-11 "E/L5/DW4190/SD123/Psg nr Entry"
				-- 7:5-124 HFP-11 "E/L5/DW4190/SD124/Pantry"
				-- 7:5-125 HTRI-R "E/L5/DW4190/CM125/Psg nr Entry d"
				-- Switch ""
				-- Relay
				-- 7:5-126 HMS-S/D/M/SA "E/L5/DW4190/MCP126/Psg nr Entry "
				-- 7:5-127 HFPT-11 "E/L5/DW4220/HD127/Pantry"
				-- 7:5-128 HFP-11 "E/L5/DW4220/SD128/Psg nr Pantry"
				-- 7:5-129 HFP-11 "E/L5/DW4220/SD129/Accounts cab"
				-- 7:5-130 HFP-11 "E/L5/DW4220/SD130/Psg nr buyer c"
				-- 7:5-131 HFP-11 "E/L5/DW4220/SD131/Buyer cab 1"
				-- 7:5-132 HFP-11 "E/L5/DW4220/SD132/Buyer cab 2"
				-- 7:5-133 HFP-11 "E/L5/DW4220/SD133/Sales Cab"
				-- 7:5-134 HFP-11 "E/L5/DW4220/SD134/Main cab"
				-- 7:5-135 HFP-11 "E/L5/DW4220/SD135/GIA Cab"
				-- 7:5-136 HFP-11 "E/L5/DW4220/SD136/Buyer Cab 3"
				-- 7:5-137 HFP-11 "E/L5/DW4220/SD137/Buyer Cab 3"
				-- 7:5-138 HFP-11 "E/L5/DW4220/SD138/Reception"
				-- 7:5-139 HTRI-R "E/L5/DW4220/CM139/AFC Entry Psg"
				-- Switch ""
				-- Relay
				-- 7:5-140 HMS-S/D/M/SA "E/L5/DW4220/MCP140/Psg nr Entry"
				-- 7:5-142 HFP-11 "E/L5/EW4030/SD142/Main cab"
				-- 7:5-143 HFP-11 "E/L5/EW4030/SD143/Assorter cab"
				-- 7:5-144 HFP-11 "E/L5/EW4030/SD144/Psg nr Assorte"
				-- 7:5-145 HFPT-11 "E/L5/EW4030/HD145/Pantry"
				-- 7:5-146 HTRI-R "E/L5/EW4030/CM146/Entry dr PSg"
				-- Switch ""
				-- Relay
				-- 7:5-147 HMS-S/D/M/SA "E/L5/EW4030/MCP147/Entry dr PSg"
				-- 7:5-148 HFP-11 "E/L5/EW3020/SD148/Main cab"
				-- 7:5-149 HFP-11 "E/L5/EW3020/SD149/Account cab"
				-- 7:5-150 HFP-11 "E/L5/EW3020/SD150/Assorter cab"
				-- 7:5-151 HFP-11 "E/L5/EW3020/SD151/Pantry"
				-- 7:5-152 HTRI-R "E/L5/EW3020/CM152/Entry dr Psg"
				-- Switch ""
				-- Relay

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

			-- 7:5-153 HMS-S/D/M/SA "E/L5/EW3020/MCP153/Entry dr Psg"
			-- 7:5-154 HFP-11 "E/L5/EW3160/SD154/Main cab"
			-- 7:5-155 HFP-11 "E/L5/EW3160/SD155/Account cab"
			-- 7:5-156 HFP-11 "E/L5/EW3160/SD156/Assorter cab"
			-- 7:5-157 HFPT-11 "E/L5/EW3160/HD157/Entry dr Psg"
			-- 7:5-158 HTRI-R "E/L5/EW3160/CM158/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 7:5-159 HMS-S/D/M/SA "E/L5/EW3160/MCP159/Entry dr Psg"
			-- 7:5-160 HFP-11 "E/L5/EW4040/SD160/Main cab"
			-- 7:5-161 HFP-11 "E/L5/EW4040/SD161/Account cab"
			-- 7:5-162 HFP-11 "E/L5/EW4040/SD162/Psg nr Cab2"
			-- 7:5-163 HFP-11 "E/L5/EW4040/SD163/Cab 2"
			-- 7:5-164 HFP-11 "E/L5/EW4040/SD164/Pantry"
			-- 7:5-165 HTRI-R "E/L5/EW4040/CM165/Entry psg"
			-- Switch ""
			-- Relay
			-- 7:5-166 HMS-S/D/M/SA "E/L5/EW4040/MCP166/Entry psg"
			-- 7:5-168 HFP-11 "E/L5/DW3210/SD168/Pantry "
			-- 7:5-169 HFP-11 "E/L5/DW3210/SD169/Accounts cab"
			-- 7:5-170 HFP-11 "E/L5/DW3210/SD170/Assorter cab"
			-- 7:5-171 HFP-11 "E/L5/DW3210/SD171/Main cab"
			-- 7:5-172 HFP-11 "E/L5/DW3210/SD172/Psg nr Account"
			-- 7:5-173 HTRI-R "E/L5/DW3210/CM173/Psg nr Entry"
			-- Switch ""
			-- Relay
			-- 7:5-174 HMS-S/D/M/SA "E/L5/DW3210/MCP174/Psg nr Entry"
			-- 7:5-175 HFP-11 "E/L5/DW3230/SD175/Pantry "
			-- 7:5-176 HFP-11 "E/L5/DW3230/SD176/Psg nr Account"
			-- 7:5-177 HFP-11 "E/L5/DW3230/SD177/Accounts cab"
			-- 7:5-178 HFP-11 "E/L5/DW3230/SD178/Assorter cab"
			-- 7:5-179 HFP-11 "E/L5/DW3230/SD179/Executive cab"
			-- 7:5-180 HTRI-R "E/L5/DW3230/CM180/Psg nr Entry"
			-- Switch ""
			-- Relay
			-- 7:5-181 HMS-S/D/M/SA "E/L5/DW3230/MCP181/Psg nr Entry"
			-- 7:5-182 HFP-11 "E/L5/DW3240/SD182/Pantry "
			-- 7:5-183 HFP-11 "E/L5/DW3240/SD183/Cab 1"
			-- 7:5-184 HFP-11 "E/L5/DW3240/SD184/Cab 2"
			-- 7:5-185 HFP-11 "E/L5/DW3240/SD185/Main cab"
			-- 7:5-186 HFP-11 "E/L5/DW3240/SD186/Psg nr Cab 2"
			-- 7:5-188 HTRI-R "E/L5/DW3240/CM188/Psg nr Entry"
			-- Switch ""
			-- Relay
			-- 7:5-189 HMS-S/D/M/SA "E/L5/DW3240/MCP189/Psg nr Entry"
			-- 7:5-190 HFP-11 "E/L5/DW3310/SD190/Pantry "
			-- 7:5-191 HFP-11 "E/L5/DW3310/SD191/Main cab"
			-- 7:5-192 HTRI-R "E/L5/DW3310/CM192/Psg nr Entry"
			-- Switch ""
			-- Relay

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

```
| | | |-- 7:5-193 HMS-S/D/M/SA "E/L5/DW3310/MCP193/Psg nr Entry"
| | | |-- 7:5-194 HFP-11 "E/L5/DW3270/SD194/Main cab"
| | | |-- 7:5-195 HFP-11 "E/L5/DW3270/SD195/Assorter cab"
| | | |-- 7:5-196 HFP-11 "E/L5/DW3270/SD196/Entry Psg "
| | | |-- 7:5-197 HFP-11 "E/L5/DW3270/SD197/Account cab"
| | | |-- 7:5-198 HFP-11 "E/L5/DW3270/SD198/Pantry"
| | | |-- 7:5-199 HTRI-R "E/L5/DW3270/CM199/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-200 HFP-11 "E/L5/DW3280/SD200/Pantry "
| | | |-- 7:5-201 HFP-11 "E/L5/DW3280/SD201/Entry Psg"
| | | |-- 7:5-202 HFP-11 "E/L5/DW3280/SD202/Accounts cab"
| | | |-- 7:5-203 HFP-11 "E/L5/DW3280/SD203/Main cab"
| | | |-- 7:5-204 HFP-11 "E/L5/DW3280/SD204/Assorter cab"
| | | |-- 7:5-205 HTRI-R "E/L5/DW3280/CM205/Psg nr Assorte"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-206 HMS-S/D/M/SA "E/L5/DW3280/MCP206/Psg nr Assort"
| | | |-- 7:5-207 HFP-11 "E/L5/DW4200/SD207/Reception psg"
| | | |-- 7:5-208 HFP-11 "E/L5/DW4200/SD208/Buyer cab3"
| | | |-- 7:5-209 HFP-11 "E/L5/DW4200/SD209/Buyer cab4"
| | | |-- 7:5-210 HFP-11 "E/L5/DW4200/SD210/Acc cab"
| | | |-- 7:5-211 HFP-11 "E/L5/DW4200/SD211/Acc cab"
| | | |-- 7:5-212 HFP-11 "E/L5/DW4200/SD212/Account cab"
| | | |-- 7:5-213 HFP-11 "E/L5/DW4200/SD213/Marketing cab"
| | | |-- 7:5-214 HFP-11 "E/L5/DW4200/SD214/Kiran Shah cab"
| | | |-- 7:5-215 HFP-11 "E/L5/DW4200/SD215/Stock cab"
| | | |-- 7:5-216 HFP-11 "E/L5/DW4200/SD216/Buyer cab1"
| | | |-- 7:5-217 HFP-11 "E/L5/DW4200/SD217/Psgnr buyerC1"
| | | |-- 7:5-218 HFP-11 "E/L5/DW4200/SD218/Buyer cab2"
| | | |-- 7:5-219 HFP-11 "E/L5/DW4200/SD219/Psgnr buyer C2"
| | | |-- 7:5-220 HFP-11 "E/L5/DW4200/SD220/Pantry"
| | | |-- 7:5-221 HMS-S/D/M/SA "E/L5/DW4200/MCP221/Psg nr Entry"
| | | |-- 7:5-222 HTRI-R "E/L5/DW4200/CM222/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-231 HFP-11 "E/L5/EW4170/SD231/Cab 1"
| | | |-- 7:5-232 HFP-11 "E/L5/EW4170/SD232/Cab 2"
| | | |-- 7:5-233 HFP-11 "E/L5/EW4170/SD233/Cab 3"
| | | |-- 7:5-234 HFP-11 "E/L5/EW4170/SD234/Psg nr Cab 3"
| | | |-- 7:5-235 HFP-11 "E/L5/EW4170/SD235/AFC Entry dr P"
| | | |-- 7:5-236 HTRI-R "E/L5/EW4170/CM236/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-237 HMS-S/D/M/SA "E/L5/EW4170/MCP237/Entry dr Psg"
| | | |-- 7:5-238 HFP-11 "E/L5/EW4090/SD238/Main cab"
| | | |-- 7:5-239 HFP-11 "E/L5/EW4090/SD239/Assorter Cab"
| | | |-- 7:5-240 HFP-11 "E/L5/EW4090/SD240/Assorter Cab p"
| | | |-- 7:5-241 HFP-11 "E/L5/EW4090/SD241/Pantry "
| | | |-- 7:5-242 HTRI-R "E/L5/EW4090/CM242/Entry dr Psg"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

7:5-242 HTRI-R "E/L5/EW4090/CM242/Entry dr Psg"

```
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-243 HMS-S/D/M/SA "E/L5/EW4090/MCP243/Entry dr Psg"
| | | |-- 7:5-244 HFP-11 "E/L5/EW3010/SD244/Main cab"
| | | |-- 7:5-245 HFP-11 "E/L5/EW3010/SD245/account cab"
| | | |-- 7:5-246 HFP-11 "E/L5/EW3010/SD246/Entry Psg"
| | | |-- 7:5-247 HFPT-11 "E/L5/EW3010/HD247/Pantry"
| | | |-- 7:5-248 HTRI-R "E/L5/EW3010/CM248/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-249 HMS-S/D/M/SA "E/L5/EW3010/MCP249/Entry dr Psg"
| | | |-- 7:5-59 HFP-11 "E/L5/DW4210/SD59/Account Cab"
| | | |-- 7:5-60 HFP-11 "E/L5/DW4210/SD60/Assortor Cab"
| | | |-- 7:5-61 HFP-11 "E/L5/DW4210/SD61/Main Cab 1"
| | | |-- 7:5-62 HFP-11 "E/L5/DW4210/SD62/Store RM"
| | | |-- 7:5-63 HFP-11 "E/L5/DW4210/SD63/Main Cab2"
| | | |-- 7:5-65 HFP-11 "E/L5/DW4210/SD65/PSG NR Pantry"
| | | |-- 7:5-66 HFP-11 "E/L5/DW4210/SD66/Pantry"
| | | |-- 7:5-73 HMS-S/D/M/SA "E/L5/DW4210/MCP73/Entry Psg"
| | | |-- 7:5-70 HTRI-R "E/L5/DW4210/CM70/Entry Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-76 HFP-11 "E/L5/EW3060/SD76/Assoter cabin"
| | | |-- 7:5-77 HFP-11 "E/L5/EW3060/SD77/Assoter cabin"
| | | |-- 7:5-80 HFP-11 "E/L5/EW3060/SD80/Account cabin"
| | | |-- 7:5-82 HFP-11 "E/L5/EW3060/SD82/main cabin"
| | | |-- 7:5-83 HFP-11 "E/L5/EW3060/SD83/Assoter cabin"
| | | |-- 7:5-84 HFP-11 "E/L5/EW3060/SD84/pantry"
| | | |-- 7:5-85 HTRI-R "E/L5/EW3060/CM85/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-87 HMS-S/D/M/SA "E/L5/EW3060/MCP87/Entry dr Psg"
| | | |-- 7:5-223 HFP-11 "E/L5/EW3030/SD223/MAIN CAB"
| | | |-- 7:5-224 HFP-11 "E/L5/EW3030/SD224/Cab 1"
| | | |-- 7:5-225 HFP-11 "E/L5/EW3030/SD225/Cab 2"
| | | |-- 7:5-226 HFP-11 "E/L5/EW3030/SD226/account cab"
| | | |-- 7:5-227 HFP-11 "E/L5/EW3030/SD227/assoter cab"
| | | |-- 7:5-228 HFP-11 "E/L5/EW3030/SD/228/pantry"
| | | |-- 7:5-230 HTRI-R "E/L5/EW3030/CM230/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-229 HMS-S/D/M/SA "E/L5/EW3030/MCP229/Entry dr Psg"
| | | |-- 7:5-250 HFP-11 "E/L5/EW4090/SD250/Pantry"
| | | |-- 7:5-251 HFP-11 "E/L5/DW4130/SD251/Psg. Nr Accoun"
| | | |-- 7:5-94 HMS-S/D/M/SA "E/L5/DW3270/MCP94/Psg nr Entry"
| | |-- CC-5 "Card Cage 5 Slots"
| | | |-- 7:6 XDLC "DLC @ address 6 L6"
| | | | |-- 7:6-1 HTRI-R "E/L6/7F/CM1/EC door release"
| | | | |-- Switch ""
| | | | |-- Relay
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:6 XDLC "DLC @ address 6 L6"

					-- 7:6-2 HFP-11 "E/L6/7F/SD2/Corr. Nr EC plumbing"
					-- 7:6-3 HFP-11 "E/L6/7F/SD3/Corr. Nr EC plumbing"
					-- 7:6-4 HFP-11 "E/L6/7F/SD4/EC Small Corridor"
					-- 7:6-5 HFP-11 "E/L6/7F/SD5/EC Small Corridor"
					-- 7:6-6 HFP-11 "E/L6/7F/SD6/Corr. Nr EC7050"
					-- 7:6-7 HFP-11 "E/L6/7F/SD7/Corr. Nr EC7060"
					-- 7:6-8 HFP-11 "E/L6/7F/SD8/Corr. Nr EC7060"
					-- 7:6-9 HMS-S/D/M/SA "E/L6/7F/MCP9/EC Fire Escape dr"
					-- 7:6-10 HTRI-R "E/L6/7F/CM10/EC Fire Escape str"
					-- Switch ""
					-- Relay
					-- 7:6-11 HFP-11 "E/L6/7F/SD11/Corr. Nr EC7031"
					-- 7:6-12 HFP-11 "E/L6/7F/SD12/Corr. Nr EC7020"
					-- 7:6-13 HFP-11 "E/L6/7F/SD13/Corr. Nr EC7020"
					-- 7:6-14 HFP-11 "L6/E/7F/SD14/CORR NR EC 7081"
					-- 7:6-15 HFP-11 "L6/E/7F/SD15/CORR NR EC 7081"
					-- 7:6-16 HFP-11 "E/L6/7F/SD16/EC Electric rm"
					-- 7:6-17 HFP-11 "E/L6/7F/SD17/EC Lift Lobby"
					-- 7:6-18 HFP-11 "E/L6/7F/SD18/EC Lift Lobby"
					-- 7:6-19 HMS-S/D/M/SA "E/L6/7F/MCP19/EC Lift Lobby"
					-- 7:6-20 HTRI-R "E/L6/7F/CM20/EC Fire shaft dr"
					-- Switch ""
					-- Relay
					-- 7:6-21 HTRI-S "E/L6/7F/MM21/EC Fire shaft dr"
					-- 7:6-22 HFP-11 "E/L6/7F/SD22/EC AHU Rm"
					-- 7:6-23 HTRI-R "E/L6/7F/CM23/EC AHU Rm"
					-- Switch ""
					-- Relay
					-- 7:6-26 HFP-11 "E/L6/7F/SD26/EE Electric Rm"
					-- 7:6-27 HFP-11 "E/L6/7F/SD27/EE AHU Rm"
					-- 7:6-28 HTRI-R "E/L6/7F/CM28/EE AHU Rm"
					-- Switch ""
					-- Relay
					-- 7:6-29 HMS-S/D/M/SA "E/L6/7F/MCP29/EE Fire shaft Lift"
					-- 7:6-30 HTRI-R "E/L6/7F/CM30/EE Fire shaft Lift "
					-- Switch ""
					-- Relay
					-- 7:6-31 HTRI-S "E/L6/7F/MM31/EE Fire shaft Lift "
					-- 7:6-32 HFP-11 "E/L6/7F/SD32/EE Lift Lobby"
					-- 7:6-33 HTRI-R "E/L6/6F/CM33/EE Fire Shaft"
					-- Switch ""
					-- Relay
					-- 7:6-34 HTRI-S "E/L6/6F/MM34/EE Fire Shaft"
					-- 7:6-35 HMS-S/D/M/SA "E/L6/6F/MCP35/EE Fire Shaft"
					-- 7:6-36 HFP-11 "E/L6/6F/SD36/EE Lift Lobby"
					-- 7:6-37 HTRI-R "E/L6/6F/CM37/EE AHU Rm"
					-- Switch ""
					-- Relay
					-- 7:6-38 HFP-11 "E/L6/6F/SD38/EE AHU Rm"
					-- 7:6-39 HFP-11 "E/L6/6F/SD39/EE Electric Rm"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:6 XDLC "DLC @ address 6 L6"

					-- 7:6-40 HTRI-R "E/L6/6F/CM40/Near EW Electric rm"
					-- Switch ""
					-- Relay
					-- 7:6-41 HFP-11 "E/L6/6F/SD41/Near EW Electric rm"
					-- 7:6-42 HFP-11 "E/L6/6F/SD42/Near EC Electric rm"
					-- 7:6-43 HFP-11 "E/L6/6F/SD43/Corr Nr EC6040"
					-- 7:6-44 HFP-11 "E/L6/6F/SD44/Corr Nr EC6032"
					-- 7:6-45 HTRI-R "E/L6/6F/CM45/EC Fire shaft"
					-- Switch ""
					-- Relay
					-- 7:6-46 HMS-S/D/M/SA "E/L6/6F/MCP46/EC Fire shaft"
					-- 7:6-47 HFP-11 "E/L6/6F/SD47/EC Fire shaft"
					-- 7:6-48 HFP-11 "E/L6/6F/SD48/Corr Nr EC6060"
					-- 7:6-49 HFP-11 "E/L6/6F/SD49/Corr Nr EC6070"
					-- 7:6-50 HFP-11 "E/L6/6F/SD50/Corr Nr EC6070"
					-- 7:6-51 HFP-11 "E/L6/6F/SD51/Corr Nr EC6090"
					-- 7:6-52 HFP-11 "E/L6/6F/SD52/Corr Nr EC6010"
					-- 7:6-53 HFP-11 "E/L6/6F/SD53/EC Electric rm"
					-- 7:6-54 HTRI-R "E/L6/6F/CM54/EC Fire escape dr"
					-- Switch ""
					-- Relay
					-- 7:6-55 HTRI-R "E/L6/6F/CM55/EC Fire shaft Lift "
					-- Switch ""
					-- Relay
					-- 7:6-56 HTRI-S "E/L6/6F/MM56/EC Fire shaft Lift "
					-- 7:6-57 HMS-S/D/M/SA "E/L6/6F/MCP57/EC Fire shaft Lift"
					-- 7:6-58 HFP-11 "E/L6/6F/SD58/EC Lift lobby"
					-- 7:6-59 HFP-11 "E/L6/6F/SD59/EC Lift lobby"
					-- 7:6-60 HTRI-R "E/L6/6F/CM60/EC AHU RM"
					-- Switch ""
					-- Relay
					-- 7:6-61 HFP-11 "E/L6/6F/SD61/EC AHU RM"
					-- 7:6-62 HFP-11 "E/L6/6F/SD62/Corr nr EC6130"
					-- 7:6-63 HFP-11 "E/L6/6F/SD63/Corr nr EC6100"
					-- 7:6-64 HTRI-R "E/L6/6F/CM64/EC Fire Escape dr"
					-- Switch ""
					-- Relay
					-- 7:6-68 HTRI-R "E/L6/7F/CM68/nr EC door release"
					-- Switch ""
					-- Relay
					-- 7:6-69 HTRI-S "E/L6/C/7F/MM69/EC7091"
					-- 7:6-81 HTRI-S "E/L6/7F/MM81/EC7092"
					-- 7:6-82 HTRI-S "E/L6/7F/MM82/EC7082"
					-- 7:6-83 HTRI-S "E/L6/7F/MM83/EC7081"
					-- 7:6-84 HTRI-S "E/L6/7F/MM84/EC7010"
					-- 7:6-85 HTRI-S "E/L6/7F/MM85/EC7020"
					-- 7:6-87 HTRI-S "E/L6/7F/MM87/EC7032"
					-- 7:6-88 HTRI-S "E/L6/7F/MM88/EC7070"
					-- 7:6-89 HTRI-S "E/L6/7F/MM89/EC7060"
					-- 7:6-90 HTRI-S "E/L6/7F/MM90/EC7050"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:6 XDLC "DLC @ address 6 L6"

```
| | | | | -- 7:6-91 HTRI-S "E/L6/7F/MM91/EC7041"
| | | | | -- 7:6-92 HTRI-S "E/L6/6F/MM92/EC6040"
| | | | | -- 7:6-95 HTRI-S "E/L6/6F/MM95/EC6031"
| | | | | -- 7:6-96 HTRI-S "E/L6/6F/MM96/EC6060"
| | | | | -- 7:6-98 HTRI-S "E/L6/6F/MM98/EC6070"
| | | | | -- 7:6-100 HTRI-S "E/L6/6F/MM100/EC6010"
| | | | | -- 7:6-101 HTRI-S "E/L6/6F/MM101/EC6090"
| | | | | -- 7:6-102 HTRI-S "E/L6/6F/MM102/EC6130"
| | | | | -- 7:6-103 HTRI-S "E/L6/6F/MM103/EC6100"
| | | | | -- 7:6-105 HTRI-S "E/L6/7F/MM105/EE7010"
| | | | | -- 7:6-106 HFP-11 "E/L6/EC6080/SD106/Main cab"
| | | | | -- 7:6-107 HFP-11 "E/L6/EC6080/SD107/Assorter cab"
| | | | | -- 7:6-108 HFP-11 "E/L6/EC6080/SD108/Account cab"
| | | | | -- 7:6-109 HFP-11 "E/L6/EC6080/SD109/Account cab"
| | | | | -- 7:6-110 HFP-11 "E/L6/EC6080/SD110/Psg nr Account"
| | | | | -- 7:6-111 HFPT-11 "E/L6/EC6080/HD111/Psg nr Account"
| | | | | -- 7:6-112 HFP-11 "E/L6/EC6080/SD112/Entry dr Psg"
| | | | | -- 7:6-113 HTRI-R "E/L6/EC6080/CM113/Entry dr Psg"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 7:6-114 HMS-S/D/M/SA "E/L6/EC6080/MCP114/Entry dr Psg"
| | | | | -- 7:6-115 HFP-11 "E/L6/EC6032/SD115/Assorter cab"
| | | | | -- 7:6-116 HFP-11 "E/L6/EC6032/SD116/Psg nr Assorte"
| | | | | -- 7:6-117 HFP-11 "E/L6/EC6032/SD117/Jewellery cab"
| | | | | -- 7:6-118 HFP-11 "E/L6/EC6032/SD118/Buyer cab"
| | | | | -- 7:6-119 HFP-11 "E/L6/EC6032/SD119/Lunch cab"
| | | | | -- 7:6-120 HFP-11 "E/L6/EC6032/SD120/Accounts cab"
| | | | | -- 7:6-121 HFP-11 "E/L6/EC6032/SD121/Psg nr pantry"
| | | | | -- 7:6-122 HFP-11 "E/L6/EC6032/SD122/Reception"
| | | | | -- 7:6-123 HFP-11 "E/L6/EC6032/SD123/Entry psg"
| | | | | -- 7:6-124 HFP-11 "E/L6/EC6032/HD124/Pantry"
| | | | | -- 7:6-125 HFP-11 "E/L6/EC6032/SD125/Main cab 1"
| | | | | -- 7:6-126 HFP-11 "E/L6/EC6032/SD126/Main cab 2"
| | | | | -- 7:6-127 HFP-11 "E/L6/EC6032/SD127/Main cab 3"
| | | | | -- 7:6-128 HTRI-R "E/L6/EC6032/CM128/AFC Entry Psg"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 7:6-129 HMS-S/D/M/SA "E/L6/EC6032/MCP129/Entry Psg"
| | | | | -- 7:8 XDLC "DLC @ address 8 L8"
| | | | | -- 7:8-9 HFP-11 "E/L8/9F/SD9/EC Electricct rm"
| | | | | -- 7:8-10 HFP-11 "E/L8/9F/SD10/EC LiftLobby"
| | | | | -- 7:8-11 HFP-11 "E/L8/9F/SD11/EC LiftLobby"
| | | | | -- 7:8-12 HMS-S/D/M/SA "E/L8/9F/MCP12/EC LiftLobby"
| | | | | -- 7:8-13 HTRI-R "E/L8/9F/CM13/EC Fire Shaft LiftL"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 7:8-14 HTRI-S "E/L8/9F/MM14/EC Fire Shaft LiftL"
| | | | | -- 7:8-15 HFP-11 "E/L8/9F/SD15/EC AHU Rm"
| | | | | -- 7:8-16 HTRI-R "E/L8/9F/CM16/EC AHU Rm"
| | | | | | -- Switch ""
```

```
7 Desigo Fire Safety Modular "BDB TOWER E" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      7:8 XDLC "DLC @ address 8 L8"
        7:8-16 HTRI-R "E/L8/9F/CM16/EC AHU Rm"
```

```
| | | | | |-- Relay
| | | | |-- 7:8-17 HFP-11 "E/L8/9F/SD17/EC corr nr AHU Rm"
| | | | |-- 7:8-18 HFP-11 "E/L8/9F/SD18/EC corr nr AHU Rm"
| | | | |-- 7:8-19 HTRI-R "E/L8/9F/CM19/nr EC Dr release"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-23 HFP-11 "E/L8/9F/SD23/EE Corr nr S0/2"
| | | | |-- 7:8-24 HFP-11 "E/L8/9F/SD24/EE Corr nr S0/2"
| | | | |-- 7:8-25 HFP-11 "E/L8/9F/SD25/EE Electric Rm"
| | | | |-- 7:8-26 HFP-11 "E/L8/9F/SD26/EE AHU Rm"
| | | | |-- 7:8-27 HTRI-R "E/L8/9F/CM27/EE AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-28 HFP-11 "E/L8/9F/SD28/EE LiftLobby"
| | | | |-- 7:8-29 HMS-S/D/M/SA "E/L8/9F/MCP29/EE Fire Shaft Lift"
| | | | |-- 7:8-30 HTRI-R "E/L8/9F/CM30/EE Fire Shaft LiftL"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-31 HTRI-S "E/L8/9F/MM31/EE Fire Shaft LiftL"
| | | | |-- 7:8-40 HFP-11 "E/L8/8F/SD40/EC Electric RM"
| | | | |-- 7:8-41 HFP-11 "E/L8/8F/SD41/EC LiftLobby"
| | | | |-- 7:8-42 HFP-11 "E/L8/8F/SD42/EC LiftLobby"
| | | | |-- 7:8-43 HMS-S/D/M/SA "E/L8/8F/MCP43/EC Fire shaft Lift"
| | | | |-- 7:8-44 HTRI-R "E/L8/8F/CM44/EC Fire shaft LiftL"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-45 HTRI-S "E/L8/8F/MM45/EC Fire shaft LiftL"
| | | | |-- 7:8-46 HFP-11 "E/L8/8F/SD46/EC AHU Rm"
| | | | |-- 7:8-47 HTRI-R "E/L8/8F/CM47/EC AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-48 HTRI-R "E/L8/8F/CM48/EC Nr AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-49 HFP-11 "E/L8/8F/SD49/Corr nr EE8070"
| | | | |-- 7:8-50 HFP-11 "E/L8/8F/SD50/Corr nr EE8090"
| | | | |-- 7:8-51 HFP-11 "E/L8/8F/SD51/Corr nr EE8060"
| | | | |-- 7:8-52 HFP-11 "E/L8/8F/SD52/Corr nr EE8040"
| | | | |-- 7:8-53 HFP-11 "E/L8/8F/SD53/Corr nr EE8040"
| | | | |-- 7:8-54 HMS-S/D/M/SA "E/L8/8F/MCP54/EE Fr Esc dr"
| | | | |-- 7:8-55 HTRI-R "E/L8/8F/CM55/EE Fr Esc dr"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-56 HFP-11 "E/L8/8F/SD56/Corr nr EE8112"
| | | | |-- 7:8-57 HFP-11 "E/L8/8F/SD57/Corr nr EE8114"
| | | | |-- 7:8-58 HFP-11 "E/L8/8F/SD58/Corr nr EE8114"
| | | | |-- 7:8-59 HFP-11 "E/L8/8F/SD59/EE nr Electric Rm"
| | | | |-- 7:8-60 HFP-11 "E/L8/8F/SD60/EE Esc Door"
| | | | |-- 7:8-61 HFP-11 "E/L8/8F/SD61/EE Electric Rm"
| | | | |-- 7:8-62 HFP-11 "E/L8/8F/SD62/EE AHU Rm"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:8 XDLC "DLC @ address 8 L8"

```
| | | | |-- 7:8-63 HTRI-R "E/L8/8F/CM63/EE AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-64 HFP-11 "E/L8/8F/SD64/EE LiftLobby"
| | | | |-- 7:8-65 HMS-S/D/M/SA "E/L8/8F/MCP65/EE LiftLobby"
| | | | |-- 7:8-66 HTRI-R "E/L8/8F/CM66/EE Fire shaft LiftL"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-67 HTRI-S "E/L8/8F/MM67/EE Fire shaft LiftL"
| | | | |-- 7:8-77 HTRI-S "E/L8/9F/MM77/EC9012"
| | | | |-- 7:8-79 HTRI-S "E/L8/9F/MM79/EC8010"
| | | | |-- 7:8-80 HTRI-S "E/L8/9F/MM80/EE9011"
| | | | |-- 7:8-88 HTRI-S "E/L8/8F/MM88/EE8050"
| | | | |-- 7:8-90 HTRI-S "E/L8/8F/MM90/EE8100"
| | | | |-- 7:8-91 HFP-11 "E/L8/EE8090/SD91/AFC Assorter ca"
| | | | |-- 7:8-92 HFP-11 "E/L8/EE8090/SD92/AFC Lunch room"
| | | | |-- 7:8-93 HFP-11 "E/L8/EE8090/SD93/AFC Accounts ca"
| | | | |-- 7:8-94 HFP-11 "E/L8/EE8090/SD94/AFC Reception c"
| | | | |-- 7:8-95 HFP-11 "E/L8/EE8090/SD95/AFC Entry dr Ps"
| | | | |-- 7:8-96 HFP-11 "E/L8/EE8090/SD96/AFC Entry Psg"
| | | | |-- 7:8-99 HTRI-S "E/L8/8F/MM99/EE8020"
| | | | |-- 7:8-101 HFP-11 "E/L8/EE8120/SD101/Main cab"
| | | | |-- 7:8-102 HFP-11 "E/L8/EE8120/SD102/Account cab"
| | | | |-- 7:8-103 HFP-11 "E/L8/EE8120/SD103/Psg nr Account"
| | | | |-- 7:8-104 HFP-11 "E/L8/EE8120/SD104/Pantry"
| | | | |-- 7:8-105 HTRI-R "E/L8/EE8120/CM105/Entry dr Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-106 HMS-S/D/M/SA "E/L8/EE8120/MCP106/Entry dr Psg"
| | | | |-- 7:8-107 HFP-11 "E/L8/EE8111/SD107/Main cab"
| | | | |-- 7:8-108 HFP-11 "E/L8/EE8111/SD108/Assorter cab"
| | | | |-- 7:8-109 HFP-11 "E/L8/EE8111/SD109/Psg nr Assorte"
| | | | |-- 7:8-110 HFP-11 "E/L8/EE8111/SD110/Accounts cab"
| | | | |-- 7:8-111 HFP-11 "E/L8/EE8111/SD111/Pantry"
| | | | |-- 7:8-112 HTRI-R "E/L8/EE8111/CM112/Entry dr psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-113 HMS-S/D/M/SA "E/L8/EE8111/MCP113/Entry dr psg"
| | | | |-- 7:8-114 HFP-11 "E/L8/EE8112/SD114/Main cab"
| | | | |-- 7:8-115 HFP-11 "E/L8/EE8112/SD115/Accounts cab"
| | | | |-- 7:8-116 HFP-11 "E/L8/EE8112/SD116/Psg nr Account"
| | | | |-- 7:8-117 HFP-11 "E/L8/EE8112/SD117/Assorter cab"
| | | | |-- 7:8-118 HFP-11 "E/L8/EE8112/SD118/Pantry Psg"
| | | | |-- 7:8-119 HTRI-R "E/L8/EE8112/CM119/Entry dr Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-120 HMS-S/D/M/SA "E/L8/EE8112/MCP120/Entry dr Psg"
| | | | |-- 7:8-121 HFP-11 "E/L8/EE8080/SD121/Buyer cab"
| | | | |-- 7:8-122 HFP-11 "E/L8/EE8080/SD122/Cabin 2"
| | | | |-- 7:8-123 HFP-11 "E/L8/EE8080/SD123/Account cab1"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:8 XDLC "DLC @ address 8 L8"

					-- 7:8-124 HFP-11 "E/L8/EE8080/SD124/Main cab"
					-- 7:8-125 HFP-11 "E/L8/EE8080/SD125/Account cab2"
					-- 7:8-126 HFP-11 "E/L8/EE8080/SD126/Psg nr Buyer c"
					-- 7:8-127 HFP-11 "E/L8/EE8080/SD127/Pantry"
					-- 7:8-128 HFP-11 "E/L8/EE8080/SD128/Entry dr Psg"
					-- 7:8-129 HTRI-R "E/L8/EE8080/CM129/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:8-130 HMS-S/D/M/SA "E/L8/EE8080/MCP130/Entry dr Psg"
					-- 7:8-131 HFP-11 "E/L8/EE8070/SD131/Pantry"
					-- 7:8-132 HFP-11 "E/L8/EE8070/SD132/Lunch room"
					-- 7:8-133 HFP-11 "E/L8/EE8070/SD133/Accounts cab"
					-- 7:8-134 HFP-11 "E/L8/EE8070/SD134/Assorter cab"
					-- 7:8-135 HFP-11 "E/L8/EE8070/SD135/Assorter cab"
					-- 7:8-136 HFP-11 "E/L8/EE8070/SD136/Main cab"
					-- 7:8-137 FDOT421 "E/L8/EE8070/SD137/Main cab"
					-- 7:8-138 HFP-11 "E/L8/EE8070/SD138/Entry dr Psg"
					-- 7:8-139 HTRI-R "E/L8/EE8070/CM139/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:8-140 HMS-S/D/M/SA "E/L8/EE8070/MCP140/Entry dr Psg"
					-- 7:8-141 HFP-11 "E/L8/EE8114/SD141/Main cab"
					-- 7:8-142 HFP-11 "E/L8/EE8114/SD142/Cab 1"
					-- 7:8-143 HFP-11 "E/L8/EE8114/SD143/Cab 2"
					-- 7:8-144 HFP-11 "E/L8/EE8114/SD144/Psg nr MC"
					-- 7:8-145 HFP-11 "E/L8/EE8114/SD145/Pantry Psg"
					-- 7:8-146 HTRI-R "E/L8/EE8114/CM146/AFC Entry dr P"
					-- Switch ""
					-- Relay
					-- 7:8-147 HMS-S/D/M/SA "E/L8/EE8114/MCP147/Entry dr Psg"
					-- 7:8-154 HFP-11 "E/L8/EE8113/SD154/Main cab"
					-- 7:8-155 HFP-11 "E/L8/EE8113/SD155/Assorter cab"
					-- 7:8-156 HFP-11 "E/L8/EE8113/SD156/Account cab"
					-- 7:8-157 HFP-11 "E/L8/EE8113/SD157/Psg nr Accout "
					-- 7:8-158 HFP-11 "E/L8/EE8113/SD158/Pantry"
					-- 7:8-159 HTRI-R "E/L8/EE8113/CM159/Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:8-160 HMS-S/D/M/SA "E/L8/EE8113/MCP160/Entry Psg"
					-- 7:8-161 HFP-11 "E/L8/EE8090/SD161/Storage cab"
					-- 7:8-162 HFP-11 "E/L8/EE8090/SD162/Pantry"
					-- 7:8-163 HFP-11 "E/L8/EE8090/SD163/Main cab"
					-- 7:8-164 HFP-11 "E/L8/EE8090/SD164/Rajbhai cab"
					-- 7:8-165 HFP-11 "E/L8/EE8090/SD165/Assorter cab"
					-- 7:8-166 HFP-11 "E/L8/EE8090/SD166/Psg nr Assorte"
					-- 7:8-167 HFP-11 "E/L8/EE8090/SD167/Lunch room"
					-- 7:8-168 HFP-11 "E/L8/EE8090/SD168/Accounts cab"
					-- 7:8-169 HFP-11 "E/L8/EE8090/SD169/Reception cab"
					-- 7:8-238 HTRI-R "E/L8/EE8090/CM238/Entry dr Psg"
					-- Switch ""

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:8 XDLC "DLC @ address 8 L8"

7:8-238 HTRI-R "E/L8/EE8090/CM238/Entry dr Psg"

```
| | | | | |-- Relay
| | | | |-- 7:8-171 HMS-S/D/M/SA "E/L8/EE8090/MCP171/Entry dr Psg"
| | | | |-- 7:8-172 HFP-11 "E/L8/EE8090/SD172/AFC storage ro"
| | | | |-- 7:8-173 HFP-11 "E/L8/EE8090/SD173/AFC Main cab"
| | | | |-- 7:8-148 HFP-11 "E/L8/EE8130/SD148/Assorter cab"
| | | | |-- 7:8-149 HFP-11 "E/L8/EE8130/SD149/Psg nr MC"
| | | | |-- 7:8-150 HFP-11 "E/L8/EE8130/SD150/Entry Psg"
| | | | |-- 7:8-151 HFP-11 "E/L8/EE8130/SD151/Main cab"
| | | | |-- 7:8-152 HTRI-R "E/L8/EE8130/CM152/Entry Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-153 HMS-S/D/M/SA "E/L8/EE8130/MCP153/Entry Psg"
| | | | |-- 7:8-69 HFP-11 "E/L8/9F/SD69/EC TERACE LIFT RM"
| | | | |-- 7:8-70 HFP-11 "E/L8/9F/SD70/EC TERACE LIFT RM"
| | | | |-- 7:8-71 HFP-11 "E/L8/9F/SD71/EC TERACE LIFT RM"
| | | | |-- 7:8-72 HFP-11 "E/L8/9F/SD72/EC TERACE LIFT RM"
| | | | |-- 7:8-73 HFP-11 "E/L8/9F/SD73/EC TERACE LIFT RM"
| | | | |-- 7:8-74 HTRI-R "E/L8/9F/CM74/EC TERACE LIFT RM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:8-174 HFPT-11 "E/L8/EE8130/HD174/Pantry"
| | | | |-- 7:8-240 HFP-11 "E/L8/EE8090/SD240/AFC"
| | | | |-- 7:8-195 HTRI-S "E/L8/8F/MM195/EE8030"
| | | | |-- 7:8-196 HTRI-S "E/L8/8F/MM196/EE8010B2"
| | | |-- 7:9 XDLC "DLC @ address 9 L9"
| | | | |-- 7:9-1 HTRI-R "E/L9/9F/CM1/EW LiftLobby"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-2 HTRI-S "E/L9/9F/MM2/EW LiftLobby"
| | | | |-- 7:9-3 HMS-S/D/M/SA "E/L9/9F/MCP3/EW LiftLobby"
| | | | |-- 7:9-4 HFP-11 "E/L9/9F/SD4/EW AHU Rm"
| | | | |-- 7:9-5 HTRI-R "E/L9/9F/CM5/EW AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-6 HFP-11 "E/L9/9F/SD6/EW Lift Lobby"
| | | | |-- 7:9-7 HFP-11 "E/L9/9F/SD7/EW Lift Lobby"
| | | | |-- 7:9-8 HFP-11 "E/L9/9F/SD8/EW Electric rm"
| | | | |-- 7:9-9 HTRI-R "E/L9/9F/CM9/nr EW door release"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-10 HFP-11 "E/L9/9F/SD10/Corr.nr EW9010"
| | | | |-- 7:9-11 HFP-11 "E/L9/9F/SD11/CORR NR 9021"
| | | | |-- 7:9-12 HFP-11 "E/L9/9F/SD12/Corr.nr EW9020"
| | | | |-- 7:9-13 HFP-11 "E/L9/9F/SD13/Corr.nr EW9051"
| | | | |-- 7:9-14 HFP-11 "E/L9/9F/SD14/Corr.nr EW9032"
| | | | |-- 7:9-15 HTRI-R "E/L9/9F/CM15/EW Escape dr"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-16 HMS-S/D/M/SA "E/L9/9F/MCP16/EW Esc str"
| | | | |-- 7:9-17 HTRI-R "E/L9/9F/CM17/EW Shaft LiftLobby"
```

```

| | | | | | Switch ""
| | | | | | |-- Relay
| | | | | | |-- 7:9-18 HMS-S/D/M/SA "E/L9/8F/MCP18/EW Shaft LiftLobby"
| | | | | | |-- 7:9-19 HTRI-S "E/L9/8F/MM19/EW Shaft LiftLobby"
| | | | | | |-- 7:9-20 HFP-11 "E/L9/8F/SD20/EW LiftLobby"
| | | | | | |-- 7:9-21 HFP-11 "E/L9/8F/SD21/EW LiftLobby"
| | | | | | |-- 7:9-22 HFP-11 "E/L9/8F/SD22/EW AHU Rm"
| | | | | | |-- 7:9-23 HTRI-R "E/L9/8F/CM23/EW AHU Rm"
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | | |-- 7:9-24 HFP-11 "E/L9/8F/SD24/EW Electric Rm"
| | | | | | |-- 7:9-25 HFP-11 "E/L9/8F/SD25/EW nr Electric rm"
| | | | | | |-- 7:9-26 HFP-11 "E/L9/8F/SD26/AFC EW"
| | | | | | |-- 7:9-27 HFP-11 "E/L9/8F/SD27/AFC EW"
| | | | | | |-- 7:9-28 HFP-11 "E/L9/8F/SD28/Corr nr EW8021"
| | | | | | |-- 7:9-29 HTRI-R "E/L9/7F/CM29/EW Shaft LiftLobby"
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | | |-- 7:9-30 HMS-S/D/M/SA "E/L9/7F/MCP30/EW shaft LiftLobby"
| | | | | | |-- 7:9-31 HTRI-S "E/L9/7F/MM31/EW shaft LiftLobby"
| | | | | | |-- 7:9-32 HFP-11 "E/L9/7F/SD32/EW LiftLobby"
| | | | | | |-- 7:9-33 HFP-11 "E/L9/7F/SD33/EW LiftLobby"
| | | | | | |-- 7:9-34 HFP-11 "E/L9/7F/SD34/EW AHU Rm"
| | | | | | |-- 7:9-35 HFP-11 "E/L9/7F/SD35/EW AHU Rm"
| | | | | | |-- 7:9-36 HTRI-R "E/L9/7F/CM36/EW AHU Rm"
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | | |-- 7:9-37 HFP-11 "E/L9/7F/SD37/EW Electric rm"
| | | | | | |-- 7:9-44 HTRI-S "E/L9/8F/MM44/EW8012"
| | | | | | |-- 7:9-50 HTRI-S "E/L9/9F/MM50/EW9010"
| | | | | | |-- 7:9-51 HTRI-S "E/L9/9F/MM51/EW9020"
| | | | | | |-- 7:9-54 HTRI-S "E/L9/9F/MM54/EW9051"
| | | | | | |-- 7:9-55 HTRI-S "E/L9/9F/MM55/EW9031"
| | | | | | |-- 7:9-58 HTRI-S "E/L9/9F/MM58/EW9040B"
| | | | | | |-- 7:9-59 HTRI-S "E/L9/8F/MM59/EW8010"
| | | | | | |-- 7:9-60 HTRI-S "E/L9/8F/MM60/EW8011"
| | | | | | |-- 7:9-63 HTRI-S "E/L9/9F/MM63/EW 9060"
| | | | | | |-- 7:9-38 HFP-11 "E/L9/SD38/EW Terrace Lift Mch RM"
| | | | | | |-- 7:9-39 HFP-11 "E/L9/SD39/EW Terrace Lift Mch RM"
| | | | | | |-- 7:9-40 HFP-11 "E/L9/SD40/EW Terrace Lift Mch RM"
| | | | | | |-- 7:9-41 HFP-11 "E/L9/SD41/EW Terrace Lift Mch RM"
| | | | | | |-- 7:9-42 HFP-11 "E/L9/SD42/EW Terrace Lift Mch RM"
| | | | | | |-- 7:9-43 HTRI-R "E/L9/CM43/EW Terrace Lift Mch RM"
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | | |-- 7:9-62 HTRI-S "E/L9/7F/MM62/EW 7010"NR ELE RM"
| | | | | | |-- 7:10 NIC-C(XNet) "NIC_Xnet @ address 10"
| | | | | | |-- 7:11 NIC-C(HNet) "NIC @ address 11"
| | | | | | |-- 7:249 PSC-12 "PSC-12 @ address 249"
| | | | | | |-- 7:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"

```

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
7:249 PSC-12 "PSC-12 @ address 249"

| | | |-- 7:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
| | |-- Inner Door
| | |-- 7:253 PMI-D "PMI-D Tower E -7"
| |-- CAB-1 "CAB-1 Enclosure #2"
| |-- CC-5 "Card Cage 5 Slots"
| | |-- 7:7 XDLC "DLC @ address 7 L7"
| | | |-- 7:7-1 HFP-11 "E/L7/6F/SD1/CORR NR 6280"
| | | |-- 7:7-2 HFP-11 "E/L7/6F/SD2/CORR NR 6280"
| | | |-- 7:7-3 HTRI-R "E/L7/6F/CM3/FIRE ESC STR"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:7-4 HMS-S/D/M/SA "E/L7/6F/MCP4/FIRE ESC STR"
| | | |-- 7:7-5 HFP-11 "E/L7/6F/SD5/CORR NR DW 6270"
| | | |-- 7:7-6 HFP-11 "E/L7/6F/SD6/CORR NR 6260"
| | | |-- 7:7-7 HFP-11 "E/L7/6F/SD7/CORR NR 6260"
| | | |-- 7:7-8 HFP-11 "E/L7/6F/SD8/CORR NR 6260"
| | | |-- 7:7-9 HFP-11 "E/L7/6F/SD9/CORR NR 6251"
| | | |-- 7:7-10 HFP-11 "E/L7/6F/SD10/CORR NR 6251"
| | | |-- 7:7-11 HFP-11 "E/L7/6F/SD11/AHU RM SD"
| | | |-- 7:7-12 HTRI-R "E/L7/6F/CM12/AHU RM CM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:7-13 HTRI-R "E/L7/6F/CM13/DR RELESE CM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:7-14 HMS-S/D/M/SA "E/L7/6F/MCP14/FIRE SHAFT L.L."
| | | |-- 7:7-15 HTRI-R "E/L7/6F/CM15/FIRE SHAFT L.L."
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:7-16 HTRI-S "E/L7/6F/MM16/FIRE SHAFT L.L."
| | | |-- 7:7-17 HFP-11 "E/L7/6F/SD17/LIFT LOBBY SD"
| | | |-- 7:7-18 HFP-11 "E/L7/6F/SD18/LIFT LOBBY SD"
| | | |-- 7:7-19 HFP-11 "E/L7/6F/SD19/ELECT RM SD"
| | | |-- 7:7-20 HTRI-R "E/L7/6F/CM20/DR RELESE CM "
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:7-21 HFP-11 "E/L7/6F/SD21/CORR NR DR"
| | | |-- 7:7-22 HFP-11 "E/L7/6F/SD22/CORR NR EW 6050"
| | | |-- 7:7-23 HFP-11 "E/L7/6F/SD23/CORR NR 6060"
| | | |-- 7:7-24 HFP-11 "E/L7/6F/SD24/CORR NR EW 6070"
| | | |-- 7:7-25 HFP-11 "E/L7/5F/SD25/CORR NR DW 5280"
| | | |-- 7:7-26 HFP-11 "E/L7/5F/SD26/CORR NR 5280"
| | | |-- 7:7-27 HTRI-R "E/L7/5F/CM27/FIRE ESC STR"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:7-28 HMS-S/D/M/SA "E/L7/5F/MCP28/FIRE ESC STR"
| | | |-- 7:7-29 HFP-11 "E/L7/5F/SD29/CORR NR DW 5210"
| | | |-- 7:7-30 HFP-11 "E/L7/5F/SD30/CORR NR 5210"
| | | |-- 7:7-31 HFP-11 "E/L7/5F/SD31/CORR NR 5263"
| | | |-- 7:7-32 HFP-11 "E/L7/5F/SD32/CORR NR 5261"

```
7 Desigo Fire Safety Modular "BDB TOWER E" Local
  CAB-1 "CAB-1 Enclosure #2"
    CC-5 "Card Cage 5 Slots"
      7:7 XDLC "DLC @ address 7 L7"
```

```
|      |      |  |-- 7:7-33 HTRI-R "E/L7/5F/CM33/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 7:7-34 HFP-11 "E/L7/5F/SD34/AHU RM SD"
|      |      |  |-- 7:7-35 HFP-11 "E/L7/5F/SD35/CORR NR DR"
|      |      |  |-- 7:7-36 HTRI-R "E/L7/5F/CM36/DR RELESE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 7:7-37 HTRI-R "E/L7/5F/CM37/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 7:7-38 HMS-S/D/M/SA "E/L7/5F/MCP38/FIRE SHAFT L.L."
|      |      |  |-- 7:7-39 HTRI-S "E/L7/5F/MM39/FIRE SHAFT L.L."
|      |      |  |-- 7:7-40 HFP-11 "E/L7/5F/SD40/LIFT LOBBY SD"
|      |      |  |-- 7:7-41 HFP-11 "E/L7/5F/SD41/LIFT LOBBY SD"
|      |      |  |-- 7:7-42 HFP-11 "E/L7/5F/SD42/ELECT RM SD"
|      |      |  |-- 7:7-43 HTRI-R "E/L7/5F/CM43/DR RELESE 5 TO 6"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 7:7-44 HFP-11 "E/L7/5F/SD44/CORR NR 5010"
|      |      |  |-- 7:7-45 HFP-11 "E/L7/5F/SD45/CORR NR 5020"
|      |      |  |-- 7:7-46 HFP-11 "E/L7/5F/SD46/CORR NR 5181"
|      |      |  |-- 7:7-47 HFP-11 "E/L7/5F/SD47/CORR NR 5170"
|      |      |  |-- 7:7-48 HFP-11 "E/L7/5F/SD48/CORR NR EW 5/S17"
|      |      |  |-- 7:7-49 HTRI-R "E/L7/EW/5F/CM49/DR RELESE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 7:7-50 HFP-11 "E/L7/EW/5F/SD50/CORR NR EW5050"
|      |      |  |-- 7:7-51 HFP-11 "E/L7/EW/5F/SD51/CORR NR EW5030"
|      |      |  |-- 7:7-52 HFP-11 "E/L7/EW/5F/SD52/CORR NR EW5020"
|      |      |  |-- 7:7-53 HFP-11 "E/L7/EW/5F/SD53/CORR NR EW5010"
|      |      |  |-- 7:7-54 HFP-11 "E/L7/EW/5F/SD54/CORR NR LL"
|      |      |  |-- 7:7-55 HTRI-R "E/L7/EW/5F/CM55/FIRE ESC DR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 7:7-56 HMS-S/D/M/SA "E/L7/EW/5F/MCP56/FIRE ESC DR"
|      |      |  |-- 7:7-60 HTRI-S "E/L7/6F/MM60/EW6070"
|      |      |  |-- 7:7-62 HTRI-S "E/L7/6F/MM62/EW6090"
|      |      |  |-- 7:7-63 HTRI-S "E/L7/6F/MM63/EW6060"
|      |      |  |-- 7:7-64 HTRI-S "E/L7/6F/MM64/EW6050"
|      |      |  |-- 7:7-66 HTRI-S "E/L7/6F/MM66/EW6040"
|      |      |  |-- 7:7-67 HTRI-S "E/L7/6F/MM67/EW6030"
|      |      |  |-- 7:7-68 HTRI-S "E/L7/6F/MM68/EW6020"
|      |      |  |-- 7:7-71 HFP-11 "E/L7/DW6240/SD71/AFC Entry Psg"
|      |      |  |-- 7:7-72 HFP-11 "E/L7/DW6240/SD72/Entry Psg"
|      |      |  |-- 7:7-73 HTRI-S "E/W/6F/MM73/DW6220"
|      |      |  |-- 7:7-75 HTRI-S "E/L7/6F/MM75/DW6260"
|      |      |  |-- 7:7-77 HTRI-S "E/L7/6F/MM77/DW6270"
|      |      |  |-- 7:7-78 HTRI-S "E/L7/6F/MM78/DW6200"
|      |      |  |-- 7:7-79 HTRI-S "E/L7/6F/MM79/DW6190"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:7 XDLC "DLC @ address 7 L7"

```
|      |      |      |-- 7:7-80 HTRI-S "E/L7/6F/MM80/DW6180"
|      |      |      |-- 7:7-81 HTRI-S "E/L7/6F/MM81/DW6280"
|      |      |      |-- 7:7-82 HTRI-S "E/L7/6F/MM82/DW6170"
|      |      |      |-- 7:7-84 HTRI-S "E/L7/5F/MM84/DW5280"
|      |      |      |-- 7:7-90 HTRI-S "E/L7/5F/MM90/DW5230"
|      |      |      |-- 7:7-91 HTRI-S "E/L7/5F/MM91/DW5240/50"
|      |      |      |-- 7:7-93 HTRI-S "E/L7/5F/MM93/DW5262/63"
|      |      |      |-- 7:7-94 HTRI-S "E/L7/5F/MM94/DW5261"
|      |      |      |-- 7:7-97 HTRI-S "E/L7/5F/MM97/EW5190"
|      |      |      |-- 7:7-98 HTRI-S "E/L7/5F/MM98/EW5010"
|      |      |      |-- 7:7-102 HFP-11 "E/L7/EW5071/SD102/Executive cab"
|      |      |      |-- 7:7-103 HFP-11 "E/L7/EW5071/SD103/Display rm"
|      |      |      |-- 7:7-104 HFP-11 "E/L7/EW5071/SD104/Pantry"
|      |      |      |-- 7:7-105 HFP-11 "E/L7/EW5071/SD105/Assorter cab"
|      |      |      |-- 7:7-106 HFP-11 "E/L7/EW5071/SD106/Accounts cab"
|      |      |      |-- 7:7-110 HFP-11 "E/L7/DW5270/SD110/Account cab"
|      |      |      |-- 7:7-111 HFP-11 "E/L7/DW5270/SD111/Pantry"
|      |      |      |-- 7:7-112 HTRI-R "E/L7/DW5270/CM112/Psg nr Entry"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 7:7-113 HMS-S/D/M/SA "E/L7/DW5270/MCP113/Psg nr Entry"
|      |      |      |-- 7:7-114 HFP-11 "E/L7/DW5220/SD114/Main cab"
|      |      |      |-- 7:7-115 HFP-11 "E/L7/DW5220/SD115/Buyers cab"
|      |      |      |-- 7:7-116 HFP-11 "E/L7/DW5220/SD116/Psg nr Buyers "
|      |      |      |-- 7:7-117 HFP-11 "E/L7/DW5220/SD117/Accounts cab"
|      |      |      |-- 7:7-118 HFP-11 "E/L7/DW5220/SD118/Psg nr Entry"
|      |      |      |-- 7:7-119 HTRI-R "E/L7/DW5220/CM119/Psg nr Entry"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 7:7-120 HMS-S/D/M/SA "E/L7/DW5220/MCP120/Psg nr Entry"
|      |      |      |-- 7:7-121 HFP-11 "E/L7/DW5210/SD121/Pantry"
|      |      |      |-- 7:7-122 HFP-11 "E/L7/DW5210/SD122/Accounts cab"
|      |      |      |-- 7:7-123 HFP-11 "E/L7/DW5210/SD123/Assorter cab"
|      |      |      |-- 7:7-124 HFP-11 "E/L7/DW5210/SD124/Main cab"
|      |      |      |-- 7:7-125 HFP-11 "E/L7/DW5210/SD125/Psg nr Entry D"
|      |      |      |-- 7:7-126 HTRI-R "E/L7/DW5210/CM126/Psg nr Entry D"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 7:7-127 HMS-S/D/M/SA "E/L7/DW5210/MCP127/Psg nr Entry "
|      |      |      |-- 7:7-161 HFP-11 "E/L7/DW6240/SD161/Buyers cab 1"
|      |      |      |-- 7:7-162 HFP-11 "E/L7/DW6240/SD162/Buyers cab 2"
|      |      |      |-- 7:7-163 HFP-11 "E/L7/DW6240/SD163/Main cab"
|      |      |      |-- 7:7-164 HFP-11 "E/L7/DW6240/SD164/Psg nr Main ca"
|      |      |      |-- 7:7-165 HTRI-R "E/L7/DW6240/CM165/Psg nr Entry d"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 7:7-166 HMS-S/D/M/SA "E/L7/DW6240/MCP166/Psg nr Entry "
|      |      |      |-- 7:7-167 HFP-11 "E/L7/EW5181/SD167/Cab 13"
|      |      |      |-- 7:7-168 HFP-11 "E/L7/EW5181/SD168/Cab 14"
|      |      |      |-- 7:7-169 HFP-11 "E/L7/EW5181/SD169/Cab 15"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:7 XDLC "DLC @ address 7 L7"

```
|      |      |  |-- 7:7-170 HFP-11 "E/L7/EW5181/SD170/Cab 11"
|      |      |  |-- 7:7-171 HFP-11 "E/L7/EW5181/SD171/Cab 11"
|      |      |  |-- 7:7-172 HFP-11 "E/L7/EW5181/SD172/Reception Psg"
|      |      |  |-- 7:7-173 HMS-S/D/M/SA "E/L7/EW5181/MCP173/Psg nr cab 9"
|      |      |  |-- 7:7-174 HMS-S/D/M/SA "E/L7/EW5181/MCP174/Psg nr cab 14"
|      |      |  |-- 7:7-175 HTRI-R "E/L7/EW5181/CM175/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-176 HFP-11 "E/L7/DW6230/SD176/Main Cabin"
|      |      |  |-- 7:7-177 HFP-11 "E/L7/DW6230/SD177/Psg nr Account"
|      |      |  |-- 7:7-178 HFP-11 "E/L7/DW6230/SD178/Account cab"
|      |      |  |-- 7:7-179 HFP-11 "E/L7/DW6230/SD179/Assorter cab"
|      |      |  |-- 7:7-180 HFPT-11 "E/L7/DW6230/HD180/Pantry"
|      |      |  |-- 7:7-181 HTRI-R "E/L7/DW6230/CM181/Entry dr psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-182 HMS-S/D/M/SA "E/L7/DW6230/MCP182/Entry dr psg"
|      |      |  |-- 7:7-190 HFP-11 "E/L7/EW6010/SD190/Main cab"
|      |      |  |-- 7:7-191 HFP-11 "E/L7/EW6010/SD191/Assorter cab"
|      |      |  |-- 7:7-192 HFP-11 "E/L7/EW6010/SD192/Assorter cab"
|      |      |  |-- 7:7-193 HFP-11 "E/L7/EW6010/SD193/Psg nr Assorte"
|      |      |  |-- 7:7-194 HFP-11 "E/L7/EW6010/SD194/Pantry"
|      |      |  |-- 7:7-195 HTRI-R "E/L7/EW6010/CM195/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-196 HMS-S/D/M/SA "E/L7/EW6010/MCP196/Entry dr Psg"
|      |      |  |-- 7:7-197 HFP-11 "E/L7/EW5030/SD197/Main cab"
|      |      |  |-- 7:7-198 HFP-11 "E/L7/EW5030/SD198/Assorter cab"
|      |      |  |-- 7:7-199 HFP-11 "E/L7/EW5030/SD199/Account cab"
|      |      |  |-- 7:7-200 HFP-11 "E/L7/EW5030/SD200/Entry dr Psg"
|      |      |  |-- 7:7-201 HTRI-R "E/L7/EW5030/CM201/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-202 HMS-S/D/M/SA "E/L7/EW5030/MCP202/Entry dr Psg"
|      |      |  |-- 7:7-203 HFP-11 "E/L7/EW5060/SD203/Staff rm"
|      |      |  |-- 7:7-204 HFP-11 "E/L7/EW5060/SD204/Staff dinning "
|      |      |  |-- 7:7-205 HFP-11 "E/L7/EW5060/SD205/Staff dinning "
|      |      |  |-- 7:7-206 HTRI-R "E/L7/EW5060/CM206/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-207 HMS-S/D/M/SA "E/L7/EW5060/MCP207/Entry dr Psg"
|      |      |  |-- 7:7-208 HFP-11 "E/L7/EW5040/SD208/Assorter cab"
|      |      |  |-- 7:7-209 HFP-11 "E/L7/EW5040/SD209/Account cab"
|      |      |  |-- 7:7-210 HFP-11 "E/L7/EW5040/SD210/Psg nr Main ca"
|      |      |  |-- 7:7-211 HFP-11 "E/L7/EW5040/SD211/Main cab"
|      |      |  |-- 7:7-212 HFP-11 "E/L7/EW5040/SD212/Pantry"
|      |      |  |-- 7:7-213 HTRI-R "E/L7/EW5040/CM213/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-214 HMS-S/D/M/SA "E/L7/EW5040/MCP214/Entry dr Psg"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:7 XDLC "DLC @ address 7 L7"

```
|      |      |  |-- 7:7-215 HFP-11 "E/L7/EW5201/SD215/Big cab"
|      |      |  |-- 7:7-216 HFP-11 "E/L7/EW5201/SD216/Manager cab"
|      |      |  |-- 7:7-217 HFP-11 "E/L7/EW5201/SD217/Psg nr Manager"
|      |      |  |-- 7:7-218 HFP-11 "E/L7/EW5201/SD218/lunch rm"
|      |      |  |-- 7:7-219 HFP-11 "E/L7/EW5201/SD219/Pantry"
|      |      |  |-- 7:7-220 HFP-11 "E/L7/EW5201/SD220/Assorter cab"
|      |      |  |-- 7:7-221 HFP-11 "E/L7/EW5201/SD221/Psg nr Assorte"
|      |      |  |-- 7:7-222 HFP-11 "E/L7/EW5201/SD222/Reception cab"
|      |      |  |-- 7:7-223 HFP-11 "E/L7/EW5201/SD223/Accounts cab"
|      |      |  |-- 7:7-224 HFP-11 "E/L7/EW5201/SD224/Assorter cab"
|      |      |  |-- 7:7-225 HFP-11 "E/L7/EW5201/SD225/Main cab"
|      |      |  |-- 7:7-226 HFP-11 "E/L7/EW5201/SD226/Main cab"
|      |      |  |-- 7:7-227 HFP-11 "E/L7/EW5201/SD227/Stock cab"
|      |      |  |-- 7:7-228 HFP-11 "E/L7/EW5201/SD228/Assorter cab"
|      |      |  |-- 7:7-229 HTRI-R "E/L7/EW5201/CM229/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 7:7-230 HMS-S/D/M/SA "E/L7/EW5201/MCP230/Entry Psg"
|      |      |  |-- 7:7-231 HFP-11 "E/L7/EW5201/SD231/Big cab"
|      |      |  |-- 7:7-232 HFP-11 "E/L7/EW5020/SD232/Main cab"
|      |      |  |-- 7:7-233 HFP-11 "E/L7/EW5020/SD233/Assorter cab"
|      |      |  |-- 7:7-234 HFP-11 "E/L7/EW5020/SD234/Psg nr Assorte"
|      |      |  |-- 7:7-235 HFP-11 "E/L7/EW5020/SD235/Accounts cab"
|      |      |  |-- 7:7-236 HFPT-11 "E/L7/EW5020/HD236/Pantry"
|      |      |  |-- 7:7-237 HTRI-R "E/L7/EW5020/CM237/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 7:7-238 HMS-S/D/M/SA "E/L7/EW5020/MCP238/Entry dr Psg"
|      |      |  |-- 7:7-239 HFP-11 "E/L7/EW5181/SD239/Cab 2"
|      |      |  |-- 7:7-240 HFP-11 "E/L7/EW5181/SD240/Cab 3"
|      |      |  |-- 7:7-241 HFP-11 "E/L7/EW5181/SD241/Cab 4"
|      |      |  |-- 7:7-242 HFP-11 "E/L7/EW5181/SD242/Cab 5"
|      |      |  |-- 7:7-243 HFP-11 "E/L7/EW5181/SD243/Psg nr Cab 5"
|      |      |  |-- 7:7-244 HFP-11 "E/L7/EW5181/SD244/Cab 6"
|      |      |  |-- 7:7-245 HFP-11 "E/L7/EW5181/SD245/Cab 7"
|      |      |  |-- 7:7-246 HFP-11 "E/L7/EW5181/SD246/Psg nr Cab 7"
|      |      |  |-- 7:7-247 HFP-11 "E/L7/EW5181/SD247/Cab 8"
|      |      |  |-- 7:7-248 HFP-11 "E/L7/EW5181/SD248/Cab 9"
|      |      |  |-- 7:7-249 HFP-11 "E/L7/EW5181/SD249/Cab 10"
|      |      |  |-- 7:7-250 HFP-11 "E/L7/EW5181/SD250/Cab 10"
|      |      |  |-- 7:7-251 HFP-11 "E/L7/EW5181/SD251/Psg nr Cab 10"
|      |      |  |-- 7:7-252 HFP-11 "E/L7/EW5181/SD252/Cab 12"
|      |      |  |-- 7:7-59 HTRI-S "E/L7/6F/MM59/DW6251"
|      |      |  |-- 7:7-74 HTRI-S "E/L7/W/6F/MM74/DW6210"
|      |      |  |-- 7:7-99 FDOT421 "E/L7/EW5071/SD99/Reception"
|      |      |  |-- 7:7-100 HTRI-R "E/L7/EW5071/CM100/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 7:7-101 HMS-S/D/M/SA "E/L7/EW5071/MCP101/Entry Psg"
|      |      |  |-- 7:7-183 HFP-11 "E/L7/DW6230/SD183/Main cab"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:7 XDLC "DLC @ address 7 L7"

```
|      |      |  |-- 7:7-143 HFP-11 "E/L7/EW5060/SD143/Pantry""
|      |      |  |-- 7:7-128 HFP-11 "E/L7/DW5190/SD128/Psg nr Pantry"
|      |      |  |-- 7:7-129 HFP-11 "E/L7/DW5190/SD129/Reception"
|      |      |  |-- 7:7-130 HFP-11 "E/L7/DW5190/SD130/Cab 1"
|      |      |  |-- 7:7-131 HFP-11 "E/L7/DW5190/SD131/Main Cab"
|      |      |  |-- 7:7-132 HFP-11 "E/L7/DW5190/SD132/Account Cab"
|      |      |  |-- 7:7-133 HFP-11 "E/L7/DW5190/SD133/Cab 2"
|      |      |  |-- 7:7-135 HMS-S/D/M/SA "E/L7/DW5190/MCP135/Entry Psg"
|      |      |  |-- 7:7-134 HTRI-R "E/L7/DW5190/CM134/Entry Psg AFC"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-142 HFP-11 "E/L7/EW5060/SD142/Psg Nr Sales C"
|      |      |  |-- 7:7-57 FDOT421 "E/L7/EW5201/SD57/Assorter cab"
|      |      |  |-- 7:7-107 HFP-11 "E/L7/EW5270/SD107/assoter cab"
|      |      |  |-- 7:7-108 HFP-11 "E/L7/EW5270/SD108/Main cab"
|      |      |  |-- 7:7-109 HFP-11 "E/L7/EW5270/SD109/psg nr pantry"
|      |      |  |-- 7:12 NIC-C(HNet) "NIC @ address 12"
|      |      |  |-- 7:13 XDLC "DLC @ address 13 L10"
|      |      |  |-- 7:13-8 HFP-11 "E/L10/EE3030/SD8/Main cab"
|      |      |  |-- 7:13-9 HFP-11 "E/L10/EE3030/SD9/Assorter cab"
|      |      |  |-- 7:13-10 HTRI-R "E/L10/EE3030/CM10/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:13-11 HMS-S/D/M/SA "E/L10/EE3030/MCP11/Entry Psg"
|      |      |  |-- 7:13-13 HFP-11 "E/L10/EE3050/SD13/Main cab"
|      |      |  |-- 7:13-14 HFP-11 "E/L10/EE3050/SD14/Assorter cab"
|      |      |  |-- 7:13-15 HFP-11 "E/L10/EE3050/SD15/Account cab"
|      |      |  |-- 7:13-16 HFP-11 "E/L10/EE3050/SD16/Pantry"
|      |      |  |-- 7:13-17 HTRI-R "E/L10/EE3050/CM17/AFC Entry dr P"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:13-18 HMS-S/D/M/SA "E/L10/EE3050/MCP18/Entry dr Psg"
|      |      |  |-- 7:13-26 HFP-11 "E/L10/EE3100/SD26/Main cab"
|      |      |  |-- 7:13-27 HFP-11 "E/L10/EE3100/SD27/GIA cab1"
|      |      |  |-- 7:13-28 HFP-11 "E/L10/EE3100/SD28/Accounts cab"
|      |      |  |-- 7:13-29 HFP-11 "E/L10/EE3100/SD29/GIA cab2"
|      |      |  |-- 7:13-30 HFP-11 "E/L10/EE3100/SD30/Pantry"
|      |      |  |-- 7:13-31 HTRI-R "E/L10/EE3100/CM31/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:13-32 HMS-S/D/M/SA "E/L10/EE3100/MCP32/Entry dr Psg"
|      |      |  |-- 7:13-33 HFP-11 "E/L10/EE2030/SD33/Main cab"
|      |      |  |-- 7:13-34 HFP-11 "E/L10/EE2030/SD34/Main cab"
|      |      |  |-- 7:13-35 HFP-11 "E/L10/EE2030/SD35/Assorter cab"
|      |      |  |-- 7:13-36 HFP-11 "E/L10/EE2030/SD36/Psg nr MC"
|      |      |  |-- 7:13-37 HFP-11 "E/L10/EE2030/SD37/Pantry"
|      |      |  |-- 7:13-38 HTRI-R "E/L10/EE2030/CM38/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:13-39 HMS-S/D/M/SA "E/L10/EE2030/MCP39/Entry dr Psg"
```


7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

```
|      |      |-- 7:13-40 HFP-11 "E/L10/EE3020/SD40/Accounts cab"
|      |      |-- 7:13-41 HFP-11 "E/L10/EE3020/SD41/Rishilbhai cab"
|      |      |-- 7:13-42 HFP-11 "E/L10/EE3020/SD42/Main cab"
|      |      |-- 7:13-43 HFP-11 "E/L10/EE3020/SD43/Assorter cab"
|      |      |-- 7:13-44 HFP-11 "E/L10/EE3020/SD44/Planning cab"
|      |      |-- 7:13-45 HFP-11 "E/L10/EE3020/SD45/Cab nr buyers "
|      |      |-- 7:13-46 HFP-11 "E/L10/EE3020/SD46/buyers cab"
|      |      |-- 7:13-47 HFP-11 "E/L10/EE3020/SD47/Psg nr MC"
|      |      |-- 7:13-48 HFP-11 "E/L10/EE3020/SD48/Pantry Psg"
|      |      |-- 7:13-49 HFP-11 "E/L10/EE3020/SD49/Entry Psg"
|      |      |-- 7:13-50 HFP-11 "E/L10/EE3020/SD50/Assorter cab 1"
|      |      |-- 7:13-51 HFP-11 "E/L10/EE3020/SD51/Assorter cab 2"
|      |      |-- 7:13-52 HFP-11 "E/L10/EE3020/SD52/Assorter cab 3"
|      |      |-- 7:13-53 HMS-S/D/M/SA "E/L10/EE3020/MCP53/Reception Psg"
|      |      |-- 7:13-54 HTRI-R "E/L10/EE3020/CM54/Reception Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-55 HFP-11 "E/L10/EC3021/SD55/Reception Psg"
|      |      |-- 7:13-56 HFP-11 "E/L10/EC3021/SD56/Psg nr Fauna c"
|      |      |-- 7:13-57 HFP-11 "E/L10/EC3021/SD57/Pricing cab"
|      |      |-- 7:13-58 HFP-11 "E/L10/EC3021/SD58/Sales dept"
|      |      |-- 7:13-59 HFP-11 "E/L10/EC3021/SD59/Grading cab"
|      |      |-- 7:13-60 HFP-11 "E/L10/EC3021/SD60/Export cab"
|      |      |-- 7:13-61 HFP-11 "E/L10/EC3021/SD61/Export cab"
|      |      |-- 7:13-62 HFP-11 "E/L10/EC3021/SD62/Buyers cab1"
|      |      |-- 7:13-63 HFP-11 "E/L10/EC3021/SD63/Buyers cab2"
|      |      |-- 7:13-64 HFP-11 "E/L10/EC3021/SD64/Fauna cab"
|      |      |-- 7:13-65 HFP-11 "E/L10/EC3021/SD65/Sales dept"
|      |      |-- 7:13-66 HFP-11 "E/L10/EC3021/SD66/Boss cab"
|      |      |-- 7:13-67 HFP-11 "E/L10/EC3021/SD67/Boss cab"
|      |      |-- 7:13-68 HFP-11 "E/L10/EC3021/SD68/Psg nr MC"
|      |      |-- 7:13-69 HFP-11 "E/L10/EC3021/SD69/Sant Kabir cab"
|      |      |-- 7:13-70 HFP-11 "E/L10/EC3021/SD70/Cust Relatn ca"
|      |      |-- 7:13-71 HFP-11 "E/L10/EC3021/SD71/Sales direct. "
|      |      |-- 7:13-72 HFP-11 "E/L10/EC3021/SD72/Vivekanand cab"
|      |      |-- 7:13-73 HFP-11 "E/L10/EC3021/SD73/Budha cab"
|      |      |-- 7:13-74 FDOT421 "E/L10/EC3021/SD74/osho cab"
|      |      |-- 7:13-75 HFP-11 "E/L10/EC3021/SD75/IT room"
|      |      |-- 7:13-76 HFP-11 "E/L10/EC3021/SD76/stock cab"
|      |      |-- 7:13-77 HFP-11 "E/L10/EC3021/SD77/Psg nr stock c"
|      |      |-- 7:13-78 HFP-11 "E/L10/EC3021/SD78/Pramukh cab"
|      |      |-- 7:13-79 HFPT-11 "E/L10/EC3021/HD79/Pantry"
|      |      |-- 7:13-80 XTRI-R "E/L10/EC3021/CM80/Reception Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-81 HMS-S/D/M/SA "E/L10/EC3021/MCP81/Reception Psg"
|      |      |-- 7:13-82 HFP-11 "E/L10/EC2030/SD82/Main cab"
|      |      |-- 7:13-83 HFP-11 "E/L10/EC2030/SD83/Pantry Psg"
|      |      |-- 7:13-84 HFP-11 "E/L10/EC2030/SD84/Cab 1"
|      |      |-- 7:13-85 HTRI-R "E/L10/EC2030/CM85/Entry dr Psg"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

7:13-85 HTRI-R "E/L10/EC2030/CM85/Entry dr Psg"

```
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 7:13-86 HMS-S/D/M/SA "E/L10/EC2030/MCP86/Entry dr Psg"
|      |      | |-- 7:13-87 HFP-11 "E/L10/EC2050/SD87/Main cab"
|      |      | |-- 7:13-88 HFP-11 "E/L10/EC2050/SD88/Pantry Psg"
|      |      | |-- 7:13-89 HFP-11 "E/L10/EC2050/SD89/Cab 1"
|      |      | |-- 7:13-90 HTRI-R "E/L10/EC2050/CM90/Entry dr Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 7:13-91 HMS-S/D/M/SA "E/L10/EC2050/MCP91/Entry dr Psg"
|      |      | |-- 7:13-92 HFP-11 "E/L10/EC2070/SD92/Main cab"
|      |      | |-- 7:13-93 HFP-11 "E/L10/EC2070/SD93/Cab 1"
|      |      | |-- 7:13-94 HFP-11 "E/L10/EC2070/SD94/Cab 2"
|      |      | |-- 7:13-95 HFP-11 "E/L10/EC2070/SD95/Entry Psg"
|      |      | |-- 7:13-96 HFPT-11 "E/L10/EC2070/HD96/Pantry"
|      |      | |-- 7:13-97 HTRI-R "E/L10/EC2070/CM97/Entry Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 7:13-98 HMS-S/D/M/SA "E/L10/EC2070/MCP98/Entry Psg"
|      |      | |-- 7:13-99 HFP-11 "E/L10/EC2110/SD99/Main cab"
|      |      | |-- 7:13-100 HFP-11 "E/L10/EC2110/SD100/Assorter cab"
|      |      | |-- 7:13-101 HFP-11 "E/L10/EC2110/SD101/Psg nr Assort"
|      |      | |-- 7:13-102 HFP-11 "E/L10/EC2110/SD102/Pantry Psg"
|      |      | |-- 7:13-103 HTRI-R "E/L10/EC2110/CM103/Entry Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 7:13-104 HMS-S/D/M/SA "E/L10/EC2110/MCP104/Entry Psg"
|      |      | |-- 7:13-105 HFP-11 "E/L10/EC1010/SD105/Main cab"
|      |      | |-- 7:13-106 HFP-11 "E/L10/EC1010/SD106/Assorter cab"
|      |      | |-- 7:13-107 HFP-11 "E/L10/EC1010/SD107/Psg nr MC"
|      |      | |-- 7:13-108 HFP-11 "E/L10/EC1010/SD108/Pantry"
|      |      | |-- 7:13-109 HTRI-R "E/L10/EC1010/CM109/Entry dr Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 7:13-110 HMS-S/D/M/SA "E/L10/EC1010/MCP110/Entry dr Psg"
|      |      | |-- 7:13-111 HFP-11 "E/L10/EC1030/SD111/Main cab"
|      |      | |-- 7:13-112 HFP-11 "E/L10/EC1030/SD112/Pantry Psg"
|      |      | |-- 7:13-113 HTRI-R "E/L10/EC1030/CM113/Entry dr Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 7:13-114 HMS-S/D/M/SA "E/L10/EC1030/MCP114/Entry dr Psg"
|      |      | |-- 7:13-115 HFP-11 "E/L10/EE3010/SD115/Accounts cab"
|      |      | |-- 7:13-116 HFP-11 "E/L10/EE3010/SD116/Jewellery cab"
|      |      | |-- 7:13-117 HFP-11 "E/L10/EE3010/SD117/Cab 3"
|      |      | |-- 7:13-118 HFP-11 "E/L10/EE3010/SD118/Cab 2"
|      |      | |-- 7:13-119 HFP-11 "E/L10/EE3010/SD119/Cab 1"
|      |      | |-- 7:13-120 HFP-11 "E/L10/EE3010/SD120/Assorter cab"
|      |      | |-- 7:13-121 HFP-11 "E/L10/EE3010/SD121/Entry Psg"
|      |      | |-- 7:13-122 HFP-11 "E/L10/EE3010/SD122/Pantry"
|      |      | |-- 7:13-123 HTRI-R "E/L10/EE3010/CM123/Entry Psg"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

7:13-123 HTRI-R "E/L10/EE3010/CM123/Entry Psg"

```
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 7:13-124 HMS-S/D/M/SA "E/L10/EE3010/MCP124/Entry Psg"
|      |      | |-- 7:13-125 HFP-11 "E/L10/EC1140/SD125/Cab 1"
|      |      | |-- 7:13-126 HFP-11 "E/L10/EC1140/SD126/Cab 2"
|      |      | |-- 7:13-127 HFP-11 "E/L10/EC1140/SD127/Cab 3"
|      |      | |-- 7:13-128 HFP-11 "E/L10/EC1140/SD128/Entry Psg"
|      |      | |-- 7:13-129 HTRI-R "E/L10/EC1140/CM129/Entry Psg"
|      |      | | |-- Switch ""
|      |      | | |-- Relay
|      |      | |-- 7:13-130 HMS-S/D/M/SA "E/L10/EC1140/MCP130/Entry Psg"
|      |      | |-- 7:13-131 HFP-11 "E/L10/EC2081/SD131/Cab 1"
|      |      | |-- 7:13-132 HFP-11 "E/L10/EC2081/SD132/Cab 2"
|      |      | |-- 7:13-133 HFP-11 "E/L10/EC2081/SD133/Cab 3"
|      |      | |-- 7:13-134 HFP-11 "E/L10/EC2081/SD134/Cab 4"
|      |      | |-- 7:13-135 HFPT-11 "E/L10/EC2081/HD135/Pantry"
|      |      | |-- 7:13-136 HFP-11 "E/L10/EC2081/SD136/AFC Pantry"
|      |      | |-- 7:13-137 HTRI-R "E/L10/EC2081/CM137/Entry dr Psg"
|      |      | | |-- Switch ""
|      |      | | |-- Relay
|      |      | |-- 7:13-138 HMS-S/D/M/SA "E/L10/EC2081/MCP138/Entry dr Psg"
|      |      | |-- 7:13-139 HFP-11 "E/L10/EC1040/SD139/Assorter cab"
|      |      | |-- 7:13-140 HFP-11 "E/L10/EC1040/SD140/Main cab"
|      |      | |-- 7:13-141 HFP-11 "E/L10/EC1040/SD141/Accounts cab"
|      |      | |-- 7:13-142 HFP-11 "E/L10/EC1040/SD142/Pantry"
|      |      | |-- 7:13-143 HFP-11 "E/L10/EC1040/SD143/Pantry"
|      |      | |-- 7:13-144 HTRI-R "E/L10/EC1040/CM144/Entry dr Psg"
|      |      | | |-- Switch ""
|      |      | | |-- Relay
|      |      | |-- 7:13-145 HMS-S/D/M/SA "E/L10/EC1040/MCP145/Entry dr Psg"
|      |      | |-- 7:13-146 HFP-11 "E/L10/EC3040/SD146/Main cab"
|      |      | |-- 7:13-147 HFP-11 "E/L10/EC3040/SD147/Main cab"
|      |      | |-- 7:13-148 HFP-11 "E/L10/EC3040/SD148/Accounts cab"
|      |      | |-- 7:13-149 HFPT-11 "E/L10/EC3040/HD149/Pantry"
|      |      | |-- 7:13-150 HFP-11 "E/L10/EC3040/SD150/Pantry"
|      |      | |-- 7:13-151 HTRI-R "E/L10/EC3040/CM151/Entry dr Psg"
|      |      | | |-- Switch ""
|      |      | | |-- Relay
|      |      | |-- 7:13-152 HMS-S/D/M/SA "E/L10/EC3040/MCP152/Entry dr Psg"
|      |      | |-- 7:13-153 HFP-11 "E/L10/EC3040/SD153/Reception"
|      |      | |-- 7:13-154 HFP-11 "E/L10/EC3040/SD154/Assorter cab"
|      |      | |-- 7:13-155 HFP-11 "E/L10/EC2083/SD155/Entry Psg"
|      |      | |-- 7:13-156 HFP-11 "E/L10/EC2083/SD156/Psg nr Acct c"
|      |      | |-- 7:13-157 HFP-11 "E/L10/EC2083/SD157/Accounts cab"
|      |      | |-- 7:13-158 HFPT-11 "E/L10/EC2083/HD158/Pantry"
|      |      | |-- 7:13-159 HFP-11 "E/L10/EC2083/SD159/Accounts cab"
|      |      | |-- 7:13-160 HFP-11 "E/L10/EC2083/SD160/Main cab 1"
|      |      | |-- 7:13-161 HFP-11 "E/L10/EC2083/SD161/Main cab 1"
|      |      | |-- 7:13-162 HFP-11 "E/L10/EC2083/SD162/Main cab 2"
|      |      | |-- 7:13-163 HFP-11 "E/L10/EC2083/SD163/Main cab 3"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

```
|      |      |-- 7:13-164 HFP-11 "E/L10/EC2083/SD164/Main cab 3"
|      |      |-- 7:13-165 HFP-11 "E/L10/EC2083/SD165/Psg nr Pantry"
|      |      |-- 7:13-166 HTRI-R "E/L10/EC2083/CM166/Entry Psg "
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-167 HMS-S/D/M/SA "E/L10/EC2083/MCP167/Entry Psg "
|      |      |-- 7:13-168 HFP-11 "E/L10/EC2090/SD168/Main cab1"
|      |      |-- 7:13-169 HFP-11 "E/L10/EC2090/SD169/Main cab2"
|      |      |-- 7:13-170 HFP-11 "E/L10/EC2090/SD170/Entry Psg"
|      |      |-- 7:13-171 HTRI-R "E/L10/EC2090/CM171/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-172 HMS-S/D/M/SA "E/L10/EC2090/MCP172/Entry Psg"
|      |      |-- 7:13-211 HFP-11 "E/L10/EE2020/SD211/Main cab"
|      |      |-- 7:13-212 HFP-11 "E/L10/EE2020/SD212/Assorter cab"
|      |      |-- 7:13-213 HFP-11 "E/L10/EE2020/SD213/Psg nr Assort"
|      |      |-- 7:13-214 HFPT-11 "E/L10/EE2020/HD214/Pantry"
|      |      |-- 7:13-215 HTRI-R "E/L10/EE2020/CM215/Pantry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-216 HMS-S/D/M/SA "E/L10/EE2020/MCP216/Pantry Psg"
|      |      |-- 7:13-217 HFP-11 "E/L10/EC2131/SD217/Cab 4"
|      |      |-- 7:13-218 HFP-11 "E/L10/EC2131/SD218/Cab 3"
|      |      |-- 7:13-219 HFP-11 "E/L10/EC2131/SD219/Cab 2"
|      |      |-- 7:13-220 HFP-11 "E/L10/EC2131/SD220/Cab 1"
|      |      |-- 7:13-221 HFP-11 "E/L10/EC2131/SD221/Cab 5"
|      |      |-- 7:13-222 HFP-11 "E/L10/EC2131/SD222/Cab 6"
|      |      |-- 7:13-223 HFP-11 "E/L10/EC2131/SD223/Cab 7"
|      |      |-- 7:13-224 HFP-11 "E/L10/EC2131/SD224/Psg nr Cab 3"
|      |      |-- 7:13-225 HFP-11 "E/L10/EC2131/SD225/Reception"
|      |      |-- 7:13-226 HFP-11 "E/L10/EC2131/SD226/Pantry"
|      |      |-- 7:13-227 HTRI-R "E/L10/EC2131/CM227/Entry dr psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-228 HMS-S/D/M/SA "E/L10/EC2131/MCP228/Entry dr psg"
|      |      |-- 7:13-229 HFP-11 "E/L10/EE3090/SD229/Cab 2"
|      |      |-- 7:13-230 HFP-11 "E/L10/EE3090/SD230/Cab 3"
|      |      |-- 7:13-231 HFP-11 "E/L10/EE3090/SD231/Account cab"
|      |      |-- 7:13-232 HFP-11 "E/L10/EE3090/SD232/Psg nr Accoun"
|      |      |-- 7:13-233 HFP-11 "E/L10/EE3090/SD233/Entry psg"
|      |      |-- 7:13-234 HFP-11 "E/L10/EE3090/SD234/Main cab"
|      |      |-- 7:13-235 HTRI-R "E/L10/EE3090/CM235/Entry psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-236 HMS-S/D/M/SA "E/L10/EE3090/MCP236/Entry psg"
|      |      |-- 7:13-237 HFP-11 "E/L10/EE3090/SD237/Pantry"
|      |      |-- 7:13-238 HFP-11 "E/L10/EE3080/SD238/Entry psg"
|      |      |-- 7:13-239 HFP-11 "E/L10/EE3080/SD239/Psg nr sales "
|      |      |-- 7:13-240 HFP-11 "E/L10/EE3080/SD240/Psg nr Assort"
|      |      |-- 7:13-241 HFP-11 "E/L10/EE3080/SD241/Sales cab"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

```
|      |      |-- 7:13-242 HFP-11 "E/L10/EE3080/SD242/Assorter cab"
|      |      |-- 7:13-243 HFP-11 "E/L10/EE3080/SD243/Lunch cab"
|      |      |-- 7:13-244 HFP-11 "E/L10/EE3080/SD244/Pantry"
|      |      |-- 7:13-245 HFP-11 "E/L10/EE3080/SD245/Main cab 1"
|      |      |-- 7:13-246 HFP-11 "E/L10/EE3080/SD246/Main cab 2"
|      |      |-- 7:13-247 HFP-11 "E/L10/EE3080/SD247/Main cab 2"
|      |      |-- 7:13-248 HTRI-R "E/L10/EE3080/CM248/Entry psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 7:13-249 HMS-S/D/M/SA "E/L10/EE3080/MCP249/Entry psg"
|      |      |-- 7:13-250 HFP-11 "E/L10/EC1140/SD250/AFC"
|      |      |-- 7:13-251 HFP-11 "E/L10/EC1140/SD251/AFC"
|      |-- 7:18 PSC-12 "PSC-12 @ address 18"
|          |-- 7:18-1 PSC Relay "Relay @ 011:001 - Common Alarm"
|          |-- 7:18-2 PSC Relay "Relay @ 011:002 - Common Trouble"
```

|-- 8 Desigo Fire Safety Modular "BDB TOWER F" Local

```
|      |-- System Flags
|      |-- History Log
|      |-- Behavior
|      |-- Voice
|      |-- Maintenance
|      |-- Field Devices
|      |-- Miscellaneous
|      |-- CAB-2 "CAB-2 Enclosure #1"
|          |-- CC-5 "Card Cage 5 Slots"
|              |-- 8:1 XDLC "XDLC @ address 1 L1"
|                  |-- 8:1-1 HMS-S/D/M/SA "F/L1/EC/GND/MCP1/LIFT LOBBY"
|                  |-- 8:1-2 HTRI-R "F/L1/EC/GND/CM2/LIFT LOBBY"
|                  |      |-- Switch ""
|                  |      |-- Relay
|                  |-- 8:1-3 HTRI-S "F/L1/EC/GND/MM3/LIFT LOBBY"
|                  |-- 8:1-4 HFP-11 "F/L1/EC/GND/SD4/ERM"
|                  |-- 8:1-5 HFP-11 "F/L1/EC/GND/SD5/LIFT LOBBY"
|                  |-- 8:1-6 HFP-11 "F/L1/EC/GND/SD6/LIFT LOBBY"
|                  |-- 8:1-7 HFP-11 "F/L1/EC/GND/SD7/LIFT LOBBY"
|                  |-- 8:1-8 HFP-11 "F/L1/EC/GND/SD8/LIFT LOBBY"
|                  |-- 8:1-9 HTRI-R "F/L1/EC/GND/CM9/AHU RM"
|                  |      |-- Switch ""
|                  |      |-- Relay
|                  |-- 8:1-10 HFP-11 "F/L1/EC/GND/SD10/AHU RM"
|                  |-- 8:1-11 HMS-S/D/M/SA "F/L1/CC/GND/MCP11/LIFT LOBBY"
|                  |-- 8:1-12 HTRI-R "F/L1/CC/GND/CM12/LIFT LOBBY"
|                  |      |-- Switch ""
|                  |      |-- Relay
|                  |-- 8:1-13 HTRI-S "F/L1/CC/GND/MM13/LIFT LOBBY"
|                  |-- 8:1-14 HFP-11 "F/L1/CC/GND/SD14/LIFT LOBBY"
|                  |-- 8:1-15 HFP-11 "F/L1/CC/GND/SD15/LIFT LOBBY"
|                  |-- 8:1-16 HFP-11 "F/L1/CC/GND/SD16/LIFT LOBBY"
|                  |-- 8:1-17 HFP-11 "F/L1/CC/GND/SD17/ELEC RM"
|                  |-- 8:1-18 HTRI-S "F/L1/UB/MM18/Nr Fire panel AC "
```