

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:8 XDLC "XDLC @ address L8"

```
|      |      |  |-- 9:8-124 HFP-11 "H/L8/HW8011B/SD124/Assortor cab1"
|      |      |  |-- 9:8-125 HFP-11 "H/L8/HW8011B/SD125/Assortor cab1"
|      |      |  |-- 9:8-126 HFPT-11 "H/L8/HW8011B/HD126/pantry"
|      |      |  |-- 9:8-127 HMS-S/D/M/SA "H/L8/HW8011B/MCP127/Assortor cab"
|      |      |  |-- 9:8-128 HMS-S/D/M/SA "H/L8/HW8011B/MCP128/Entry psg"
|      |      |  |-- 9:8-129 HTRI-R "H/L8/HW8011B/CM129/Entry psg AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:8-35 HFP-11 "G/L8/7F/SD35/ Corr. Nr. HW 7011E"
|      |      |  |-- 9:8-137 HTRI-S "G/L8/HW/7F/MM137/HW7011-C&D"
|      |      |  |-- 9:8-49 HTRI-S "G/L8/HE/8F/MM49/HE8011-A"
|      |      |  |-- 9:8-132 HTRI-S "G/L8/HW/7F/MM132/HW7012-B"
|      |      |  |-- 9:8-133 HTRI-S "G/L8/HW/7F/MM133/HW7012-A"
|      |      |  |-- 9:8-135 HTRI-S "G/L8/HW/7F/MM135/HW7013"
|      |      |  |-- 9:8-136 HTRI-S "G/L8/HW/7F/MM136/HW7011-E"
|      |      |  |-- 9:8-138 HTRI-S "G/L8/HW/7F/MM138/HW7011-A"
|      |      |  |-- 9:8-139 HTRI-S "G/L8/HW/7F/MM139/HW7011-B"
|      |      |  |-- 9:9 NIC-C(XNet) "NIC_Xnet @ address 9"
|      |      |  |-- 9:249 PSC-12 "PSC-12 @ address 1"
|      |      |  |-- 9:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      |      |  |-- 9:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      |      |  |-- Inner Door
|      |      |  |-- 9:253 PMI-D "PMI-D @ address 253"
```

|-- 1 Desigo Fire Safety Modular "BDB TOWER J" Local

```
|      |-- System Flags
|      |-- History Log
|      |-- Behavior
|      |-- Voice
|      |-- Maintenance
|      |-- Field Devices
|      |-- Miscellaneous
|      |-- CAB-2 "CAB-2 Enclosure #1"
|      |-- CC-5 "Card Cage 5 Slots"
|      |      |-- 1:1 DLC "DLC @ address 1 L1"
|      |      |      |-- 1:1-5 HFP-11 "J/L1/EC/GND/SD5/SECURITY CABIN"
|      |      |      |-- 1:1-6 HFP-11 "J/L1/EC/GND/SD6/LIFT LOBY"
|      |      |      |-- 1:1-7 HFP-11 "J/L1/EC/GND/SD7/LIFT LOBY"
|      |      |      |-- 1:1-8 HFP-11 "J/L1/EC/GND/SD8/LIFT LOBY"
|      |      |      |-- 1:1-15 HFP-11 "J/L1/WC/GND/SD15/SECURITY CABIN"
|      |      |      |-- 1:1-16 HFP-11 "J/L1/WC/GND/SD16/LIFT LOBY"
|      |      |      |-- 1:1-17 HFP-11 "J/L1/WC/GND/SD17/LIFT LOBY"
|      |      |      |-- 1:1-18 HFP-11 "J/L1/WC/GND/SD18/LIFT LOBY"
|      |      |      |-- 1:1-42 HFP-11 "J/L1/J-DTC/SD-42/Cab 25"
|      |      |      |-- 1:1-43 HFP-11 "J/L1/J-DTC/SD-43/Cab 26"
|      |      |      |-- 1:1-44 HFP-11 "J/L1/J-DTC/SD-44/Cab 27"
|      |      |      |-- 1:1-45 HFP-11 "J/L1/J-DTC/SD-45/Cab 28"
|      |      |      |-- 1:1-46 HFP-11 "J/L1/J-DTC/SD-46/Cab 29"
|      |      |      |-- 1:1-47 HFP-11 "J/L1/J-DTC/SD-47/Cab 30"
|      |      |      |-- 1:1-48 HFP-11 "J/L1/J-DTC/SD-48/Cab 31"
|      |      |      |-- 1:1-49 HFP-11 "J/L1/J-DTC/SD-49/Cab 32"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:1 DLC "DLC @ address 1 L1"
```

```
|      |      |  |-- 1:1-50 HFP-11 "J/L1/J-DTC/SD-50/Cab 33"
|      |      |  |-- 1:1-51 HFP-11 "J/L1/J-DTC/SD-51/Cab 34"
|      |      |  |-- 1:1-52 HFP-11 "J/L1/J-DTC/SD-52/Cab 35"
|      |      |  |-- 1:1-53 HFP-11 "J/L1/J-DTC/SD-53/Cab 36"
|      |      |  |-- 1:1-54 HFP-11 "J/L1/J-DTC/SD-54/Cab 37"
|      |      |  |-- 1:1-55 HFP-11 "J/L1/J-DTC/SD-55/Cab 38"
|      |      |  |-- 1:1-56 HFP-11 "J/L1/J-DTC/SD-56/Cab 39"
|      |      |  |-- 1:1-57 HFP-11 "J/L1/J-DTC/SD-57/Cab 40"
|      |      |  |-- 1:1-58 HFP-11 "J/L1/J-DTC/SD-58/Cab 41"
|      |      |  |-- 1:1-59 HFP-11 "J/L1/J-DTC/SD-59/Cab 42"
|      |      |  |-- 1:1-60 HFP-11 "J/L1/J-DTC/SD-60/Cab 43"
|      |      |  |-- 1:1-61 HFP-11 "J/L1/J-DTC/SD-61/Cab 44"
|      |      |  |-- 1:1-62 HFP-11 "J/L1/J-DTC/SD-62/Cab 45"
|      |      |  |-- 1:1-63 HFP-11 "J/L1/J-DTC/SD-63/Cab 46"
|      |      |  |-- 1:1-64 HFP-11 "J/L1/J-DTC/SD-64/Cab 47"
|      |      |  |-- 1:1-65 HFP-11 "J/L1/J-DTC/SD-65/Cab 48"
|      |      |  |-- 1:1-66 HFP-11 "J/L1/J-DTC/SD-66/Cab 49"
|      |      |  |-- 1:1-67 HFP-11 "J/L1/J-DTC/SD-67/Cab 50"
|      |      |  |-- 1:1-68 HFP-11 "J/L1/J-DTC/SD-68/Cab 51"
|      |      |  |-- 1:1-71 HFP-11 "J/L1/J-DTC/SD-71/Cab 54"
|      |      |  |-- 1:1-72 HFP-11 "J/L1/J-DTC/SD-72/Cab 55"
|      |      |  |-- 1:1-73 HFP-11 "J/L1/J-DTC/SD-73/Cab 56"
|      |      |  |-- 1:1-74 HFP-11 "J/L1/J-DTC/SD-74/Reception Area"
|      |      |  |-- 1:1-79 HFP-11 "J/L1/J-DTC/SD-79/Psg near Cab 25"
|      |      |  |-- 1:1-80 HFP-11 "J/L1/J-DTC/SD-80/Psg near Cab 27"
|      |      |  |-- 1:1-81 HFP-11 "J/L1/J-DTC/SD-81/Psg near Cab 29"
|      |      |  |-- 1:1-83 FDOT421 "J/L1/J-DTC/SD-83/Psg near Cab 32"
|      |      |  |-- 1:1-84 FDOT421 "J/L1/J-DTC/SD-84/Psg near Cab 34"
|      |      |  |-- 1:1-85 FDOT421 "J/LJ-DTC/SD-85/Psg NRCab38"
|      |      |  |-- 1:1-86 FDOT421 "J/L1/J-DTC/SD-86/Psg NRserver"
|      |      |  |-- 1:1-87 FDOT421 "J/L1/J-DTC/SD-87/Psg NRCab44"
|      |      |  |-- 1:1-88 FDOT421 "J/L1/J-DTC/SD-88/Psg NRFireE"
|      |      |  |-- 1:1-89 FDOT421 "J/L1/J-DTC/SD-89/Psg NRCab50"
|      |      |  |-- 1:1-90 FDOT421 "J/L1/J-DTC/SD-90/Psg NRElectr"
|      |      |  |-- 1:1-91 FDOT421 "J/L1/J-DTC/SD-91/Psg NRCab53"
|      |      |  |-- 1:1-93 FDOT421 "J/L1/J-DTC/SD-93/Electrical Room"
|      |      |  |-- 1:1-94 FDOT421 "J/L1/J-DTC/SD-94/Server Room"
|      |      |  |-- 1:1-100 HMS-S/D/M/SA "J/L1/JDTC/MCP100/psg near cab 25"
|      |      |  |-- 1:1-101 HMS-S/D/M/SA "J/L1/JDTC/MCP101/psg near cab 32"
|      |      |  |-- 1:1-102 HMS-S/D/M/SA "J/L1/J-DTC/MCP-102/psg near Elec"
|      |      |  |-- 1:1-103 HTRI-S "H/L1/WC/UB/MM103/ELEC ROOM"
|      |      |  |-- 1:1-104 HTRI-S "H/L1/WC/UB/MM104/LIFT MC RM"
|      |      |  |-- 1:1-105 HTRI-R "H/L1/WC/UB/CM105/STAIRCASE"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:1-106 HMS-S/D/M/SA "H/L1/WC/UB/MCP106/STAIRCASE"
|      |      |  |-- 1:1-107 HMS-S/D/M/SA "H/L1/CC/UB/MCP107/STAIRCASE"
|      |      |  |-- 1:1-108 HTRI-R "H/L1/CC/UB/CM108/STAIRCASE"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:1 DLC "DLC @ address 1 L1"

				--	1:1-109	HTRI-S	"H/L1/EC/UB/MM109/ELEC ROOM"
				--	1:1-110	HTRI-S	"H/L1/EC/UB/MM110/LIFT MC RM"
				--	1:1-111	HTRI-S	"J/L1/EC/UB/MM111/ELEC RM"
				--	1:1-116	HMS-S/D/M/SA	"J/L1/WC/UB/MCP116/STAIRCASE HE E"
				--	1:1-117	HTRI-R	"J/L1/WC/UB/CM117/STAIRCASE HE EX"
				--	Switch	"	"
				--	Relay		
				--	1:1-118	HTRI-R	"J/L1/WC/UB/CM118/STAIRCASE JE CO"
				--	Switch	"	"
				--	Relay		
				--	1:1-119	HMS-S/D/M/SA	"J/L1/WC/UB/MCP119/STAIRCASE JE C"
				--	1:1-121	HMS-S/D/M/SA	"J/L1/EC/UB/MCP121/STAIRCASE CUST"
				--	1:1-122	HTRI-R	"J/L1/EC/UB/CM122/STAIRCASE CUSTO"
				--	Switch	"	"
				--	Relay		
				--	1:1-123	HTRI-S	"J/L1/EC/UB/MM123/ELEC ROOM"
				--	1:1-124	HFP-11	"H/L1/WC/UB/SD124/ELEC ROOM"
				--	1:1-125	HFP-11	"H/L1/WC/UB/SD125/LIFT MC RM"
				--	1:1-127	HFP-11	"H/L1/EC/UB/SD127/ELEC ROOM"
				--	1:1-128	HFP-11	"H/L1/EC/UB/SD128/LIFT MC RM"
				--	1:1-131	HFP-11	"H/L1/EC/UB/SD131/ELEC RM"
				--	1:1-135	HFP-11	"J/L1/EC/UB/SD135/ELEC RM"
				--	1:1-136	HFP-11	"J/L1/EC/UB/SD136/BMS ROOM"
				--	1:1-137	HMS-S/D/M/SA	"J/L1/J-DTC/MCP137/Psg Nr cab49 "
				--	1:1-138	HTRI-R	"J/L1/JW/GND/CM-138/electr Room"
				--	Switch	"	"
				--	Relay		
				--	1:1-139	HMS-S/D/M/SA	"J/L1/J-DTC/MCP-139/psg near recp"
				--	1:1-140	HMS-S/D/M/SA	"J/L1/J-DTC/MCP140/Psg Nr cab41 "
				--	1:1-164	HFP-11	"J/L1/J-DTC/SD-164/AFC Cab 17"
				--	1:1-165	HFP-11	"J/L1/J-DTC/SD-165/AFC Cab 18"
				--	1:1-166	HFP-11	"J/L1/J-DTC/SD-166/AFC Cab 19"
				--	1:1-167	HFP-11	"J/L1/J-DTC/SD-167/AFC Cab 20"
				--	1:1-168	HFP-11	"J/L1/J-DTC/SD-168/AFC Cab 21"
				--	1:1-169	HFP-11	"J/L1/J-DTC/SD-169/AFC Cab 22"
				--	1:1-170	HFP-11	"J/L1/J-DTC/SD-170/AFC Cab 23"
				--	1:1-171	HFP-11	"J/L1/J-DTC/SD-171/AFC Cab 24"
				--	1:1-172	HFP-11	"J/L1/J-DTC/SD-172/AFC Cab 25"
				--	1:1-173	HFP-11	"J/L1/J-DTC/SD-173/AFC Cab 26"
				--	1:1-174	HFP-11	"J/L1/J-DTC/SD-174/AFC Cab 27"
				--	1:1-175	HFP-11	"J/L1/J-DTC/SD-175/AFC Cab 28"
				--	1:1-176	HFP-11	"J/L1/J-DTC/SD-176/AFC Cab 29"
				--	1:1-177	HFP-11	"J/L1/J-DTC/SD-177/AFC Cab 30"
				--	1:1-178	HFP-11	"J/L1/J-DTC/SD-178/AFC Cab 31"
				--	1:1-179	HFP-11	"J/L1/J-DTC/SD-179/AFC Cab 32"
				--	1:1-180	HFP-11	"J/L1/J-DTC/SD-180/AFC Cab 3"
				--	1:1-181	HFP-11	"J/L1/J-DTC/SD-181/AFC Cab 34"
				--	1:1-182	HFP-11	"J/L1/J-DTC/SD-182/AFC Cab 35"
				--	1:1-183	HFP-11	"J/L1/J-DTC/SD-183/AFC Cab 36"
				--	1:1-184	HFP-11	"J/L1/J-DTC/SD-184/AFC Cab 37"

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:1 DLC "DLC @ address 1 L1"

```
|      |      |      |-- 1:1-185 HFP-11 "J/L1/J-DTC/SD-185/AFC Cab 38"
|      |      |      |-- 1:1-186 HFP-11 "J/L1/J-DTC/SD-186/AFC Cab 39"
|      |      |      |-- 1:1-187 HFP-11 "J/L1/J-DTC/SD-187/AFC Cab 40"
|      |      |      |-- 1:1-188 HFP-11 "J/L1/J-DTC/SD-188/AFC Cab 41"
|      |      |      |-- 1:1-189 HFP-11 "J/L1/J-DTC/SD-189/AFC Cab 42"
|      |      |      |-- 1:1-190 HFP-11 "J/L1/J-DTC/SD-190/AFC Cab 43"
|      |      |      |-- 1:1-193 HFP-11 "J/L1/J-DTC/SD-193/AFC Cab 46"
|      |      |      |-- 1:1-194 HFP-11 "J/L1/J-DTC/SD-194/AFC Cab 47"
|      |      |      |-- 1:1-195 HFP-11 "J/L1/J-DTC/SD-195/AFC Cab 48"
|      |      |      |-- 1:1-196 HFP-11 "J/L1/J-DTC/SD-196/AFC Cab 49"
|      |      |      |-- 1:1-201 HFP-11 "J/L1/J-DTC/SD-201/AFC Cab 54"
|      |      |      |-- 1:1-202 HFP-11 "J/L1/J-DTC/SD-202/AFC Cab 55"
|      |      |      |-- 1:1-203 HFP-11 "J/L1/J-DTC/SD-203/AFC Cab 56"
|      |      |      |-- 1:1-204 FDOT421 "J/L1/J-DTC/SD-204/AFC at Recepti"
|      |      |      |-- 1:1-205 HFP-11 "J/L1/J-DTC/SD-205/Psg AFC near C"
|      |      |      |-- 1:1-206 FDOT421 "J/L1/J-DTC/SD-206/Psg AFC NR C"
|      |      |      |-- 1:1-207 HFP-11 "J/L1/J-DTC/SD-207/Psg AFC near C"
|      |      |      |-- 1:1-208 HFP-11 "J/L1/J-DTC/SD-208/Psg AFC near C"
|      |      |      |-- 1:1-209 HFP-11 "J/L1/J-DTC/SD-209/Psg AFC near C"
|      |      |      |-- 1:1-210 FDOT421 "J/L1/JDTC/SD210/PsgAFCnearCabi47"
|      |      |      |-- 1:1-211 HFP-11 "J/L1/JDTC/SD211/PsgAFCnearCabi50"
|      |      |      |-- 1:1-212 HFP-11 "J/L1/J-DTC/SD-212/Psg AFC near C"
|      |      |      |-- 1:1-213 HFP-11 "J/L1/J-DTC/SD-213/Psg AFC near C"
|      |      |      |-- 1:1-214 FDOT421 "J/L1/GF/Custom/SD214/AFC desk 12"
|      |      |      |-- 1:1-215 FDOT421 "J/L1/GF/Custom/SD215/AFC Server"
|      |      |      |-- 1:1-216 FDOT421 "J/L1/GF/Custom/SD216/AFC desk 10"
|      |      |      |-- 1:1-217 FDOT421 "J/L1/GF/Custom/SD217/AFC Psg nr"
|      |      |      |-- 1:1-218 FDOT421 "J/L1/GF/Custom/SD218/AFC desk 4"
|      |      |      |-- 1:1-219 FDOT421 "J/L1/GF/Custom/SD219/AFC Psg nr"
|      |      |      |-- 1:1-220 FDOT421 "J/L1/GF/Custom/SD220/AFC desk 1"
|      |      |      |-- 1:1-221 FDOT421 "J/L1/GF/Custom/SD221/Psg nr serv"
|      |      |      |-- 1:1-222 FDOT421 "J/L1/GF/Custom/SD222/PsgNrDesk11"
|      |      |      |-- 1:1-223 FDOT421 "J/L1/GF/Custom/SD223/PsgNrDesk17"
|      |      |      |-- 1:1-224 FDOT421 "J/L1/GF/Custom/SD224/Psg desk 9"
|      |      |      |-- 1:1-225 FDOT421 "J/L1/GF/Custom/SD225/Psg desk 19"
|      |      |      |-- 1:1-226 FDOT421 "J/L1/GF/Custom/SD226/PsgNrDesk8"
|      |      |      |-- 1:1-227 FDOT421 "J/L1/GF/Custom/SD227/PsgNrDesk29"
|      |      |      |-- 1:1-228 FDOT421 "J/L1/GF/Custom/SD228/Psg desk 5"
|      |      |      |-- 1:1-229 FDOT421 "J/L1/GF/Custom/SD229/Psg nr wash"
|      |      |      |-- 1:1-230 FDOT421 "J/L1/GF/Custom/SD230/Psg desk 4"
|      |      |      |-- 1:1-231 FDOT421 "J/L1/GF/Custom/SD231/Psg desk 2"
|      |      |      |-- 1:1-232 FDOT421 "J/L1/GF/Cust/SD232/Cab nr Back E"
|      |      |      |-- 1:1-233 FDOT421 "J/L1/GF/Cust/SD233/Psg nrNw C Bk"
|      |      |      |-- 1:1-234 HTRI-R "J/L1/GF/Custom/CM234/Psg nr nw C"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:1-235 HMS-S/D/M/SA "J/L1/GF/Custom/MCP235/Psg nr nw "
|      |      |      |-- 1:2 DLC "DLC @ address 2 L2"
|      |      |      |-- 1:2-1 HTRI-R "J/L2/7B/1F/CM1/LIFT LOBBY CM NR "
|      |      |      |      |-- Switch ""
```

```
|      |      |      |      |      |      | Relay  
|      |      |      |      |      |      |  
|      |      |      |      |      |      | --- 1:2-2 HFP-11 "J/L2/7B/1F/SD2/CORR NR JE 1010"  
|      |      |      |      |      |      | --- 1:2-3 HFP-11 "J/L2/7B/1F/SD3/CORR NR 7B S18"  
|      |      |      |      |      |      | --- 1:2-4 HFP-11 "J/L2/7B/1F/SD4/CORR NR JE 1030"  
|      |      |      |      |      |      | --- 1:2-5 HFP-11 "J/L2/7B/1F/SD5/CORR NR JE 1030 A"  
|      |      |      |      |      |      | --- 1:2-6 HFP-11 "J/L2/7B/1F/SD6/CORR NR JE 1050"  
|      |      |      |      |      |      | --- 1:2-7 HFP-11 "J/L2/7B/1F/SD7/CORR NR 7B S14"  
|      |      |      |      |      |      | --- 1:2-8 HFP-11 "J/L2/7B/1F/SD8/CORR NR 7B S14 AF"  
|      |      |      |      |      |      | --- 1:2-9 HMS-S/D/M/SA "J/L2/7B/1F/MCP9/FIRE ESC STR"  
|      |      |      |      |      |      | --- 1:2-10 HTRI-R "J/L2/7B/1F/CM10/FIRE ESC STR"  
|      |      |      |      |      |      |  
|      |      |      |      |      |      |    |-- Switch ""  
|      |      |      |      |      |      |    |-- Relay  
|      |      |      |      |      |      |  
|      |      |      |      |      |      | --- 1:2-11 HTRI-S "J/L2/7B/1F/MM11/FIRE ESC STR"  
|      |      |      |      |      |      | --- 1:2-12 HFP-11 "J/L2/7B/1F/SD12/CORR NR 7B S11"  
|      |      |      |      |      |      | --- 1:2-13 HFP-11 "J/L2/7B/1F/SD13/CORR NR 7B S11 A"  
|      |      |      |      |      |      | --- 1:2-14 HFP-11 "J/L2/7B/1F/SD14/CORR NR JE 1150"  
|      |      |      |      |      |      | --- 1:2-15 HFP-11 "J/L2/7B/1F/SD15/AHU RM SD"  
|      |      |      |      |      |      | --- 1:2-16 HTRI-R "J/L2/7B/1F/CM16/AHU RM CM"  
|      |      |      |      |      |      |  
|      |      |      |      |      |      |    |-- Switch ""  
|      |      |      |      |      |      |    |-- Relay  
|      |      |      |      |      |      |  
|      |      |      |      |      |      | --- 1:2-17 HFP-11 "J/L2/7B/1F/SD17/CORR NR JW1210 A"  
|      |      |      |      |      |      | --- 1:2-18 HFP-11 "J/L2/7B/1F/SD18/CORR NR JW 1210 "  
|      |      |      |      |      |      | --- 1:2-20 HMS-S/D/M/SA "J/L2/7B/1F/MCP20/FIRE SHAFT L.L."  
|      |      |      |      |      |      | --- 1:2-21 HTRI-R "J/L2/7B/1F/CM21/FIRE SHAFT L.L."  
|      |      |      |      |      |      |  
|      |      |      |      |      |      |    |-- Switch ""  
|      |      |      |      |      |      |    |-- Relay  
|      |      |      |      |      |      |  
|      |      |      |      |      |      | --- 1:2-22 HTRI-S "J/L2/7B/1F/MM22/FIRE SHAFT L.L."  
|      |      |      |      |      |      | --- 1:2-23 HFP-11 "J/L2/7B/1F/SD23/LIFT LOBBY SD"  
|      |      |      |      |      |      | --- 1:2-24 HFP-11 "J/L2/7B/1F/SD24/ELECT RM SD"  
|      |      |      |      |      |      | --- 1:2-25 HFP-11 "J/L2/7B/1F/SD25/CORR NR JW 1030 "  
|      |      |      |      |      |      | --- 1:2-26 HFP-11 "J/L2/7B/1F/SD26/CORR NR JW 1030"  
|      |      |      |      |      |      | --- 1:2-29 HFP-11 "J/L2/7B/1F/SD29/CORR NR 7B S28 A"  
|      |      |      |      |      |      | --- 1:2-30 HFP-11 "J/L2/7B/1F/SD30/CORR NR 7B S 28"  
|      |      |      |      |      |      | --- 1:2-31 HFP-11 "J/L2/7B/1F/SD31/CORR NR JE 1250"  
|      |      |      |      |      |      | --- 1:2-32 HFP-11 "J/L2/7B/1F/SD32/CORR NR JE1280 A"  
|      |      |      |      |      |      | --- 1:2-33 HFP-11 "J/L2/7B/1F/SD33/CORR NR JE 7B S3"  
|      |      |      |      |      |      | --- 1:2-34 HFP-11 "J/L2/7B/1F/SD34/CORR NR JE 7B S3"  
|      |      |      |      |      |      | --- 1:2-35 HFP-11 "J/L2/7B/1F/SD35/AHU RM NR 7B S37"  
|      |      |      |      |      |      | --- 1:2-36 HTRI-R "J/L2/7B/1F/CM36/AHU RM 7B S37"  
|      |      |      |      |      |      |  
|      |      |      |      |      |      |    |-- Switch ""  
|      |      |      |      |      |      |    |-- Relay  
|      |      |      |      |      |      |  
|      |      |      |      |      |      | --- 1:2-37 HMS-S/D/M/SA "J/L2/7B/1F/MCP37/FIRE SHAFT L.L."  
|      |      |      |      |      |      | --- 1:2-38 HTRI-S "J/L2/7B/1F/MM38/FIRE SHAFT L.L."  
|      |      |      |      |      |      | --- 1:2-39 HTRI-R "J/L2/7B/1F/CM39/FIRE SHAFT L.L."  
|      |      |      |      |      |      |  
|      |      |      |      |      |      |    |-- Switch ""  
|      |      |      |      |      |      |    |-- Relay  
|      |      |      |      |      |      |  
|      |      |      |      |      |      | --- 1:2-40 HFP-11 "J/L2/7B/1F/SD40/CORR NR JE 1300"  
|      |      |      |      |      |      | --- 1:2-41 HFP-11 "J/L2/7B/1F/SD41/CORR NR JE1300 A"  
|      |      |      |      |      |      | --- 1:2-42 HFP-11 "J/L2/7B/1F/SD42/CORR NR JE 1330"  
|      |      |      |      |      |      | --- 1:2-43 HFP-11 "J/L2/7B/1F/SD43/CORR NR JE1200 A"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:2 DLC "DLC @ address 2 L2"

```
|      |      |      |-- 1:2-44 HFP-11 "J/L2/7B/1F/SD44/CORR NR JE 1200"
|      |      |      |-- 1:2-46 HFP-11 "J/L2/7B/1F/SD46/ELECT RM SD"
|      |      |      |-- 1:2-47 HFP-11 "J/L2/7B/1F/SD47/LIFT LOBBY SD"
|      |      |      |-- 1:2-48 HFP-11 "J/L2/7B/1F/SD48/LIFT LOBBY SD"
|      |      |      |-- 1:2-50 HFP-11 "J/L2/JW1120/SD50/Main cab"
|      |      |      |-- 1:2-51 HFP-11 "J/L2/JW1120/SD51/Assorter cab"
|      |      |      |-- 1:2-52 HFPT-11 "J/L2/JW1120/HD52/Pantry"
|      |      |      |-- 1:2-53 HTRI-R "J/L2/JW1120/CM53/Psg nr Entry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:2-54 HMS-S/D/M/SA "J/L2/JW1120/MCP54/Psg nr Entry"
|      |      |      |-- 1:2-55 FDOT421 "J/L2/GF/Custom/SD55/Pag Nr EDI C"
|      |      |      |-- 1:2-56 FDOT421 "J/L2/GF/Custom/SD56/Waiting Area"
|      |      |      |-- 1:2-57 FDOT421 "J/L2/GF/Custom/SD57/Waiting Area"
|      |      |      |-- 1:2-58 FDOT421 "J/L2/GF/Custom/SD58/Waiting Area"
|      |      |      |-- 1:2-59 FDOT421 "J/L2/GF/Custom/SD59/Waiting Area"
|      |      |      |-- 1:2-60 FDOT421 "J/L2/GF/Custom/SD60/Waiting Area"
|      |      |      |-- 1:2-61 FDOT421 "J/L2/GF/Custom/SD61/Waiting Area"
|      |      |      |-- 1:2-63 FDOT421 "J/L2/GF/Custom/SD63/Waiting Area"
|      |      |      |-- 1:2-64 FDOT421 "J/L2/GF/Custom/SD64/Cash Counter"
|      |      |      |-- 1:2-65 FDOT421 "J/L2/GF/Custom/SD65/Kioss Machin"
|      |      |      |-- 1:2-66 FDOT421 "J/L2/GF/Custom/SD66/Parcel Depos"
|      |      |      |-- 1:2-67 FDOT421 "J/L2/GF/Custom/SD67/Parcel Depos"
|      |      |      |-- 1:2-68 FDOT421 "J/L2/GF/Custom/SD68/Parcel Depos"
|      |      |      |-- 1:2-69 FDOT421 "J/L2/GF/Custom/SD69/GJ EPC Cabin"
|      |      |      |-- 1:2-94 FDOT421 "J/L2/GF/Custom/SD94/BVC Ltd"
|      |      |      |-- 1:2-95 FDOT421 "J/L2/GF/Custom/SD95/New Server R"
|      |      |      |-- 1:2-97 FDOT421 "J/L2/GF/Custom/SD97/Psg nr Dep.C"
|      |      |      |-- 1:2-98 FDOT421 "J/L2/GF/Custom/SD98/Dep.Commissi"
|      |      |      |-- 1:2-99 FDOT421 "J/L2/GF/Custom/SD99/Psg nr Lisce"
|      |      |      |-- 1:2-100 FDOT421 "J/L2/GF/Custom/SD100/Liscense rm"
|      |      |      |-- 1:2-101 FDOT421 "J/L2/GF/Custom/SD101/Liscense rm"
|      |      |      |-- 1:2-102 FDOT421 "J/L2/GF/Custom/SD102/Liscense rm"
|      |      |      |-- 1:2-103 HTRI-S "J/L2/GF/Custom/MM103/Psg nr Lisc"
|      |      |      |-- 1:2-104 HTRI-R "J/L2/GF/Custom/CM104/Psg nr Lisc"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:2-105 HMS-S/D/M/SA "J/L2/GF/Custom/MCP105/Psg nr Lis"
|      |      |      |-- 1:2-106 FDOT421 "J/L2/GF/Custom/SD106/Reception"
|      |      |      |-- 1:2-107 FDOT421 "J/L2/GF/Custom/SD107/Parcel Coll"
|      |      |      |-- 1:2-108 FDOT421 "J/L2/GF/Custom/SD108/Parcel Coll"
|      |      |      |-- 1:2-109 HFP-11 "J/L2/GF/Custom/SD109/Table 21"
|      |      |      |-- 1:2-110 FDOT421 "J/L2/GF/Custom/SD110/Commissione"
|      |      |      |-- 1:2-111 FDOT421 "J/L2/GF/Custom/SD111/Commissione"
|      |      |      |-- 1:2-112 FDOT421 "J/L2/GF/Custom/SD112/Vinay Singh"
|      |      |      |-- 1:2-113 FDOT421 "J/L2/GF/Custom/SD113/Vinay Singh"
|      |      |      |-- 1:2-114 HMS-S/D/M/SA "J/L2/GF/Custom/MCP114/Export cab"
|      |      |      |-- 1:2-115 FDOT421 "J/L2/GF/Custom/SD115/Export Tabl"
|      |      |      |-- 1:2-116 FDOT421 "J/L2/GF/Custom/SD116/Export Tabl"
|      |      |      |-- 1:2-117 FDOT421 "J/L2/GF/Custom/SD117/BDB stock r"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:2 DLC "DLC @ address 2 L2"

| | | |-- 1:2-118 HFP-11 "J/L2/GF/Custom/SD118/Brinks area"
| | | |-- 1:2-119 FDOT421 "J/L2/GF/Custom/SD119/Brinks area"
| | | |-- 1:2-120 FDOT421 "J/L2/GF/Custom/SD120/Malca Amit"
| | | |-- 1:2-121 HMS-S/D/M/SA "J/L2/GF/Custom/MCP121/Malca Amit"
| | | |-- 1:2-122 FDOT421 "J/L2/GF/Custom/SD122/Gomes cab"
| | | |-- 1:2-123 FDOT421 "J/L2/GF/Custom/SD123/MMTC cab"
| | | |-- 1:2-124 FDOT421 "J/L2/GF/Custom/SD124/Custodian A"
| | | |-- 1:2-125 FDOT421 "J/L2/GF/Custom/SD125/Custodian A"
| | | |-- 1:2-126 HMS-S/D/M/SA "J/L2/GF/Custom/MCP126/Custodian A"
| | | |-- 1:2-127 FDOT421 "J/L2/GF/Custom/SD127/Conference"
| | | |-- 1:2-128 FDOT421 "J/L2/GF/Custom/SD128/Conference"
| | | |-- 1:2-129 FDOT421 "J/L2/GF/Custom/SD129/Conference"
| | | |-- 1:2-130 FDOT421 "J/L2/GF/Custom/SD130/Server rm"
| | | |-- 1:2-131 FDOT421 "J/L2/GF/Custom/SD131/Server rm"
| | | |-- 1:2-132 HTRI-R "J/L2/GF/Custom/CM132/Psg nr Serv"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **1:2-133 FDOT421 "J/L2/GF/Custom/SD133/Psg nr CHA"**
| | | |-- 1:2-134 FDOT421 "J/L2/GF/Custom/SD134/CHA cab"
| | | |-- 1:2-135 FDOT421 "J/L2/GF/Custom/SD135/Table 13"
| | | |-- 1:2-136 FDOT421 "J/L2/GF/Custom/SD136/Table 15"
| | | |-- 1:2-137 FDOT421 "J/L2/GF/Custom/SD137/Table 7"
| | | |-- 1:2-138 FDOT421 "J/L2/GF/Custom/SD138/Table 17"
| | | |-- 1:2-139 HMS-S/D/M/SA "J/L2/GF/Custom/MCP139/Psg nr Tab"
| | | |-- 1:2-140 FDOT421 "J/L2/GF/Custom/SD140/Table 21"
| | | |-- 1:2-141 FDOT421 "J/L2/GF/Custom/SD141/Table 24"
| | | |-- 1:2-142 FDOT421 "J/L2/GF/Custom/SD142/Table 27"
| | | |-- 1:2-143 HMS-S/D/M/SA "J/L2/GF/Custom/MCP143/Custom Ent"
| | | |-- 1:2-144 HFP-11 "J/L2/GF/Custom/SD144/Custom Entr"
| | | |-- 1:2-145 FDOT421 "J/L2/GF/Custom/SD145/BKFF Pvt Lt"
| | | |-- 1:2-146 FDOT421 "J/L2/GF/Custom/SD146/Psg nr Sequ"
| | | |-- 1:2-147 FDOT421 "J/L2/GF/Custom/SD147/Sequel Log"
| | | |-- 1:2-148 HFP-11 "J/L2/GF/Cus/SD148/Psg nr BVchena"
| | | |-- 1:2-150 HTRI-S "J/L2/JE1F/MM150/Psg nr JE1020"
| | | |-- 1:2-151 HFP-11 "J/L2/JE1010/SD151/Assorter cab1"
| | | |-- 1:2-152 HFP-11 "J/L2/JE1010/SD152/Main cab"
| | | |-- 1:2-153 HFP-11 "J/L2/JE1010/SD153/Assorter cab2"
| | | |-- 1:2-154 HFP-11 "J/L2/JE1010/SD154/Pantry"
| | | |-- 1:2-155 HTRI-R "J/L2/JE1010/CM155/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **1:2-156 HMS-S/D/M/SA "J/L2/JE1010/MCP156/Psg nr Entry"**
| | | |-- 1:2-157 HFP-11 "J/L2/JE1170/SD157/Psg nr Entry"
| | | |-- 1:2-158 HFP-11 "J/L2/JE1170/SD158/Main cab"
| | | |-- 1:2-159 HFP-11 "J/L2/JE1170/SD159/Assorter cab"
| | | |-- 1:2-160 HTRI-R "J/L2/JE1170/CM160/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **1:2-161 HMS-S/D/M/SA "J/L2/JE1170/MCP161/Entry dr Psg"**
| | | |-- 1:2-162 HFP-11 "J/L2/JE1040/SD162/Assorter cab"

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:2 DLC "DLC @ address 2 L2"
```

```
|      |      |  |-- 1:2-163 HFP-11 "J/L2/JE1040/SD163/Main cab1"
|      |      |  |-- 1:2-164 HFP-11 "J/L2/JE1040/SD164/Main cab2"
|      |      |  |-- 1:2-165 HFP-11 "J/L2/JE1040/SD165/Waiting rm"
|      |      |  |-- 1:2-166 HTRI-R "J/L2/JE1040/CM166/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:2-167 HMS-S/D/M/SA "J/L2/JE1040/MCP167/Entry dr Psg"
|      |      |  |-- 1:2-168 HFP-11 "J/L2/JW1110/SD168/Entry Psg"
|      |      |  |-- 1:2-169 HFP-11 "J/L2/JW1110/SD169/Entry Psg"
|      |      |  |-- 1:2-170 HTRI-R "J/L2/JW1110/CM170/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:2-171 HMS-S/D/M/SA "J/L2/JW1110/MCP171/Entry Psg"
|      |      |  |-- 1:2-172 HFP-11 "J/L2/JE1180/SD172/Main cab"
|      |      |  |-- 1:2-173 HFP-11 "J/L2/JE1180/SD173/Assorter cab"
|      |      |  |-- 1:2-174 HFP-11 "J/L2/JE1180/SD174/Entry Psg"
|      |      |  |-- 1:2-175 HTRI-R "J/L2/JE1180/CM175/AFC Entry psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:2-176 HMS-S/D/M/SA "J/JL2/JE1180/MCP176/Pantry"
|      |      |  |-- 1:2-177 HFP-11 "J/L2/JE1100/SD177/AFC Entry psg"
|      |      |  |-- 1:2-178 HFP-11 "J/L2/JE1100/SD178/Main cab"
|      |      |  |-- 1:2-179 HFP-11 "J/L2/JE1100/SD179/Assorter cab"
|      |      |  |-- 1:2-180 HFP-11 "J/L2/JE1100/SD180/Entry Psg"
|      |      |  |-- 1:2-181 HFP-11 "J/L2/JE1100/SD181/Pantry"
|      |      |  |-- 1:2-182 HTRI-R "J/L2/JE1100/CM182/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:2-183 HMS-S/D/M/SA "J/L2/JE1100/MCP183/Entry Psg"
|      |      |  |-- 1:2-184 HFP-11 "J/L2/JE1130/SD184/Main cab"
|      |      |  |-- 1:2-185 HFP-11 "J/L2/JE1130/SD185/Assorter cab"
|      |      |  |-- 1:2-186 HFPT-11 "J/L2/JE1130/HD186/Pantry Psg"
|      |      |  |-- 1:2-187 HFPT-11 "J/L2/JE1130/HD187/Pantry "
|      |      |  |-- 1:2-188 HTRI-R "J/L2/JE1130/CM188/Entry dr"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:2-189 HMS-S/D/M/SA "J/L2/JE1130/MCP189/Entry dr"
|      |      |  |-- 1:2-190 HFP-11 "J/L2/JE1150/SD190/Main cab"
|      |      |  |-- 1:2-191 HTRI-R "J/L2/JE1150/CM191/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:2-192 HMS-S/D/M/SA "J/L2/JE1150/MCP192/Entry Psg"
|      |      |  |-- 1:2-193 HFP-11 "J/L2/JE1220/SD193/Main cab"
|      |      |  |-- 1:2-194 HFP-11 "J/L2/JE1220/SD194/Assorter cab"
|      |      |  |-- 1:2-195 HFP-11 "J/L2/JE1220/SD195/Pantry"
|      |      |  |-- 1:2-196 HFP-11 "J/L2/JE1220/SD196/Entry Psg"
|      |      |  |-- 1:2-197 HTRI-R "J/L2/JE1220/CM197/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:2-198 HMS-S/D/M/SA "J/L2/JE1220MCP198/Pantry Psg"
```


1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:2 DLC "DLC @ address 2 L2"

			-- 1:2-201	HTRI-S	"J/L2/JE/1F/MM201/Psg nr JE1190"
			-- 1:2-202	HTRI-S	"J/L2/JE/1F/MM202/Psg nr JE1030"
			-- 1:2-203	HTRI-S	"J/L2/JE/1F/MM203/Psg nr JE1140"
			-- 1:2-205	HTRI-S	"J/L2/JE/1F/MM205/Psg nr JE1060"
			-- 1:2-206	HTRI-S	"J/L2/JE/1F/MM206/Psg nr JE1120"
			-- 1:2-207	HTRI-S	"J/L2/JE/1F/MM207/Psg nr JE1080"
			-- 1:2-208	HTRI-S	"J/L2/JE/1F/MM208/Psg nr JE1090"
			-- 1:2-209	HTRI-S	"J/L2/JW/1F/MM209/Psg nr JW1190"
			-- 1:2-210	HTRI-S	"J/L2/JW/1F/MM210/Psg nr JW1160"
			-- 1:2-211	HTRI-S	"J/L2/JW/1F/MM211/Psg nr JW1150"
			-- 1:2-212	HTRI-S	"J/L2/JW/1F/MM212/Psg nr JW1090"
			-- 1:2-213	HTRI-S	"J/L2/JW/1F/MM213/Psg nr JW1060"
			-- 1:2-214	HTRI-S	"J/L2/JW/1F/MM214/Psg nr JW1050"
			-- 1:2-215	HTRI-S	"J/L2/JW/1F/MM215/Psg nr JW1010"
			-- 1:2-216	HTRI-S	"J/L2/JE/1F/MM216/Psg nr JE1240"
			-- 1:2-217	HTRI-S	"J/L2/JE/1F/MM217/Psg nr JE1320"
			-- 1:2-218	HFP-11	"J/L2/JE1290/SD218/Assorter cab1"
			-- 1:2-219	HFP-11	"J/L2/JE1290/SD219/Main cab"
			-- 1:2-220	HFP-11	"J/L2/JE1290/SD220/Pantry"
			-- 1:2-221	HFP-11	"J/L2/JE1290/SD221/Assorter cab2"
			-- 1:2-222	HFP-11	"J/L2/JE1290/SD222/Entry dr Psg"
			-- 1:2-223	HFP-11	"J/L2/JE1290/SD223/Accounts cab"
			-- 1:2-224	HTRI-R	"J/L2/JE1290/CM224/Entry dr Psg"
				-- Switch	" "
				-- Relay	
			-- 1:2-225	HMS-S/D/M/SA	"J/L2/JE1290/MCP225/Entry dr Psg"
			-- 1:2-226	HFP-11	"J/L2/JE1200/SD226/Main cab"
			-- 1:2-227	HFP-11	"J/L2/JE1200/SD227/Assorter cab1"
			-- 1:2-228	HFP-11	"J/L2/JE1200/SD228/Assorter cab2"
			-- 1:2-229	HFP-11	"J/L2/JE1200/SD229/Entry dr Psg"
			-- 1:2-230	HTRI-R	"J/L2/JE1200/CM230/Entry dr Psg"
				-- Switch	" "
				-- Relay	
			-- 1:2-231	HMS-S/D/M/SA	"J/L2/JE1200/MCP231/Entry dr Psg"
			-- 1:2-232	HFP-11	"J/L2/JW1140/SD232/Accounts cab"
			-- 1:2-233	HFP-11	"J/L2/JW1140/SD233/Assorter cab"
			-- 1:2-234	HFP-11	"J/L2/JW1140/SD234/Main cab"
			-- 1:2-235	HFP-11	"J/L2/JW1140/SD235/Entry dr Psg"
			-- 1:2-236	HTRI-R	"J/L2/JW1140/CM236/Entry dr Psg"
				-- Switch	" "
				-- Relay	
			-- 1:2-237	HMS-S/D/M/SA	"J/L2/JW1140/MCP237/Entry dr Psg"
			-- 1:2-238	HTRI-S	"J/L2/1F/MM238/JW1040"
			-- 1:2-239	HTRI-S	"J/L2/1F/MM239/JW1210"
			-- 1:2-240	HTRI-S	"J/L2/1F/MM240/JE1310"
			-- 1:2-241	HTRI-S	"J/L2/1F/MM241/JE1110"
			-- 1:2-242	HTRI-S	"J/L2/1F/MM242/JE1300"
			-- 1:2-250	HTRI-S	"J/L2/1F/MM250/JE1050"
			-- 1:2-251	HTRI-S	"J/L2/1F/MM251/JE1230"
			-- 1:2-245	HFP-11	"J/L2/JE1330/SD245/Assortor Cabin"

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:2 DLC "DLC @ address 2 L2"

```
|      |      |      |-- 1:2-246 HFP-11 "J/L2/JE1330/SD246/Main Cabin"
|      |      |      |-- 1:2-247 HFPT-11 "J/L2/JE1330/HD247/Pantry"
|      |      |      |-- 1:2-248 HTRI-R "J/L2/JE1330/CM248/Entry Psg AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:2-249 HMS-S/D/M/SA "J/L2/JE1330/MCP249/Entry Psg "
|      |      |      |-- 1:2-199 HFP-11 "J/L2/JW1080/SD199/Main CAB"
|      |      |      |-- 1:2-200 HFP-11 "J/L2/JW1080/SD200/Assortor Psg"
|      |      |      |-- 1:2-204 HTRI-R "J/L2/JW1080/CM204/Entry Psg AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:2-243 HMS-S/D/M/SA "J/L2/JW1080/MCP243/Entry Psg"
|      |      |      |-- 1:2-149 HTRI-S "J/L2/1F/MM149/JE1260"
|      |      |      |-- 1:2-19 HFP-11 "J/L2/JW1200/SD19/PANTRY"
|      |      |      |-- 1:2-27 HFP-11 "J/L2/JW1200/SD27/Main Cab"
|      |      |      |-- 1:2-28 HFP-11 "J/L2/JW1200/SD28/Assortor cab"
|      |      |      |-- 1:2-45 HFP-11 "J/L2/JW1200/SD45/Entry Psg"
|      |      |      |-- 1:2-49 HTRI-R "J/L2/JW1200/CM49/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:2-244 HMS-S/D/M/SA "J/L2/JW1200/MCP244/Enrty Psg"
|      |      |      |-- 1:2-72 HMS-S/D/M/SA "J/L2/GF/Custom/MCP72/Parcel Depo"
|      |      |      |-- 1:2-73 HMS-S/D/M/SA "J/L2/GF/Custom/MCP73/Waiting Are"
|      |      |      |-- 1:2-74 HMS-S/D/M/SA "J/L2/GF/Custom/MCP74/Entry Psg"
|      |      |      |-- 1:2-75 HTRI-S "J/L2/GF/Custom/MM75/EDI Center "
|      |      |      |-- 1:2-76 HMS-S/D/M/SA "J/L2/GF/Custom/MCP76/Psg Nr Ladi"
|      |      |      |-- 1:2-77 FDOT421 "J/L2/GF/Custom/SD77/Psg Nr Wash "
|      |      |      |-- 1:2-78 HTRI-R "J/L2/GF/Custom/CM78/Waiting Area"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:2-79 HTRI-R "J/L2/GF/Custom/CM79/Parcel Depos"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:2-62 FDOT421 "J/L2/GF/Custom/SD62/Waiting Are"
|      |      |      |-- 1:2-70 FDOT421 "J/L2/GF/Custom/SD70/Psg nr Wash "
|      |      |      |-- 1:2-71 FDOT421 "J/L2/GF/Custom/SD71/Psg nrWash R"
|      |      |      |-- 1:2-93 FDOT421 "J/L2/GF/Custom/SD93/Pantry Area"
|      |      |      |-- 1:2-96 HMS-S/D/M/SA "J/L2/GF/Custom/MCP96/Nr Commision"
|      |      |      |-- 1:3 DLC "DLC @ address 3 L3"
|      |      |      |-- 1:3-1 HTRI-R "J/L3/7B/2F/CM1/DR RELESE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:3-2 HFP-11 "J/L3/7B/2F/SD2/COR NR JE2180 AFC"
|      |      |      |-- 1:3-3 HFP-11 "J/L3/7B/2F/SD3/COR Nr JE2180J"
|      |      |      |-- 1:3-4 HFP-11 "J/L3/7B/2F/SD4/CORR NR JE 2050"
|      |      |      |-- 1:3-5 HFP-11 "J/L3/7B/2F/SD5/COR NR 7B/S43 AFC"
|      |      |      |-- 1:3-6 HFP-11 "J/L3/7B/2F/SD6/CORR NR JE 2070"
|      |      |      |-- 1:3-7 HFP-11 "J/L3/7B/2F/SD7/CORR NR 7B S14"
|      |      |      |-- 1:3-8 HMS-S/D/M/SA "J/L3/7B/2F/MCP8/FIRE ESC STR "
|      |      |      |-- 1:3-9 HTRI-R "J/L3/7B/2F/CM9/FIRE ESC STR "
```

```
| | | Switch ""
| | | |-- Relay
| | | |-- 1:3-11 HFP-11 "J/L3/7B/2F/SD11/CORR NR JE2120 A"
| | | |-- 1:3-12 HFP-11 "J/L3/7B/2F/SD12/CORR NR JW 2170"
| | | |-- 1:3-13 HFP-11 "J/L3/7B/2F/SD13/CORR NR JW2170 A"
| | | |-- 1:3-14 HFP-11 "J/L3/7B/2F/SD14/JW AHU RM SD"
| | | |-- 1:3-15 HTRI-R "J/L3/7B/2F/CM15/JW AHU RM CM "
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:3-16 HFP-11 "J/L3/7B/2F/SD16/CORR NR JW 2140"
| | | |-- 1:3-17 HFP-11 "J/L3/7B/2F/SD17/CORR NR JW2120 A"
| | | |-- 1:3-18 HFP-11 "J/L3/7B/2F/SD18/CORR NR JW 2120"
| | | |-- 1:3-19 HTRI-R "J/L3/7B/2F/CM19/DR RELESE JW 212"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:3-20 HMS-S/D/M/SA "J/L3/7B/2F/MCP20/FIRE SHAFT L.L."
| | | |-- 1:3-21 HTRI-R "J/L3/7B/2F/CM21/FIRE SHAFT L.L."
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:3-22 HTRI-S "J/L3/7B/2F/MM22/FIRE SHAFT L.L."
| | | |-- 1:3-23 HFP-11 "J/L3/7B/2F/SD23/LIFT LOBBY SD"
| | | |-- 1:3-24 HFP-11 "J/L3/7B/2F/SD24/ELECT RM SD"
| | | |-- 1:3-25 HTRI-R "J/L3/7B/2F/CM25/DR RELSE JW 2050"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:3-26 HFP-11 "J/L3/7B/2F/SD26/CORR NR JW2050 A"
| | | |-- 1:3-27 HFP-11 "J/L3/7B/2F/SD27/CORR NR JW 2050"
| | | |-- 1:3-28 HFP-11 "J/L3/7B/2F/SD28/CORR NR JW 2010"
| | | |-- 1:3-29 HFP-11 "J/L3/7B/2F/SD29/CORR NR 7B S48 A"
| | | |-- 1:3-30 HTRI-R "J/L3/7B/2F/CM30/DR RELESE CM"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:3-31 HTRI-R "J/L3/7B/2F/CM31/DR RELESE CM"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:3-32 HFP-11 "J/L3/7B/2F/SD32/CORR NR JE2220 A"
| | | |-- 1:3-33 HFP-11 "J/L3/7B/2F/SD33/CORR NR JE 2220"
| | | |-- 1:3-34 HFP-11 "J/L3/7B/2F/SD34/CORR NR JE2270 A"
| | | |-- 1:3-35 HFP-11 "J/L3/7B/2F/SD35/CORR NR JE 2270"
| | | |-- 1:3-36 HFP-11 "J/L3/7B/2F/SD36/CORR NR JE 2280"
| | | |-- 1:3-37 HMS-S/D/M/SA "J/L3/7B/2F/MCP37/FIRE ESC STR "
| | | |-- 1:3-38 HTRI-R "J/L3/7B/2F/CM38/FIRE ESC STR "
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:3-40 HFP-11 "J/L3/7B/2F/SD40/CORR NR JE 2290"
| | | |-- 1:3-41 HFP-11 "J/L3/7B/2F/SD41/CORR NR JE 2290"
| | | |-- 1:3-42 HFP-11 "J/L3/7B/2F/SD42/CORR NR JE 2310"
| | | |-- 1:3-43 HFP-11 "J/L3/7B/2F/SD43/CORR NR JE 2190"
| | | |-- 1:3-44 HFP-11 "J/L3/7B/2F/SD44/CORR NR JE 2190"
| | | |-- 1:3-45 HTRI-R "J/L3/7B/2F/CM45/DR RELESE JE 219"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:3 DLC "DLC @ address 3 L3"
        1:3-45 HTRI-R "J/L3/7B/2F/CM45/DR RELESE JE 219"
```

```
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |      |-- 1:3-49 HFP-11 "J/L3/7B/2F/SD49/AHU RM SD NR JE "
|      |      |      |      |-- 1:3-50 HTRI-R "J/L3/7B/2F/CM50/AHU RM CM NR JE "
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |      |-- 1:3-51 HFP-11 "J/L3/7B/2F/SD51/ELECT RM SD"
|      |      |      |      |-- 1:3-52 HFP-11 "J/L3/7B/2F/SD52/LIFT LOBBY SD"
|      |      |      |      |-- 1:3-54 HTRI-S "J/L3/JE/2F/MM54/Psg nr JE2180"
|      |      |      |      |-- 1:3-55 HTRI-S "J/L3/JE/2F/MM55/Psg nr JE2030"
|      |      |      |      |-- 1:3-56 HTRI-S "J/L3/JE/2F/MM56/Psg nr JE2040"
|      |      |      |      |-- 1:3-57 HTRI-S "J/L3/JE/2F/MM57/Psg nr JE2050"
|      |      |      |      |-- 1:3-58 HTRI-S "J/L3/JE/2F/MM58/Psg nr JE2090"
|      |      |      |      |-- 1:3-59 HTRI-S "J/L3/JE/2F/MM59/Psg nr JE2130"
|      |      |      |      |-- 1:3-60 HTRI-S "J/L3/JW/2F/MM60/Psg nr JW2160"
|      |      |      |      |-- 1:3-61 HTRI-S "J/L3/JW/2F/MM61/Psg nr JW2070"
|      |      |      |      |-- 1:3-62 HTRI-S "J/L3/JW/2F/MM62/Psg nr JW2050"
|      |      |      |      |-- 1:3-63 HTRI-S "J/L3/JW/2F/MM63/Psg nr JW2030"
|      |      |      |      |-- 1:3-65 HTRI-S "J/L3/JE/2F/MM65/Psg nr JE2230"
|      |      |      |      |-- 1:3-66 HTRI-S "J/L3/JE/2F/MM66/Psg nr JE2260"
|      |      |      |      |-- 1:3-67 HTRI-S "J/L3/JE/2F/MM67/Psg nr JE2290"
|      |      |      |      |-- 1:3-68 HTRI-S "J/L3/JE/2F/MM68/Psg nr JE2300"
|      |      |      |      |-- 1:3-69 HTRI-S "J/L3/JE/2F/MM69/Psg nr JE2190"
|      |      |      |      |-- 1:3-72 HFP-11 "J/L3/JE2010/SD72/Cab 1"
|      |      |      |      |-- 1:3-73 HFP-11 "J/L3/JE2010/SD73/Cab 2"
|      |      |      |      |-- 1:3-74 HFP-11 "J/L3/JE2010/SD74/Entry dr Psg"
|      |      |      |      |-- 1:3-75 HTRI-R "J/L3/JE2010/CM75/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |      |-- 1:3-76 HMS-S/D/M/SA "J/L3/JE2010/MCP76/Entry dr Psg"
|      |      |      |      |-- 1:3-77 HFP-11 "J/L3/JE2070/SD77/Main cab"
|      |      |      |      |-- 1:3-78 HFP-11 "J/L3/JE2070/SD78/Pantry Psg"
|      |      |      |      |-- 1:3-79 HTRI-R "J/L3/JE2070/CM79/Pantry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |      |-- 1:3-80 HMS-S/D/M/SA "J/L3/JE2070/MCP80/Pantry Psg"
|      |      |      |      |-- 1:3-81 HFP-11 "J/L3/JE2060/SD81/Main cab"
|      |      |      |      |-- 1:3-82 HFP-11 "J/L3/JE2060/SD82/Assorter cab"
|      |      |      |      |-- 1:3-83 HFP-11 "J/L3/JE2060/SD83/Entry dr Psg"
|      |      |      |      |-- 1:3-84 HFPT-11 "J/L3/JE2060/HD84/Pantry Psg"
|      |      |      |      |-- 1:3-85 HTRI-R "J/L3/JE2060/CM85/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |      |-- 1:3-86 HMS-S/D/M/SA "J/L3/JE2060/MCP86/Entry dr Psg"
|      |      |      |      |-- 1:3-87 HFP-11 "J/L3/JE2162/SD87/Main cab"
|      |      |      |      |-- 1:3-88 HFP-11 "J/L3/JE2162/SD88/Entry Psg"
|      |      |      |      |-- 1:3-89 HTRI-R "J/L3/JE2162/CM89/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |      |-- 1:3-90 HMS-S/D/M/SA "J/L3/JE2162/MCP90/Entry Psg"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:3 DLC "DLC @ address 3 L3"
```

```
|      |      |  |-- 1:3-91 HFP-11 "J/L3/JE2161/SD91/Main cab"
|      |      |  |-- 1:3-92 HFP-11 "J/L3/JE2161/SD92/Assorter cab"
|      |      |  |-- 1:3-93 HFP-11 "J/L3/JE2161/SD93/Entry Psg"
|      |      |  |-- 1:3-94 HTRI-R "J/L3/JE2161/CM94/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-95 HMS-S/D/M/SA "J/L3/JE2161/MCP95/Entry Psg"
|      |      |  |-- 1:3-96 HFP-11 "J/L3/JW2120/SD96/Main cab"
|      |      |  |-- 1:3-97 HFP-11 "J/L3/JW2120/SD97/Assorter cab"
|      |      |  |-- 1:3-98 HTRI-R "J/L3/JW2120/CM98/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-99 HMS-S/D/M/SA "J/L3/JW2120/MCP99/Entry Psg"
|      |      |  |-- 1:3-100 HFP-11 "J/L3/JW2090/SD100/Assorter cab"
|      |      |  |-- 1:3-101 HFP-11 "J/L3/JW2090/SD101/Main cab"
|      |      |  |-- 1:3-102 HFP-11 "J/L3/JW2090/SD102/Entry Psg"
|      |      |  |-- 1:3-103 HTRI-R "J/L3/JW2090/CM103/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-104 HMS-S/D/M/SA "J/L3/JW2090/MCP104/Entry Psg"
|      |      |  |-- 1:3-105 HFP-11 "J/L3/JW2130/SD105/Main cab"
|      |      |  |-- 1:3-106 HFP-11 "J/L3/JW2130/SD106/Assorter cab"
|      |      |  |-- 1:3-107 HFP-11 "J/L3/JW2130/SD107/nr Assorter ca"
|      |      |  |-- 1:3-108 HFP-11 "J/L3/JW2130/SD108/Entry Psg"
|      |      |  |-- 1:3-109 HTRI-R "J/L3/JW2130/CM109/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-110 HMS-S/D/M/SA "J/L3/JW2130/MCP110/Entry Psg"
|      |      |  |-- 1:3-111 HFP-11 "J/L3/JE2120/SD111/Main cab"
|      |      |  |-- 1:3-112 HFP-11 "J/L3/JE2120/SD112/Assorter cab"
|      |      |  |-- 1:3-113 HFP-11 "J/L3/JE2120/SD113/Pantry"
|      |      |  |-- 1:3-114 HTRI-R "J/L3/JE2120/CM114/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-115 HMS-S/D/M/SA "J/L3/JE2120/MCP115/Entry dr Psg"
|      |      |  |-- 1:3-116 HFP-11 "J/L3/JW2190/SD116/Main cab"
|      |      |  |-- 1:3-117 HFP-11 "J/L3/JW2190/SD117/Pantry"
|      |      |  |-- 1:3-118 HFP-11 "J/L3/JW2190/SD118/Entry Psg"
|      |      |  |-- 1:3-119 HTRI-R "J/L3/JW2190/CM119/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-120 HMS-S/D/M/SA "J/L3/JW2190/MCP120/Entry Psg"
|      |      |  |-- 1:3-121 HFP-11 "J/L3/JE2100/SD121/Main cab"
|      |      |  |-- 1:3-122 HFP-11 "J/L3/JE2100/SD122/Assorter cab"
|      |      |  |-- 1:3-123 HFP-11 "J/L3/JE2100/SD123/Entry Psg"
|      |      |  |-- 1:3-124 HTRI-R "J/L3/JE2100/CM124/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-125 HMS-S/D/M/SA "J/L3/JE2100/MCP125/Entry Psg"
|      |      |  |-- 1:3-126 HFP-11 "J/L3/JW2010/SD126/Main cab"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:3 DLC "DLC @ address 3 L3"

```
|      |      |  |-- 1:3-127 HFP-11 "J/L3/JW2010/SD127/Assorter cab"
|      |      |  |-- 1:3-128 HFP-11 "J/L3/JW2010/SD128/Entry Psg"
|      |      |  |-- 1:3-129 HTRI-R "J/L3/JW2010/CM129/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-130 HMS-S/D/M/SA "J/L3/JW2010/MCP130/Entry Psg"
|      |      |  |-- 1:3-131 HFP-11 "J/L3/JE2280/SD131/Assorter cab1"
|      |      |  |-- 1:3-132 HFP-11 "J/L3/JE2280/SD132/Entry Psg"
|      |      |  |-- 1:3-133 HFP-11 "J/L3/JE2280/SD133/Main cab"
|      |      |  |-- 1:3-134 HFP-11 "J/L3/JE2280/SD134/Assorter cab2"
|      |      |  |-- 1:3-135 HFP-11 "J/L3/JE2280/SD135/Pantry"
|      |      |  |-- 1:3-136 HTRI-R "J/L3/JE2280/CM136/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-137 HMS-S/D/M/SA "J/L3/JE2280/MCP137/Entry Psg"
|      |      |  |-- 1:3-138 HFP-11 "J/L3/JE2270/SD138/Assorter cab1"
|      |      |  |-- 1:3-139 HFP-11 "J/L3/JE2270/SD139/Main cab"
|      |      |  |-- 1:3-140 HFP-11 "J/L3/JE2270/SD140/Entry Psg"
|      |      |  |-- 1:3-141 HFP-11 "J/L3/JE2270/SD141/Assorter cab2"
|      |      |  |-- 1:3-142 HTRI-R "J/L3/JE2270/CM142/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-143 HMS-S/D/M/SA "J/L3/JE2270/MCP143/Entry Psg"
|      |      |  |-- 1:3-144 HFP-11 "J/L3/JE2240/SD144/Assorter cab1"
|      |      |  |-- 1:3-145 HFP-11 "J/L3/JE2240/SD145/Accounts cab"
|      |      |  |-- 1:3-146 HFP-11 "J/L3/JE2240/SD146/Entry Psg"
|      |      |  |-- 1:3-147 HFP-11 "J/L3/JE2240/SD147/Assorter cab2"
|      |      |  |-- 1:3-148 HFP-11 "J/L3/JE2240/SD148/Main cab"
|      |      |  |-- 1:3-149 HFP-11 "J/L3/JE2240/SD149/Pantry"
|      |      |  |-- 1:3-150 HFP-11 "J/L3/JE2240/SD150/Entry Psg"
|      |      |  |-- 1:3-151 HTRI-R "J/L3/JE2240/CM151/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-152 HMS-S/D/M/SA "J/L3/JE2240/MCP152/Entry Psg"
|      |      |  |-- 1:3-153 HFP-11 "J/L3/JE2220/SD153/Assorter cab1"
|      |      |  |-- 1:3-154 HFP-11 "J/L3/JE2220/SD154/Assorter cab2"
|      |      |  |-- 1:3-155 HFP-11 "J/L3/JE2220/SD155/Assorter cab3"
|      |      |  |-- 1:3-156 HFP-11 "J/L3/JE2220/SD156/Assorter cab4"
|      |      |  |-- 1:3-157 HFP-11 "J/L3/JE2220/SD157/Pantry"
|      |      |  |-- 1:3-158 HTRI-R "J/L3/JE2220/CM158/Entry dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-159 HMS-S/D/M/SA "J/L3/JE2220/MCP159/Entry dr"
|      |      |  |-- 1:3-160 HFP-11 "J/L3/JE2200/SD160/Main cab"
|      |      |  |-- 1:3-161 HFP-11 "J/L3/JE2200/SD161/Assorter cab"
|      |      |  |-- 1:3-162 HFP-11 "J/L3/JE2200/SD162/Accounts cab"
|      |      |  |-- 1:3-163 HFP-11 "J/L3/JE2200/SD163/cab 1"
|      |      |  |-- 1:3-164 HFP-11 "J/L3/JE2200/SD164/cab 2"
|      |      |  |-- 1:3-165 HFP-11 "J/L3/JE2200/SD165/Pantry"
|      |      |  |-- 1:3-166 HTRI-R "J/L3/JE2200/CM166/Entry Psg"
```

1:3-166 HTRI-R "J/L3/JE2200/CM166/Entry Psg"

```
| | | Switch ""  
| | | |-- Relay  
| | | |-- 1:3-167 HMS-S/D/M/SA "J/L3/JE2200/MCP167/Entry Psg"  
| | | |-- 1:3-168 HFP-11 "J/L3/JW2040/SD168/Entry dr Psg"  
| | | |-- 1:3-169 HFP-11 "J/L3/JW2040/SD169/Account cab"  
| | | |-- 1:3-170 HFP-11 "J/L3/JW2040/SD170/Main cab"  
| | | |-- 1:3-171 HFP-11 "J/L3/JW2040/SD171/AFC account ca"  
| | | |-- 1:3-172 HFPT-11 "J/L3/JW2040/HD172/Pantry"  
| | | |-- 1:3-173 HTRI-R "J/L3/JW2040/CM173/Entry dr Psg"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 1:3-174 HMS-S/D/M/SA "J/L3/JW2040/MCP174/Entry dr Psg"  
| | | |-- 1:3-175 HFP-11 "J/L3/JE2080/SD175/Entry dr Psg"  
| | | |-- 1:3-176 HFP-11 "J/L3/JE2080/SD176/Pantry Psg"  
| | | |-- 1:3-177 HTRI-R "J/L3/JE2080/CM177/Entry dr Psg"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 1:3-178 HMS-S/D/M/SA "J/L3/JE2080/MCP178/Entry dr Psg"  
| | | |-- 1:3-179 HFP-11 "J/L3/JE2172/SD179/Main cab"  
| | | |-- 1:3-180 HFP-11 "J/L3/JE2172/SD180/Cab 1"  
| | | |-- 1:3-181 HFP-11 "J/L3/JE2172/SD181/Entry Psg"  
| | | |-- 1:3-182 HMS-S/D/M/SA "J/L3/JE2172/MCP182/Entry Psg"  
| | | |-- 1:3-183 HTRI-R "J/L3/JE2172/CM183/Entry Psg"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 1:3-184 HFP-11 "J/L3/JE2330/SD184/Main cab"  
| | | |-- 1:3-185 HFP-11 "J/L3/JE2330/SD185/Assorter cab"  
| | | |-- 1:3-186 HFP-11 "J/L3/JE2330/SD186/Entry Psg"  
| | | |-- 1:3-187 HTRI-R "J/L3/JE2330/CM187/Entry Psg"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 1:3-188 HMS-S/D/M/SA "J/L3/JE2330/MCP188/Entry Psg"  
| | | |-- 1:3-189 HFP-11 "J/L3/JW2060/SD189/Main cab"  
| | | |-- 1:3-190 HFP-11 "J/L3/JW2060/SD190/Cab 1"  
| | | |-- 1:3-191 HFP-11 "J/L3/JW2060/SD191/pantry Psg"  
| | | |-- 1:3-192 HFP-11 "J/L3/JW2060/SD192/Entry dr Psg"  
| | | |-- 1:3-193 HTRI-R "J/L3/JW2060/CM193/Entry dr Psg"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 1:3-194 HMS-S/D/M/SA "J/L3/JW2060/MCP194/Entry dr Psg"  
| | | |-- 1:3-196 HFP-11 "J/L3/JE2320/SD196/Main cab"  
| | | |-- 1:3-197 HFP-11 "J/L3/JE2320/SD197/Assorter cab"  
| | | |-- 1:3-198 HFP-11 "J/L3/JE2320/SD198/Psg nr Assorte"  
| | | |-- 1:3-199 HTRI-R "J/L3/JE2320/CM199/Entry dr Psg"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 1:3-200 HMS-S/D/M/SA "J/L3/JE2320/MCP200/Entry dr Psg"  
| | | |-- 1:3-201 HFP-11 "J/L3/JE2140/SD201/Main cab1"  
| | | |-- 1:3-202 HFP-11 "J/L3/JE2140/SD202/Main cab2"  
| | | |-- 1:3-203 HFP-11 "J/L3/JE2140/SD203/Cab 1"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:3 DLC "DLC @ address 3 L3"

```
|      |      |  |-- 1:3-204 HFP-11 "J/L3/JE2140/SD204/Psg nr Pantry"
|      |      |  |-- 1:3-205 HFP-11 "J/L3/JE2140/SD205/Cab 2"
|      |      |  |-- 1:3-206 HFP-11 "J/L3/JE2140/SD206/Cab 3"
|      |      |  |-- 1:3-207 HFPT-11 "J/L3/JE2140/HD207/Pantry"
|      |      |  |-- 1:3-208 HTRI-R "J/L3/JE2140/CM208/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-209 HMS-S/D/M/SA "J/L3/JE2140/MCP209/Entry dr Psg"
|      |      |  |-- 1:3-221 HFP-11 "J/L3/JW2020/SD221/Main cab"
|      |      |  |-- 1:3-222 HFP-11 "J/L3/JW2020/SD222/Assorter cab"
|      |      |  |-- 1:3-223 HFP-11 "J/L3/JW2020/SD223/Entry dr psg"
|      |      |  |-- 1:3-224 HTRI-R "J/L3/JW2020/CM224/Entry dr psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-225 HMS-S/D/M/SA "J/L3/JW2020/MCP225/Entry dr psg"
|      |      |  |-- 1:3-46 HTRI-S "J/L3/2F/MM46/Psg. Nr. JE2020"
|      |      |  |-- 1:3-195 HTRI-S "J/L3/2F/MM195/Psg. Nr. JE 2310"
|      |      |  |-- 1:3-211 HTRI-S "J/L3/2F/MM211/Psg. Nr. JW 2110"
|      |      |  |-- 1:3-212 HTRI-S "J/L3/2F/MM212/Psg. Nr. JW 2170"
|      |      |  |-- 1:3-213 HTRI-S "J/L3/2F/MM213/Psg. Nr. JE 2171"
|      |      |  |-- 1:3-214 HTRI-S "J/L3/2F/MM214/Psg. Nr. JE 2151"
|      |      |  |-- 1:3-217 HTRI-S "J/L3/2F/MM217/Psg. Nr. JW 2140"
|      |      |  |-- 1:3-218 HTRI-S "J/L3/2F/MM218/Psg. Nr. JW 2150"
|      |      |  |-- 1:3-220 HTRI-S "J/L3/2F/MM220/Psg. Nr. JW2200/10"
|      |      |  |-- 1:3-226 HFP-11 "J/L3/JW2010/SD226/Entry Psg"
|      |      |  |-- 1:3-227 HFP-11 "J/L3/JW2010/SD227/Account Cab"
|      |      |  |-- 1:3-231 HFP-11 "J/L3/JW2100/SD231/Main Cabin"
|      |      |  |-- 1:3-232 HFP-11 "J/L3/JW2100/SD232/Assortor Cabin"
|      |      |  |-- 1:3-233 HFP-11 "J/L3/JW2100/SD233/ntry Psg"
|      |      |  |-- 1:3-234 HTRI-R "J/L3/JW2100/CM234/EntryElect Box"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-235 HMS-S/D/M/SA "J/L3/JW2100/MCP235/Entry Psg"
|      |      |  |-- 1:3-236 HFP-11 "J/L3/JE2152/SD236/Entry Pgs"
|      |      |  |-- 1:3-237 HFP-11 "J/L3/JE2152/SD237/Main Cab"
|      |      |  |-- 1:3-238 HMS-S/D/M/SA "J/L3/JE2152/SD238/Entry Pgs"
|      |      |  |-- 1:3-239 HTRI-R "J/L3/JE2152/SD239/Entry Pgs AFC"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:4 DLC "DLC @ address 4 L4"
|      |      |  |-- 1:4-1 HTRI-R "J/L4/7B/3F/CM1/DR RELESE JE 3021"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:4-2 HFP-11 "J/L4/7B/3F/SD2/CORR NR JE3021 AF"
|      |      |  |-- 1:4-3 HFP-11 "J/L4/7B/3F/SD3/CORR NR JE 3021"
|      |      |  |-- 1:4-4 HFP-11 "J/L4/7B/3F/SD4/CORR NR JE 3160"
|      |      |  |-- 1:4-5 HFP-11 "J/L4/7B/3F/SD5/CORR NR JE7B3/S43"
|      |      |  |-- 1:4-6 HFP-11 "J/L4/7B/3F/SD6/CORR NR JE 3050"
|      |      |  |-- 1:4-7 HFP-11 "J/L4/7B/3F/SD7/CORR NR JE 3060"
|      |      |  |-- 1:4-8 HMS-S/D/M/SA "J/L4/7B/3F/MCP8/FIRE ESC STR"
```


1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 1:4-9 HTRI-R "J/L4/7B/3F/CM9/FIRE ESC STR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-11 HFP-11 "J/L4/7B/3F/SD11/CORR NR JE3080 A"
|      |      |      |-- 1:4-12 HFP-11 "J/L4/7B/3F/SD12/CORR NR JW 3200"
|      |      |      |-- 1:4-13 HFP-11 "J/L4/7B/3F/SD13/CORR NR JW3200 A"
|      |      |      |-- 1:4-14 HTRI-R "J/L4/7B/3F/CM14/JW AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-15 HFP-11 "J/L4/7B/3F/SD15/JWAHU RM SD"
|      |      |      |-- 1:4-16 HFP-11 "J/L4/7B/3F/SD16/CORR NR JW 3180"
|      |      |      |-- 1:4-17 HFP-11 "J/L4/7B/3F/SD17/CORR NR JW 3150"
|      |      |      |-- 1:4-18 HFP-11 "J/L4/7B/3F/SD18/CORR NR JW3150 A"
|      |      |      |-- 1:4-19 HFP-11 "J/L4/7B/3F/SD19/ELECT RM SD"
|      |      |      |-- 1:4-20 HTRI-R "J/L4/7B/3F/CM20/DR RELESE CM NR "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-21 HFP-11 "J/L4/7B/3F/SD21/LIFT LOBBY SD EC"
|      |      |      |-- 1:4-22 HTRI-R "J/L4/7B/3F/CM22/DR RELESE JW 308"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-23 HFP-11 "J/L4/7B/3F/SD23/CORR NR JW 3080"
|      |      |      |-- 1:4-24 HFP-11 "J/L4/7B/3F/SD24/CORR NR JW 3080"
|      |      |      |-- 1:4-25 HFP-11 "J/L4/7B/3F/SD25/CORR NR JW 3030"
|      |      |      |-- 1:4-26 HTRI-R "J/L4/7B/3F/CM26/DR RELESE JW 303"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-27 HTRI-R "J/L4/7B/3F/CM27/DR RELESE JW 324"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-28 HFP-11 "J/L4/7B/3F/SD28/CORR NR JE3240 A"
|      |      |      |-- 1:4-29 HFP-11 "J/L4/7B/3F/SD29/CORR NR JE 3250"
|      |      |      |-- 1:4-30 HFP-11 "J/L4/7B/3F/SD30/CORR NR JE 3260"
|      |      |      |-- 1:4-31 HFP-11 "J/L4/7B/3F/SD31/CORR NR JE 3280"
|      |      |      |-- 1:4-32 HTRI-R "J/L4/7B/3F/CM32/AHU RM CM NR JE "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-33 HFP-11 "J/L4/7B/3F/SD33/AHU RM SD NR JE "
|      |      |      |-- 1:4-34 HFP-11 "J/L4/7B/3F/SD34/CORR NR AHU RM"
|      |      |      |-- 1:4-35 HMS-S/D/M/SA "J/L4/7B/3F/MCP35/FIRE ESC STR"
|      |      |      |-- 1:4-36 HTRI-R "J/L4/7B/3F/CM36/FIRE ESC STR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-37 HTRI-S "J/L4/7B/3F/MM37/FIRE ESC STR"
|      |      |      |-- 1:4-38 HFP-11 "J/L4/7B/3F/SD38/CORR NR FIRE ESC"
|      |      |      |-- 1:4-39 HFP-11 "J/L4/7B/3F/SD39/CORR NR FIRE ESC"
|      |      |      |-- 1:4-40 HFP-11 "J/L4/7B/3F/SD40/CORR NR JE 3210"
|      |      |      |-- 1:4-41 HFP-11 "J/L4/7B/3F/SD41/CORR NR JE DR AF"
|      |      |      |-- 1:4-42 HFP-11 "J/L4/7B/3F/SD42/CORR NR JE DR "
|      |      |      |-- 1:4-43 HTRI-R "J/L4/7B/3F/CM43/DR RELESE CM"
```

1:4-43 HTRI-R "J/L4/7B/3F/CM43/DR RELEASE CM"

```
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:4-44 HFP-11 "J/L4/7B/3F/SD44/LIFT LOBBY SD "
| | | | -- 1:4-45 HFP-11 "J/L4/7B/3F/SD45/ELECT RM JE 3021"
| | | | -- 1:4-48 HTRI-S "J/L4/JE/3F/MM48/Psg nr JE3021"
| | | | -- 1:4-50 HTRI-S "J/L4/JE/3F/MM50/Psg nr JE3181"
| | | | -- 1:4-51 HTRI-S "J/L4/JE/3F/MM51/Psg nr JE3170"
| | | | -- 1:4-52 HTRI-S "J/L4/JE/3F/MM52/Psg nr JE3160"
| | | | -- 1:4-53 HTRI-S "J/L4/JE/3F/MM53/Psg nr JE3150"
| | | | -- 1:4-54 HTRI-S "J/L4/JE/3F/MM54/Psg nr JE3041"
| | | | -- 1:4-55 HTRI-S "J/L4/JE/3F/MM55/Psg nr JE3042"
| | | | -- 1:4-56 HTRI-S "J/L4/JE/3F/MM56/Psg nr JE3050"
| | | | -- 1:4-57 HTRI-S "J/L4/JE/3F/MM57/Psg nr JE3060"
| | | | -- 1:4-58 HTRI-S "J/L4/JE/3F/MM58/Psg nr JE3080"
| | | | -- 1:4-59 HTRI-S "J/L4/JE/3F/MM59/Psg nr JE3100"
| | | | -- 1:4-60 HTRI-S "J/L4/JW/3F/MM60/Psg nr JW3170"
| | | | -- 1:4-61 HTRI-S "J/L4/JW/3F/MM61/Psg nr JW3160"
| | | | -- 1:4-62 HTRI-S "J/L4/JW/3F/MM62/Psg nr JW3140"
| | | | -- 1:4-63 HTRI-S "J/L4/JW/3F/MM63/Psg nr JW3130"
| | | | -- 1:4-64 HTRI-S "J/L4/JW/3F/MM64/Psg nr JW3230"
| | | | -- 1:4-65 HTRI-S "J/L4/JW/3F/MM65/Psg nr JW3120"
| | | | -- 1:4-66 HTRI-S "J/L4/JW/3F/MM66/Psg nr JW3050"
| | | | -- 1:4-67 HTRI-S "J/L4/JW/3F/MM67/Psg nr JW3040"
| | | | -- 1:4-68 HTRI-S "J/L4/JW/3F/MM68/Psg nr JW3030"
| | | | -- 1:4-69 HTRI-S "J/L4/JW/3F/MM69/Psg nr JW3020"
| | | | -- 1:4-70 HTRI-S "J/L4/JW/3F/MM70/Psg nr JW3010"
| | | | -- 1:4-71 HTRI-S "J/L4/JE/3F/MM71/Psg nr JE3240"
| | | | -- 1:4-72 HTRI-S "J/L4/JE/3F/MM72/Psg nr JE3260"
| | | | -- 1:4-73 HTRI-S "J/L4/JE/3F/MM73/Psg nr JE3290"
| | | | -- 1:4-74 HTRI-S "J/L4/JE/3F/MM74/Psg nr JE3360"
| | | | -- 1:4-75 HTRI-S "J/L4/JE/3F/MM75/Psg nr JE3370"
| | | | -- 1:4-76 HTRI-S "J/L4/JE/3F/MM76/Psg nr JE3190"
| | | | -- 1:4-77 HTRI-S "J/L4/JE/3F/MM77/Psg nr JE3200"
| | | | -- 1:4-78 HTRI-S "J/L4/JE/3F/MM78/Psg nr JE3310"
| | | | -- 1:4-79 HTRI-S "J/L4/JE/3F/MM79/Psg nr JE3220"
| | | | -- 1:4-81 HFP-11 "J/L4/JE3250/SD81/Assorter cab"
| | | | -- 1:4-82 HFP-11 "J/L4/JE3250/SD82/Main cab"
| | | | -- 1:4-83 HFP-11 "J/L4/JE3250/SD83/Entry Psg"
| | | | -- 1:4-84 HFPT-11 "J/L4/JE3250/HD84/Pantry"
| | | | -- 1:4-85 HTRI-R "J/L4/JE3250/CM85/Entry Psg"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 1:4-86 HMS-S/D/M/SA "J/L4/JE3250/MCP86/Entry Psg"
| | | | -- 1:4-87 HFP-11 "J/L4/JE3140/SD87/Main cab"
| | | | -- 1:4-88 HFP-11 "J/L4/JE3140/SD88/Pantry"
| | | | -- 1:4-89 HTRI-R "J/L4/JE3140/CM89/Entry Psg"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 1:4-90 HMS-S/D/M/SA "J/L4/JE3140/MCP90/Entry Psg"
| | | | -- 1:4-91 HFP-11 "J/L4/JE3010/SD91/Main cab1"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:4 DLC "DLC @ address 4 L4"
```

```
|      |      |  |-- 1:4-92 HFP-11 "J/L4/JE3010/SD92/Main cab2"
|      |      |  |-- 1:4-93 HFP-11 "J/L4/JE3010/SD93/Main cab3"
|      |      |  |-- 1:4-94 HFP-11 "J/L4/JE3010/SD94/Account cab"
|      |      |  |-- 1:4-95 HFP-11 "J/L4/JE3010/SD95/Pantry"
|      |      |  |-- 1:4-96 HTRI-R "J/L4/JE3010/CM96/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:4-97 HMS-S/D/M/SA "J/L4/JE3010/MCP97/Entry Psg"
|      |      |  |-- 1:4-98 HFP-11 "J/L4/JE3270/SD98/Main cab"
|      |      |  |-- 1:4-99 HFP-11 "J/L4/JE3270/SD99/Assorter cab"
|      |      |  |-- 1:4-100 HTRI-R "J/L4/JE3270/CM100/Entry dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:4-101 HMS-S/D/M/SA "J/L4/JE3270/MCP101/Entry dr"
|      |      |  |-- 1:4-102 HFP-11 "J/L4/JE3320/SD102/Main cab"
|      |      |  |-- 1:4-103 HFP-11 "J/L4/JE3320/SD103/Assorter cab"
|      |      |  |-- 1:4-104 HFP-11 "J/L4/JE3320/SD104/Entry dr Psg"
|      |      |  |-- 1:4-105 HTRI-R "J/L4/JE3320/CM105/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:4-106 HMS-S/D/M/SA "J/L4/JE3320/MCP106/Entry dr Psg"
|      |      |  |-- 1:4-107 HFP-11 "J/L4/JE3340/SD107/Main cab"
|      |      |  |-- 1:4-108 HFP-11 "J/L4/JE3340/SD108/Assorter cab"
|      |      |  |-- 1:4-109 HFP-11 "J/L4/JE3340/SD109/Pantry Psg"
|      |      |  |-- 1:4-110 HTRI-R "J/L4/JE3340/CM110/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:4-111 HMS-S/D/M/SA "J/L4/JE3340/MCP111/Entry Psg"
|      |      |  |-- 1:4-112 HFP-11 "J/L4/JE3300/SD112/Main cab"
|      |      |  |-- 1:4-113 HFP-11 "J/L4/JE3300/SD113/Entry dr Psg"
|      |      |  |-- 1:4-114 HTRI-R "J/L4/JE3300/CM114/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:4-115 HMS-S/D/M/SA "J/L4/JE3300/MCP115/Entry dr Psg"
|      |      |  |-- 1:4-120 HFP-11 "J/L4/JW3180/SD120/Main cab"
|      |      |  |-- 1:4-121 HFP-11 "J/L4/JW3180/SD121/Account cab"
|      |      |  |-- 1:4-122 HFP-11 "J/L4/JW3180/SD122/Entry Psg"
|      |      |  |-- 1:4-123 HTRI-R "J/L4/JW3180/CM123/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:4-124 HMS-S/D/M/SA "J/L4/JW3180/MCP124/Entry Psg"
|      |      |  |-- 1:4-125 HFP-11 "J/L4/JE3350/SD125/Main cab"
|      |      |  |-- 1:4-126 HFP-11 "J/L4/JE3350/SD126/Assorter cab"
|      |      |  |-- 1:4-127 HFP-11 "J/L4/JE3350/SD127/Entry Psg"
|      |      |  |-- 1:4-128 HFPT-11 "J/L4/JE3350/HD128/Pantry"
|      |      |  |-- 1:4-129 HTRI-R "J/L4/JE3350/CM129/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:4-130 HMS-S/D/M/SA "J/L4/JE3350/MCP130/Entry Psg"
|      |      |  |-- 1:4-131 HFP-11 "J/L4/JE3090/SD131/Main cab"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 1:4-132 HFP-11 "J/L4/JE3090/SD132/Assorter cab"
|      |      |      |-- 1:4-133 HFP-11 "J/L4/JE3090/SD133/Pantry"
|      |      |      |-- 1:4-134 HTRI-R "J/L4/JE3090/CM134/Psg nr Entry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-135 HMS-S/D/M/SA "J/L4/JE3090/MCP135/Psg nr Entry"
|      |      |      |-- 1:4-136 HFP-11 "J/L4/JW3110/SD136/Main cab"
|      |      |      |-- 1:4-137 HFP-11 "J/L4/JW3110/SD137/Assorter cab"
|      |      |      |-- 1:4-138 HFP-11 "J/L4/JW3110/SD138/Entry dr Psg"
|      |      |      |-- 1:4-139 HTRI-R "J/L4/JW3110/CM139/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-140 HMS-S/D/M/SA "J/L4/JW3110/MCP140/Entry dr Psg"
|      |      |      |-- 1:4-141 HFP-11 "J/L4/JW3150/SD141/Assorter cab"
|      |      |      |-- 1:4-142 HFP-11 "J/L4/JW3150/SD142/Entry dr Psg"
|      |      |      |-- 1:4-143 HFP-11 "J/L4/JW3150/SD143/Main cab"
|      |      |      |-- 1:4-144 HTRI-R "J/L4/JW3150/CM144/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-145 HMS-S/D/M/SA "J/L4/JW3150/MCP145/Entry dr Psg"
|      |      |      |-- 1:4-146 HFP-11 "J/L4/JW3070/SD146/Main cab"
|      |      |      |-- 1:4-147 HFP-11 "J/L4/JW3070/SD147/Assorter cab"
|      |      |      |-- 1:4-148 HFP-11 "J/L4/JW3070/SD148/Entry dr Psg"
|      |      |      |-- 1:4-149 HTRI-R "J/L4/JW3070/CM149/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-150 HMS-S/D/M/SA "J/L4/JW3070/MCP150/Entry dr Psg"
|      |      |      |-- 1:4-151 HFP-11 "J/L4/JE3210/SD151/Main cab1"
|      |      |      |-- 1:4-152 HFP-11 "J/L4/JE3210/SD152/Main cab2"
|      |      |      |-- 1:4-153 HFP-11 "J/L4/JE3210/SD153/Assorter cab"
|      |      |      |-- 1:4-154 HFP-11 "J/L4/JE3210/SD154/Psg nr Pantry"
|      |      |      |-- 1:4-155 HTRI-R "J/L4/JE3210/CM155/Psg nr Entry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-156 HMS-S/D/M/SA "J/L4/JE3210/MCP156/Psg nr Entry"
|      |      |      |-- 1:4-157 HFP-11 "J/L4/JE3280/SD157/Main cab"
|      |      |      |-- 1:4-158 HFP-11 "J/L4/JE3280/SD158/Assorter cab"
|      |      |      |-- 1:4-159 HFP-11 "J/L4/JE3280/SD159/Psg nr Assorte"
|      |      |      |-- 1:4-160 HFP-11 "J/L4/JE3280/SD160/Pantry Psg"
|      |      |      |-- 1:4-161 HTRI-R "J/L4/JE3280/CM161/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-162 HMS-S/D/M/SA "J/L4/JE3280/MCP162/Entry Psg"
|      |      |      |-- 1:4-169 HFP-11 "J/L4/JE3182/SD169/Main cab"
|      |      |      |-- 1:4-170 HFP-11 "J/L4/JE3182/SD170/Pantry"
|      |      |      |-- 1:4-171 HTRI-R "J/L4/JE3182/CM171/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-172 HMS-S/D/M/SA "J/L4/JE3182/MCP172/Entry dr Psg"
|      |      |      |-- 1:4-173 HFP-11 "J/L4/JE3022/SD173/Main cab"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 1:4-174 HFP-11 "J/L4/JE3022/SD174/Psg nr Main ca"
|      |      |      |-- 1:4-175 HFP-11 "J/L4/JE3022/SD175/Assorter cab"
|      |      |      |-- 1:4-176 HFPT-11 "J/L4/JE3022/HD176/Pantry""
|      |      |      |-- 1:4-177 HTRI-R "J/L4/JE3022/CM177/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:4-178 HMS-S/D/M/SA "J/L4/JE3022/MCP178/Entry dr Psg"
|      |      |      |-- 1:4-184 HFP-11 "J/L4/JE3110/SD184/main cab"
|      |      |      |-- 1:4-185 HFP-11 "J/L4/JE3110/SD185/cab2"
|      |      |      |-- 1:4-186 HFP-11 "J/L4/JE3110/SD186/Entry psg"
|      |      |      |-- 1:4-188 HMS-S/D/M/SA "J/L4/JE3110/MCP188/Entry dr psg"
|      |      |      |-- 1:4-187 HTRI-R "J/L4/JE3110/CM187/Entry psg AFC"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:4-182 HFP-11 "J/L4/JE3300/SD182/PANTRY"
|      |      |      |-- 1:4-183 HFP-11 "J/L4/JE3300/SD183/ASSORTOR CAB"
|      |      |      |-- 1:4-163 HFP-11 "J/L4/JW3060/SD163/Cabin 1"
|      |      |      |-- 1:4-164 HFP-11 "J/L4/JW3060/SD164/Cabin 2"
|      |      |      |-- 1:4-165 HFP-11 "J/L4/JW3060/SD165/Cabin 3"
|      |      |      |-- 1:4-166 HFP-11 "J/L4/JW3060/SD166/Pantry"
|      |      |      |-- 1:4-191 HFP-11 "J/L4/JE3031/SD191/Main Cab"
|      |      |      |-- 1:4-192 HFP-11 "J/L4/JE3031/SD192/Assortor Cab"
|      |      |      |-- 1:4-193 HFP-11 "J/L4/JE3031/SD193/Entry Psg"
|      |      |      |-- 1:4-195 HTRI-R "J/L4/JE3031/CM195/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:4-194 HMS-S/D/M/SA "J/L4/JE3031/MCP194/Entry Psg"
|      |      |      |-- 1:4-196 HTRI-S "J/L4/MM196/Psg. Nr. JE3070"
|      |      |      |-- 1:4-116 HTRI-S "J/L4/MM116/PSG. NR. JE3330"
|      |      |      |-- 1:4-167 HTRI-R "J/L4/JE3060/CM167/Entry Dr AFC"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:4-168 HMS-S/D/M/SA "J/L4/JE3060/MCP168/Entry Dr psg"
|      |      |      |-- 1:4-10 HMS-S/D/M/SA "J/L4/7B/3F/MCP10/JW FIRE STR L L"
|      |      |      |-- 1:5 XDLC "XDLC @ address 5"
|      |      |      |-- 1:5-1 HTRI-R "J/L5/7B/4F/CM1/DR RELESE CM NR L"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:5-2 HFP-11 "J/L5/7B/4F/SD2/CORR NR DR 7B S19"
|      |      |      |-- 1:5-3 HFP-11 "J/L5/7B/4F/SD3/CORR NR 7B S19"
|      |      |      |-- 1:5-4 HFP-11 "J/L5/7B/4F/SD4/CORR NR JE 4030"
|      |      |      |-- 1:5-5 HFP-11 "J/L5/7B/4F/SD5/CORR NR JE 4060 A"
|      |      |      |-- 1:5-6 HFP-11 "J/L5/7B/4F/SD6/CORR NR JE 4060"
|      |      |      |-- 1:5-7 HFP-11 "J/L5/7B/4F/SD7/CORR NR JE 4080"
|      |      |      |-- 1:5-8 HMS-S/D/M/SA "J/L5/7B/4F/MCP8/FIRE ESC STR NR "
|      |      |      |-- 1:5-9 HTRI-R "J/L5/7B/4F/CM9/FIRE ESC STR NR J"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:5-10 HFP-11 "J/L5/7B/4F/SD10/CORR NR JE4100 A"
|      |      |      |-- 1:5-11 HFP-11 "J/L5/7B/4F/SD11/CORR NR JE 4100 "
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

```
|      |      |-- 1:5-12 HFP-11 "J/L5/7B/4F/SD12/CORR NR JW 4170"
|      |      |-- 1:5-13 HFP-11 "J/L5/7B/4F/SD13/CORR NR 7B S10 A"
|      |      |-- 1:5-14 HFP-11 "J/L5/7B/4F/SD14/CORR NR 7B S45"
|      |      |-- 1:5-15 HFP-11 "J/L5/7B/4F/SD15/CORR NR JW 4140"
|      |      |-- 1:5-16 HFP-11 "J/L5/7B/4F/SD16/CORR NR JW4180 A"
|      |      |-- 1:5-17 HFP-11 "J/L5/7B/4F/SD17/CORR NR JW 4180"
|      |      |-- 1:5-18 HTRI-R "J/L5/7B/4F/CM18/DR RELESE CM NR "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-19 HMS-S/D/M/SA "J/L5/7B/4F/MCP19/FIRE SHAFT L.L"
|      |      |-- 1:5-20 HTRI-R "J/L5/7B/4F/CM20/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-21 HTRI-S "J/L5/7B/4F/MM21/FIRE SHAFT L.L"
|      |      |-- 1:5-22 HFP-11 "J/L5/7B/4F/SD22/ELECT RM JW 4080"
|      |      |-- 1:5-23 HTRI-R "J/L5/7B/4F/CM23/DR RELESE JW 408"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-24 HFP-11 "J/L5/7B/4F/SD24/CORR NR JW 4080"
|      |      |-- 1:5-25 HFP-11 "J/L5/7B/4F/SD25/CORR NR JW4040 A"
|      |      |-- 1:5-26 HFP-11 "J/L5/7B/4F/SD26/CORR NR JW 4040"
|      |      |-- 1:5-27 HTRI-R "J/L5/7B/4F/CM27/DR RELESE JW 404"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-28 HTRI-R "J/L5/7B/4F/CM28/DR RELESE JE 404"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-29 HFP-11 "J/L5/7B/4F/SD29/CORR NR JE4220 A"
|      |      |-- 1:5-30 HFP-11 "J/L5/7B/4F/SD30/CORR NR JE 4220"
|      |      |-- 1:5-31 HFP-11 "J/L5/7B/4F/SD31/CORR NR JE4250 A"
|      |      |-- 1:5-32 HFP-11 "J/L5/7B/4F/SD32/CORR NR JE 4250"
|      |      |-- 1:5-33 HFP-11 "J/L5/7B/4F/SD33/CORR NR JE 7B S3"
|      |      |-- 1:5-34 HFP-11 "J/L5/7B/4F/SD34/CORR NR JE4300 A"
|      |      |-- 1:5-35 HFP-11 "J/L5/7B/4F/SD35/CORR NR JE 4300"
|      |      |-- 1:5-36 HFP-11 "J/L5/7B/4F/SD36/CORR NR JE 4320"
|      |      |-- 1:5-37 HFP-11 "J/L5/7B/4F/SD37/CORR NR JE4170 A"
|      |      |-- 1:5-38 HFP-11 "J/L5/7B/4F/SD38/CORR NR JE 4170"
|      |      |-- 1:5-39 HTRI-R "J/L5/7B/4F/CM39/DR RELESE CM NR "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-40 HMS-S/D/M/SA "J/L5/7B/4F/MCP40/FIRE ESC STR "
|      |      |-- 1:5-41 HTRI-R "J/L5/7B/4F/CM41/FIRE ESC STR NR "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-42 HTRI-S "J/L5/7B/4F/MM42/FIRE ESC STR NR "
|      |      |-- 1:5-44 HFP-11 "J/L5/7B/4F/SD44/AHURM SDnr 7BS4 "
|      |      |-- 1:5-45 HTRI-R "J/L5/7B/4F/CM45/AHU RM 7B S45"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-46 HFP-11 "J/L5/7B/4F/SD46/ELECT RM SD"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

```
|      |      |-- 1:5-47 HFP-11 "J/L5/7B/4F/SD47/CORR NR 7B S37"
|      |      |-- 1:5-48 HTRI-R "J/L5/7B/4F/CM48/AHU RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-49 HFP-11 "J/L5/7B/4F/SD49/LIFT LOBBY 7B S1"
|      |      |-- 1:5-50 HFP-11 "J/L5/7B/4F/SD50/L. L. NR JW 4080"
|      |      |-- 1:5-61 HTRI-S "J/L5/JE/4F/MM61/Psg nr JE4160"
|      |      |-- 1:5-62 HTRI-S "J/L5/JE/4F/MM62/Psg nr JE4020"
|      |      |-- 1:5-63 HTRI-S "J/L5/JE/4F/MM63/Psg nr JE4040"
|      |      |-- 1:5-64 HTRI-S "J/L5/JE/4F/MM64/Psg nr JE4060"
|      |      |-- 1:5-65 HTRI-S "J/L5/JE/4F/MM65/Psg nr JE4090"
|      |      |-- 1:5-66 HTRI-S "J/L5/JE/4F/MM66/Psg nr JE4120"
|      |      |-- 1:5-67 HTRI-S "J/L5/JW/4F/MM67/Psg nr JW4160"
|      |      |-- 1:5-68 HTRI-S "J/L5/JW/4F/MM68/Psg nr JW4140"
|      |      |-- 1:5-69 HTRI-S "J/L5/JW/4F/MM69/Psg nr JW4110"
|      |      |-- 1:5-70 HTRI-S "J/L5/JW/4F/MM70/Psg nr JW4100"
|      |      |-- 1:5-71 HTRI-S "J/L5/JW/4F/MM71/Psg nr JW4080"
|      |      |-- 1:5-72 HTRI-S "J/L5/JW/4F/MM72/Psg nr JW4020"
|      |      |-- 1:5-73 HTRI-S "J/L5/JW/4F/MM73/Psg nr JW4050"
|      |      |-- 1:5-74 HTRI-S "J/L5/JE/4F/MM74/Psg nr JE4220"
|      |      |-- 1:5-75 HTRI-S "J/L5/JE/4F/MM75/Psg nr JE4200"
|      |      |-- 1:5-76 HTRI-S "J/L5/JE/4F/MM76/Psg nr JE4270"
|      |      |-- 1:5-77 HTRI-S "J/L5/JE/4F/MM77/Psg nr JE4320"
|      |      |-- 1:5-78 HTRI-S "J/L5/JE/4F/MM78/Psg nr JE4330"
|      |      |-- 1:5-79 HTRI-S "J/L5/JE/4F/MM79/Psg nr JE4170"
|      |      |-- 1:5-80 HFP-11 "J/L5/JE4050/SD80/Entry dr Psg "
|      |      |-- 1:5-81 HFP-11 "J/L5/JE4050/SD81/Main cab"
|      |      |-- 1:5-82 HMS-S/D/M/SA "J/L5/JE4050/MCP82/Entry Psg"
|      |      |-- 1:5-83 HTRI-R "J/L5/JE4050/CM83/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-84 HFP-11 "J/L5/JE4130/SD84/Main cab"
|      |      |-- 1:5-85 HFP-11 "J/L5/JE4130/SD85/Recep.Psg"
|      |      |-- 1:5-86 HFP-11 "J/L5/JE4130/SD86/Pantry"
|      |      |-- 1:5-87 HFP-11 "J/L5/JE4130/SD87/Psg nr Pantry"
|      |      |-- 1:5-88 HFP-11 "J/L5/JE4130/SD88/Account cab"
|      |      |-- 1:5-89 HFP-11 "J/L5/JE4130/SD89/Assort. Cab1"
|      |      |-- 1:5-90 HFP-11 "J/L5/JE4130/SD90/Assort. Cab2"
|      |      |-- 1:5-91 HFP-11 "J/L5/JE4130/SD91/Assort. Cab 3"
|      |      |-- 1:5-92 HFP-11 "J/L5/JE4130/SD92/Assort. Cab 4"
|      |      |-- 1:5-93 HFP-11 "J/L5/JE4130/SD93/MD cab"
|      |      |-- 1:5-94 HTRI-R "J/L5/JE4130/CM94/Psg nr Entry"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-95 HMS-S/D/M/SA "J/L5/JE4130/MCP95/Psg nr Entry"
|      |      |-- 1:5-96 HFP-11 "J/L5/JE4080/SD96/Pantry"
|      |      |-- 1:5-97 HFP-11 "J/L5/JE4080/SD97/Main cab"
|      |      |-- 1:5-98 HTRI-R "J/L5/JE4080/CM98/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

```
|      |      |-- 1:5-99 HMS-S/D/M/SA "J/L5/JE4080/MCP99/Entry Psg"
|      |      |-- 1:5-100 HFP-11 "J/L5/JE4030/SD100/Main cab"
|      |      |-- 1:5-101 HFP-11 "J/L5/JE4030/SD101/Entry dr Psg "
|      |      |-- 1:5-102 HMS-S/D/M/SA "J/L5/JE4030/MCP102/Entry dr Psg "
|      |      |-- 1:5-103 HTRI-R "J/L5/JE4030/CM103/Entry dr Psg "
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-104 HFP-11 "J/L5/JE4110/SD104/Main cab"
|      |      |-- 1:5-105 HFP-11 "J/L5/JE4110/SD105/Main cab"
|      |      |-- 1:5-106 HFP-11 "J/L5/JE4110/SD106/Accounts cab"
|      |      |-- 1:5-107 HFP-11 "J/L5/JE4110/SD107/Pantry"
|      |      |-- 1:5-108 HFP-11 "J/L5/JE4110/SD108/Entry Psg"
|      |      |-- 1:5-109 HMS-S/D/M/SA "J/L5/JE4110/MCP109/Entry Psg"
|      |      |-- 1:5-110 HTRI-R "J/L5/JE4110/CM110/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-111 HFP-11 "J/L5/JW4180/SD111/Account 1"
|      |      |-- 1:5-112 HFP-11 "J/L5/JW4180/SD112/Main cab"
|      |      |-- 1:5-113 HFP-11 "J/L5/JW4180/SD113/Assorter cab"
|      |      |-- 1:5-114 HFP-11 "J/L5/JW4180/SD114/Main cab1"
|      |      |-- 1:5-115 HFP-11 "J/L5/JW4180/SD115/Main cab1"
|      |      |-- 1:5-116 HFP-11 "J/L5/JW4180/SD116/Account cab"
|      |      |-- 1:5-117 HFPT-11 "J/L5/JW4180/HD117/Pantry"
|      |      |-- 1:5-118 HFP-11 "J/L5/JW4180/SD118/Psg nr Pantry"
|      |      |-- 1:5-119 HFP-11 "J/L5/JW4180/SD119/Reception"
|      |      |-- 1:5-120 HFP-11 "J/L5/JW4180/SD120/Entry Psg"
|      |      |-- 1:5-121 HTRI-R "J/L5/JW4180/CM121/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-122 HMS-S/D/M/SA "J/L5/JW4180/MCP122/Entry Psg"
|      |      |-- 1:5-123 HFP-11 "J/L5/JW4170/SD123/Main cab"
|      |      |-- 1:5-124 HFP-11 "J/L5/JW4170/SD124/Account cab"
|      |      |-- 1:5-125 HFP-11 "J/L5/JW4170/SD125/Pantry"
|      |      |-- 1:5-126 HTRI-R "J/L5/JW4170/CM126/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-127 HMS-S/D/M/SA "J/L5/JW4170/MCP127/Entry Psg"
|      |      |-- 1:5-128 HFP-11 "J/L5/JW4060/SD128/cab1"
|      |      |-- 1:5-129 HFP-11 "J/L5/JW4060/SD129/cab2"
|      |      |-- 1:5-130 HFP-11 "J/L5/JW4060/SD130/cab3"
|      |      |-- 1:5-131 HFP-11 "J/L5/JW4060/SD131/Pantry Psg"
|      |      |-- 1:5-132 HFP-11 "J/L5/JW4060/SD132/Entry Psg"
|      |      |-- 1:5-133 HTRI-R "J/L5/JW4060/CM133/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-134 HMS-S/D/M/SA "J/L5/JW4060/MCP134/Entry Psg"
|      |      |-- 1:5-135 HFP-11 "J/L5/JW4130/SD135/Main cab"
|      |      |-- 1:5-136 HFP-11 "J/L5/JW4130/SD136/Assorter cab"
|      |      |-- 1:5-137 HFP-11 "J/L5/JW4130/SD137/Entry Psg"
|      |      |-- 1:5-138 HTRI-R "J/L5/JW4130/CM138/Entry Psg"
```


1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

1:5-138 HTRI-R "J/L5/JW4130/CM138/Entry Psg"

```
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:5-139 HMS-S/D/M/SA "J/L5/JW4130/MCP139/Entry Psg"
|      |      | |-- 1:5-140 HFP-11 "J/L5/JW4040/SD140/Main cab"
|      |      | |-- 1:5-141 HFP-11 "J/L5/JW4040/SD141/Assorter cab"
|      |      | |-- 1:5-142 HFPT-11 "J/L5/JW4040/HD142/Pantry"
|      |      | |-- 1:5-143 HTRI-R "J/L5/JW4040/CM143/Entry Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:5-144 HMS-S/D/M/SA "J/L5/JW4040/MCP144/Entry Psg"
|      |      | |-- 1:5-145 HFP-11 "J/L5/JW4150/SD145/Assorter cab1"
|      |      | |-- 1:5-146 HFP-11 "J/L5/JW4150/SD146/Assorter cab2"
|      |      | |-- 1:5-147 HFP-11 "J/L5/JW4150/SD147/Main cab"
|      |      | |-- 1:5-148 HFP-11 "J/L5/JW4150/SD148/Pantry"
|      |      | |-- 1:5-149 HFP-11 "J/L5/JW4150/SD149/Entry Psg"
|      |      | |-- 1:5-150 HTRI-R "J/L5/JW4150/CM150/Entry Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:5-151 HMS-S/D/M/SA "J/L5/JW4150/MCP151/Entry Psg"
|      |      | |-- 1:5-152 HFP-11 "J/L5/JW4010/SD152/Account cab"
|      |      | |-- 1:5-153 HFP-11 "J/L5/JW4010/SD153/Assorter cab"
|      |      | |-- 1:5-154 HFP-11 "J/L5/JW4010/SD154/Main cab"
|      |      | |-- 1:5-155 HFP-11 "J/L5/JW4010/SD155/Entry Psg"
|      |      | |-- 1:5-156 HTRI-R "J/L5/JW4010/CM156/Entry Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:5-157 HMS-S/D/M/SA "J/L5/JW4010/MCP157/Entry Psg"
|      |      | |-- 1:5-158 HFP-11 "J/L5/JE4230/SD158/Account cab"
|      |      | |-- 1:5-159 HFP-11 "J/L5/JE4230/SD159/Main cab"
|      |      | |-- 1:5-160 HFP-11 "J/L5/JE4230/SD160/Cab 1"
|      |      | |-- 1:5-161 HFP-11 "J/L5/JE4230/SD161/Entry Psg"
|      |      | |-- 1:5-162 HTRI-R "J/L5/JE4230/CM162/Entry Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:5-163 HMS-S/D/M/SA "J/L5/JE4230/MCP163/Entry Psg"
|      |      | |-- 1:5-164 HFP-11 "J/L5/JE4240/SD164/Main cab"
|      |      | |-- 1:5-165 HFP-11 "J/L5/JE4240/SD165/Main cab"
|      |      | |-- 1:5-166 HFP-11 "J/L5/JE4240/SD166/Staff cab"
|      |      | |-- 1:5-167 HFPT-11 "J/L5/JE4240/HD167/Pantry"
|      |      | |-- 1:5-168 HFP-11 "J/L5/JE4240/SD168/Entry Psg"
|      |      | |-- 1:5-169 HTRI-R "J/L5/JE4240/CM169/Entry Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:5-170 HMS-S/D/M/SA "J/L5/JE4240/MCP170/Entry Psg"
|      |      | |-- 1:5-171 HFP-11 "J/L5/JE4280/SD171/Main cab"
|      |      | |-- 1:5-172 HFP-11 "J/L5/JE4280/SD172/Main cab"
|      |      | |-- 1:5-173 HFPT-11 "J/L5/JE4280/HD173/Pantry"
|      |      | |-- 1:5-174 HTRI-R "J/L5/JE4280/CM174/Entry Psg"
|      |      | |-- Switch ""
|      |      | |-- Relay
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

```
|      |      |-- 1:5-175 HMS-S/D/M/SA "J/L5/JE4280/MCP175/Entry Psg"
|      |      |-- 1:5-176 HFP-11 "J/L5/JE4210/SD176/Main cab"
|      |      |-- 1:5-177 HFP-11 "J/L5/JE4210/SD177/Cab 1"
|      |      |-- 1:5-178 HFP-11 "J/L5/JE4210/SD178/Psg nr cab1"
|      |      |-- 1:5-179 HFP-11 "J/L5/JE4210/SD179/Pantry Psg"
|      |      |-- 1:5-180 HTRI-R "J/L5/JE4210/CM180/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-181 HMS-S/D/M/SA "J/L5/JE4210/MCP181/Entry Psg"
|      |      |-- 1:5-193 HFP-11 "J/L5/JE4310/SD193/Main cab"
|      |      |-- 1:5-194 HFP-11 "J/L5/JE4310/SD194/Assorter cab"
|      |      |-- 1:5-195 HFP-11 "J/L5/JE4310/SD195/Entry Psg"
|      |      |-- 1:5-196 HTRI-R "J/L5/JE4310/CM196/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-197 HMS-S/D/M/SA "J/L5/JE4310/MCP197/Entry Psg"
|      |      |-- 1:5-203 HTRI-S "J/J/L5/4F/MM203/Psg. Nr. JW 4030"
|      |      |-- 1:5-204 HTRI-S "J/L5/4F/MM204/Psg. Nr. JE 4120"
|      |      |-- 1:5-188 HFP-11 "J/L5/JE4300/SD188/Main cab"
|      |      |-- 1:5-189 HFP-11 "J/L5/JE4300/SD189/Psg nr Main ca"
|      |      |-- 1:5-190 HFP-11 "J/L5/JE4300/SD190/Psg nr Main ca"
|      |      |-- 1:5-191 HTRI-R "J/L5/JE4300/CM191/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-192 HMS-S/D/M/SA "J/L5/JE4300/MCP192/Entry Psg"
|      |      |-- 1:5-198 HFP-11 "J/L5/JE4290/SD198/Main Cabin"
|      |      |-- 1:5-199 HFP-11 "J/L5/JE4290/SD199/Assortor Cabin"
|      |      |-- 1:5-200 HFP-11 "J/L5/JE4290/SD200/Entry Psg."
|      |      |-- 1:5-201 HTRI-R "J/L5/JE4290/CM201/Entry Psg. AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-202 HMS-S/D/M/SA "J/L5/JE4290/MCP202/Entry Psg."
|      |      |-- CC-5 "Card Cage 5 Slots"
|      |      |  |-- 1:6 XDLC "XDLC @ address 6 L6"
|      |      |  |  |-- 1:6-1 HTRI-R "J/L6/7B/5F/CM1/DR RELESE JE 501"
|      |      |  |  |  |-- Switch ""
|      |      |  |  |  |-- Relay
|      |      |  |  |-- 1:6-2 HFP-11 "J/L6/7B/5F/SD2/CORR NR JE 5010"
|      |      |  |  |-- 1:6-3 HFP-11 "J/L6/7B/5F/SD3/CORR NR JE5010 AF"
|      |      |  |  |-- 1:6-4 HFP-11 "J/L6/7B/5F/SD4/CORR NR JE S/20"
|      |      |  |  |-- 1:6-5 HFP-11 "J/L6/7B/5F/SD5/CORR NR JE 5040"
|      |      |  |  |-- 1:6-6 HFP-11 "J/L6/7B/5F/SD6/CORR NR JE 5040 A"
|      |      |  |  |-- 1:6-7 HFP-11 "J/L6/7B/5F/SD7/CORR NR JE5100"
|      |      |  |  |-- 1:6-8 HMS-S/D/M/SA "J/L6/7B/5F/MCP8/FIRE ESC STR NR "
|      |      |  |  |-- 1:6-9 HTRI-R "J/L6/7B/5F/CM9/FIRE ESC STR NR J"
|      |      |  |  |  |-- Switch ""
|      |      |  |  |  |-- Relay
|      |      |  |  |-- 1:6-11 HFP-11 "J/L6/7B/5F/SD11/CORR NR JE 7B5/S"
|      |      |  |  |-- 1:6-12 HFP-11 "J/L6/7B/5F/SD12/CorrNrJE7B5/S14A"
|      |      |  |  |-- 1:6-13 HFP-11 "J/L6/7B/5F/SD13/CORR NR JE 5130"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:6 XDLC "XDLC @ address 6 L6"

```
|      |      |      |-- 1:6-14 HFP-11 "J/L6/7B/5F/SD14/CORR NR JE5130 A"
|      |      |      |-- 1:6-15 HFP-11 "J/L6/7B/5F/SD15/CORR NR JE 5110"
|      |      |      |-- 1:6-16 HTRI-R "J/L7/7B/6F/CM16/AHU RM CM JW"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-17 HFP-11 "J/L7/7B/6F/SD17/AHU RM SD JW"
|      |      |      |-- 1:6-18 HFP-11 "J/L6/7B/5F/SD18/CORR NR JW 5140"
|      |      |      |-- 1:6-19 HFP-11 "J/L6/7B/5F/SD19/CORR NR JW 5140"
|      |      |      |-- 1:6-20 HFP-11 "J/L6/7B/5F/SD20/CORR NR JW 5150"
|      |      |      |-- 1:6-21 HTRI-R "J/L6/7B/5F/CM21/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-22 HMS-S/D/M/SA "J/L6/7B/5F/MCP22/FIRE SHAFT L.L."
|      |      |      |-- 1:6-23 HTRI-S "J/L6/7B/5F/MM23/FIRE SHAFT L.L."
|      |      |      |-- 1:6-24 HTRI-R "J/L6/7B/5F/CM24/DR RELEASE L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-25 HFP-11 "J/L6/7B/5F/SD25/LIFT LOBBY SD"
|      |      |      |-- 1:6-26 HFP-11 "J/L6/7B/5F/SD26/ELECT RM SD"
|      |      |      |-- 1:6-27 HTRI-R "J/L6/7B/5F/CM27/DR RELEASE L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-28 HFP-11 "J/L6/7B/5F/SD28/CORR NR JW5060 A"
|      |      |      |-- 1:6-29 HFP-11 "J/L6/7B/5F/SD29/CORR NR JW 5060"
|      |      |      |-- 1:6-30 HFP-11 "J/L6/7B/5F/SD30/CORR NR JW5020 A"
|      |      |      |-- 1:6-31 HFP-11 "J/L6/7B/5F/SD31/CORR NR JW 5020"
|      |      |      |-- 1:6-32 HFP-11 "J/L6/7B/5F/SD32/CORR NR 7B S02"
|      |      |      |-- 1:6-33 HTRI-R "J/L6/7B/5F/CM33/DR RELEASE 7B S0"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-34 HTRI-R "J/L6/7B/5F/CM34/DR RELEASE JE 51"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-35 HFP-11 "J/L6/7B/5F/SD35/CORR NR JE5170 A"
|      |      |      |-- 1:6-36 HFP-11 "J/L6/7B/5F/SD36/CORR NR JE 5170"
|      |      |      |-- 1:6-37 HFP-11 "J/L6/7B/5F/SD37/CORR NR JE 5200"
|      |      |      |-- 1:6-38 HFP-11 "J/L6/7B/5F/SD38/CORR NR JE5200 A"
|      |      |      |-- 1:6-39 HFP-11 "J/L6/7B/6F/SD39/AHU RM SD JW"
|      |      |      |-- 1:6-40 HTRI-R "J/L6/7B/6F/CM40/AHU RM CM JW"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-41 HFP-11 "J/L6/7B/5F/SD41/CORR NR JE 5220"
|      |      |      |-- 1:6-42 HMS-S/D/M/SA "J/L6/7B/5F/MCP42/FIRE ESC STR NR"
|      |      |      |-- 1:6-43 HTRI-R "J/L6/7B/5F/CM43/FIRE ESC STR NR "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-44 HTRI-S "J/L6/7B/5F/MM44/FIRE ESC STR NR "
|      |      |      |-- 1:6-45 HFP-11 "J/L6/7B/5F/SD45/CORR NR JE 5230"
|      |      |      |-- 1:6-46 HFP-11 "J/L6/7B/5F/SD46/CORR NR JE5230 A"
|      |      |      |-- 1:6-47 HFP-11 "J/L6/7B/5F/SD47/CORR NR JE 5240"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:6 XDLC "XDLC @ address 6 L6"

```
|      |      |      |-- 1:6-48 HFP-11 "J/L6/7B/5F/SD48/CORR NR JE 5130"
|      |      |      |-- 1:6-49 HFP-11 "J/L6/7B/5F/SD49/CORR NR JE5130 A"
|      |      |      |-- 1:6-50 HTRI-R "J/L6/7B/5F/CM50/DR RELEASE L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-51 HFP-11 "J/L6/JE5130/SD51/Assorter cab"
|      |      |      |-- 1:6-52 HFP-11 "J/L6/JE5130/SD52/Main cab"
|      |      |      |-- 1:6-53 HFPT-11 "J/L6/JE5130/HD53/Pantry"
|      |      |      |-- 1:6-54 HFP-11 "J/L6/JE5130/SD54/Psg nr Entry"
|      |      |      |-- 1:6-55 HTRI-R "J/L6/JE5130/CM55/Psg nr Entry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-56 HMS-S/D/M/SA "J/L6/JE5130/MCP56/Psg nr Entry"
|      |      |      |-- 1:6-57 HFP-11 "J/L6/JE5130/SD57/Accounts cab"
|      |      |      |-- 1:6-58 HFP-11 "J/L6/7B/5F/SD58/ELECT RM SD"
|      |      |      |-- 1:6-59 HFP-11 "J/L6/7B/5F/SD59/LIFT LOBBY SD"
|      |      |      |-- 1:6-60 HTRI-S "J/L6/JE/5F/MM60/Psg nr JE5020"
|      |      |      |-- 1:6-61 HTRI-S "J/L6/JE/5F/MM61/Psg nr JE5120"
|      |      |      |-- 1:6-62 HTRI-S "J/L6/JE/5F/MM62/Psg nr JE5100"
|      |      |      |-- 1:6-63 HTRI-S "J/L6/JW/5F/MM63/Psg nr JW5120"
|      |      |      |-- 1:6-64 HTRI-S "J/L6/JW/5F/MM64/Psg nr JW5110"
|      |      |      |-- 1:6-65 HTRI-S "J/L6/JW/5F/MM65/Psg nr JW5140"
|      |      |      |-- 1:6-66 HTRI-S "J/L6/JW/5F/MM66/Psg nr JW5150"
|      |      |      |-- 1:6-67 HTRI-S "J/L6/JW/5F/MM67/Psg nr JW5060"
|      |      |      |-- 1:6-68 HTRI-S "J/L6/JW/5F/MM68/Psg nr JW5010"
|      |      |      |-- 1:6-69 HTRI-S "J/L6/JE/5F/MM69/Psg nr JE5170"
|      |      |      |-- 1:6-70 HTRI-S "J/L6/JE/5F/MM70/Psg nr JE5200"
|      |      |      |-- 1:6-71 HTRI-S "J/L6/JE/5F/MM71/Psg nr JE5220"
|      |      |      |-- 1:6-72 HTRI-S "J/L6/JE/5F/MM72/Psg nr JE5230"
|      |      |      |-- 1:6-73 HTRI-S "J/L6/JE/5F/MM73/Psg nr JE5240"
|      |      |      |-- 1:6-74 HTRI-S "J/L6/JE/5F/MM74/Psg nr JE5150"
|      |      |      |-- 1:6-75 HFP-11 "J/L6/JE5010/SD75/Main cab"
|      |      |      |-- 1:6-76 HFP-11 "J/L6/JE5010/SD76/Assorter cab1"
|      |      |      |-- 1:6-77 HFP-11 "J/L6/JE5010/SD77/Assorter cab2"
|      |      |      |-- 1:6-78 HFP-11 "J/L6/JE5010/SD78/Pantry"
|      |      |      |-- 1:6-79 HFP-11 "J/L6/JE5010/SD79/Psg nr Pantry"
|      |      |      |-- 1:6-80 HTRI-R "J/L6/JE5010/CM80/Psg nr Entry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-81 HMS-S/D/M/SA "J/L6/JE5010/MCP81/Psg nr Entry"
|      |      |      |-- 1:6-82 HFP-11 "J/L6/JE5030/SD82/Assorter cab"
|      |      |      |-- 1:6-83 HFP-11 "J/L6/JE5030/SD83/Main cab"
|      |      |      |-- 1:6-84 HFPT-11 "J/L6/JE5030/HD84/Pantry"
|      |      |      |-- 1:6-85 HFP-11 "J/L6/JE5030/SD85/Psg nr MC"
|      |      |      |-- 1:6-86 HFP-11 "J/L6/JE5030/SD86/Entry Psg"
|      |      |      |-- 1:6-87 HTRI-R "J/L6/JE5030/CM87/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-88 HMS-S/D/M/SA "J/L6/JE5030/MCP88/Entry Psg"
|      |      |      |-- 1:6-89 HFP-11 "J/L6/JE5050/SD89/Assorter cab"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:6 XDLC "XDLC @ address 6 L6"

			-- 1:6-90 HFP-11 "J/L6/JE5050/SD90/Main cab"
			-- 1:6-91 HFP-11 "J/L6/JE5050/SD91/Accounts cab"
			-- 1:6-92 HFP-11 "J/L6/JE5050/SD92/Pantry"
			-- 1:6-93 HFP-11 "J/L6/JE5050/SD93/Entry Psg"
			-- 1:6-94 HTRI-R "J/L6/JE5050/CM94/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:6-95 HMS-S/D/M/SA "J/L6/JE5050/MCP95/Entry Psg"
			-- 1:6-96 HFP-11 "J/L6/JE5060/SD96/Cab 1"
			-- 1:6-97 HFP-11 "J/L6/JE5060/SD97/Cab 2"
			-- 1:6-98 HFP-11 "J/L6/JE5060/SD98/Cab 3"
			-- 1:6-99 HFP-11 "J/L6/JE5060/SD99/Entry Psg"
			-- 1:6-100 HFPT-11 "J/L6/JE5060/HD100/Pantry"
			-- 1:6-101 HTRI-R "J/L6/JE5060/CM101/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:6-102 HMS-S/D/M/SA "J/L6/JE5060/MCP102/Entry Psg"
			-- 1:6-103 HFP-11 "J/L6/JW5020/SD103/Assorter Cab 1"
			-- 1:6-104 HFP-11 "J/L6/JW5020/SD104/Assorter Cab 2"
			-- 1:6-105 HFP-11 "J/L6/JW5020/SD105/Assorter Cab 2"
			-- 1:6-106 HFP-11 "J/L6/JW5020/SD106/Entry Psg"
			-- 1:6-107 HTRI-R "J/L6/JW5020/CM107/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:6-108 HMS-S/D/M/SA "J/L6/JW5020/MCP108/Entry Psg"
			-- 1:6-109 HFP-11 "J/L6/JW5130/SD109/Main cab"
			-- 1:6-110 HFP-11 "J/L6/JW5130/SD110/Accounts Cab"
			-- 1:6-111 HFP-11 "J/L6/JW5130/SD111/Pantry Psg"
			-- 1:6-112 HTRI-R "J/L6/JW5130/CM112/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:6-113 HMS-S/D/M/SA "J/L6/JW5130/MCP113/Entry Psg"
			-- 1:6-114 HFP-11 "J/L6/JW5040/SD114/Main cab"
			-- 1:6-115 HFP-11 "J/L6/JW5040/SD115/Cab 1"
			-- 1:6-116 HFP-11 "J/L6/JW5040/SD116/Accounts cab"
			-- 1:6-117 HFP-11 "J/L6/JW5040/SD117/Pantry Psg"
			-- 1:6-118 HFP-11 "J/L6/JW5040/SD118/Entry Psg"
			-- 1:6-119 HTRI-R "J/L6/JW5040/CM119/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:6-120 HMS-S/D/M/SA "J/L6/JW5040/MCP120/Entry Psg"
			-- 1:6-121 HFPT-11 "J/L6/JE5140/HD121/cab2"
			-- 1:6-122 HFP-11 "J/L6/JE5140/SD122/Main cab"
			-- 1:6-123 HTRI-R "J/L6/JE5140/CM123/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:6-124 HMS-S/D/M/SA "J/L6/JE5140/MCP124/Entry Psg"
			-- 1:6-125 HFP-11 "J/L6/JW5050/SD125/Main cab"
			-- 1:6-126 HFP-11 "J/L6/JW5050/SD126/Assorter cab"
			-- 1:6-127 HFP-11 "J/L6/JW5050/SD127/Psg nr Main ca"

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:6 XDLC "XDLC @ address 6 L6"
```

```
|      |      |  |-- 1:6-128 HTRI-R "J/L6/JW5050/CM128/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:6-129 HMS-S/D/M/SA "J/L6/JW5050/MCP129/Entry Psg"
|      |      |  |-- 1:6-130 HFP-11 "J/L6/JE5190/SD130/Main cab"
|      |      |  |-- 1:6-131 HFP-11 "J/L6/JE5190/SD131/Pantry Psg"
|      |      |  |-- 1:6-132 HTRI-R "J/L6/JE5190/CM132/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:6-133 HMS-S/D/M/SA "J/L6/JE5190/MCP133/Entry Psg"
|      |      |  |-- 1:6-134 HFP-11 "J/L6/JE5110/SD134/Main cab"
|      |      |  |-- 1:6-135 HFP-11 "J/L6/JE5110/SD135/Assorter cab"
|      |      |  |-- 1:6-136 HTRI-R "J/L6/JE5110/CM136/Entry dr "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:6-137 HMS-S/D/M/SA "J/L6/JE5110/MCP137/Entry dr "
|      |      |  |-- 1:6-138 HFP-11 "J/L6/JW5030/SD138/Conference rm"
|      |      |  |-- 1:6-139 HFP-11 "J/L6/JW5030/SD139/Accounts cab"
|      |      |  |-- 1:6-140 HFP-11 "J/L6/JW5030/SD140/Entry Psg"
|      |      |  |-- 1:6-141 HFP-11 "J/L6/JW5030/SD141/Cab1"
|      |      |  |-- 1:6-142 HTRI-R "J/L6/JW5030/CM142/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:6-143 HMS-S/D/M/SA "J/L6/JW5030/MCP143/Entry Psg"
|      |      |  |-- 1:6-144 HFP-11 "J/L6/JE5070/SD144/Account cab"
|      |      |  |-- 1:6-145 HFP-11 "J/L6/JE5070/SD145/Main cab"
|      |      |  |-- 1:6-146 HFP-11 "J/L6/JE5070/SD146/Assortor Cabin"
|      |      |  |-- 1:6-147 HFP-11 "J/L6/JE5070/SD147/Psg nr Pantry"
|      |      |  |-- 1:6-148 HFP-11 "J/L6/JE5070/SD148/Pantry"
|      |      |  |-- 1:6-149 HTRI-R "J/L6/JE5070/CM149/Entry dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:6-150 HMS-S/D/M/SA "J/L6/JE5070/MCP150/Entry dr"
|      |      |  |-- 1:6-154 HFP-11 "J/L6/JE5110/SD154/Accounts cab"
|      |      |  |-- 1:6-155 HFPT-11 "J/L6/JE5110/HD155/Pantry Psg"
|      |      |  |-- 1:6-156 HFP-11 "J/L6/JW5070/SD156/Main cab 1"
|      |      |  |-- 1:6-157 HFP-11 "J/L6/JW5070/SD157/Main cab 2"
|      |      |  |-- 1:6-158 HFP-11 "J/L6/JW5070/SD158/Account cab"
|      |      |  |-- 1:6-159 HFP-11 "J/L6/JW5070/SD159/Pantry"
|      |      |  |-- 1:6-160 HFP-11 "J/L6/JW5070/SD160/Entry Psg"
|      |      |  |-- 1:6-161 HTRI-R "J/L6/JW5070/CM161/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:6-162 HMS-S/D/M/SA "J/L6/JW5070/MCP162/Entry Psg"
|      |      |  |-- 1:6-163 HFP-11 "J/L6/JE5180/SD163/Accounts cab"
|      |      |  |-- 1:6-164 HFP-11 "J/L6/JE5180/SD164/Main Cab"
|      |      |  |-- 1:6-165 HFP-11 "J/L6/JE5180/SD165/Psg nr MC"
|      |      |  |-- 1:6-166 HFP-11 "J/L6/JE5180/SD166/Main Cab2"
|      |      |  |-- 1:6-167 HFPT-11 "J/L6/JE5180/HD167/Pantry"
|      |      |  |-- 1:6-168 HTRI-R "J/L6/JE5180/CM168/Entry Psg"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:6 XDLC "XDLC @ address 6 L6"

1:6-168 HTRI-R "J/L6/JE5180/CM168/Entry Psg"

```
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 1:6-169 HMS-S/D/M/SA "J/L6/JE5180/MCP169/Entry Psg"
|      | | | |-- 1:7 XDLC "XDLC @ address 7 L7"
|      | | | |-- 1:7-1 HTRI-R "J/L7/6F/CM1/DR RELEASE CM"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 1:7-2 HFP-11 "J/L7/6F/SD2/CORR NR JE 6010"
|      | | | |-- 1:7-3 HFP-11 "J/L7/6F/SD3/CORR NR JE6010 AFC"
|      | | | |-- 1:7-4 HFP-11 "J/L7/6F/SD4/CORR NR JE 6030"
|      | | | |-- 1:7-5 HFP-11 "J/L7/6F/SD5/CORR NR JE 6050"
|      | | | |-- 1:7-6 HFP-11 "J/L7/6F/SD6/CORR NR JE6050 AFC"
|      | | | |-- 1:7-7 HFP-11 "J/L7/6F/SD7/CORR NR 7B S15"
|      | | | |-- 1:7-8 HFP-11 "J/L7/6F/SD8/CORR NR 7B S14"
|      | | | |-- 1:7-9 HFP-11 "J/L7/6F/SD9/CORR NR 7B S14 AFC"
|      | | | |-- 1:7-10 HMS-S/D/M/SA "J/L7/6F/MCP10/FIRE ESC STR"
|      | | | |-- 1:7-11 HTRI-R "J/L7/6F/CM11/FIRE ESC STR"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 1:7-12 HTRI-S "J/L7/6F/MM12/FIRE ESC STR"
|      | | | |-- 1:7-13 HFP-11 "J/L7/6F/SD13/CORR NR JE 6080"
|      | | | |-- 1:7-14 HFP-11 "J/L7/6F/SD14/CORR NR 7B S11 AFC"
|      | | | |-- 1:7-15 HFP-11 "J/L7/6F/SD15/CORR NR 7B S10"
|      | | | |-- 1:7-16 HFP-11 "J/L7/6F/SD16/AHU RM SD JW"
|      | | | |-- 1:7-17 HTRI-R "J/L7/6F/CM17/AHU RM CM JW"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 1:7-18 HFP-11 "J/L7/6F/SD18/CORR NR JE 6190"
|      | | | |-- 1:7-19 HFP-11 "J/L7/6F/SD19/CORR NR 7B S46 AFC"
|      | | | |-- 1:7-20 HFP-11 "J/L7/6F/SD20/CORR NR 7B S08"
|      | | | |-- 1:7-21 HFP-11 "J/L7/6F/SD21/CORR NR JW6110AFC"
|      | | | |-- 1:7-22 HTRI-R "J/L7/6F/CM22/DR RELELSE CM"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 1:7-23 HMS-S/D/M/SA "J/L7/6F/MCP23/FIRE SHAFT L.L."
|      | | | |-- 1:7-24 HTRI-R "J/L7/6F/CM24/FIRE SHAFT L.L."
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 1:7-25 HTRI-S "J/L7/6F/MM25/FIRE SHAFT L.L."
|      | | | |-- 1:7-26 HFP-11 "J/L7/6F/SD26/LIFT LOBBY SD"
|      | | | |-- 1:7-27 HFP-11 "J/L7/6F/SD27/ELECT RM SD JW"
|      | | | |-- 1:7-28 HFP-11 "J/L7/6F/SD28/CORR NR JW 6060"
|      | | | |-- 1:7-29 HFP-11 "J/L7/6F/SD29/CORR NR JW6010AFC"
|      | | | |-- 1:7-30 HFP-11 "J/L7/6F/SD30/CORR NR JW 6010"
|      | | | |-- 1:7-31 HTRI-R "J/L7/6F/CM31/DR RELEASE CM"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 1:7-32 HTRI-R "J/L7/6F/CM32/DR RELEASE CM"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:7 XDLC "XDLC @ address 7 L7"

			-- 1:7-33 HFP-11 "J/L7/6F/SD33/CORR NR JE 6170"
			-- 1:7-34 HFP-11 "J/L7/6F/SD34/CORR NR JE6170 AFC"
			-- 1:7-35 HFP-11 "J/L7/6F/SD35/CORR NR 7B S25"
			-- 1:7-36 HFP-11 "J/L7/6F/SD36/CORR NR 7B S25 AFC"
			-- 1:7-37 HFP-11 "J/L7/6F/SD37/AHU RM SD JE"
			-- 1:7-38 HTRI-R "J/L7/6F/CM38/AHU RM CM JE"
			-- Switch ""
			-- Relay
			-- 1:7-39 HFP-11 "J/L7/6F/SD39/CORR NR JE 6242"
			-- 1:7-40 HMS-S/D/M/SA "J/L7/6F/MCP40/FIRE ESC STR"
			-- 1:7-41 HTRI-R "J/L7/6F/CM41/FIRE ESC STR"
			-- Switch ""
			-- Relay
			-- 1:7-42 HTRI-S "J/L7/6F/MM42/FIRE ESC STR"
			-- 1:7-45 HFP-11 "J/L7/6F/SD45/CORR NR JE 6262"
			-- 1:7-43 HFP-11 "J/L7/6F/SD43/CORR NR JE 6252"
			-- 1:7-44 HFP-11 "J/L7/6F/SD44/CORR NR JE6252 AFC"
			-- 1:7-46 HFP-11 "J/L7/6F/SD46/CORR NR JE 6140"
			-- 1:7-47 HFP-11 "J/L7/6F/SD47/CORR NR JE6140 AFC"
			-- 1:7-48 HTRI-R "J/L7/6F/CM48/ELECT RM SD"
			-- Switch ""
			-- Relay
			-- 1:7-49 HFP-11 "J/L7/6F/SD49/ELECT RM SD JE"
			-- 1:7-50 HFP-11 "J/L7/6F/SD50/LIFT LOBBY SD"
			-- 1:7-54 HTRI-S "J/L7/JE/6F/MM54/Psg nr JE6100"
			-- 1:7-55 HTRI-S "J/L7/JE/6F/MM55/Psg nr JE6060"
			-- 1:7-56 HTRI-S "J/L7/JW/6F/MM56/Psg nr JW6160"
			-- 1:7-57 HTRI-S "J/L7/JW/6F/MM57/Psg nr JW6150"
			-- 1:7-58 HTRI-S "J/L7/JW/6F/MM58/Psg nr JW6140"
			-- 1:7-59 HTRI-S "J/L7/JW/6F/MM59/Psg nr JW6190"
			-- 1:7-60 HTRI-S "J/L7/JW/6F/MM60/Psg nr JW6130"
			-- 1:7-61 HTRI-S "J/L7/JW/6F/MM61/Psg nr JW6090"
			-- 1:7-62 HTRI-S "J/L7/JW/6F/MM62/Psg nr JW6080"
			-- 1:7-63 HTRI-S "J/L7/JW/6F/MM63/Psg nr JW6060"
			-- 1:7-64 HTRI-S "J/L7/JW/6F/MM64/Psg nr JW6050"
			-- 1:7-65 HTRI-S "J/L7/JW/6F/MM65/Psg nr JW6040"
			-- 1:7-66 HTRI-S "J/L7/JW/6F/MM66/Psg nr JW6030"
			-- 1:7-67 HTRI-S "J/L7/JW/6F/MM67/Psg nr JW6010"
			-- 1:7-68 HTRI-S "J/L7/JE/6F/MM68/Psg nr JE6210"
			-- 1:7-69 HTRI-S "J/L7/JE/6F/MM69/Psg nr JE6230"
			-- 1:7-70 HTRI-S "J/L7/JE/6F/MM70/Psg nr JE6241"
			-- 1:7-71 HTRI-S "J/L7/JE/6F/MM71/Psg nr JE6242"
			-- 1:7-72 HTRI-S "J/L7/JE/6F/MM72/Psg nr JE6140"
			-- 1:7-75 HFP-11 "J/L7/JE6010/SD75/Main Cab 1"
			-- 1:7-76 HFP-11 "J/L7/JE6010/SD76/Main Cab 2"
			-- 1:7-77 HFP-11 "J/L7/JE6010/SD77/Assorter cab"
			-- 1:7-78 HFP-11 "J/L7/JE6010/SD78/Entry Psg"
			-- 1:7-79 HTRI-R "J/L7/JE6010/CM79/Entry Psg"
			-- Switch ""
			-- Relay

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:7 XDLC "XDLC @ address 7 L7"

```
|      |      |      |-- 1:7-80 HMS-S/D/M/SA "J/L7/JE6010/MCP80/Entry Psg"
|      |      |      |-- 1:7-81 HFP-11 "J/L7/JE6030/SD81/Assorter cab"
|      |      |      |-- 1:7-82 HFP-11 "J/L7/JE6030/SD82/Psg nr Main cab"
|      |      |      |-- 1:7-83 HFPT-11 "J/L7/JE6030/HD83/Entry Psg"
|      |      |      |-- 1:7-84 HFP-11 "J/L7/JE6030/SD84/Main cab"
|      |      |      |-- 1:7-85 HTRI-R "J/L7/JE6030/CM85/Entry Psg "
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:7-86 HMS-S/D/M/SA "J/L7/JE6030/MCP86/Entry Psg "
|      |      |      |-- 1:7-87 HFP-11 "J/L7/JE6130/SD87/Cab 1"
|      |      |      |-- 1:7-88 HFP-11 "J/L7/JE6130/SD88/Cab 2"
|      |      |      |-- 1:7-89 HFP-11 "J/L7/JE6130/SD89/Cab 3"
|      |      |      |-- 1:7-90 HFP-11 "J/L7/JE6130/SD90/Entry Psg"
|      |      |      |-- 1:7-91 HTRI-R "J/L7/JE6130/CM91/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:7-92 HMS-S/D/M/SA "J/L7/JE6130/MCP92/Entry Psg"
|      |      |      |-- 1:7-93 HFP-11 "J/L7/JE6080/SD93/Cab 1"
|      |      |      |-- 1:7-94 HFP-11 "J/L7/JE6080/SD94/Cab 2"
|      |      |      |-- 1:7-95 HFP-11 "J/L7/JE6080/SD95/Assorter cab"
|      |      |      |-- 1:7-96 HFP-11 "J/L7/JE6080/SD96/Pantry"
|      |      |      |-- 1:7-97 HFP-11 "J/L7/JE6080/SD97/Psg nr Pantry"
|      |      |      |-- 1:7-98 HMS-S/D/M/SA "J/L7/JE6080/MCP98/Entry Psg"
|      |      |      |-- 1:7-99 HTRI-R "J/L7/JE6080/CM99/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:7-100 HFP-11 "J/L7/JW6170/SD100/Cab 1"
|      |      |      |-- 1:7-101 HFP-11 "J/L7/JW6170/SD101/Cab 2"
|      |      |      |-- 1:7-102 HFP-11 "J/L7/JW6170/SD102/Cab 3"
|      |      |      |-- 1:7-103 HFP-11 "J/L7/JW6170/SD103/Cab 4"
|      |      |      |-- 1:7-104 HFP-11 "J/L7/JW6170/SD104/Entry Psg"
|      |      |      |-- 1:7-105 HTRI-R "J/L7/JW6170/CM105/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:7-106 HMS-S/D/M/SA "J/L7/JW6170/MCP106/Entry Psg"
|      |      |      |-- 1:7-107 HFP-11 "J/L7/JW6120/SD107/Main cab"
|      |      |      |-- 1:7-108 HFP-11 "J/L7/JW6120/SD108/Pantry Psg"
|      |      |      |-- 1:7-109 HTRI-R "J/L7/JW6120/CM109/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:7-110 HMS-S/D/M/SA "J/L7/JW6120/MCP110/Entry Psg"
|      |      |      |-- 1:7-111 HFP-11 "J/L7/JW6100/SD111/Main cab"
|      |      |      |-- 1:7-112 HFP-11 "J/L7/JW6100/SD112/Entry Psg"
|      |      |      |-- 1:7-113 HTRI-R "J/L7/JW6100/CM113/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:7-114 HMS-S/D/M/SA "J/L7/JW6100/MCP114/Entry Psg"
|      |      |      |-- 1:7-115 HFP-11 "J/L7/JW6070/SD115/Cab 1"
|      |      |      |-- 1:7-116 HFP-11 "J/L7/JW6070/SD116/Cab 2"
|      |      |      |-- 1:7-117 HFP-11 "J/L7/JW6070/SD117/Psg nr Cab 2"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:7 XDLC "XDLC @ address 7 L7"

```
|      |      |      |-- 1:7-118 HFP-11 "J/L7/JW6070/SD118/Pantry Psg"
|      |      |      |-- 1:7-119 HTRI-R "J/L7/JW6070/CM119/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:7-120 HMS-S/D/M/SA "J/L7/JW6070/MCP120/Entry Psg"
|      |      |      |-- 1:7-121 HFP-11 "J/L7/JW6110/SD121/Main cab"
|      |      |      |-- 1:7-122 FDOT421 "J/L7/JW6110/SD122/Cab nr Pantry"
|      |      |      |-- 1:7-123 FDOT421 "J/L7/JW6110/SD123/Pantry"
|      |      |      |-- 1:7-124 HTRI-R "J/L7/JW6110/CM124/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:7-125 HMS-S/D/M/SA "J/L7/JW6110/MCP125/Entry Psg"
|      |      |      |-- 1:7-126 HFP-11 "J/L7/JE6040/SD126/Entry Psg"
|      |      |      |-- 1:7-127 HFP-11 "J/L7/JE6040/SD127/Accounts cab"
|      |      |      |-- 1:7-128 HFP-11 "J/L7/JE6040/SD128/Assorter cab"
|      |      |      |-- 1:7-129 HFP-11 "J/L7/JE6040/SD129/Main cab"
|      |      |      |-- 1:7-130 HTRI-R "J/L7/JE6040/CM130/Psg nr Entry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:7-131 HMS-S/D/M/SA "J/L7/JE6040/MCP131/Psg nr Entry"
|      |      |      |-- 1:7-132 HFP-11 "J/L7/JE6160/SD132/Accounts cab"
|      |      |      |-- 1:7-133 HFP-11 "J/L7/JE6160/SD133/Main cab"
|      |      |      |-- 1:7-134 HFP-11 "J/L7/JE6160/SD134/Assorter cab"
|      |      |      |-- 1:7-135 HFP-11 "J/L7/JE6160/SD135/Pantry"
|      |      |      |-- 1:7-136 HTRI-R "J/L7/JE6160/CM136/Psg nr Entry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:7-137 HMS-S/D/M/SA "J/L7/JE6160/MCP137/Psg nr Entry"
|      |      |      |-- 1:7-138 HFP-11 "J/L7/JE6261/SD138/Main cab"
|      |      |      |-- 1:7-139 HFP-11 "J/L7/JE6261/SD139/Entry Psg"
|      |      |      |-- 1:7-141 HTRI-R "J/L7/JE6261/CM141/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:7-140 HMS-S/D/M/SA "J/L7/JE6261/MCP140/Entry Psg"
|      |      |      |-- 1:7-142 HFP-11 "J/L7/JE6170/SD142/Accounts cab"
|      |      |      |-- 1:7-143 HFP-11 "J/L7/JE6170/SD143/Main cab"
|      |      |      |-- 1:7-144 HFP-11 "J/L7/JE6170/SD144/Assorter cab"
|      |      |      |-- 1:7-145 HFP-11 "J/L7/JE6170/SD145/Entry Psg"
|      |      |      |-- 1:7-146 HTRI-R "J/L7/JE6170/CM146/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:7-147 HMS-S/D/M/SA "J/L7/JE6170/MCP147/Entry dr Psg"
|      |      |      |-- 1:7-155 HFP-11 "J/L7/JE6090/SD155/Main cab 1"
|      |      |      |-- 1:7-156 HFP-11 "J/L7/JE6090/SD156/Main cab 2"
|      |      |      |-- 1:7-157 HFP-11 "J/L7/JE6090/SD157/Pantry Psg"
|      |      |      |-- 1:7-158 HTRI-R "J/L7/JE6090/CM158/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:7-159 HMS-S/D/M/SA "J/L7/JE6090/MCP159/Entry Psg"
|      |      |      |-- 1:7-160 HFP-11 "J/L7/JE6090/SD160/Entry Psg"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:7 XDLC "XDLC @ address 7 L7"

```
|      |      |      |-- 1:7-161 HFP-11 "J/L7/JE6200/SD161/Main cab "
```

```
|      |      |      |-- 1:7-162 HFP-11 "J/L7/JE6200/SD162/Assorter cab"
```

```
|      |      |      |-- 1:7-163 HFP-11 "J/L7/JE6200/SD163/Account cab"
```

```
|      |      |      |-- 1:7-164 HFP-11 "J/L7/JE6200/SD164/Psg nr acc.cab"
```

```
|      |      |      |-- 1:7-165 HFP-11 "J/L7/JE6200/SD165/Boss cab"
```

```
|      |      |      |-- 1:7-166 HFPT-11 "J/L7/JE6200/HD166/Pantry"
```

```
|      |      |      |-- 1:7-167 HTRI-R "J/L7/JE6200/CM167/AFC Entry Psg"
```

```
|      |      |      |      |-- Switch ""
```

```
|      |      |      |      |-- Relay
```

```
|      |      |      |-- 1:7-168 HMS-S/D/M/SA "J/L7/JE6200/MCP168/Entry Psg"
```

```
|      |      |      |-- 1:7-169 HFP-11 "J/L7/JE6180/SD169/Main cab "
```

```
|      |      |      |-- 1:7-170 HFPT-11 "J/L7/JE6180/HD170/Pantry entrysi"
```

```
|      |      |      |-- 1:7-171 HTRI-R "J/L7/JE6180/CM171/Entry dr psg"
```

```
|      |      |      |      |-- Switch ""
```

```
|      |      |      |      |-- Relay
```

```
|      |      |      |-- 1:7-172 HMS-S/D/M/SA "J/L7/JE6180/MCP172/Entry dr psg"
```

```
|      |      |      |-- 1:7-148 HTRI-S "J/L7/6F/MM148/Psg. Nr. JE 6190"
```

```
|      |      |      |-- 1:7-149 HTRI-S "J/L7/6F/MM149/Psg. Nr. JE 6252"
```

```
|      |      |      |-- 1:7-151 HTRI-S "J/L7/6F/MM151/Psg. Nr. JE 6270"
```

```
|      |      |      |-- 1:7-152 HTRI-S "J/L7/6F/MM152/Psg. Nr. JE 6280"
```

```
|      |      |      |-- 1:7-153 HTRI-S "J/L7/6F/MM153/Psg. Nr. JW 6020"
```

```
|      |      |      |-- 1:7-74 HTRI-S "J/L7/6F/MM74/Psg. Nr. JE 6120"
```

```
|      |      |      |-- 1:7-173 HFPT-11 "J/L7/JW6110/HD173/Pantry"
```

```
|      |      |      |-- 1:8 XDLC "XDLC @ address 8 L8"
```

```
|      |      |      |-- 1:8-1 HTRI-R "J/L8/7B/7F/CM1/DR RELESE CM"
```

```
|      |      |      |      |-- Switch ""
```

```
|      |      |      |      |-- Relay
```

```
|      |      |      |-- 1:8-2 HFP-11 "J/L8/7B/7F/SD2/CORR NR JE 7010"
```

```
|      |      |      |-- 1:8-3 HFP-11 "J/L8/7B/7F/SD3/CORR NR JE7010 AF"
```

```
|      |      |      |-- 1:8-4 HFP-11 "J/L8/7B/7F/SD4/CORR NR JE 7120"
```

```
|      |      |      |-- 1:8-5 HFP-11 "J/L8/7B/7F/SD5/CORR NR JE 7040"
```

```
|      |      |      |-- 1:8-6 HFP-11 "J/L8/7B/7F/SD6/CORR NR JE7040 AF"
```

```
|      |      |      |-- 1:8-7 HFP-11 "J/L8/7B/7F/SD7/CORR NR 7B S44"
```

```
|      |      |      |-- 1:8-8 HMS-S/D/M/SA "J/L8/7B/7F/MCP8/FIRE ESC STR"
```

```
|      |      |      |-- 1:8-9 HTRI-R "J/L8/7B/7F/CM9/FIRE ESC STR"
```

```
|      |      |      |      |-- Switch ""
```

```
|      |      |      |      |-- Relay
```

```
|      |      |      |-- 1:8-10 HTRI-S "J/L8/7B/7F/MM10/FIRE ESC STR"
```

```
|      |      |      |-- 1:8-11 HFP-11 "J/L8/7B/7F/SD11/CORR NR 7B S14"
```

```
|      |      |      |-- 1:8-12 HFP-11 "J/L8/7B/7F/SD12/CORR NR 7BS14 AF"
```

```
|      |      |      |-- 1:8-13 HFP-11 "J/L8/7B/7F/SD13/CORR NR JE 7070"
```

```
|      |      |      |-- 1:8-14 HFP-11 "J/L8/7B/7F/SD14/CORR NR AHU JW A"
```

```
|      |      |      |-- 1:8-15 HFP-11 "J/L8/7B/7F/SD15/CORR NR AHU"
```

```
|      |      |      |-- 1:8-16 HFP-11 "J/L8/7B/7F/SD16/AHU RM SD JW"
```

```
|      |      |      |-- 1:8-17 HTRI-R "J/L8/7B/7F/CM17/AHU RM CM JW"
```

```
|      |      |      |      |-- Switch ""
```

```
|      |      |      |      |-- Relay
```

```
|      |      |      |-- 1:8-18 HFP-11 "J/L8/7B/7F/SD18/CorrNr7B/S46JWAF"
```

```
|      |      |      |-- 1:8-19 HFP-11 "J/L8/7B/7F/SD19/CORR NR JW 7190"
```

```
|      |      |      |-- 1:8-20 HFP-11 "J/L8/7B/7F/SD20/CORR NR JW7180 A"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:8 XDLC "XDLC @ address 8 L8"
```

```
|      |      |  |-- 1:8-21 HTRI-R "J/L8/7B/7F/CM21/DR RELESE CM JW"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:8-22 HMS-S/D/M/SA "J/L8/7B/7F/MCP22/FIRE SHAFT L.L."
|      |      |  |-- 1:8-23 HTRI-R "J/L8/7B/7F/CM23/FIRE SHAFT L.L. "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:8-24 HTRI-S "J/L8/7B/7F/MM24/FIRE SHAFT L.L.J"
|      |      |  |-- 1:8-25 HFP-11 "J/L8/7B/7F/SD25/LIFT LOBBY SD JW"
|      |      |  |-- 1:8-26 HFP-11 "J/L8/7B/7F/SD26/JW ELECT RM SD"
|      |      |  |-- 1:8-27 HTRI-R "J/L8/7B/7F/CM27/DR RELESE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:8-28 HFP-11 "J/L8/7B/7F/SD28/CORR NR JW7140 A"
|      |      |  |-- 1:8-29 HFP-11 "J/L8/7B/7F/SD29/CORR NR JW 7140"
|      |      |  |-- 1:8-30 HFP-11 "J/L8/7B/7F/SD30/CORR NR JW 7B7/S"
|      |      |  |-- 1:8-31 HFP-11 "J/L8/7B/7F/SD31/CORR NR JW 7020"
|      |      |  |-- 1:8-32 HFP-11 "J/L8/7B/7F/SD32/CORR NR JW7040 A"
|      |      |  |-- 1:8-33 HFP-11 "J/L8/7B/7F/SD33/CORR NR JW7030"
|      |      |  |-- 1:8-34 HFP-11 "J/L8/7B/7F/SD34/CORR NR JW7040"
|      |      |  |-- 1:8-35 HFP-11 "J/L8/7B/7F/SD35/CORR NR 7B S35 A"
|      |      |  |-- 1:8-36 HFP-11 "J/L8/7B/7F/SD36/CORR NR 7B S27"
|      |      |  |-- 1:8-37 HFP-11 "J/L8/7B/7F/SD37/CORR NR JE7170AF"
|      |      |  |-- 1:8-38 HFP-11 "J/L8/7B/7F/SD38/CORR NR JE7170"
|      |      |  |-- 1:8-39 HFP-11 "J/L8/7B/7F/SD39/AHU RM SD JE"
|      |      |  |-- 1:8-40 HTRI-R "J/L8/7B/7F/CM40/AHU RM CM JE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:8-41 HFP-11 "J/L8/7B/7F/SD41/CORR NR WERWISE "
|      |      |  |-- 1:8-42 HMS-S/D/M/SA "J/L8/7B/7F/MCP42/FIRE ESC STR"
|      |      |  |-- 1:8-43 HTRI-R "J/L8/7B/7F/CM43/FIRE ESC STR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:8-44 HTRI-S "J/L8/7B/7F/MM44/FIRE ESC STR"
|      |      |  |-- 1:8-45 HFP-11 "J/L8/7B/7F/SD45/CORR NR JE 7190"
|      |      |  |-- 1:8-46 HFP-11 "J/L8/7B/7F/SD46/CORR NR JE7190 A"
|      |      |  |-- 1:8-47 HFP-11 "J/L8/7B/7F/SD47/CORR NR JE7140"
|      |      |  |-- 1:8-48 HFP-11 "J/L8/7B/7F/SD48/CORR NR JE 7210"
|      |      |  |-- 1:8-49 HFP-11 "J/L8/7B/7F/SD49/CORR NR JE7210 A"
|      |      |  |-- 1:8-50 HTRI-R "J/L8/7B/7F/CM50/DR RELESE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:8-51 HFP-11 "J/L8/7B/7F/SD51/JE ELECT RM SD"
|      |      |  |-- 1:8-52 HFP-11 "J/L8/7B/7F/SD52/LIFT LOBBY SD JE"
|      |      |  |-- 1:8-54 HTRI-S "J/L8/JE/7F/MM54/Psg nr JE7010"
|      |      |  |-- 1:8-55 HTRI-S "J/L8/JE/7F/MM55/Psg nr JE7120"
|      |      |  |-- 1:8-56 HTRI-S "J/L8/JE/7F/MM56/Psg nr JE7110"
|      |      |  |-- 1:8-57 HTRI-S "J/L8/JE/7F/MM57/Psg nr JE7040"
|      |      |  |-- 1:8-58 HTRI-S "J/L8/JE/7F/MM58/Psg nr JE7070"
|      |      |  |-- 1:8-59 HTRI-S "J/L8/JW/7F/MM59/Psg nr JW7220"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:8 XDLC "XDLC @ address 8 L8"

			-- 1:8-60	HTRI-S	"J/L8/JW/7F/MM60/Psg nr JW7210"
			-- 1:8-61	HTRI-S	"J/L8/JW/7F/MM61/Psg nr JW7180"
			-- 1:8-62	HTRI-S	"J/L8/JW/7F/MM62/Psg nr JW7160"
			-- 1:8-63	HTRI-S	"J/L8/JW/7F/MM63/Psg nr JW7140"
			-- 1:8-64	HTRI-S	"J/L8/JW/7F/MM64/Psg nr JW7130"
			-- 1:8-65	HTRI-S	"J/L8/JW/7F/MM65/Psg nr JW7020"
			-- 1:8-66	HTRI-S	"J/L8/JW/7F/MM66/Psg nr JW7100"
			-- 1:8-67	HTRI-S	"J/L8/JW/7F/MM67/Psg nr JW7090"
			-- 1:8-68	HTRI-S	"J/L8/JW/7F/MM68/Psg nr JW7040"
			-- 1:8-69	HTRI-S	"J/L8/JW/7F/MM69/Psg nr JW7080"
			-- 1:8-70	HTRI-S	"J/L8/JW/7F/MM70/Psg nr JW7060"
			-- 1:8-71	HTRI-S	"J/L8/JW/7F/MM71/Psg nr JE7190"
			-- 1:8-75	HFP-11	"J/L8/JE7020/SD75/Assorter cab"
			-- 1:8-76	HFP-11	"J/L8/JE7020/SD76/Main cab"
			-- 1:8-77	HFP-11	"J/L8/JE7020/SD77/Main cab"
			-- 1:8-78	HFP-11	"J/L8/JE7020/SD78/Entry Psg"
			-- 1:8-79	HFPT-11	"J/L8/JE7020/HD79/Pantry"
			-- 1:8-80	HTRI-R	"J/L8/JE7020/CM80/Entry Psg"
				-- Switch	" "
				-- Relay	
			-- 1:8-81	HMS-S/D/M/SA	"J/L8/JE7020/MCP81/Entry Psg"
			-- 1:8-82	HFP-11	"J/L8/JE7030/SD82/Account cab"
			-- 1:8-83	HFP-11	"J/L8/JE7030/SD83/Pantry"
			-- 1:8-84	HFP-11	"J/L8/JE7030/SD84/Main cab"
			-- 1:8-85	HFP-11	"J/L8/JE7030/SD85/Main cab"
			-- 1:8-86	HTRI-R	"J/L8/JE7030/CM86/Entry Psg"
				-- Switch	" "
				-- Relay	
			-- 1:8-87	HMS-S/D/M/SA	"J/L8/JE7030/MCP87/Entry Psg"
			-- 1:8-88	HFP-11	"J/L8/JE7030/SD88/AFC Main cab"
			-- 1:8-89	HFP-11	"J/L8/JE7050/SD89/Pantry psg"
			-- 1:8-90	HFP-11	"J/L8/JE7050/SD90/Main cab"
			-- 1:8-91	HFP-11	"J/L8/JE7050/SD91/Account cab"
			-- 1:8-92	HTRI-R	"J/L8/JE7050/CM92/Entry psg"
				-- Switch	" "
				-- Relay	
			-- 1:8-93	HMS-S/D/M/SA	"J/L8/JE7050/MCP93/Entry psg"
			-- 1:8-94	HFP-11	"J/L8/JE7060/SD94/Assorter cab"
			-- 1:8-95	HFP-11	"J/L8/JE7060/SD95/Main cab"
			-- 1:8-96	HFP-11	"J/L8/JE7060/SD96/Account cab"
			-- 1:8-97	HFP-11	"J/L8/JE7060/SD97/Pantry"
			-- 1:8-98	HTRI-R	"J/L8/JE7060/CM98/Entry door"
				-- Switch	" "
				-- Relay	
			-- 1:8-99	HMS-S/D/M/SA	"J/L8/JE7060/MCP99/Entry door"
			-- 1:8-100	HFP-11	"J/L8/JE7090/SD100/Main cab"
			-- 1:8-101	HFP-11	"J/L8/JE7090/SD101/Cab 1"
			-- 1:8-102	HFP-11	"J/L8/JE7090/SD102/Cab 2"
			-- 1:8-103	HFP-11	"J/L8/JE7090/SD103/Cab 3"
			-- 1:8-104	HFP-11	"J/L8/JE7090/SD104/Cab 4"

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:8 XDLC "XDLC @ address 8 L8"

```
|      |      |      |-- 1:8-105 HFP-11 "J/L8/JE7090/SD105/Pantry"
|      |      |      |-- 1:8-106 HFP-11 "J/L8/JE7090/SD106/Entry Psg"
|      |      |      |-- 1:8-107 HTRI-R "J/L8/JE7090/CM107/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-108 HMS-S/D/M/SA "J/L8/JE7090/MCP108/Entry Psg"
|      |      |      |-- 1:8-109 HFP-11 "J/L8/JW7200/SD109/Assorter cab"
|      |      |      |-- 1:8-110 HFP-11 "J/L8/JW7200/SD110/Main cab"
|      |      |      |-- 1:8-111 HFP-11 "J/L8/JW7200/SD111/Account cab"
|      |      |      |-- 1:8-112 HFP-11 "J/L8/JW7200/SD112/Pantry Psg"
|      |      |      |-- 1:8-113 HTRI-R "J/L8/JW7200/CM113/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-114 HMS-S/D/M/SA "J/L8/JW7200/MCP114/Entry Psg"
|      |      |      |-- 1:8-115 HFP-11 "J/L8/JW7170/SD115/cab 1"
|      |      |      |-- 1:8-116 HFP-11 "J/L8/JW7170/SD116/cab 2"
|      |      |      |-- 1:8-117 HFP-11 "J/L8/JW7170/SD117/cab 3"
|      |      |      |-- 1:8-118 HFPT-11 "J/L8/JW7170/HD118/Account cab"
|      |      |      |-- 1:8-119 HTRI-R "J/L8/JW7170/CM119/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-120 HMS-S/D/M/SA "J/L8/JW7170/MCP120/Entry Psg"
|      |      |      |-- 1:8-121 HFP-11 "J/L8/JE7170/SD121/Main cab"
|      |      |      |-- 1:8-122 HFP-11 "J/L8/JE7170/SD122/Cab 1"
|      |      |      |-- 1:8-123 HFP-11 "J/L8/JE7170/SD123/Cab 2"
|      |      |      |-- 1:8-124 HFP-11 "J/L8/JE7170/SD124/Cab 3"
|      |      |      |-- 1:8-125 HFP-11 "J/L8/JE7170/SD125/Cab 4"
|      |      |      |-- 1:8-126 HTRI-R "J/L8/JE7170/CM126/Entry Psg "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-127 HMS-S/D/M/SA "J/L8/JE7170/MCP127/Entry Psg "
|      |      |      |-- 1:8-128 HFP-11 "J/L8/JE7180/SD128/Account cab"
|      |      |      |-- 1:8-129 HFP-11 "J/L8/JE7180/SD129/Main cab"
|      |      |      |-- 1:8-130 HFP-11 "J/L8/JE7180/SD130/Assorter cab"
|      |      |      |-- 1:8-131 HFP-11 "J/L8/JE7180/SD131/Entry Psg"
|      |      |      |-- 1:8-132 HTRI-R "J/L8/JE7180/CM132/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-133 HMS-S/D/M/SA "J/L8/JE7180/MCP133/Entry Psg"
|      |      |      |-- 1:8-134 HFP-11 "J/L8/JE7160/SD134/Main cab"
|      |      |      |-- 1:8-135 HFP-11 "J/L8/JE7160/SD135/Account cab"
|      |      |      |-- 1:8-136 HFP-11 "J/L8/JE7160/SD136/Pantry Psg"
|      |      |      |-- 1:8-137 HTRI-R "J/L8/JE7160/CM137/Psg nr Entry"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-138 HMS-S/D/M/SA "J/L8/JE7160/MCP138/Psg nr Entry"
|      |      |      |-- 1:8-139 HFP-11 "J/L8/JW7030/SD139/Cab 1"
|      |      |      |-- 1:8-140 HFP-11 "J/L8/JW7030/SD140/Cab 2"
|      |      |      |-- 1:8-141 HFP-11 "J/L8/JW7030/SD141/Main cab"
|      |      |      |-- 1:8-142 HFP-11 "J/L8/JW7030/SD142/Entry Psg"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:8 XDLC "XDLC @ address 8 L8"

```
|      |      |      |-- 1:8-143 HTRI-R "J/L8/JW7030/CM143/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-144 HMS-S/D/M/SA "J/L8/JW7030/MCP144/Entry Psg"
|      |      |      |-- 1:8-145 HFP-11 "J/L8/JE7130/SD145/Samarpan Jewel"
|      |      |      |-- 1:8-146 HFP-11 "J/L8/JE7130/SD146/Sachin Jewels "
|      |      |      |-- 1:8-147 HFP-11 "J/L8/JE7130/SD147/Basant Jewels "
|      |      |      |-- 1:8-148 HFP-11 "J/L8/JE7130/SD148/Riya Jems"
|      |      |      |-- 1:8-149 HFP-11 "J/L8/JE7130/SD149/Psg nr basant "
|      |      |      |-- 1:8-150 HFP-11 "J/L8/JE7130/SD150/Entry dr Psg"
|      |      |      |-- 1:8-151 HTRI-R "J/L8/JE7130/CM151/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-152 HMS-S/D/M/SA "J/L8/JE7130/MCP152/Entry dr Psg"
|      |      |      |-- 1:8-153 HFP-11 "J/L8/JW7240/SD153/Main cab"
|      |      |      |-- 1:8-154 HFP-11 "J/L8/JW7240/SD154/Main cab"
|      |      |      |-- 1:8-155 HFP-11 "J/L8/JW7240/SD155/Assorter cab"
|      |      |      |-- 1:8-156 HFP-11 "J/L8/JW7240/SD156/Assorter cab"
|      |      |      |-- 1:8-157 HFP-11 "J/L8/JW7240/SD157/Pantry"
|      |      |      |-- 1:8-158 HFP-11 "J/L8/JW7240/SD158/Reception Psg"
|      |      |      |-- 1:8-159 HTRI-R "J/L8/JW7240/CM159/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-160 HMS-S/D/M/SA "J/L8/JW7240/MCP160/Entry dr Psg"
|      |      |      |-- 1:8-167 HFP-11 "J/L8/JE7050/SD167/Buyers cab"
|      |      |      |-- 1:8-161 HTRI-S "J/L8/7F/MM161/JW7110"
|      |      |      |-- 1:8-162 HTRI-S "J/L8/7F/MM162/JW7010"
|      |      |      |-- 1:8-163 HTRI-S "J/L8/7F/MM163/JE7210"
|      |      |      |-- 1:8-166 HTRI-S "J/L8/7F/MM166/JW7070"
|      |      |      |-- 1:8-171 HFP-11 "J/L8/JE7150/SD171/Account Cabin"
|      |      |      |-- 1:8-172 HFP-11 "J/L8/JE7150/SD172/Entry Psg."
|      |      |      |-- 1:8-173 HFP-11 "J/L8/JE7150/SD173/Assortor Cabin"
|      |      |      |-- 1:8-174 HFP-11 "J/L8/JE7150/SD174/Main Cabin"
|      |      |      |-- 1:8-175 HFP-11 "J/L8/JE7150/SD175/Assortor Cabin"
|      |      |      |-- 1:8-176 HTRI-R "J/L8/JE7150/CM176/Entry Psg. AFC"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:8-177 HMS-S/D/M/SA "J/L8/JE7150/MCP177/Entry Psg."
|      |      |      |-- 1:8-180 HFP-11 "J/L8/JE7180/SD180/Entry Psg"
|      |      |      |-- 1:8-181 HFPT-11 "J/L8/JE7180/SD181/Panty"
|      |      |      |-- 1:8-73 HTRI-S "J/L8/JW/7F/MM73/Psg nr JW7190"
|      |      |      |-- 1:8-178 HFPT-11 "J/L8/JW7030/HD178/PANTRY"
|      |      |      |-- 1:9 XDLC "XDLC @ address 9 L9"
|      |      |      |-- 1:9-1 HTRI-R "J/L9/7B/8F/CM1/DR RELESE CM JE"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:9-2 HFP-11 "J/L9/7B/8F/SD2/CORR NR JE8010 AF"
|      |      |      |-- 1:9-3 HFP-11 "J/L9/7B/8F/SD3/CORR NR JE 8010"
|      |      |      |-- 1:9-4 HFP-11 "J/L9/7B/8F/SD4/CORR NR JE 8200"
|      |      |      |-- 1:9-5 HFP-11 "J/L9/7B/8F/SD5/COR NR JE 8/S18 A"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:9 XDLC "XDLC @ address 9 L9"

			-- 1:9-6 HFP-11 "J/L9/7B/8F/SD6/CORR NR JE 8170"
			-- 1:9-7 HFP-11 "J/L9/7B/8F/SD7/CORR NR JE 8080"
			-- 1:9-8 HTRI-R "J/L9/7B/8F/CM8/FIRE ESC STR NR J"
			-- Switch ""
			-- Relay
			-- 1:9-9 HFP-11 "J/L9/7B/8F/SD9/CORR NR 7B S14"
			-- 1:9-10 HMS-S/D/M/SA "J/L9/7B/8F/MCP10/FIRE SHAFT L.L."
			-- 1:9-11 HTRI-S "J/L9/7B/8F/MM11/FIRE SHAFT L.L.J"
			-- 1:9-12 HFP-11 "J/L9/7B/8F/SD12/CORR NR JE 8110A"
			-- 1:9-13 HFP-11 "J/L9/7B/8F/SD13/CorNr JW7B8/S11A"
			-- 1:9-14 HFP-11 "J/L9/7B/8F/SD14/CORR NR JW 7B8/S"
			-- 1:9-15 HFP-11 "J/L9/7B/8F/SD15/CORR NR JW 8250"
			-- 1:9-16 HFP-11 "J/L9/7B/8F/SD16/AHU RM SD JW"
			-- 1:9-17 HTRI-R "J/L9/7B/8F/CM17/AHU RM CM JW"
			-- Switch ""
			-- Relay
			-- 1:9-18 HFP-11 "J/L9/7B/8F/SD18/CORR NR 7B S09 A"
			-- 1:9-19 HFP-11 "J/L9/7B/8F/SD19/CORR NR 7B S09"
			-- 1:9-20 HFP-11 "J/L9/7B/8F/SD20/CORR NR 7B S08"
			-- 1:9-21 HTRI-R "J/L9/7B/8F/CM21/DR RELESE CM "
			-- Switch ""
			-- Relay
			-- 1:9-22 HMS-S/D/M/SA "J/L9/7B/8F/MCP22/FIRE SHAFT L.L."
			-- 1:9-23 HTRI-R "J/L9/7B/8F/CM23/FIRE SHAFT L.L."
			-- Switch ""
			-- Relay
			-- 1:9-24 HTRI-S "J/L9/7B/8F/MM24/FIRE SHAFT L.L.J"
			-- 1:9-25 HFP-11 "J/L9/7B/8F/SD25/LIFT LOBBY SD"
			-- 1:9-26 HFP-11 "J/L9/7B/8F/SD26/JW ELECT RM SD"
			-- 1:9-27 HTRI-R "J/L9/7B/8F/CM27/DR RELESE CM"
			-- Switch ""
			-- Relay
			-- 1:9-28 HFP-11 "J/L9/7B/8F/SD28/CORR NR DR JW AF"
			-- 1:9-29 HFP-11 "J/L9/7B/8F/SD29/CORR NR DR JW"
			-- 1:9-30 HFP-11 "J/L9/7B/8F/SD30/CORR NR JW 8150"
			-- 1:9-31 HFP-11 "J/L9/7B/8F/SD31/CORR NR 7B/S49 A"
			-- 1:9-32 HFP-11 "J/L9/7B/8F/SD32/CORR NR 7B/S49"
			-- 1:9-33 HFP-11 "J/L9/7B/8F/SD33/CORR NR JW 8030"
			-- 1:9-34 HFP-11 "J/L9/7B/8F/SD34/CORR NR 7B S27 A"
			-- 1:9-35 HFP-11 "J/L9/7B/8F/SD35/CORR NR JE 8090"
			-- 1:9-36 HFP-11 "J/L9/7B/8F/SD36/CORR NR 7B S27"
			-- 1:9-37 HFP-11 "J/L9/7B/8F/SD37/CORR NR JE 8270"
			-- 1:9-38 HFP-11 "J/L9/7B/8F/SD38/CORR NR JE 8270A"
			-- 1:9-39 HFP-11 "J/L9/7B/8F/SD39/AHU RM SD JE"
			-- 1:9-40 HTRI-R "J/L9/7B/8F/CM40/AHU RM CM JE"
			-- Switch ""
			-- Relay
			-- 1:9-41 HFP-11 "J/L9/7B/8F/SD41/CORR NR AHU JE"
			-- 1:9-42 HMS-S/D/M/SA "J/L9/7B/8F/MCP42/FIRE SHAFT L.L."
			-- 1:9-43 HTRI-R "J/L9/7B/8F/CM43/FIRE SHAFT JE"


```
| | | Switch ""
| | | |-- Relay
| | | |-- 1:9-44 HTRI-S "J/L9/7B/8F/MM44/FIRE SHAFT JE"
| | | |-- 1:9-45 HFP-11 "J/L9/7B/8F/SD45/CORR NR JE 8320"
| | | |-- 1:9-46 HFP-11 "J/L9/7B/8F/SD46/CORR NR JE 8320A"
| | | |-- 1:9-47 HFP-11 "J/L9/7B/8F/SD47/CORR NR JE 8240/"
| | | |-- 1:9-48 HFP-11 "J/L9/7B/8F/SD48/CORR NR JE 8220"
| | | |-- 1:9-49 HFP-11 "J/L9/7B/8F/SD49/CORR NR JE8220 A"
| | | |-- 1:9-50 HTRI-R "J/L9/7B/8F/CM50/DR RELESE CM JE"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:9-51 HFP-11 "J/L9/7B/8F/SD51/JE ELECT RM SD"
| | | |-- 1:9-52 HFP-11 "J/L9/7B/8F/SD52/JE LIFT LOBBY SD"
| | | |-- 1:9-53 HFP-11 "J/L9/JW/9F/SD53/Psg AFCnr9010/B1"
| | | |-- 1:9-54 HFP-11 "J/L9/JW/9F/SD54/Psg BFC nr9010/B"
| | | |-- 1:9-55 HFP-11 "J/L9/JW/9F/SD55/Psg AFC nr9010/B"
| | | |-- 1:9-56 HFP-11 "J/L9/JW/9F/SD56/PsgBFCnr9010B10-"
| | | |-- 1:9-57 HFP-11 "J/L9/JW/9F/SD57/PsgAFCnr9010B16-"
| | | |-- 1:9-58 HFP-11 "J/L9/JW/9F/SD58/Psg BFC nr 9010/"
| | | |-- 1:9-59 HMS-S/D/M/SA "J/L9/JW/9F/MCP-59/Psg nr Fire st"
| | | |-- 1:9-60 HTRI-R "J/L9/JW/9F/CM-60/Psg AFC nr Fire"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 1:9-61 HTRI-S "J/L9/JW/9F/MM-61/Psg AFC nr Fire"
| | | |-- 1:9-62 HFP-11 "J/L9/JW/9F/SD62/Psg AFC nr 9010/"
| | | |-- 1:9-63 HFP-11 "J/L9/JW/9F/SD63/Psg BFC nr 9010/"
| | | |-- 1:9-64 HFP-11 "J/L9/JW/9F/SD64/Psg AFC nr 9010/"
| | | |-- 1:9-65 HFP-11 "J/L9/JW/9F/SD65/Psg BFC nr 9010/"
| | | |-- 1:9-66 HFP-11 "J/L9/JW/9F/SD66/Psg AFC nr 9010/"
| | | |-- 1:9-67 HFP-11 "J/L9/JW/9F/SD67/Psg BFC nr 9010/"
| | | |-- 1:9-68 HFP-11 "J/L9/JW/9F/SD68/Psg AFC nr 9010/"
| | | |-- 1:9-69 HFP-11 "J/L9/JW/9F/SD69/Psg BFC nr 9010/"
| | | |-- 1:9-70 HFP-11 "J/L9/JW/9F/SD70/Psg AFC nr 9010/"
| | | |-- 1:9-71 HFP-11 "J/L9/JW/9F/SD71/Psg BFC nr 9010/"
| | | |-- 1:9-72 HFP-11 "J/L9/JW/9F/SD72/Psg AFC nr 9010/"
| | | |-- 1:9-73 HTRI-S "J/L9/9F/MM73/JW9010/B15"
| | | |-- 1:9-75 HTRI-S "J/L9/JE/8F/MM75/Psg nr JE8190"
| | | |-- 1:9-76 HTRI-S "J/L9/JE/8F/MM76/Psg nr JE8040"
| | | |-- 1:9-77 HTRI-S "J/L9/JE/8F/MM77/Psg nr JE8050"
| | | |-- 1:9-78 HTRI-S "J/L9/JE/8F/MM78/Psg nr JE8090"
| | | |-- 1:9-79 HTRI-S "J/L9/JE/8F/MM79/Psg nr JE8100"
| | | |-- 1:9-80 HTRI-S "J/L9/JW/8F/MM80/Psg nr JW8280"
| | | |-- 1:9-81 HTRI-S "J/L9/JW/8F/MM81/Psg nr JW8290"
| | | |-- 1:9-82 HTRI-S "J/L9/JW/8F/MM82/Psg nr JW8170"
| | | |-- 1:9-83 HTRI-S "J/L9/JW/8F/MM83/Psg nr JW8130"
| | | |-- 1:9-84 HTRI-S "J/L9/JW/8F/MM84/Psg nr JW8020"
| | | |-- 1:9-85 HTRI-S "J/L9/JW/8F/MM85/Psg nr JW8100"
| | | |-- 1:9-86 HTRI-S "J/L9/JW/8F/MM86/Psg nr JW8030"
| | | |-- 1:9-87 HTRI-S "J/L9/JW/8F/MM87/Psg nr JW8040"
| | | |-- 1:9-88 HTRI-S "J/L9/JW/8F/MM88/Psg nr JW8060"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:9 XDLC "XDLC @ address 9 L9"
```

```
|      |      |  |-- 1:9-89 HTRI-S "J/L9/JE/8F/MM89/Psg nr JE8320"
|      |      |  |-- 1:9-90 HTRI-S "J/L9/JE/8F/MM90/Psg nr JE8330"
|      |      |  |-- 1:9-91 HTRI-S "J/L9/JE/8F/MM91/Psg nr JE8220"
|      |      |  |-- 1:9-94 HFP-11 "J/L9/JE8130/SD94/Main cab"
|      |      |  |-- 1:9-95 HFP-11 "J/L9/JE8130/SD95/Accounts cab"
|      |      |  |-- 1:9-96 HFP-11 "J/L9/JE8130/SD96/Entry Psg"
|      |      |  |-- 1:9-97 HMS-S/D/M/SA "J/L9/JE8130/MCP97/Entry Psg"
|      |      |  |-- 1:9-98 HTRI-R "J/L9/JE8130/CM98/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:9-99 HFP-11 "J/L9/JE8160/SD99/Main cab"
|      |      |  |-- 1:9-100 HFP-11 "J/L9/JE8160/SD100/Entry Psg"
|      |      |  |-- 1:9-101 HTRI-R "J/L9/JE8160/CM101/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:9-102 HMS-S/D/M/SA "J/L9/JE8160/MCP102/Entry Psg"
|      |      |  |-- 1:9-104 HTRI-S "J/L9/JE/9F/MM104/Psg nr JW9010B\"
|      |      |  |-- 1:9-105 HTRI-S "J/L9/JE/9F/MM105/Psg nr JW9010B\"
|      |      |  |-- 1:9-106 HTRI-S "J/L9/JE/9F/MM106/Psg nr JW9010B\"
|      |      |  |-- 1:9-107 HTRI-S "J/L9/JE/9F/MM107/Psg nr JW9010B\"
|      |      |  |-- 1:9-108 HTRI-S "J/L9/JE/9F/MM108/Psg nr JW9010B\"
|      |      |  |-- 1:9-109 HFP-11 "J/L9/JE8170/SD109/Main cab"
|      |      |  |-- 1:9-110 HFP-11 "J/L9/JE8170/SD110/Account cab"
|      |      |  |-- 1:9-111 HFP-11 "J/L9/JE8170/SD111/Psg nr Pantry"
|      |      |  |-- 1:9-112 HTRI-R "J/L9/JE8170/CM112/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:9-113 HMS-S/D/M/SA "J/L9/JE8170/MCP113/Entry dr Psg"
|      |      |  |-- 1:9-114 HFP-11 "J/L9/JE8120/SD114/Main cab"
|      |      |  |-- 1:9-115 HFP-11 "J/L9/JE8120/SD115/Account cab"
|      |      |  |-- 1:9-116 HFP-11 "J/L9/JE8120/SD116/Assorter cab"
|      |      |  |-- 1:9-117 HFP-11 "J/L9/JE8120/SD117/Pantry"
|      |      |  |-- 1:9-118 HTRI-R "J/L9/JE8120/CM118/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:9-119 HMS-S/D/M/SA "J/L9/JE8120/MCP119/Entry dr Psg"
|      |      |  |-- 1:9-120 HFP-11 "J/L9/JE8210/SD120/Main cab"
|      |      |  |-- 1:9-121 HFP-11 "J/L9/JE8210/SD121/Entry dr Psg "
|      |      |  |-- 1:9-122 HTRI-R "J/L9/JE8210/CM122/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:9-123 HMS-S/D/M/SA "J/L9/JE8210/MCP123/Entry dr Psg"
|      |      |  |-- 1:9-124 HFP-11 "J/L9/JE8260/SD124/Main cab"
|      |      |  |-- 1:9-125 HFP-11 "J/L9/JE8260/SD125/Assorter cab"
|      |      |  |-- 1:9-126 HFP-11 "J/L9/JE8260/SD126/Entry Psg"
|      |      |  |-- 1:9-127 HFP-11 "J/L9/JE8260/SD127/Entry Psg"
|      |      |  |-- 1:9-128 HTRI-R "J/L9/JE8260/CM128/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:9-129 HMS-S/D/M/SA "J/L9/JE8260/MCP129/Entry Psg"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:9 XDLC "XDLC @ address 9 L9"
```

```
|      |      |  |-- 1:9-130 HFP-11 "J/L9/JE8280/SD130/Assorter cab"
|      |      |  |-- 1:9-131 HFP-11 "J/L9/JE8280/SD131/Account cab"
|      |      |  |-- 1:9-132 HFP-11 "J/L9/JE8280/SD132/Sales cab"
|      |      |  |-- 1:9-133 HFP-11 "J/L9/JE8280/SD133/Psg nr Entry"
|      |      |  |-- 1:9-134 HTRI-R "J/L9/JE8280/CM134/Psg nr Entry"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:9-135 HMS-S/D/M/SA "J/L9/JE8280/MCP135/Psg nr Entry"
|      |      |  |-- 1:9-136 HFP-11 "J/L9/JW8080/SD136/Cab 1"
|      |      |  |-- 1:9-137 HFP-11 "J/L9/JW8080/SD137/Cab 2"
|      |      |  |-- 1:9-138 HFP-11 "J/L9/JW8080/SD138/Cab 3"
|      |      |  |-- 1:9-139 HFP-11 "J/L9/JW8080/SD139/Pantry"
|      |      |  |-- 1:9-140 HFP-11 "J/L9/JW8080/SD140/Entry Psg"
|      |      |  |-- 1:9-141 HMS-S/D/M/SA "J/L9/JW8080/MCP141/Entry Psg"
|      |      |  |-- 1:9-142 HTRI-R "J/L9/JW8080/CM142/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:9-143 HFP-11 "J/L9/JE8350/SD143/Main cab"
|      |      |  |-- 1:9-144 HFP-11 "J/L9/JE8350/SD144/Entry Psg"
|      |      |  |-- 1:9-145 HTRI-R "J/L9/JE8350/CM145/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:9-146 HMS-S/D/M/SA "J/L9/JE8350/MCP146/Entry Psg"
|      |      |  |-- 1:9-147 HFP-11 "J/L9/JW8110/SD147/Entry Psg"
|      |      |  |-- 1:9-148 HFP-11 "J/L9/JW8110/SD148/Cab 1"
|      |      |  |-- 1:9-149 HFP-11 "J/L9/JW8110/SD149/Cab 2"
|      |      |  |-- 1:9-150 HFP-11 "J/L9/JW8110/SD150/Account cab"
|      |      |  |-- 1:9-151 HTRI-R "J/L9/JW8110/CM151/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:9-152 HMS-S/D/M/SA "J/L9/JW8110/MCP152/Entry Psg"
|      |      |  |-- 1:9-153 HFP-11 "J/L9/JE8340/SD153/Main cab"
|      |      |  |-- 1:9-154 HFP-11 "J/L9/JE8340/SD154/Accounts cab"
|      |      |  |-- 1:9-155 HFP-11 "J/L9/JE8340/SD155/Entry Psg"
|      |      |  |-- 1:9-156 HTRI-R "J/L9/JE8340/CM156/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:9-157 HMS-S/D/M/SA "J/L9/JE8340/MCP157/Entry Psg"
|      |      |  |-- 1:9-158 HFP-11 "J/L9/JW8120/SD158/Cab 1"
|      |      |  |-- 1:9-159 HFP-11 "J/L9/JW8120/SD159/Cab 2"
|      |      |  |-- 1:9-160 HFP-11 "J/L9/JW8120/SD160/Cab 3"
|      |      |  |-- 1:9-161 HFP-11 "J/L9/JW8120/SD161/Pantry Psg"
|      |      |  |-- 1:9-162 HTRI-R "J/L9/JW8120/CM162/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:9-163 HMS-S/D/M/SA "J/L9/JW8120/MCP163/Entry Psg"
|      |      |  |-- 1:9-164 HFP-11 "J/L9/JW8150/SD164/Main cab"
|      |      |  |-- 1:9-165 HFP-11 "J/L9/JW8150/SD165/Account cab"
|      |      |  |-- 1:9-166 HFP-11 "J/L9/JW8150/SD166/Entry Psg"
|      |      |  |-- 1:9-167 HTRI-R "J/L9/JW8150/CM167/Entry Psg"
```

```
| | | | Switch ""
| | | | -- Relay
| | | | -- 1:9-168 HMS-S/D/M/SA "J/L9/JW8150/MCP168/Entry Psg"
| | | | -- 1:9-169 HFP-11 "J/L9/JW8160/SD169/Main cab"
| | | | -- 1:9-170 HFP-11 "J/L9/JW8160/SD170/Psg Main cab"
| | | | -- 1:9-171 HFP-11 "J/L9/JW8160/SD171/Assorter cab"
| | | | -- 1:9-172 HFP-11 "J/L9/JW8160/SD172/Pantry Psg"
| | | | -- 1:9-173 HTRI-R "J/L9/JW8160/CM173/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:9-174 HMS-S/D/M/SA "J/L9/JW8160/MCP174/Entry Psg"
| | | | -- 1:9-175 HFP-11 "J/L9/JW8210/SD175/Main cab"
| | | | -- 1:9-176 HFP-11 "J/L9/JW8210/SD176/Assorter cab"
| | | | -- 1:9-177 HFP-11 "J/L9/JW8210/SD177/Entry Psg"
| | | | -- 1:9-178 HTRI-R "J/L9/JW8210/CM178/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:9-179 HMS-S/D/M/SA "J/L9/JW8210/MCP179/Entry Psg"
| | | | -- 1:9-180 HFP-11 "J/L9/JW8070/SD180/Main cab"
| | | | -- 1:9-181 HFP-11 "J/L9/JW8070/SD181/Pantry"
| | | | -- 1:9-182 HTRI-R "J/L9/JW8070/CM182/Entry dr Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:9-183 HMS-S/D/M/SA "J/L9/JW8070/MCP183/Entry dr Psg"
| | | | -- 1:9-184 HTRI-S "J/L9/JE/9F/MM184/PsgNr JW9010A-7"
| | | | -- 1:9-185 HTRI-S "J/L9/JE/9F/MM185/Psg nr JW9010\A"
| | | | -- 1:9-186 HTRI-S "J/L9/JE/9F/MM186/Psg nr JW9010\A"
| | | | -- 1:9-191 HTRI-S "J/L9/9F/MM191/JW9010 A8"
| | | | -- 1:9-230 HFP-11 "J/L9/JE8020/SD230/Main cab 1"
| | | | -- 1:9-231 HFP-11 "J/L9/JE8020/SD231/Main cab 2"
| | | | -- 1:9-232 HFP-11 "J/L9/JE8020/SD232/Entry Psg"
| | | | -- 1:9-233 HTRI-R "J/L9/JE8020/CM233/AFC Pantry "
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:9-234 HMS-S/D/M/SA "J/L9/JE8020/MCP234/Main Entry"
| | | | -- 1:9-235 HFP-11 "J/L9/JW8190/SD235/Main cab 1"
| | | | -- 1:9-236 HFP-11 "J/L9/JW8190/SD236/Main cab 2"
| | | | -- 1:9-237 HFP-11 "J/L9/JW8190/SD237/Assorter cab"
| | | | -- 1:9-238 HFP-11 "J/L9/JW8190/SD238/Entry Psg"
| | | | -- 1:9-239 HFP-11 "J/L9/JW8190/SD239/Pantry rm"
| | | | -- 1:9-240 HTRI-R "J/L9/JW8190/CM240/AFC Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:9-241 HMS-S/D/M/SA "J/L9/JW8190/MCP241/Entry Psg"
| | | | -- 1:9-242 HTRI-S "J/L9/9F/MM242/JE9010A"
| | | | -- 1:9-243 HFP-11 "J/L9/JW8200/SD243/Assorter cab "
| | | | -- 1:9-244 HFP-11 "J/L9/JW8200/SD244/Main cab "
```

```
| | | | | Switch ""
| | | | | Relay
| | | | | -- 1:9-188 HTRI-S "J/L9/9F/MM188/JW9010 A4"
| | | | | -- 1:9-189 HTRI-S "J/L9/9F/MM189/JW9010 A5"
| | | | | -- 1:9-190 HTRI-S "J/L9/9F/MM190/JW9010 A6"
| | | | | -- 1:9-192 HTRI-S "J/L9/9F/MM192/JW9010 B"
| | | | | -- 1:9-193 HTRI-S "J/L9/9F/MM193/JW9010 B5"
| | | | | -- 1:9-194 HTRI-S "J/L9/9F/MM194/JW9010 B6"
| | | | | -- 1:9-195 HTRI-S "J/L9/9F/MM195/JW9010 B8"
| | | | | -- 1:9-196 HTRI-S "J/L9/9F/MM196/JW9010 B9"
| | | | | -- 1:9-197 HTRI-S "J/L9/9F/MM197/JW9010 B13"
| | | | | -- 1:9-198 HTRI-S "J/L9/8F/MM198/JW8270"
| | | | | -- 1:9-201 HTRI-S "J/L9/9F/MM201/JW9010 A9"
| | | | | -- 1:9-209 HTRI-S "J/L9/9F/MM209/JW9010 B10-12"
| | | | | -- 1:9-211 HTRI-S "J/L9/8F/MM211/JE8010"
| | | | | -- 1:9-212 HTRI-S "J/L9/8F/MM212/JE8030"
| | | | | -- 1:9-213 HTRI-S "J/L9/8F/MM213/JE8060"
| | | | | -- 1:9-214 HTRI-S "J/L9/8F/MM214/JE8110"
| | | | | -- 1:9-215 HTRI-S "J/L9/8F/MM215/JE8140"
| | | | | -- 1:9-217 HTRI-S "J/L9/8F/MM217/JE8200"
| | | | | -- 1:9-220 HTRI-S "J/L9/8F/MM220/JE8270"
| | | | | -- 1:9-221 HTRI-S "J/L9/8F/MM221/JE8290"
| | | | | -- 1:9-222 HTRI-S "J/L9/8F/MM222/JE8300"
| | | | | -- 1:9-224 HTRI-S "J/L9/8F/MM224/JW8090"
| | | | | -- 1:9-225 HTRI-S "J/L9/8F/MM225/JW8140"
| | | | | -- 1:9-226 HTRI-S "J/L9/8F/MM226/JW8010"
| | | | | -- 1:9-227 HTRI-S "J/L9/8F/MM227/JW8220"
| | | | | -- 1:9-228 HTRI-S "J/L9/8F/MM228/JW8260"
| | | | | -- 1:9-202 HFP-11 "J/L9/JE8180/SD202/MAIN CABIN"
| | | | | -- 1:9-203 HFP-11 "J/L9/JE8180/SD203/ACCOUNT CABIN"
| | | | | -- 1:9-204 HFP-11 "J/L9/JE8180/SD204/ENTRY PSG"
| | | | | -- 1:9-205 HFP-11 "J/L9/JE8180/SD205/PANTRY"
| | | | | -- 1:9-206 HTRI-R "J/L9/JE8180/CM206/ENTRY PSG AFC"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | | -- 1:9-207 HMS-S/D/M/SA "J/L9/JE8180/MCP207/ENTRY PSG"
| | | | | -- 1:9-248 HFP-11 "J/L9/JW8070/SD248/Account Cabin"
| | | | | -- 1:9-249 HFP-11 "J/L9/JW8070/SD249/Entry Psg."
| | | | | -- 1:9-250 HFP-11 "J/L9/JE8340/SD250/MAIN CABIN AFC"
| | | | | -- 1:9-251 HFP-11 "J/L9/JE8340/SD251/MAIN CABIN AFC"
| | | | | -- 1:9-92 HTRI-S "J/L9/8F/MM92/JE8310"
| | | | | -- 1:9-199 HFP-11 "J/L9/JW8230/SD199/Main Cab"
| | | | | -- 1:9-200 HFP-11 "J/L9/JW8230/SD200/Account Cab"
| | | | | -- 1:9-208 HFP-11 "J/L9/JW8230/SD208/Account Cab1"
| | | | | -- 1:9-210 HFP-11 "J/L9/JW8230/SD210/Account Cab2"
| | | | | -- 1:9-216 HFPT-11 "J/L9/JW8230/SD216/Pantry"
| | | | | -- 1:9-218 HTRI-R "J/L9/JW8230/MCP218/ENTRY PSG AFC"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | | -- 1:9-219 HMS-S/D/M/SA "J/L9/JW8230/MCP219/PANTRY PS
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
```

```
|      | |-- 1:10 NIC-C(XNet) "NIC_Xnet @ address 10"
|      | |-- 1:249 PSC-12 "PSC-12 @ address 249"
|      | |-- 1:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      | |-- 1:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      | |-- Inner Door
|      | |-- 1:253 PMI-D "PMI-D Tower J -10"
|-- 11 Desigo Fire Safety Modular "BDB DC-2" Local
| |-- System Flags
| |-- History Log
| |-- Behavior
| |-- Voice
| |-- Maintenance
| |-- Field Devices
| |-- Miscellaneous
| |-- CAB-1 "CAB-1 Enclosure #1"
|     |-- CC-5 "Card Cage 5 Slots"
|     | |-- 11:1 DLC "DLC @ address 1"
|     | | |-- 11:1-1 HTRI-R "DC2/L1/CM1/GSS/Z1"
|     | | | |-- Switch ""
|     | | | |-- Relay
|     | | |-- 11:1-2 HTRI-R "DC2/L1/CM1/GSS/Z2"
|     | | | |-- Switch ""
|     | | | |-- Relay
|     | | |-- 11:1-3 HFP-11 "DC2/L1/SD 3/SERVER RM/BFF"
|     | | |-- 11:1-4 HFP-11 "DC2/L1/SD 4/SERVER RM/BFF"
|     | | |-- 11:1-5 HFP-11 "DC2/L1/SD 5/SERVER RM/BFF"
|     | | |-- 11:1-6 HFP-11 "DC2/L1/SD 6/SERVER RM/BFF"
|     | | |-- 11:1-7 HFP-11 "DC2/L1/SD 7/NOC RM/BFF"
|     | | |-- 11:1-8 HFP-11 "DC2/L1/SD 8/ELECTRICAL RM/BFF"
|     | | |-- 11:1-9 HFP-11 "DC2/L1/SD 9/ELECTRICAL RM/BFF"
|     | | |-- 11:1-10 HTRI-S "DC2/L1/MM 10/BUILDING FAS INPUT"
|     | | |-- 11:1-11 HTRI-S "DC2/L1/MM 11/VESDA INPUT"
|     | | |-- 11:1-12 HFP-11 "DC2/L2/SD 12/SERVER RM"
|     | | |-- 11:1-13 HTRI-R "DC2/L2/CM 13/SERVER RM HOOTER"
|     | | | |-- Switch ""
|     | | | |-- Relay
|     | | |-- 11:1-14 HMS-S/D/M/SA "DC2/L2/MCP14/SER RM/NR FIRE EXIT"
|     | | |-- 11:1-15 HFP-11 "DC2/L2/SD 15/SERVER RM"
|     | | |-- 11:1-16 HFP-11 "DC2/L2/SD 16/SERVER RM"
|     | | |-- 11:1-17 HFP-11 "DC2/L2/SD 17/SERVER RM"
|     | | |-- 11:1-18 HFP-11 "DC2/L2/SD 18/NOC RM"
|     | | |-- 11:1-19 HFP-11 "DC2/L2/SD 19/ELECTRICAL RM"
|     | | |-- 11:1-20 HFP-11 "DC2/L2/SD 20/ELECTRICAL RM"
|     | | |-- 11:1-21 HFP-11 "DC2/L2/SD 21/NR MAIN ENTRANCE"
|     | | |-- 11:1-22 HTRI-R "DC2/L1/CM 22/ FAS INPUT TO BUILD"
|     | | | |-- Switch ""
|     | | | |-- Relay
|     | |-- 11:2 NIC-C(XNet) "NIC_Xnet @ address 2"
|     |-- 11:249 PSC-12 "PSC-12 @ address 249"
|     | |-- 11:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
```