

Project

```
|-- Global System Flags
|-- 12 Management Station "Management System @ address12"
|-- 1 Desigo Fire Safety Modular "BDB TOWER J" Local
|   |-- System Flags
|   |-- History Log
|   |-- Behavior
|   |-- Voice
|   |-- Maintenance
|   |-- Field Devices
|   |-- Miscellaneous
|   |-- CAB-2 "CAB-2 Enclosure #1"
|       |-- CC-5 "Card Cage 5 Slots"
|           |-- 1:1 DLC "DLC @ address 1 L1"
|               |-- 1:1-5 HFP-11 "J/L1/EC/GND/SD5/SECURITY CABIN"
|               |-- 1:1-6 HFP-11 "J/L1/EC/GND/SD6/LIFT LOBY"
|               |-- 1:1-7 HFP-11 "J/L1/EC/GND/SD7/LIFT LOBY"
|               |-- 1:1-8 HFP-11 "J/L1/EC/GND/SD8/LIFT LOBY"
|               |-- 1:1-15 HFP-11 "J/L1/WC/GND/SD15/SECURITY CABIN"
|               |-- 1:1-16 HFP-11 "J/L1/WC/GND/SD16/LIFT LOBY"
|               |-- 1:1-17 HFP-11 "J/L1/WC/GND/SD17/LIFT LOBY"
|               |-- 1:1-18 HFP-11 "J/L1/WC/GND/SD18/LIFT LOBY"
|               |-- 1:1-42 HFP-11 "J/L1/J-DTC/SD-42/Cab 25"
|               |-- 1:1-43 HFP-11 "J/L1/J-DTC/SD-43/Cab 26"
|               |-- 1:1-44 HFP-11 "J/L1/J-DTC/SD-44/Cab 27"
|               |-- 1:1-45 HFP-11 "J/L1/J-DTC/SD-45/Cab 28"
|               |-- 1:1-46 HFP-11 "J/L1/J-DTC/SD-46/Cab 29"
|               |-- 1:1-47 HFP-11 "J/L1/J-DTC/SD-47/Cab 30"
|               |-- 1:1-48 HFP-11 "J/L1/J-DTC/SD-48/Cab 31"
|               |-- 1:1-49 HFP-11 "J/L1/J-DTC/SD-49/Cab 32"
|               |-- 1:1-50 HFP-11 "J/L1/J-DTC/SD-50/Cab 33"
|               |-- 1:1-51 HFP-11 "J/L1/J-DTC/SD-51/Cab 34"
|               |-- 1:1-52 HFP-11 "J/L1/J-DTC/SD-52/Cab 35"
|               |-- 1:1-53 HFP-11 "J/L1/J-DTC/SD-53/Cab 36"
|               |-- 1:1-54 HFP-11 "J/L1/J-DTC/SD-54/Cab 37"
|               |-- 1:1-55 HFP-11 "J/L1/J-DTC/SD-55/Cab 38"
|               |-- 1:1-56 HFP-11 "J/L1/J-DTC/SD-56/Cab 39"
|               |-- 1:1-57 HFP-11 "J/L1/J-DTC/SD-57/Cab 40"
|               |-- 1:1-58 HFP-11 "J/L1/J-DTC/SD-58/Cab 41"
|               |-- 1:1-59 HFP-11 "J/L1/J-DTC/SD-59/Cab 42"
|               |-- 1:1-60 HFP-11 "J/L1/J-DTC/SD-60/Cab 43"
|               |-- 1:1-61 HFP-11 "J/L1/J-DTC/SD-61/Cab 44"
|               |-- 1:1-62 HFP-11 "J/L1/J-DTC/SD-62/Cab 45"
|               |-- 1:1-63 HFP-11 "J/L1/J-DTC/SD-63/Cab 46"
|               |-- 1:1-64 HFP-11 "J/L1/J-DTC/SD-64/Cab 47"
|               |-- 1:1-65 HFP-11 "J/L1/J-DTC/SD-65/Cab 48"
|               |-- 1:1-66 HFP-11 "J/L1/J-DTC/SD-66/Cab 49"
|               |-- 1:1-67 HFP-11 "J/L1/J-DTC/SD-67/Cab 50"
|               |-- 1:1-68 HFP-11 "J/L1/J-DTC/SD-68/Cab 51"
|               |-- 1:1-71 HFP-11 "J/L1/J-DTC/SD-71/Cab 54"
|               |-- 1:1-72 HFP-11 "J/L1/J-DTC/SD-72/Cab 55"
|               |-- 1:1-73 HFP-11 "J/L1/J-DTC/SD-73/Cab 56"
|               |-- 1:1-74 FDOT421 "J/L1/J-DTC/SD-74/Reception Area"
|               |-- 1:1-79 HFP-11 "J/L1/J-DTC/SD-79/Psg near Cab 25"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:1 DLC "DLC @ address 1 L1"

				--	1:1-80	HFP-11	"J/L1/J-DTC/SD-80/Psg near Cab 27"
				--	1:1-81	HFP-11	"J/L1/J-DTC/SD-81/Psg near Cab 29"
				--	1:1-83	FDOT421	"J/L1/J-DTC/SD-83/Psg near Cab 32"
				--	1:1-84	FDOT421	"J/L1/J-DTC/SD-84/Psg near Cab 34"
				--	1:1-85	FDOT421	"J/LJ-DTC/SD-85/Psg NRCab38"
				--	1:1-86	FDOT421	"J/L1/J-DTC/SD-86/Psg NRserver"
				--	1:1-87	FDOT421	"J/L1/J-DTC/SD-87/Psg NRCab44"
				--	1:1-88	FDOT421	"J/L1/J-DTC/SD-88/Psg NRFireE"
				--	1:1-89	FDOT421	"J/L1/J-DTC/SD-89/Psg NRCab50"
				--	1:1-90	FDOT421	"J/L1/J-DTC/SD-90/Psg NRElectr"
				--	1:1-91	FDOT421	"J/L1/J-DTC/SD-91/Psg NRCab53"
				--	1:1-93	FDOT421	"J/L1/J-DTC/SD-93/Electrical Room"
				--	1:1-94	FDOT421	"J/L1/J-DTC/SD-94/Server Room"
				--	1:1-100	HMS-S/D/M/SA	"J/L1/JDTC/MCP100/psg near cab 25"
				--	1:1-101	HMS-S/D/M/SA	"J/L1/JDTC/MCP101/psg near cab 32"
				--	1:1-102	HMS-S/D/M/SA	"J/L1/J-DTC/MCP-102/psg near Elec"
				--	1:1-103	HTRI-S	"H/L1/WC/UB/MM103/ELEC ROOM"
				--	1:1-104	HTRI-S	"H/L1/WC/UB/MM104/LIFT MC RM"
				--	1:1-105	HTRI-R	"H/L1/WC/UB/CM105/STAIRCASE"
					--	Switch	" "
					--	Relay	
				--	1:1-106	HMS-S/D/M/SA	"H/L1/WC/UB/MCP106/STAIRCASE"
				--	1:1-107	HMS-S/D/M/SA	"H/L1/CC/UB/MCP107/STAIRCASE"
				--	1:1-108	HTRI-R	"H/L1/CC/UB/CM108/STAIRCASE"
					--	Switch	" "
					--	Relay	
				--	1:1-109	HTRI-S	"H/L1/EC/UB/MM109/ELEC ROOM"
				--	1:1-110	HTRI-S	"H/L1/EC/UB/MM110/LIFT MC RM"
				--	1:1-111	HTRI-S	"J/L1/EC/UB/MM111/ELEC RM"
				--	1:1-116	HMS-S/D/M/SA	"J/L1/WC/UB/MCP116/STAIRCASE HE E"
				--	1:1-117	HTRI-R	"J/L1/WC/UB/CM117/STAIRCASE HE EX"
					--	Switch	" "
					--	Relay	
				--	1:1-118	HTRI-R	"J/L1/WC/UB/CM118/STAIRCASE JE CO"
					--	Switch	" "
					--	Relay	
				--	1:1-119	HMS-S/D/M/SA	"J/L1/WC/UB/MCP119/STAIRCASE JE C"
				--	1:1-121	HMS-S/D/M/SA	"J/L1/EC/UB/MCP121/STAIRCASE CUST"
				--	1:1-122	HTRI-R	"J/L1/EC/UB/CM122/STAIRCASE CUSTO"
					--	Switch	" "
					--	Relay	
				--	1:1-123	HTRI-S	"J/L1/EC/UB/MM123/ELEC ROOM"
				--	1:1-124	HFP-11	"H/L1/WC/UB/SD124/ELEC ROOM"
				--	1:1-125	HFP-11	"H/L1/WC/UB/SD125/LIFT MC RM"
				--	1:1-127	HFP-11	"H/L1/EC/UB/SD127/ELEC ROOM"
				--	1:1-128	HFP-11	"H/L1/EC/UB/SD128/LIFT MC RM"
				--	1:1-131	HFP-11	"H/L1/EC/UB/SD131/ELEC RM"
				--	1:1-135	HFP-11	"J/L1/EC/UB/SD135/ELEC RM"
				--	1:1-136	HFP-11	"J/L1/EC/UB/SD136/BMS ROOM"
				--	1:1-137	HMS-S/D/M/SA	"J/L1/J-DTC/MCP137/Psg Nr cab49 "

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:1 DLC "DLC @ address 1 L1"
```

```
|      |      |      | 1:1-138 HTRI-R "J/L1/JW/GND/CM-138/electr Room"
|      |      |      |      | 1:1-139 Switch ""
|      |      |      |      | 1:1-140 Relay
|      |      |      | 1:1-139 HMS-S/D/M/SA "J/L1/J-DTC/MCP-139/psg near recp"
|      |      |      | 1:1-140 HMS-S/D/M/SA "J/L1/J-DTC/MCP140/Psg Nr cab41 "
|      |      |      | 1:1-164 HFP-11 "J/L1/J-DTC/SD-164/AFC Cab 17"
|      |      |      | 1:1-165 HFP-11 "J/L1/J-DTC/SD-165/AFC Cab 18"
|      |      |      | 1:1-166 HFP-11 "J/L1/J-DTC/SD-166/AFC Cab 19"
|      |      |      | 1:1-167 HFP-11 "J/L1/J-DTC/SD-167/AFC Cab 20"
|      |      |      | 1:1-168 HFP-11 "J/L1/J-DTC/SD-168/AFC Cab 21"
|      |      |      | 1:1-169 HFP-11 "J/L1/J-DTC/SD-169/AFC Cab 22"
|      |      |      | 1:1-170 HFP-11 "J/L1/J-DTC/SD-170/AFC Cab 23"
|      |      |      | 1:1-171 HFP-11 "J/L1/J-DTC/SD-171/AFC Cab 24"
|      |      |      | 1:1-172 HFP-11 "J/L1/J-DTC/SD-172/AFC Cab 25"
|      |      |      | 1:1-173 HFP-11 "J/L1/J-DTC/SD-173/AFC Cab 26"
|      |      |      | 1:1-174 HFP-11 "J/L1/J-DTC/SD-174/AFC Cab 27"
|      |      |      | 1:1-175 HFP-11 "J/L1/J-DTC/SD-175/AFC Cab 28"
|      |      |      | 1:1-176 HFP-11 "J/L1/J-DTC/SD-176/AFC Cab 29"
|      |      |      | 1:1-177 HFP-11 "J/L1/J-DTC/SD-177/AFC Cab 30"
|      |      |      | 1:1-178 HFP-11 "J/L1/J-DTC/SD-178/AFC Cab 31"
|      |      |      | 1:1-179 HFP-11 "J/L1/J-DTC/SD-179/AFC Cab 32"
|      |      |      | 1:1-180 HFP-11 "J/L1/J-DTC/SD-180/AFC Cab 3"
|      |      |      | 1:1-181 HFP-11 "J/L1/J-DTC/SD-181/AFC Cab 34"
|      |      |      | 1:1-182 HFP-11 "J/L1/J-DTC/SD-182/AFC Cab 35"
|      |      |      | 1:1-183 HFP-11 "J/L1/J-DTC/SD-183/AFC Cab 36"
|      |      |      | 1:1-184 HFP-11 "J/L1/J-DTC/SD-184/AFC Cab 37"
|      |      |      | 1:1-185 HFP-11 "J/L1/J-DTC/SD-185/AFC Cab 38"
|      |      |      | 1:1-186 HFP-11 "J/L1/J-DTC/SD-186/AFC Cab 39"
|      |      |      | 1:1-187 HFP-11 "J/L1/J-DTC/SD-187/AFC Cab 40"
|      |      |      | 1:1-188 HFP-11 "J/L1/J-DTC/SD-188/AFC Cab 41"
|      |      |      | 1:1-189 HFP-11 "J/L1/J-DTC/SD-189/AFC Cab 42"
|      |      |      | 1:1-190 HFP-11 "J/L1/J-DTC/SD-190/AFC Cab 43"
|      |      |      | 1:1-193 HFP-11 "J/L1/J-DTC/SD-193/AFC Cab 46"
|      |      |      | 1:1-194 HFP-11 "J/L1/J-DTC/SD-194/AFC Cab 47"
|      |      |      | 1:1-195 HFP-11 "J/L1/J-DTC/SD-195/AFC Cab 48"
|      |      |      | 1:1-196 HFP-11 "J/L1/J-DTC/SD-196/AFC Cab 49"
|      |      |      | 1:1-201 HFP-11 "J/L1/J-DTC/SD-201/AFC Cab 54"
|      |      |      | 1:1-202 HFP-11 "J/L1/J-DTC/SD-202/AFC Cab 55"
|      |      |      | 1:1-203 HFP-11 "J/L1/J-DTC/SD-203/AFC Cab 56"
|      |      |      | 1:1-204 FDOT421 "J/L1/J-DTC/SD-204/AFC at Recepti"
|      |      |      | 1:1-205 HFP-11 "J/L1/J-DTC/SD-205/Psg AFC near C"
|      |      |      | 1:1-206 FDOT421 "J/L1/J-DTC/SD-206/Psg AFC NR C"
|      |      |      | 1:1-207 HFP-11 "J/L1/J-DTC/SD-207/Psg AFC near C"
|      |      |      | 1:1-208 HFP-11 "J/L1/J-DTC/SD-208/Psg AFC near C"
|      |      |      | 1:1-209 HFP-11 "J/L1/J-DTC/SD-209/Psg AFC near C"
|      |      |      | 1:1-210 FDOT421 "J/L1/JDTC/SD210/PsgAFCnearCabi47"
|      |      |      | 1:1-211 HFP-11 "J/L1/JDTC/SD211/PsgAFCnearCabi50"
|      |      |      | 1:1-212 HFP-11 "J/L1/J-DTC/SD-212/Psg AFC near C"
|      |      |      | 1:1-213 HFP-11 "J/L1/J-DTC/SD-213/Psg AFC near C"
|      |      |      | 1:1-214 FDOT421 "J/L1/GF/Custom/SD214/AFC desk 12"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:1 DLC "DLC @ address 1 L1"

				--	1:1-215	FDOT421	"J/L1/GF/Custom/SD215/AFC Server"
				--	1:1-216	FDOT421	"J/L1/GF/Custom/SD216/AFC desk 10"
				--	1:1-217	FDOT421	"J/L1/GF/Custom/SD217/AFC Psg nr"
				--	1:1-218	FDOT421	"J/L1/GF/Custom/SD218/AFC desk 4"
				--	1:1-219	FDOT421	"J/L1/GF/Custom/SD219/AFC Psg nr"
				--	1:1-220	FDOT421	"J/L1/GF/Custom/SD220/AFC desk 1"
				--	1:1-221	FDOT421	"J/L1/GF/Custom/SD221/Psg nr serv"
				--	1:1-222	FDOT421	"J/L1/GF/Custom/SD222/PsgNrDesk11"
				--	1:1-223	FDOT421	"J/L1/GF/Custom/SD223/PsgNrDesk17"
				--	1:1-224	FDOT421	"J/L1/GF/Custom/SD224/Psg desk 9"
				--	1:1-225	FDOT421	"J/L1/GF/Custom/SD225/Psg desk 19"
				--	1:1-226	FDOT421	"J/L1/GF/Custom/SD226/PsgNrDesk8"
				--	1:1-227	FDOT421	"J/L1/GF/Custom/SD227/PsgNrDesk29"
				--	1:1-228	FDOT421	"J/L1/GF/Custom/SD228/Psg desk 5"
				--	1:1-229	FDOT421	"J/L1/GF/Custom/SD229/Psg nr wash"
				--	1:1-230	FDOT421	"J/L1/GF/Custom/SD230/Psg desk 4"
				--	1:1-231	FDOT421	"J/L1/GF/Custom/SD231/Psg desk 2"
				--	1:1-232	FDOT421	"J/L1/GF/Cust/SD232/Cab nr Back E"
				--	1:1-233	FDOT421	"J/L1/GF/Cust/SD233/Psg nrNw C Bk"
				--	1:1-234	HTRI-R	"J/L1/GF/Custom/CM234/Psg nr nw C"
				--		Switch	" "
				--		Relay	
				--	1:1-235	HMS-S/D/M/SA	"J/L1/GF/Custom/MCP235/Psg nr nw "
				--	1:2	DLC	"DLC @ address 2 L2"
				--	1:2-1	HTRI-R	"J/L2/7B/1F/CM1/LIFT LOBBY CM NR "
				--		Switch	" "
				--		Relay	
				--	1:2-2	HFP-11	"J/L2/7B/1F/SD2/CORR NR JE 1010"
				--	1:2-3	HFP-11	"J/L2/7B/1F/SD3/CORR NR 7B S18"
				--	1:2-4	HFP-11	"J/L2/7B/1F/SD4/CORR NR JE 1030"
				--	1:2-5	HFP-11	"J/L2/7B/1F/SD5/CORR NR JE 1030 A"
				--	1:2-6	HFP-11	"J/L2/7B/1F/SD6/CORR NR JE 1050"
				--	1:2-7	HFP-11	"J/L2/7B/1F/SD7/CORR NR 7B S14"
				--	1:2-8	HFP-11	"J/L2/7B/1F/SD8/CORR NR 7B S14 AF"
				--	1:2-9	HMS-S/D/M/SA	"J/L2/7B/1F/MCP9/FIRE ESC STR"
				--	1:2-10	HTRI-R	"J/L2/7B/1F/CM10/FIRE ESC STR"
				--		Switch	" "
				--		Relay	
				--	1:2-11	HTRI-S	"J/L2/7B/1F/MM11/FIRE ESC STR"
				--	1:2-12	HFP-11	"J/L2/7B/1F/SD12/CORR NR 7B S11"
				--	1:2-13	HFP-11	"J/L2/7B/1F/SD13/CORR NR 7B S11 A"
				--	1:2-14	HFP-11	"J/L2/7B/1F/SD14/CORR NR JE 1150"
				--	1:2-15	HFP-11	"J/L2/7B/1F/SD15/AHU RM SD"
				--	1:2-16	HTRI-R	"J/L2/7B/1F/CM16/AHU RM CM"
				--		Switch	" "
				--		Relay	
				--	1:2-17	HFP-11	"J/L2/7B/1F/SD17/CORR NR JW1210 A"
				--	1:2-18	HFP-11	"J/L2/7B/1F/SD18/CORR NR JW 1210 "
				--	1:2-19	HFP-11	"J/L2/JW1200/SD19/PANTRY"
				--	1:2-20	HMS-S/D/M/SA	"J/L2/7B/1F/MCP20/FIRE SHAFT L.L."

```
| | | | 1:2-21 HTRI-R "J/L2/7B/1F/CM21/FIRE SHAFT L.L."
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 1:2-22 HTRI-S "J/L2/7B/1F/MM22/FIRE SHAFT L.L."
| | | | |-- 1:2-23 HFP-11 "J/L2/7B/1F/SD23/LIFT LOBBY SD"
| | | | |-- 1:2-24 HFP-11 "J/L2/7B/1F/SD24/ELECT RM SD"
| | | | |-- 1:2-25 HFP-11 "J/L2/7B/1F/SD25/CORR NR JW 1030 "
| | | | |-- 1:2-26 HFP-11 "J/L2/7B/1F/SD26/CORR NR JW 1030"
| | | | |-- 1:2-27 HFP-11 "J/L2/JW1200/SD27/Main Cab"
| | | | |-- 1:2-28 HFP-11 "J/L2/JW1200/SD28/Assortor cab"
| | | | |-- 1:2-29 HFP-11 "J/L2/7B/1F/SD29/CORR NR 7B S28 A"
| | | | |-- 1:2-30 HFP-11 "J/L2/7B/1F/SD30/CORR NR 7B S 28"
| | | | |-- 1:2-31 HFP-11 "J/L2/7B/1F/SD31/CORR NR JE 1250"
| | | | |-- 1:2-32 HFP-11 "J/L2/7B/1F/SD32/CORR NR JE1280 A"
| | | | |-- 1:2-33 HFP-11 "J/L2/7B/1F/SD33/CORR NR JE 7B S3"
| | | | |-- 1:2-34 HFP-11 "J/L2/7B/1F/SD34/CORR NR JE 7B S3"
| | | | |-- 1:2-35 HFP-11 "J/L2/7B/1F/SD35/AHU RM NR 7B S37"
| | | | |-- 1:2-36 HTRI-R "J/L2/7B/1F/CM36/AHU RM 7B S37"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 1:2-37 HMS-S/D/M/SA "J/L2/7B/1F/MCP37/FIRE SHAFT L.L."
| | | | |-- 1:2-38 HTRI-S "J/L2/7B/1F/MM38/FIRE SHAFT L.L."
| | | | |-- 1:2-39 HTRI-R "J/L2/7B/1F/CM39/FIRE SHAFT L.L."
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 1:2-40 HFP-11 "J/L2/7B/1F/SD40/CORR NR JE 1300"
| | | | |-- 1:2-41 HFP-11 "J/L2/7B/1F/SD41/CORR NR JE1300 A"
| | | | |-- 1:2-42 HFP-11 "J/L2/7B/1F/SD42/CORR NR JE 1330"
| | | | |-- 1:2-43 HFP-11 "J/L2/7B/1F/SD43/CORR NR JE1200 A"
| | | | |-- 1:2-44 HFP-11 "J/L2/7B/1F/SD44/CORR NR JE 1200"
| | | | |-- 1:2-45 HFP-11 "J/L2/JW1200/SD45/Entry Psg"
| | | | |-- 1:2-46 HFP-11 "J/L2/7B/1F/SD46/ELECT RM SD"
| | | | |-- 1:2-47 HFP-11 "J/L2/7B/1F/SD47/LIFT LOBBY SD"
| | | | |-- 1:2-48 HFP-11 "J/L2/7B/1F/SD48/LIFT LOBBY SD"
| | | | |-- 1:2-49 HTRI-R "J/L2/JW1200/CM49/Entry Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 1:2-50 HFP-11 "J/L2/JW1120/SD50/Main cab"
| | | | |-- 1:2-51 HFP-11 "J/L2/JW1120/SD51/Assorter cab"
| | | | |-- 1:2-52 HFPT-11 "J/L2/JW1120/HD52/Pantry"
| | | | |-- 1:2-53 HTRI-R "J/L2/JW1120/CM53/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 1:2-54 HMS-S/D/M/SA "J/L2/JW1120/MCP54/Psg nr Entry"
| | | | |-- 1:2-55 FDOT421 "J/L2/GF/Custom/SD55/Pag Nr EDI C"
| | | | |-- 1:2-56 FDOT421 "J/L2/GF/Custom/SD56/Waiting Area"
| | | | |-- 1:2-57 FDOT421 "J/L2/GF/Custom/SD57/Waiting Area"
| | | | |-- 1:2-58 FDOT421 "J/L2/GF/Custom/SD58/Waiting Area"
| | | | |-- 1:2-59 FDOT421 "J/L2/GF/Custom/SD59/Waiting Area"
| | | | |-- 1:2-60 FDOT421 "J/L2/GF/Custom/SD60/Waiting Area"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:2 DLC "DLC @ address 2 L2"
```

```
|      |      |  |-- 1:2-61 FDOT421 "J/L2/GF/Custom/SD61/Waiting Area"
|      |      |  |-- 1:2-62 FDOT421 "J/L2/GF/Custom/SD62/Waiting Are"
|      |      |  |-- 1:2-63 FDOT421 "J/L2/GF/Custom/SD63/Waiting Area"
|      |      |  |-- 1:2-64 FDOT421 "J/L2/GF/Custom/SD64/Cash Counter"
|      |      |  |-- 1:2-65 FDOT421 "J/L2/GF/Custom/SD65/Kioss Machin"
|      |      |  |-- 1:2-66 FDOT421 "J/L2/GF/Custom/SD66/Parcel Depos"
|      |      |  |-- 1:2-67 FDOT421 "J/L2/GF/Custom/SD67/Parcel Depos"
|      |      |  |-- 1:2-68 FDOT421 "J/L2/GF/Custom/SD68/Parcel Depos"
|      |      |  |-- 1:2-69 FDOT421 "J/L2/GF/Custom/SD69/GJ EPC Cabin"
|      |      |  |-- 1:2-70 FDOT421 "J/L2/GF/Custom/SD70/Psg nr Wash "
|      |      |  |-- 1:2-71 FDOT421 "J/L2/GF/Custom/SD71/Psg nrWash R"
|      |      |  |-- 1:2-72 HMS-S/D/M/SA "J/L2/GF/Custom/MCP72/Parcel Depo"
|      |      |  |-- 1:2-73 HMS-S/D/M/SA "J/L2/GF/Custom/MCP73/Waiting Are"
|      |      |  |-- 1:2-74 HMS-S/D/M/SA "J/L2/GF/Custom/MCP74/Entry Psg"
|      |      |  |-- 1:2-75 HTRI-S "J/L2/GF/Custom/MM75/EDI Center "
|      |      |  |-- 1:2-76 HMS-S/D/M/SA "J/L2/GF/Custom/MCP76/Psg Nr Ladi"
|      |      |  |-- 1:2-77 FDOT421 "J/L2/GF/Custom/SD77/Psg Nr Wash "
|      |      |  |-- 1:2-78 HTRI-R "J/L2/GF/Custom/CM78/Waiting Area"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-79 HTRI-R "J/L2/GF/Custom/CM79/Parcel Depos"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-81 HTRI-S "J/L2/1F/MM82/JE1250"
|      |      |  |-- 1:2-93 FDOT421 "J/L2/GF/Custom/SD93/Pantry Area"
|      |      |  |-- 1:2-94 FDOT421 "J/L2/GF/Custom/SD94/BVC Ltd"
|      |      |  |-- 1:2-95 FDOT421 "J/L2/GF/Custom/SD95/New Server R"
|      |      |  |-- 1:2-96 HMS-S/D/M/SA "/L2/GF/Custom/MCP96/Nr Commision"
|      |      |  |-- 1:2-97 FDOT421 "J/L2/GF/Custom/SD97/Psg nr Dep.C"
|      |      |  |-- 1:2-98 FDOT421 "J/L2/GF/Custom/SD98/Dep.Commissi"
|      |      |  |-- 1:2-99 FDOT421 "J/L2/GF/Custom/SD99/Psg nr Lisce"
|      |      |  |-- 1:2-100 FDOT421 "J/L2/GF/Custom/SD100/Liscense rm"
|      |      |  |-- 1:2-101 FDOT421 "J/L2/GF/Custom/SD101/Liscense rm"
|      |      |  |-- 1:2-102 FDOT421 "J/L2/GF/Custom/SD102/Liscense rm"
|      |      |  |-- 1:2-103 HTRI-S "J/L2/GF/Custom/MM103/Psg nr Lisc"
|      |      |  |-- 1:2-104 HTRI-R "J/L2/GF/Custom/CM104/Psg nr Lisc"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-105 HMS-S/D/M/SA "J/L2/GF/Custom/MCP105/Psg nr Lis"
|      |      |  |-- 1:2-106 FDOT421 "J/L2/GF/Custom/SD106/Reception"
|      |      |  |-- 1:2-107 FDOT421 "J/L2/GF/Custom/SD107/Parcel Coll"
|      |      |  |-- 1:2-108 FDOT421 "J/L2/GF/Custom/SD108/Parcel Coll"
|      |      |  |-- 1:2-109 HFP-11 "J/L2/GF/Custom/SD109/Table 21"
|      |      |  |-- 1:2-110 FDOT421 "J/L2/GF/Custom/SD110/Commissione"
|      |      |  |-- 1:2-111 FDOT421 "J/L2/GF/Custom/SD111/Commissione"
|      |      |  |-- 1:2-112 FDOT421 "J/L2/GF/Custom/SD112/Vinay Singh"
|      |      |  |-- 1:2-113 FDOT421 "J/L2/GF/Custom/SD113/Vinay Singh"
|      |      |  |-- 1:2-114 HMS-S/D/M/SA "J/L2/GF/Custom/MCP114/Export cab"
|      |      |  |-- 1:2-115 FDOT421 "J/L2/GF/Custom/SD115/Export Tabl"
|      |      |  |-- 1:2-116 FDOT421 "J/L2/GF/Custom/SD116/Export Tabl"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:2 DLC "DLC @ address 2 L2"

```
|      |      |  |-- 1:2-117 FDOT421 "J/L2/GF/Custom/SD117/BDB stock r"
|      |      |  |-- 1:2-118 HFP-11 "J/L2/GF/Custom/SD118/Brinks area"
|      |      |  |-- 1:2-119 FDOT421 "J/L2/GF/Custom/SD119/Brinks area"
|      |      |  |-- 1:2-120 FDOT421 "J/L2/GF/Custom/SD120/Malca Amit"
|      |      |  |-- 1:2-121 HMS-S/D/M/SA "J/L2/GF/Custom/MCP121/Malca Amit"
|      |      |  |-- 1:2-122 FDOT421 "J/L2/GF/Custom/SD122/Gomes cab"
|      |      |  |-- 1:2-123 FDOT421 "J/L2/GF/Custom/SD123/MMTC cab"
|      |      |  |-- 1:2-124 FDOT421 "J/L2/GF/Custom/SD124/Custodian A"
|      |      |  |-- 1:2-125 FDOT421 "J/L2/GF/Custom/SD125/Custodian A"
|      |      |  |-- 1:2-126 HMS-S/D/M/SA "J/L2/GF/Custom/MCP126/Custodian "
|      |      |  |-- 1:2-127 FDOT421 "J/L2/GF/Custom/SD127/Conference"
|      |      |  |-- 1:2-128 FDOT421 "J/L2/GF/Custom/SD128/Conference"
|      |      |  |-- 1:2-129 FDOT421 "J/L2/GF/Custom/SD129/Conference"
|      |      |  |-- 1:2-130 FDOT421 "J/L2/GF/Custom/SD130/Server rm"
|      |      |  |-- 1:2-131 FDOT421 "J/L2/GF/Custom/SD131/Server rm"
|      |      |  |-- 1:2-132 HTRI-R "J/L2/GF/Custom/CM132/Psg nr Serv"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-133 FDOT421 "J/L2/GF/Custom/SD133/Psg nr CHA"
|      |      |  |-- 1:2-134 FDOT421 "J/L2/GF/Custom/SD134/CHA cab"
|      |      |  |-- 1:2-135 FDOT421 "J/L2/GF/Custom/SD135/Table 13"
|      |      |  |-- 1:2-136 FDOT421 "J/L2/GF/Custom/SD136/Table 15"
|      |      |  |-- 1:2-137 FDOT421 "J/L2/GF/Custom/SD137/Table 7"
|      |      |  |-- 1:2-138 FDOT421 "J/L2/GF/Custom/SD138/Table 17"
|      |      |  |-- 1:2-139 HMS-S/D/M/SA "J/L2/GF/Custom/MCP139/Psg nr Tab"
|      |      |  |-- 1:2-140 FDOT421 "J/L2/GF/Custom/SD140/Table 21"
|      |      |  |-- 1:2-141 FDOT421 "J/L2/GF/Custom/SD141/Table 24"
|      |      |  |-- 1:2-142 FDOT421 "J/L2/GF/Custom/SD142/Table 27"
|      |      |  |-- 1:2-143 HMS-S/D/M/SA "J/L2/GF/Custom/MCP143/Custom Ent"
|      |      |  |-- 1:2-144 HFP-11 "J/L2/GF/Custom/SD144/Custom Entr"
|      |      |  |-- 1:2-145 FDOT421 "J/L2/GF/Custom/SD145/BKFF Pvt Lt"
|      |      |  |-- 1:2-146 FDOT421 "J/L2/GF/Custom/SD146/Psg nr Sequ"
|      |      |  |-- 1:2-147 FDOT421 "J/L2/GF/Custom/SD147/Sequel Log"
|      |      |  |-- 1:2-148 HFP-11 "J/L2/GF/Cus/SD148/Psg nr BVchena"
|      |      |  |-- 1:2-149 HTRI-S "J/L2/1F/MM149/JE1260"
|      |      |  |-- 1:2-150 HTRI-S "J/L2/JE1170/SD150/Psg nr JE1020"
|      |      |  |-- 1:2-151 HFP-11 "J/L2/JE1010/SD151/Assorter cab1"
|      |      |  |-- 1:2-152 HFP-11 "J/L2/JE1010/SD152/Main cab"
|      |      |  |-- 1:2-153 HFP-11 "J/L2/JE1010/SD153/Assorter cab2"
|      |      |  |-- 1:2-154 HFP-11 "J/L2/JE1010/SD154/Pantry"
|      |      |  |-- 1:2-155 HTRI-R "J/L2/JE1010/CM155/Psg nr Entry"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-156 HMS-S/D/M/SA "J/L2/JE1010/MCP156/Psg nr Entry"
|      |      |  |-- 1:2-157 HFP-11 "J/L2/JE1170/SD157/Psg nr Entry"
|      |      |  |-- 1:2-158 HFP-11 "J/L2/JE1170/SD158/Main cab"
|      |      |  |-- 1:2-159 HFP-11 "J/L2/JE1170/SD159/Assorter cab"
|      |      |  |-- 1:2-160 HTRI-R "J/L2/JE1170/CM160/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:2 DLC "DLC @ address 2 L2"
```

```
|      |      |  |-- 1:2-161 HMS-S/D/M/SA "J/L2/JE1170/MCP161/Entry dr Psg"
|      |      |  |-- 1:2-162 HFP-11 "J/L2/JE1040/SD162/Assorter cab"
|      |      |  |-- 1:2-163 HFP-11 "J/L2/JE1040/SD163/Main cab1"
|      |      |  |-- 1:2-164 HFP-11 "J/L2/JE1040/SD164/Main cab2"
|      |      |  |-- 1:2-165 HFP-11 "J/L2/JE1040/SD165/Waiting rm"
|      |      |  |-- 1:2-166 HTRI-R "J/L2/JE1040/CM166/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-167 HMS-S/D/M/SA "J/L2/JE1040/MCP167/Entry dr Psg"
|      |      |  |-- 1:2-168 HFP-11 "J/L2/JW1110/SD168/Entry Psg"
|      |      |  |-- 1:2-169 HFP-11 "J/L2/JW1110/SD169/Entry Psg"
|      |      |  |-- 1:2-170 HTRI-R "J/L2/JW1110/CM170/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-171 HMS-S/D/M/SA "J/L2/JW1110/MCP171/Entry Psg"
|      |      |  |-- 1:2-172 HFP-11 "J/L2/JE1180/SD172/Main cab"
|      |      |  |-- 1:2-173 HFP-11 "J/L2/JE1180/SD173/Assorter cab"
|      |      |  |-- 1:2-174 HFP-11 "J/L2/JE1180/SD174/Entry Psg"
|      |      |  |-- 1:2-175 HTRI-R "J/L2/JE1180/CM175/AFC Entry psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-176 HMS-S/D/M/SA "J/JL2/JE1180/MCP176/Pantry"
|      |      |  |-- 1:2-177 HFP-11 "J/L2/JE1100/SD177/AFC Entry psg"
|      |      |  |-- 1:2-178 HFP-11 "J/L2/JE1100/SD178/Main cab"
|      |      |  |-- 1:2-179 HFP-11 "J/L2/JE1100/SD179/Assorter cab"
|      |      |  |-- 1:2-180 HFP-11 "J/L2/JE1100/SD180/Entry Psg"
|      |      |  |-- 1:2-181 HFP-11 "J/L2/JE1100/SD181/Pantry"
|      |      |  |-- 1:2-182 HTRI-R "J/L2/JE1100/CM182/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-183 HMS-S/D/M/SA "J/L2/JE1100/MCP183/Entry Psg"
|      |      |  |-- 1:2-184 HFP-11 "J/L2/JE1130/SD184/Main cab"
|      |      |  |-- 1:2-185 HFP-11 "J/L2/JE1130/SD185/Assorter cab"
|      |      |  |-- 1:2-186 HFPT-11 "J/L2/JE1130/HD186/Pantry Psg"
|      |      |  |-- 1:2-187 HFPT-11 "J/L2/JE1130/HD187/Pantry "
|      |      |  |-- 1:2-188 HTRI-R "J/L2/JE1130/CM188/Entry dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-189 HMS-S/D/M/SA "J/L2/JE1130/MCP189/Entry dr"
|      |      |  |-- 1:2-190 HFP-11 "J/L2/JE1150/SD190/Main cab"
|      |      |  |-- 1:2-191 HTRI-R "J/L2/JE1150/CM191/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-192 HMS-S/D/M/SA "J/L2/JE1150/MCP192/Entry Psg"
|      |      |  |-- 1:2-193 HFP-11 "J/L2/JE1220/SD193/Main cab"
|      |      |  |-- 1:2-194 HFP-11 "J/L2/JE1220/SD194/Assorter cab"
|      |      |  |-- 1:2-195 HFP-11 "J/L2/JE1220/SD195/Pantry"
|      |      |  |-- 1:2-196 HFP-11 "J/L2/JE1220/SD196/Entry Psg"
|      |      |  |-- 1:2-197 HTRI-R "J/L2/JE1220/CM197/Entry Psg"
|      |      |  |-- Switch ""
```


			-- Relay
			-- 1:2-198 HMS-S/D/M/SA "J/L2/JE1220MCP198/Pantry Psg"
			-- 1:2-199 HFP-11 "J/L2/JW1080/SD199/Main CAB"
			-- 1:2-200 HFP-11 "J/L2/JW1080/SD200/Assortor Psg"
			-- 1:2-201 HTRI-S "J/L2/JE/1F/MM201/Psg nr JE1190"
			-- 1:2-202 HTRI-S "J/L2/JE/1F/MM202/Psg nr JE1030"
			-- 1:2-203 HTRI-S "J/L2/JE/1F/MM203/Psg nr JE1140"
			-- 1:2-204 HTRI-R "J/L2/JW1080/CM204/Entry Psg AFC"
			-- Switch ""
			-- Relay
			-- 1:2-205 HTRI-S "J/L2/JE/1F/MM205/Psg nr JE1060"
			-- 1:2-206 HTRI-S "J/L2/JE/1F/MM206/Psg nr JE1120"
			-- 1:2-207 HTRI-S "J/L2/JE/1F/MM207/Psg nr JE1080"
			-- 1:2-208 HTRI-S "J/L2/JE/1F/MM208/Psg nr JE1090"
			-- 1:2-209 HTRI-S "J/L2/JW/1F/MM209/Psg nr JW1190"
			-- 1:2-210 HTRI-S "J/L2/JW/1F/MM210/Psg nr JW1160"
			-- 1:2-211 HTRI-S "J/L2/JW/1F/MM211/Psg nr JW1150"
			-- 1:2-212 HTRI-S "J/L2/JW/1F/MM212/Psg nr JW1090"
			-- 1:2-213 HTRI-S "J/L2/JW/1F/MM213/Psg nr JW1060"
			-- 1:2-214 HTRI-S "J/L2/JW/1F/MM214/Psg nr JW1050"
			-- 1:2-215 HTRI-S "J/L2/JW/1F/MM215/Psg nr JW1010"
			-- 1:2-216 HTRI-S "J/L2/JE/1F/MM216/Psg nr JE1240"
			-- 1:2-217 HTRI-S "J/L2/JE/1F/MM217/Psg nr JE1320"
			-- 1:2-218 HFP-11 "J/L2/JE1290/SD218/Assorter cab1"
			-- 1:2-219 HFP-11 "J/L2/JE1290/SD219/Main cab"
			-- 1:2-220 HFP-11 "J/L2/JE1290/SD220/Pantry"
			-- 1:2-221 HFP-11 "J/L2/JE1290/SD221/Assorter cab2"
			-- 1:2-222 HFP-11 "J/L2/JE1290/SD222/Entry dr Psg"
			-- 1:2-223 HFP-11 "J/L2/JE1290/SD223/Accounts cab"
			-- 1:2-224 HTRI-R "J/L2/JE1290/CM224/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 1:2-225 HMS-S/D/M/SA "J/L2/JE1290/MCP225/Entry dr Psg"
			-- 1:2-226 HFP-11 "J/L2/JE1200/SD226/Main cab"
			-- 1:2-227 HFP-11 "J/L2/JE1200/SD227/Assorter cab1"
			-- 1:2-228 HFP-11 "J/L2/JE1200/SD228/Assorter cab2"
			-- 1:2-229 HFP-11 "J/L2/JE1200/SD229/Entry dr Psg"
			-- 1:2-230 HTRI-R "J/L2/JE1200/CM230/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 1:2-231 HMS-S/D/M/SA "J/L2/JE1200/MCP231/Entry dr Psg"
			-- 1:2-232 HFP-11 "J/L2/JW1140/SD232/Accounts cab"
			-- 1:2-233 HFP-11 "J/L2/JW1140/SD233/Assorter cab"
			-- 1:2-234 HFP-11 "J/L2/JW1140/SD234/Main cab"
			-- 1:2-235 HFP-11 "J/L2/JW1140/SD235/Entry dr Psg"
			-- 1:2-236 HTRI-R "J/L2/JW1140/CM236/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 1:2-237 HMS-S/D/M/SA "J/L2/JW1140/MCP237/Entry dr Psg"
			-- 1:2-238 HTRI-S "J/L2/1F/MM238/JW1040"

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:2 DLC "DLC @ address 2 L2"

```
|      |      |  |-- 1:2-239 HTRI-S "J/L2/1F/MM239/JW1210"
|      |      |  |-- 1:2-240 HTRI-S "J/L2/1F/MM240/JE1310"
|      |      |  |-- 1:2-241 HTRI-S "J/L2/1F/MM241/JE1110"
|      |      |  |-- 1:2-242 HTRI-S "J/L2/1F/MM242/JE1300"
|      |      |  |-- 1:2-243 HMS-S/D/M/SA "J/L2/JW1080/MCP243/Entry Psg"
|      |      |  |-- 1:2-244 HMS-S/D/M/SA "J/L2/JW1200/MCP244/Enrty Psg"
|      |      |  |-- 1:2-245 HFP-11 "J/L2/JE1330/SD245/Assortor Cabin"
|      |      |  |-- 1:2-246 HFP-11 "J/L2/JE1330/SD246/Main Cabin"
|      |      |  |-- 1:2-247 HFPT-11 "J/L2/JE1330/HD247/Pantry"
|      |      |  |-- 1:2-248 HTRI-R "J/L2/JE1330/CM248/Entry Psg AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:2-249 HMS-S/D/M/SA "J/L2/JE1330/MCP249/Entry Psg "
|      |      |  |-- 1:2-250 HTRI-S "J/L2/1F/MM250/JE1050"
|      |      |  |-- 1:2-251 HTRI-S "J/L2/1F/MM251/JE1230"
|      |      |  |-- 1:2-82 HTRI-S "J/L2/1F/MM82/JW1030"
|      |      |  |-- 1:2-80 HTRI-S "J/L2/1F/MM80/JE1210"
|      |      |  |-- 1:3 DLC "DLC @ address 3 L3"
|      |      |  |-- 1:3-1 HTRI-R "J/L3/7B/2F/CM1/DR RELESE CM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-2 HFP-11 "J/L3/7B/2F/SD2/COR NR JE2180 AFC"
|      |      |  |-- 1:3-3 HFP-11 "J/L3/7B/2F/SD3/COR NR JE2180J"
|      |      |  |-- 1:3-4 HFP-11 "J/L3/7B/2F/SD4/CORR NR JE 2050"
|      |      |  |-- 1:3-5 HFP-11 "J/L3/7B/2F/SD5/COR NR 7B/S43 AFC"
|      |      |  |-- 1:3-6 HFP-11 "J/L3/7B/2F/SD6/CORR NR JE 2070"
|      |      |  |-- 1:3-7 HFP-11 "J/L3/7B/2F/SD7/CORR NR 7B S14"
|      |      |  |-- 1:3-8 HMS-S/D/M/SA "J/L3/7B/2F/MCP8/FIRE ESC STR "
|      |      |  |-- 1:3-9 HTRI-R "J/L3/7B/2F/CM9/FIRE ESC STR "
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-11 HFP-11 "J/L3/7B/2F/SD11/CORR NR JE2120 A"
|      |      |  |-- 1:3-12 HFP-11 "J/L3/7B/2F/SD12/CORR NR JW 2170"
|      |      |  |-- 1:3-13 HFP-11 "J/L3/7B/2F/SD13/CORR NR JW2170 A"
|      |      |  |-- 1:3-14 HFP-11 "J/L3/7B/2F/SD14/JW AHU RM SD"
|      |      |  |-- 1:3-15 HTRI-R "J/L3/7B/2F/CM15/JW AHU RM CM "
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-16 HFP-11 "J/L3/7B/2F/SD16/CORR NR JW 2140"
|      |      |  |-- 1:3-17 HFP-11 "J/L3/7B/2F/SD17/CORR NR JW2120 A"
|      |      |  |-- 1:3-18 HFP-11 "J/L3/7B/2F/SD18/CORR NR JW 2120"
|      |      |  |-- 1:3-19 HTRI-R "J/L3/7B/2F/CM19/DR RELESE JW 212"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-20 HMS-S/D/M/SA "J/L3/7B/2F/MCP20/FIRE SHAFT L.L."
|      |      |  |-- 1:3-21 HTRI-R "J/L3/7B/2F/CM21/FIRE SHAFT L.L."
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-22 HTRI-S "J/L3/7B/2F/MM22/FIRE SHAFT L.L."
|      |      |  |-- 1:3-23 HFP-11 "J/L3/7B/2F/SD23/LIFT LOBBY SD"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:3 DLC "DLC @ address 3 L3"
```

```
|      |      |  |-- 1:3-24 HFP-11 "J/L3/7B/2F/SD24/ELECT RM SD"
|      |      |  |-- 1:3-25 HTRI-R "J/L3/7B/2F/CM25/DR RELSE JW 2050"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:3-26 HFP-11 "J/L3/7B/2F/SD26/CORR NR JW2050 A"
|      |      |  |-- 1:3-27 HFP-11 "J/L3/7B/2F/SD27/CORR NR JW 2050"
|      |      |  |-- 1:3-28 HFP-11 "J/L3/7B/2F/SD28/CORR NR JW 2010"
|      |      |  |-- 1:3-29 HFP-11 "J/L3/7B/2F/SD29/CORR NR 7B S48 A"
|      |      |  |-- 1:3-30 HTRI-R "J/L3/7B/2F/CM30/DR RELESE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:3-31 HTRI-R "J/L3/7B/2F/CM31/DR RELESE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:3-32 HFP-11 "J/L3/7B/2F/SD32/CORR NR JE2220 A"
|      |      |  |-- 1:3-33 HFP-11 "J/L3/7B/2F/SD33/CORR NR JE 2220"
|      |      |  |-- 1:3-34 HFP-11 "J/L3/7B/2F/SD34/CORR NR JE2270 A"
|      |      |  |-- 1:3-35 HFP-11 "J/L3/7B/2F/SD35/CORR NR JE 2270"
|      |      |  |-- 1:3-36 HFP-11 "J/L3/7B/2F/SD36/CORR NR JE 2280"
|      |      |  |-- 1:3-37 HMS-S/D/M/SA "J/L3/7B/2F/MCP37/FIRE ESC STR "
|      |      |  |-- 1:3-38 HTRI-R "J/L3/7B/2F/CM38/FIRE ESC STR "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:3-40 HFP-11 "J/L3/7B/2F/SD40/CORR NR JE 2290"
|      |      |  |-- 1:3-41 HFP-11 "J/L3/7B/2F/SD41/CORR NR JE 2290"
|      |      |  |-- 1:3-42 HFP-11 "J/L3/7B/2F/SD42/CORR NR JE 2310"
|      |      |  |-- 1:3-43 HFP-11 "J/L3/7B/2F/SD43/CORR NR JE 2190"
|      |      |  |-- 1:3-44 HFP-11 "J/L3/7B/2F/SD44/CORR NR JE 2190"
|      |      |  |-- 1:3-45 HTRI-R "J/L3/7B/2F/CM45/DR RELESE JE 219"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:3-46 HTRI-S "J/L3/2F/MM46/Psg. Nr. JE2020"
|      |      |  |-- 1:3-49 HFP-11 "J/L3/7B/2F/SD49/AHU RM SD NR JE "
|      |      |  |-- 1:3-50 HTRI-R "J/L3/7B/2F/CM50/AHU RM CM NR JE "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:3-51 HFP-11 "J/L3/7B/2F/SD51/ELECT RM SD"
|      |      |  |-- 1:3-52 HFP-11 "J/L3/7B/2F/SD52/LIFT LOBBY SD"
|      |      |  |-- 1:3-54 HTRI-S "J/L3/JE/2F/MM54/Psg nr JE2180"
|      |      |  |-- 1:3-55 HTRI-S "J/L3/JE/2F/MM55/Psg nr JE2030"
|      |      |  |-- 1:3-56 HTRI-S "J/L3/JE/2F/MM56/Psg nr JE2040"
|      |      |  |-- 1:3-57 HTRI-S "J/L3/JE/2F/MM57/Psg nr JE2050"
|      |      |  |-- 1:3-58 HTRI-S "J/L3/JE/2F/MM58/Psg nr JE2090"
|      |      |  |-- 1:3-59 HTRI-S "J/L3/JE/2F/MM59/Psg nr JE2130"
|      |      |  |-- 1:3-60 HTRI-S "J/L3/JW/2F/MM60/Psg nr JW2160"
|      |      |  |-- 1:3-61 HTRI-S "J/L3/JW/2F/MM61/Psg nr JW2070"
|      |      |  |-- 1:3-62 HTRI-S "J/L3/JW/2F/MM62/Psg nr JW2050"
|      |      |  |-- 1:3-63 HTRI-S "J/L3/JW/2F/MM63/Psg nr JW2030"
|      |      |  |-- 1:3-65 HTRI-S "J/L3/JE/2F/MM65/Psg nr JE2230"
|      |      |  |-- 1:3-66 HTRI-S "J/L3/JE/2F/MM66/Psg nr JE2260"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:3 DLC "DLC @ address 3 L3"

```
|      |      |  |-- 1:3-67 HTRI-S "J/L3/JE/2F/MM67/Psg nr JE2290"
|      |      |  |-- 1:3-68 HTRI-S "J/L3/JE/2F/MM68/Psg nr JE2300"
|      |      |  |-- 1:3-69 HTRI-S "J/L3/JE/2F/MM69/Psg nr JE2190"
|      |      |  |-- 1:3-72 HFP-11 "J/L3/JE2010/SD72/Cab 1"
|      |      |  |-- 1:3-73 HFP-11 "J/L3/JE2010/SD73/Cab 2"
|      |      |  |-- 1:3-74 HFP-11 "J/L3/JE2010/SD74/Entry dr Psg"
|      |      |  |-- 1:3-75 HTRI-R "J/L3/JE2010/CM75/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-76 HMS-S/D/M/SA "J/L3/JE2010/MCP76/Entry dr Psg"
|      |      |  |-- 1:3-77 HFP-11 "J/L3/JE2070/SD77/Main cab"
|      |      |  |-- 1:3-78 HFP-11 "J/L3/JE2070/SD78/Pantry Psg"
|      |      |  |-- 1:3-79 HTRI-R "J/L3/JE2070/CM79/Pantry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-80 HMS-S/D/M/SA "J/L3/JE2070/MCP80/Pantry Psg"
|      |      |  |-- 1:3-81 HFP-11 "J/L3/JE2060/SD81/Main cab"
|      |      |  |-- 1:3-82 HFP-11 "J/L3/JE2060/SD82/Assorter cab"
|      |      |  |-- 1:3-83 HFP-11 "J/L3/JE2060/SD83/Entry dr Psg"
|      |      |  |-- 1:3-84 HFPT-11 "J/L3/JE2060/HD84/Pantry Psg"
|      |      |  |-- 1:3-85 HTRI-R "J/L3/JE2060/CM85/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-86 HMS-S/D/M/SA "J/L3/JE2060/MCP86/Entry dr Psg"
|      |      |  |-- 1:3-87 HFP-11 "J/L3/JE2162/SD87/Main cab"
|      |      |  |-- 1:3-88 HFP-11 "J/L3/JE2162/SD88/Entry Psg"
|      |      |  |-- 1:3-89 HTRI-R "J/L3/JE2162/CM89/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-90 HMS-S/D/M/SA "J/L3/JE2162/MCP90/Entry Psg"
|      |      |  |-- 1:3-91 HFP-11 "J/L3/JE2161/SD91/Main cab"
|      |      |  |-- 1:3-92 HFP-11 "J/L3/JE2161/SD92/Assorter cab"
|      |      |  |-- 1:3-93 HFP-11 "J/L3/JE2161/SD93/Entry Psg"
|      |      |  |-- 1:3-94 HTRI-R "J/L3/JE2161/CM94/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-95 HMS-S/D/M/SA "J/L3/JE2161/MCP95/Entry Psg"
|      |      |  |-- 1:3-96 HFP-11 "J/L3/JW2120/SD96/Main cab"
|      |      |  |-- 1:3-97 HFP-11 "J/L3/JW2120/SD97/Assorter cab"
|      |      |  |-- 1:3-98 HTRI-R "J/L3/JW2120/CM98/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-99 HMS-S/D/M/SA "J/L3/JW2120/MCP99/Entry Psg"
|      |      |  |-- 1:3-100 HFP-11 "J/L3/JW2090/SD100/Assorter cab"
|      |      |  |-- 1:3-101 HFP-11 "J/L3/JW2090/SD101/Main cab"
|      |      |  |-- 1:3-102 HFP-11 "J/L3/JW2090/SD102/Entry Psg"
|      |      |  |-- 1:3-103 HTRI-R "J/L3/JW2090/CM103/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-104 HMS-S/D/M/SA "J/L3/JW2090/MCP104/Entry Psg"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:3 DLC "DLC @ address 3 L3"
```

```
|      |      |  |-- 1:3-105 HFP-11 "J/L3/JW2130/SD105/Main cab"
|      |      |  |-- 1:3-106 HFP-11 "J/L3/JW2130/SD106/Assorter cab"
|      |      |  |-- 1:3-107 HFP-11 "J/L3/JW2130/SD107/nr Assorter ca"
|      |      |  |-- 1:3-108 HFP-11 "J/L3/JW2130/SD108/Entry Psg"
|      |      |  |-- 1:3-109 HTRI-R "J/L3/JW2130/CM109/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-110 HMS-S/D/M/SA "J/L3/JW2130/MCP110/Entry Psg"
|      |      |  |-- 1:3-111 HFP-11 "J/L3/JE2120/SD111/Main cab"
|      |      |  |-- 1:3-112 HFP-11 "J/L3/JE2120/SD112/Assorter cab"
|      |      |  |-- 1:3-113 HFP-11 "J/L3/JE2120/SD113/Pantry"
|      |      |  |-- 1:3-114 HTRI-R "J/L3/JE2120/CM114/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-115 HMS-S/D/M/SA "J/L3/JE2120/MCP115/Entry dr Psg"
|      |      |  |-- 1:3-116 HFP-11 "J/L3/JW2190/SD116/Main cab"
|      |      |  |-- 1:3-117 HFP-11 "J/L3/JW2190/SD117/Pantry"
|      |      |  |-- 1:3-118 HFP-11 "J/L3/JW2190/SD118/Entry Psg"
|      |      |  |-- 1:3-119 HTRI-R "J/L3/JW2190/CM119/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-120 HMS-S/D/M/SA "J/L3/JW2190/MCP120/Entry Psg"
|      |      |  |-- 1:3-121 HFP-11 "J/L3/JE2100/SD121/Main cab"
|      |      |  |-- 1:3-122 HFP-11 "J/L3/JE2100/SD122/Assorter cab"
|      |      |  |-- 1:3-123 HFP-11 "J/L3/JE2100/SD123/Entry Psg"
|      |      |  |-- 1:3-124 HTRI-R "J/L3/JE2100/CM124/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-125 HMS-S/D/M/SA "J/L3/JE2100/MCP125/Entry Psg"
|      |      |  |-- 1:3-126 HFP-11 "J/L3/JW2010/SD126/Main cab"
|      |      |  |-- 1:3-127 HFP-11 "J/L3/JW2010/SD127/Assorter cab"
|      |      |  |-- 1:3-128 HFP-11 "J/L3/JW2010/SD128/Entry Psg"
|      |      |  |-- 1:3-129 HTRI-R "J/L3/JW2010/CM129/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-130 HMS-S/D/M/SA "J/L3/JW2010/MCP130/Entry Psg"
|      |      |  |-- 1:3-131 HFP-11 "J/L3/JE2280/SD131/Assorter cab1"
|      |      |  |-- 1:3-132 HFP-11 "J/L3/JE2280/SD132/Entry Psg"
|      |      |  |-- 1:3-133 HFP-11 "J/L3/JE2280/SD133/Main cab"
|      |      |  |-- 1:3-134 HFP-11 "J/L3/JE2280/SD134/Assorter cab2"
|      |      |  |-- 1:3-135 HFP-11 "J/L3/JE2280/SD135/Pantry"
|      |      |  |-- 1:3-136 HTRI-R "J/L3/JE2280/CM136/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:3-137 HMS-S/D/M/SA "J/L3/JE2280/MCP137/Entry Psg"
|      |      |  |-- 1:3-138 HFP-11 "J/L3/JE2270/SD138/Assorter cab1"
|      |      |  |-- 1:3-139 HFP-11 "J/L3/JE2270/SD139/Main cab"
|      |      |  |-- 1:3-140 HFP-11 "J/L3/JE2270/SD140/Entry Psg"
|      |      |  |-- 1:3-141 HFP-11 "J/L3/JE2270/SD141/Assorter cab2"
|      |      |  |-- 1:3-142 HTRI-R "J/L3/JE2270/CM142/Entry Psg"
```

```

| | | | Switch ""
| | | | -- Relay
| | | | -- 1:3-143 HMS-S/D/M/SA "J/L3/JE2270/MCP143/Entry Psg"
| | | | -- 1:3-144 HFP-11 "J/L3/JE2240/SD144/Assorter cab1"
| | | | -- 1:3-145 HFP-11 "J/L3/JE2240/SD145/Accounts cab"
| | | | -- 1:3-146 HFP-11 "J/L3/JE2240/SD146/Entry Psg"
| | | | -- 1:3-147 HFP-11 "J/L3/JE2240/SD147/Assorter cab2"
| | | | -- 1:3-148 HFP-11 "J/L3/JE2240/SD148/Main cab"
| | | | -- 1:3-149 HFP-11 "J/L3/JE2240/SD149/Pantry"
| | | | -- 1:3-150 HFP-11 "J/L3/JE2240/SD150/Entry Psg"
| | | | -- 1:3-151 HTRI-R "J/L3/JE2240/CM151/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:3-152 HMS-S/D/M/SA "J/L3/JE2240/MCP152/Entry Psg"
| | | | -- 1:3-153 HFP-11 "J/L3/JE2220/SD153/Assorter cab1"
| | | | -- 1:3-154 HFP-11 "J/L3/JE2220/SD154/Assorter cab2"
| | | | -- 1:3-155 HFP-11 "J/L3/JE2220/SD155/Assorter cab3"
| | | | -- 1:3-156 HFP-11 "J/L3/JE2220/SD156/Assorter cab4"
| | | | -- 1:3-157 HFP-11 "J/L3/JE2220/SD157/Pantry"
| | | | -- 1:3-158 HTRI-R "J/L3/JE2220/CM158/Entry dr"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:3-159 HMS-S/D/M/SA "J/L3/JE2220/MCP159/Entry dr"
| | | | -- 1:3-160 HFP-11 "J/L3/JE2200/SD160/Main cab"
| | | | -- 1:3-161 HFP-11 "J/L3/JE2200/SD161/Assorter cab"
| | | | -- 1:3-162 HFP-11 "J/L3/JE2200/SD162/Accounts cab"
| | | | -- 1:3-163 HFP-11 "J/L3/JE2200/SD163/cab 1"
| | | | -- 1:3-164 HFP-11 "J/L3/JE2200/SD164/cab 2"
| | | | -- 1:3-165 HFP-11 "J/L3/JE2200/SD165/Pantry"
| | | | -- 1:3-166 HTRI-R "J/L3/JE2200/CM166/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:3-167 HMS-S/D/M/SA "J/L3/JE2200/MCP167/Entry Psg"
| | | | -- 1:3-168 HFP-11 "J/L3/JW2040/SD168/Entry dr Psg"
| | | | -- 1:3-169 HFP-11 "J/L3/JW2040/SD169/Account cab"
| | | | -- 1:3-170 HFP-11 "J/L3/JW2040/SD170/Main cab"
| | | | -- 1:3-171 HFP-11 "J/L3/JW2040/SD171/AFC account ca"
| | | | -- 1:3-172 HFPT-11 "J/L3/JW2040/HD172/Pantry"
| | | | -- 1:3-173 HTRI-R "J/L3/JW2040/CM173/Entry dr Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:3-174 HMS-S/D/M/SA "J/L3/JW2040/MCP174/Entry dr Psg"
| | | | -- 1:3-175 HFP-11 "J/L3/JE2080/SD175/Entry dr Psg"
| | | | -- 1:3-176 HFP-11 "J/L3/JE2080/SD176/Pantry Psg"
| | | | -- 1:3-177 HTRI-R "J/L3/JE2080/CM177/Entry dr Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:3-178 HMS-S/D/M/SA "J/L3/JE2080/MCP178/Entry dr Psg"
| | | | -- 1:3-179 HFP-11 "J/L3/JE2172/SD179/Main cab"
| | | | -- 1:3-180 HFP-11 "J/L3/JE2172/SD180/Cab 1"

```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:3 DLC "DLC @ address 3 L3"
```

```
|      |      |  |-- 1:3-181 HFP-11 "J/L3/JE2172/SD181/Entry Psg"
|      |      |  |-- 1:3-182 HMS-S/D/M/SA "J/L3/JE2172/MCP182/Entry Psg"
|      |      |  |-- 1:3-183 HTRI-R "J/L3/JE2172/CM183/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-184 HFP-11 "J/L3/JE2330/SD184/Main cab"
|      |      |  |-- 1:3-185 HFP-11 "J/L3/JE2330/SD185/Assorter cab"
|      |      |  |-- 1:3-186 HFP-11 "J/L3/JE2330/SD186/Entry Psg"
|      |      |  |-- 1:3-187 HTRI-R "J/L3/JE2330/CM187/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-188 HMS-S/D/M/SA "J/L3/JE2330/MCP188/Entry Psg"
|      |      |  |-- 1:3-189 HFP-11 "J/L3/JW2060/SD189/Main cab"
|      |      |  |-- 1:3-190 HFP-11 "J/L3/JW2060/SD190/Cab 1"
|      |      |  |-- 1:3-191 HFP-11 "J/L3/JW2060/SD191/pantry Psg"
|      |      |  |-- 1:3-192 HFP-11 "J/L3/JW2060/SD192/Entry dr Psg"
|      |      |  |-- 1:3-193 HTRI-R "J/L3/JW2060/CM193/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-194 HMS-S/D/M/SA "J/L3/JW2060/MCP194/Entry dr Psg"
|      |      |  |-- 1:3-195 HTRI-S "J/L3/2F//MM195/Psg. Nr.JE 2310"
|      |      |  |-- 1:3-196 HFP-11 "J/L3/JE2320/SD196/Main cab"
|      |      |  |-- 1:3-197 HFP-11 "J/L3/JE2320/SD197/Assorter cab"
|      |      |  |-- 1:3-198 HFP-11 "J/L3/JE2320/SD198/Psg nr Assorte"
|      |      |  |-- 1:3-199 HTRI-R "J/L3/JE2320/CM199/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-200 HMS-S/D/M/SA "J/L3/JE2320/MCP200/Entry dr Psg"
|      |      |  |-- 1:3-201 HFP-11 "J/L3/JE2140/SD201/Main cab1"
|      |      |  |-- 1:3-202 HFP-11 "J/L3/JE2140/SD202/Main cab2"
|      |      |  |-- 1:3-203 HFP-11 "J/L3/JE2140/SD203/Cab 1"
|      |      |  |-- 1:3-204 HFP-11 "J/L3/JE2140/SD204/Psg nr Pantry"
|      |      |  |-- 1:3-205 HFP-11 "J/L3/JE2140/SD205/Cab 2"
|      |      |  |-- 1:3-206 HFP-11 "J/L3/JE2140/SD206/Cab 3"
|      |      |  |-- 1:3-207 HFPT-11 "J/L3/JE2140/HD207/Pantry"
|      |      |  |-- 1:3-208 HTRI-R "J/L3/JE2140/CM208/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:3-209 HMS-S/D/M/SA "J/L3/JE2140/MCP209/Entry dr Psg"
|      |      |  |-- 1:3-211 HTRI-S "J/L3/2F//MM211/Psg. Nr.JW 2110"
|      |      |  |-- 1:3-212 HTRI-S "J/L3/2F//MM212/Psg. Nr.JW 2170"
|      |      |  |-- 1:3-213 HTRI-S "J/L3/2F//MM213/Psg. Nr.JE 2171"
|      |      |  |-- 1:3-214 HTRI-S "J/L3/2F//MM214/Psg. Nr.JE 2151"
|      |      |  |-- 1:3-217 HTRI-S "J/L3/2F//MM217/Psg. Nr.JW 2140"
|      |      |  |-- 1:3-218 HTRI-S "J/L3/2F//MM218/Psg. Nr.JW 2150"
|      |      |  |-- 1:3-220 HTRI-S "J/L3/2F//MM220/Psg. Nr.JW2200/10"
|      |      |  |-- 1:3-221 HFP-11 "J/L3/JW2020/SD221/Main cab"
|      |      |  |-- 1:3-222 HFP-11 "J/L3/JW2020/SD222/Assorter cab"
|      |      |  |-- 1:3-223 HFP-11 "J/L3/JW2020/SD223/Entry dr psg"
|      |      |  |-- 1:3-224 HTRI-R "J/L3/JW2020/CM224/Entry dr psg"
```

```
| | | | Switch ""
| | | | -- Relay
| | | | -- 1:3-225 HMS-S/D/M/SA "J/L3/JW2020/MCP225/Entry dr psg"
| | | | -- 1:3-226 HFP-11 "J/L3/JW2010/SD226/Entry Psg"
| | | | -- 1:3-227 HFP-11 "J/L3/JW2010/SD227/Account Cab"
| | | | -- 1:3-231 HFP-11 "J/L3/JW2100/SD231/Main Cabin"
| | | | -- 1:3-232 HFP-11 "J/L3/JW2100/SD232/Assortor Cabin"
| | | | -- 1:3-233 HFP-11 "J/L3/JW2100/SD233/ntry Psg"
| | | | -- 1:3-234 HTRI-R "J/L3/JW2100/CM234/EntryElect Box"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:3-235 HMS-S/D/M/SA "J/L3/JW2100/MCP235/Entry Psg"
| | | | -- 1:3-236 HFP-11 "J/L3/JE2152/SD236/Entry Pgs"
| | | | -- 1:3-237 HFP-11 "J/L3/JE2152/SD237/Main Cab"
| | | | -- 1:3-238 HMS-S/D/M/SA "J/L3/JE2152/SD238/Entry Pgs"
| | | | -- 1:3-239 HTRI-R "J/L3/JE2152/SD239/Entry Pgs AFC"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:4 DLC "DLC @ address 4 L4"
| | | | -- 1:4-1 HTRI-R "J/L4/7B/3F/CM1/DR RELESE JE 3021"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 1:4-2 HFP-11 "J/L4/7B/3F/SD2/CORR NR JE3021 AF"
| | | | -- 1:4-3 HFP-11 "J/L4/7B/3F/SD3/CORR NR JE 3021"
| | | | -- 1:4-4 HFP-11 "J/L4/7B/3F/SD4/CORR NR JE 3160"
| | | | -- 1:4-5 HFP-11 "J/L4/7B/3F/SD5/CORR NR JE7B3/S43"
| | | | -- 1:4-6 HFP-11 "J/L4/7B/3F/SD6/CORR NR JE 3050"
| | | | -- 1:4-7 HFP-11 "J/L4/7B/3F/SD7/CORR NR JE 3060"
| | | | -- 1:4-8 HMS-S/D/M/SA "J/L4/7B/3F/MCP8/FIRE ESC STR"
| | | | -- 1:4-9 HTRI-R "J/L4/7B/3F/CM9/FIRE ESC STR"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 1:4-10 HMS-S/D/M/SA "J/L4/7B/3F/MCP10/JW FIRE STR L L"
| | | | -- 1:4-11 HFP-11 "J/L4/7B/3F/SD11/CORR NR JE3080 A"
| | | | -- 1:4-12 HFP-11 "J/L4/7B/3F/SD12/CORR NR JW 3200"
| | | | -- 1:4-13 HFP-11 "J/L4/7B/3F/SD13/CORR NR JW3200 A"
| | | | -- 1:4-14 HTRI-R "J/L4/7B/3F/CM14/JW AHU RM CM"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 1:4-15 HFP-11 "J/L4/7B/3F/SD15/JWAHU RM SD"
| | | | -- 1:4-16 HFP-11 "J/L4/7B/3F/SD16/CORR NR JW 3180"
| | | | -- 1:4-17 HFP-11 "J/L4/7B/3F/SD17/CORR NR JW 3150"
| | | | -- 1:4-18 HFP-11 "J/L4/7B/3F/SD18/CORR NR JW3150 A"
| | | | -- 1:4-19 HFP-11 "J/L4/7B/3F/SD19/ELECT RM SD"
| | | | -- 1:4-20 HTRI-R "J/L4/7B/3F/CM20/DR RELESE CM NR "
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 1:4-21 HFP-11 "J/L4/7B/3F/SD21/LIFT LOBBY SD EC"
| | | | -- 1:4-22 HTRI-R "J/L4/7B/3F/CM22/DR RELESE JW 308"
| | | | | -- Switch ""
```



```

1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:4 DLC "DLC @ address 4 L4"
        1:4-22 HTRI-R "J/L4/7B/3F/CM22/DR RELEASE JW 308"

```

```
| | | | | Relay
| | | | |
| | | | | |-- 1:4-23 HFP-11 "J/L4/7B/3F/SD23/CORR NR JW 3080"
| | | | | |-- 1:4-24 HFP-11 "J/L4/7B/3F/SD24/CORR NR JW 3080"
| | | | | |-- 1:4-25 HFP-11 "J/L4/7B/3F/SD25/CORR NR JW 3030"
| | | | | |-- 1:4-26 HTRI-R "J/L4/7B/3F/CM26/DR RELEASE JW 303"
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | |-- 1:4-27 HTRI-R "J/L4/7B/3F/CM27/DR RELEASE JW 324"
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | |-- 1:4-28 HFP-11 "J/L4/7B/3F/SD28/CORR NR JE3240 A"
| | | | | |-- 1:4-29 HFP-11 "J/L4/7B/3F/SD29/CORR NR JE 3250"
| | | | | |-- 1:4-30 HFP-11 "J/L4/7B/3F/SD30/CORR NR JE 3260"
| | | | | |-- 1:4-31 HFP-11 "J/L4/7B/3F/SD31/CORR NR JE 3280"
| | | | | |-- 1:4-32 HTRI-R "J/L4/7B/3F/CM32/AHU RM CM NR JE "
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | |-- 1:4-33 HFP-11 "J/L4/7B/3F/SD33/AHU RM SD NR JE "
| | | | | |-- 1:4-34 HFP-11 "J/L4/7B/3F/SD34/CORR NR AHU RM"
| | | | | |-- 1:4-35 HMS-S/D/M/SA "J/L4/7B/3F/MCP35/FIRE ESC STR"
| | | | | |-- 1:4-36 HTRI-R "J/L4/7B/3F/CM36/FIRE ESC STR"
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | |-- 1:4-37 HTRI-S "J/L4/7B/3F/MM37/FIRE ESC STR"
| | | | | |-- 1:4-38 HFP-11 "J/L4/7B/3F/SD38/CORR NR FIRE ESC"
| | | | | |-- 1:4-39 HFP-11 "J/L4/7B/3F/SD39/CORR NR FIRE ESC"
| | | | | |-- 1:4-40 HFP-11 "J/L4/7B/3F/SD40/CORR NR JE 3210"
| | | | | |-- 1:4-41 HFP-11 "J/L4/7B/3F/SD41/CORR NR JE DR AF"
| | | | | |-- 1:4-42 HFP-11 "J/L4/7B/3F/SD42/CORR NR JE DR "
| | | | | |-- 1:4-43 HTRI-R "J/L4/7B/3F/CM43/DR RELEASE CM"
| | | | | | |-- Switch ""
| | | | | | |-- Relay
| | | | | |-- 1:4-44 HFP-11 "J/L4/7B/3F/SD44/LIFT LOBBY SD "
| | | | | |-- 1:4-45 HFP-11 "J/L4/7B/3F/SD45/ELECT RM JE 3021"
| | | | | |-- 1:4-48 HTRI-S "J/L4/JE/3F/MM48/Psg nr JE3021"
| | | | | |-- 1:4-50 HTRI-S "J/L4/JE/3F/MM50/Psg nr JE3181"
| | | | | |-- 1:4-51 HTRI-S "J/L4/JE/3F/MM51/Psg nr JE3170"
| | | | | |-- 1:4-52 HTRI-S "J/L4/JE/3F/MM52/Psg nr JE3160"
| | | | | |-- 1:4-53 HTRI-S "J/L4/JE/3F/MM53/Psg nr JE3150"
| | | | | |-- 1:4-54 HTRI-S "J/L4/JE/3F/MM54/Psg nr JE3041"
| | | | | |-- 1:4-55 HTRI-S "J/L4/JE/3F/MM55/Psg nr JE3042"
| | | | | |-- 1:4-56 HTRI-S "J/L4/JE/3F/MM56/Psg nr JE3050"
| | | | | |-- 1:4-57 HTRI-S "J/L4/JE/3F/MM57/Psg nr JE3060"
| | | | | |-- 1:4-58 HTRI-S "J/L4/JE/3F/MM58/Psg nr JE3080"
| | | | | |-- 1:4-59 HTRI-S "J/L4/JE/3F/MM59/Psg nr JE3100"
| | | | | |-- 1:4-60 HTRI-S "J/L4/JW/3F/MM60/Psg nr JW3170"
| | | | | |-- 1:4-61 HTRI-S "J/L4/JW/3F/MM61/Psg nr JW3160"
| | | | | |-- 1:4-62 HTRI-S "J/L4/JW/3F/MM62/Psg nr JW3140"
| | | | | |-- 1:4-63 HTRI-S "J/L4/JW/3F/MM63/Psg nr JW3130"
| | | | | |-- 1:4-64 HTRI-S "J/L4/JW/3F/MM64/Psg nr JW3230"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 1:4-65 HTRI-S "J/L4/JW/3F/MM65/Psg nr JW3120"
|      |      |      |-- 1:4-66 HTRI-S "J/L4/JW/3F/MM66/Psg nr JW3050"
|      |      |      |-- 1:4-67 HTRI-S "J/L4/JW/3F/MM67/Psg nr JW3040"
|      |      |      |-- 1:4-68 HTRI-S "J/L4/JW/3F/MM68/Psg nr JW3030"
|      |      |      |-- 1:4-69 HTRI-S "J/L4/JW/3F/MM69/Psg nr JW3020"
|      |      |      |-- 1:4-70 HTRI-S "J/L4/JW/3F/MM70/Psg nr JW3010"
|      |      |      |-- 1:4-71 HTRI-S "J/L4/JE/3F/MM71/Psg nr JE3240"
|      |      |      |-- 1:4-72 HTRI-S "J/L4/JE/3F/MM72/Psg nr JE3260"
|      |      |      |-- 1:4-73 HTRI-S "J/L4/JE/3F/MM73/Psg nr JE3290"
|      |      |      |-- 1:4-74 HTRI-S "J/L4/JE/3F/MM74/Psg nr JE3360"
|      |      |      |-- 1:4-75 HTRI-S "J/L4/JE/3F/MM75/Psg nr JE3370"
|      |      |      |-- 1:4-76 HTRI-S "J/L4/JE/3F/MM76/Psg nr JE3190"
|      |      |      |-- 1:4-77 HTRI-S "J/L4/JE/3F/MM77/Psg nr JE3200"
|      |      |      |-- 1:4-78 HTRI-S "J/L4/JE/3F/MM78/Psg nr JE3310"
|      |      |      |-- 1:4-79 HTRI-S "J/L4/JE/3F/MM79/Psg nr JE3220"
|      |      |      |-- 1:4-81 HFP-11 "J/L4/JE3250/SD81/Assorter cab"
|      |      |      |-- 1:4-82 HFP-11 "J/L4/JE3250/SD82/Main cab"
|      |      |      |-- 1:4-83 HFP-11 "J/L4/JE3250/SD83/Entry Psg"
|      |      |      |-- 1:4-84 HFPT-11 "J/L4/JE3250/HD84/Pantry"
|      |      |      |-- 1:4-85 HTRI-R "J/L4/JE3250/CM85/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:4-86 HMS-S/D/M/SA "J/L4/JE3250/MCP86/Entry Psg"
|      |      |      |-- 1:4-87 HFP-11 "J/L4/JE3140/SD87/Main cab"
|      |      |      |-- 1:4-88 HFP-11 "J/L4/JE3140/SD88/Pantry"
|      |      |      |-- 1:4-89 HTRI-R "J/L4/JE3140/CM89/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:4-90 HMS-S/D/M/SA "J/L4/JE3140/MCP90/Entry Psg"
|      |      |      |-- 1:4-91 HFP-11 "J/L4/JE3010/SD91/Main cab1"
|      |      |      |-- 1:4-92 HFP-11 "J/L4/JE3010/SD92/Main cab2"
|      |      |      |-- 1:4-93 HFP-11 "J/L4/JE3010/SD93/Main cab3"
|      |      |      |-- 1:4-94 HFP-11 "J/L4/JE3010/SD94/Account cab"
|      |      |      |-- 1:4-95 HFP-11 "J/L4/JE3010/SD95/Pantry"
|      |      |      |-- 1:4-96 HTRI-R "J/L4/JE3010/CM96/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:4-97 HMS-S/D/M/SA "J/L4/JE3010/MCP97/Entry Psg"
|      |      |      |-- 1:4-98 HFP-11 "J/L4/JE3270/SD98/Main cab"
|      |      |      |-- 1:4-99 HFP-11 "J/L4/JE3270/SD99/Assorter cab"
|      |      |      |-- 1:4-100 HTRI-R "J/L4/JE3270/CM100/Entry dr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 1:4-101 HMS-S/D/M/SA "J/L4/JE3270/MCP101/Entry dr"
|      |      |      |-- 1:4-102 HFP-11 "J/L4/JE3320/SD102/Main cab"
|      |      |      |-- 1:4-103 HFP-11 "J/L4/JE3320/SD103/Assorter cab"
|      |      |      |-- 1:4-104 HFP-11 "J/L4/JE3320/SD104/Entry dr Psg"
|      |      |      |-- 1:4-105 HTRI-R "J/L4/JE3320/CM105/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
1:4 DLC "DLC @ address 4 L4"

			-- 1:4-106 HMS-S/D/M/SA "J/L4/JE3320/MCP106/Entry dr Psg"
			-- 1:4-107 HFP-11 "J/L4/JE3340/SD107/Main cab"
			-- 1:4-108 HFP-11 "J/L4/JE3340/SD108/Assorter cab"
			-- 1:4-109 HFP-11 "J/L4/JE3340/SD109/Pantry Psg"
			-- 1:4-110 HTRI-R "J/L4/JE3340/CM110/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:4-111 HMS-S/D/M/SA "J/L4/JE3340/MCP111/Entry Psg"
			-- 1:4-112 HFP-11 "J/L4/JE3300/SD112/Main cab"
			-- 1:4-113 HFP-11 "J/L4/JE3300/SD113/Entry dr Psg"
			-- 1:4-114 HTRI-R "J/L4/JE3300/CM114/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 1:4-115 HMS-S/D/M/SA "J/L4/JE3300/MCP115/Entry dr Psg"
			-- 1:4-116 HTRI-S "J/L4/MM116/PSG. NR. JE3330"
			-- 1:4-120 HFP-11 "J/L4/JW3180/SD120/Main cab"
			-- 1:4-121 HFP-11 "J/L4/JW3180/SD121/Account cab"
			-- 1:4-122 HFP-11 "J/L4/JW3180/SD122/Entry Psg"
			-- 1:4-123 HTRI-R "J/L4/JW3180/CM123/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:4-124 HMS-S/D/M/SA "J/L4/JW3180/MCP124/Entry Psg"
			-- 1:4-125 HFP-11 "J/L4/JE3350/SD125/Main cab"
			-- 1:4-126 HFP-11 "J/L4/JE3350/SD126/Assorter cab"
			-- 1:4-127 HFP-11 "J/L4/JE3350/SD127/Entry Psg"
			-- 1:4-128 HFPT-11 "J/L4/JE3350/HD128/Pantry"
			-- 1:4-129 HTRI-R "J/L4/JE3350/CM129/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:4-130 HMS-S/D/M/SA "J/L4/JE3350/MCP130/Entry Psg"
			-- 1:4-131 HFP-11 "J/L4/JE3090/SD131/Main cab"
			-- 1:4-132 HFP-11 "J/L4/JE3090/SD132/Assorter cab"
			-- 1:4-133 HFP-11 "J/L4/JE3090/SD133/Pantry"
			-- 1:4-134 HTRI-R "J/L4/JE3090/CM134/Psg nr Entry"
			-- Switch ""
			-- Relay
			-- 1:4-135 HMS-S/D/M/SA "J/L4/JE3090/MCP135/Psg nr Entry"
			-- 1:4-136 HFP-11 "J/L4/JW3110/SD136/Main cab"
			-- 1:4-137 HFP-11 "J/L4/JW3110/SD137/Assorter cab"
			-- 1:4-138 HFP-11 "J/L4/JW3110/SD138/Entry dr Psg"
			-- 1:4-139 HTRI-R "J/L4/JW3110/CM139/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 1:4-140 HMS-S/D/M/SA "J/L4/JW3110/MCP140/Entry dr Psg"
			-- 1:4-141 HFP-11 "J/L4/JW3150/SD141/Assorter cab"
			-- 1:4-142 HFP-11 "J/L4/JW3150/SD142/Entry dr Psg"
			-- 1:4-143 HFP-11 "J/L4/JW3150/SD143/Main cab"
			-- 1:4-144 HTRI-R "J/L4/JW3150/CM144/Entry dr Psg"
			-- Switch ""
			-- Relay

1 Desigo Fire Safety Modular "BDB TOWER J" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
1:4 DLC "DLC @ address 4 L4"

			-- 1:4-145 HMS-S/D/M/SA "J/L4/JW3150/MCP145/Entry dr Psg"
			-- 1:4-146 HFP-11 "J/L4/JW3070/SD146/Main cab"
			-- 1:4-147 HFP-11 "J/L4/JW3070/SD147/Assorter cab"
			-- 1:4-148 HFP-11 "J/L4/JW3070/SD148/Entry dr Psg"
			-- 1:4-149 HTRI-R "J/L4/JW3070/CM149/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 1:4-150 HMS-S/D/M/SA "J/L4/JW3070/MCP150/Entry dr Psg"
			-- 1:4-151 HFP-11 "J/L4/JE3210/SD151/Main cab1"
			-- 1:4-152 HFP-11 "J/L4/JE3210/SD152/Main cab2"
			-- 1:4-153 HFP-11 "J/L4/JE3210/SD153/Assorter cab"
			-- 1:4-154 HFP-11 "J/L4/JE3210/SD154/Psg nr Pantry"
			-- 1:4-155 HTRI-R "J/L4/JE3210/CM155/Psg nr Entry"
			-- Switch ""
			-- Relay
			-- 1:4-156 HMS-S/D/M/SA "J/L4/JE3210/MCP156/Psg nr Entry"
			-- 1:4-157 HFP-11 "J/L4/JE3280/SD157/Main cab"
			-- 1:4-158 HFP-11 "J/L4/JE3280/SD158/Assorter cab"
			-- 1:4-159 HFP-11 "J/L4/JE3280/SD159/Psg nr Assorte"
			-- 1:4-160 HFP-11 "J/L4/JE3280/SD160/Pantry Psg"
			-- 1:4-161 HTRI-R "J/L4/JE3280/CM161/Entry Psg"
			-- Switch ""
			-- Relay
			-- 1:4-162 HMS-S/D/M/SA "J/L4/JE3280/MCP162/Entry Psg"
			-- 1:4-163 HFP-11 "J/L4/JW3060/SD163/Cabin 1"
			-- 1:4-164 HFP-11 "J/L4/JW3060/SD164/Cabin 2"
			-- 1:4-165 HFP-11 "J/L4/JW3060/SD165/Cabin 3"
			-- 1:4-166 HFP-11 "J/L4/JW3060/SD166/Pantry"
			-- 1:4-167 HTRI-R "J/L4/JE3060/CM167/Entry Dr AFC"
			-- Switch ""
			-- Relay
			-- 1:4-168 HMS-S/D/M/SA "J/L4/JE3060/MCP168/Entry Dr psg"
			-- 1:4-169 HFP-11 "J/L4/JE3182/SD169/Main cab"
			-- 1:4-170 HFP-11 "J/L4/JE3182/SD170/Pantry"
			-- 1:4-171 HTRI-R "J/L4/JE3182/CM171/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 1:4-172 HMS-S/D/M/SA "J/L4/JE3182/MCP172/Entry dr Psg"
			-- 1:4-173 HFP-11 "J/L4/JE3022/SD173/Main cab"
			-- 1:4-174 HFP-11 "J/L4/JE3022/SD174/Psg nr Main ca"
			-- 1:4-175 HFP-11 "J/L4/JE3022/SD175/Assorter cab"
			-- 1:4-176 HFPT-11 "J/L4/JE3022/HD176/Pantry""
			-- 1:4-177 HTRI-R "J/L4/JE3022/CM177/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 1:4-178 HMS-S/D/M/SA "J/L4/JE3022/MCP178/Entry dr Psg"
			-- 1:4-182 HFP-11 "J/L4/JE3300/SD182/PANTRY"
			-- 1:4-183 HFP-11 "J/L4/JE3300/SD183/ASSORTOR CAB"
			-- 1:4-184 HFP-11 "J/L4/JE3110/SD184/main cab"
			-- 1:4-185 HFP-11 "J/L4/JE3110/SD185/cab2"

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 1:4-186 HFP-11 "J/L4/JE3110/SD186/Entry psg"
|      |      |      |-- 1:4-187 HTRI-R "J/L4/JE3110/CM187/Entry psg AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-188 HMS-S/D/M/SA "J/L4/JE3110/MCP188/Entry dr psg"
|      |      |      |-- 1:4-191 HFP-11 "J/L4/JE3031/SD191/Main Cab"
|      |      |      |-- 1:4-192 HFP-11 "J/L4/JE3031/SD192/Assortor Cab"
|      |      |      |-- 1:4-193 HFP-11 "J/L4/JE3031/SD193/Entry Psg"
|      |      |      |-- 1:4-194 HMS-S/D/M/SA "J/L4/JE3031/MCP194/Entry Psg"
|      |      |      |-- 1:4-195 HTRI-R "J/L4/JE3031/CM195/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:4-196 HTRI-S "J/L4/MM196/Psg. Nr. JE3070"
|      |      |      |-- 1:4-198 HFP-11 "J/L4/JE3320/SD198 /Pantry"
|      |      |      |-- 1:5 XDLC "XDLC @ address 5"
|      |      |      |-- 1:5-1 HTRI-R "J/L5/7B/4F/CM1/DR RELESE CM NR L"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:5-2 HFP-11 "J/L5/7B/4F/SD2/CORR NR DR 7B S19"
|      |      |      |-- 1:5-3 HFP-11 "J/L5/7B/4F/SD3/CORR NR 7B S19"
|      |      |      |-- 1:5-4 HFP-11 "J/L5/7B/4F/SD4/CORR NR JE 4030"
|      |      |      |-- 1:5-5 HFP-11 "J/L5/7B/4F/SD5/CORR NR JE 4060 A"
|      |      |      |-- 1:5-6 HFP-11 "J/L5/7B/4F/SD6/CORR NR JE 4060"
|      |      |      |-- 1:5-7 HFP-11 "J/L5/7B/4F/SD7/CORR NR JE 4080"
|      |      |      |-- 1:5-8 HMS-S/D/M/SA "J/L5/7B/4F/MCP8/FIRE ESC STR NR "
|      |      |      |-- 1:5-9 HTRI-R "J/L5/7B/4F/CM9/FIRE ESC STR NR J"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:5-10 HFP-11 "J/L5/7B/4F/SD10/CORR NR JE4100 A"
|      |      |      |-- 1:5-11 HFP-11 "J/L5/7B/4F/SD11/CORR NR JE 4100 "
|      |      |      |-- 1:5-12 HFP-11 "J/L5/7B/4F/SD12/CORR NR JW 4170"
|      |      |      |-- 1:5-13 HFP-11 "J/L5/7B/4F/SD13/CORR NR 7B S10 A"
|      |      |      |-- 1:5-14 HFP-11 "J/L5/7B/4F/SD14/CORR NR 7B S45"
|      |      |      |-- 1:5-15 HFP-11 "J/L5/7B/4F/SD15/CORR NR JW 4140"
|      |      |      |-- 1:5-16 HFP-11 "J/L5/7B/4F/SD16/CORR NR JW4180 A"
|      |      |      |-- 1:5-17 HFP-11 "J/L5/7B/4F/SD17/CORR NR JW 4180"
|      |      |      |-- 1:5-18 HTRI-R "J/L5/7B/4F/CM18/DR RELESE CM NR "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:5-19 HMS-S/D/M/SA "J/L5/7B/4F/MCP19/FIRE SHAFT L.L"
|      |      |      |-- 1:5-20 HTRI-R "J/L5/7B/4F/CM20/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:5-21 HTRI-S "J/L5/7B/4F/MM21/FIRE SHAFT L.L"
|      |      |      |-- 1:5-22 HFP-11 "J/L5/7B/4F/SD22/ELECT RM JW 4080"
|      |      |      |-- 1:5-23 HTRI-R "J/L5/7B/4F/CM23/DR RELESE JW 408"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:5-24 HFP-11 "J/L5/7B/4F/SD24/CORR NR JW 4080"
|      |      |      |-- 1:5-25 HFP-11 "J/L5/7B/4F/SD25/CORR NR JW4040 A"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

```
|      |      |-- 1:5-26 HFP-11 "J/L5/7B/4F/SD26/CORR NR JW 4040"
|      |      |-- 1:5-27 HTRI-R "J/L5/7B/4F/CM27/DR RELESE JW 404"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-28 HTRI-R "J/L5/7B/4F/CM28/DR RELESE JE 404"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-29 HFP-11 "J/L5/7B/4F/SD29/CORR NR JE4220 A"
|      |      |-- 1:5-30 HFP-11 "J/L5/7B/4F/SD30/CORR NR JE 4220"
|      |      |-- 1:5-31 HFP-11 "J/L5/7B/4F/SD31/CORR NR JE4250 A"
|      |      |-- 1:5-32 HFP-11 "J/L5/7B/4F/SD32/CORR NR JE 4250"
|      |      |-- 1:5-33 HFP-11 "J/L5/7B/4F/SD33/CORR NR JE 7B S3"
|      |      |-- 1:5-34 HFP-11 "J/L5/7B/4F/SD34/CORR NR JE4300 A"
|      |      |-- 1:5-35 HFP-11 "J/L5/7B/4F/SD35/CORR NR JE 4300"
|      |      |-- 1:5-36 HFP-11 "J/L5/7B/4F/SD36/CORR NR JE 4320"
|      |      |-- 1:5-37 HFP-11 "J/L5/7B/4F/SD37/CORR NR JE4170 A"
|      |      |-- 1:5-38 HFP-11 "J/L5/7B/4F/SD38/CORR NR JE 4170"
|      |      |-- 1:5-39 HTRI-R "J/L5/7B/4F/CM39/DR RELESE CM NR "
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-40 HMS-S/D/M/SA "J/L5/7B/4F/MCP40/FIRE ESC STR "
|      |      |-- 1:5-41 HTRI-R "J/L5/7B/4F/CM41/FIRE ESC STR NR "
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-42 HTRI-S "J/L5/7B/4F/MM42/FIRE ESC STR NR "
|      |      |-- 1:5-44 HFP-11 "J/L5/7B/4F/SD44/AHURM SDnr 7BS4 "
|      |      |-- 1:5-45 HTRI-R "J/L5/7B/4F/CM45/AHU RM 7B S45"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-46 HFP-11 "J/L5/7B/4F/SD46/ELECT RM SD"
|      |      |-- 1:5-47 HFP-11 "J/L5/7B/4F/SD47/CORR NR 7B S37"
|      |      |-- 1:5-48 HTRI-R "J/L5/7B/4F/CM48/AHU RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-49 HFP-11 "J/L5/7B/4F/SD49/LIFT LOBBY 7B S1"
|      |      |-- 1:5-50 HFP-11 "J/L5/7B/4F/SD50/L. L. NR JW 4080"
|      |      |-- 1:5-61 HTRI-S "J/L5/JE/4F/MM61/Psg nr JE4160"
|      |      |-- 1:5-62 HTRI-S "J/L5/JE/4F/MM62/Psg nr JE4020"
|      |      |-- 1:5-63 HTRI-S "J/L5/JE/4F/MM63/Psg nr JE4040"
|      |      |-- 1:5-64 HTRI-S "J/L5/JE/4F/MM64/Psg nr JE4060"
|      |      |-- 1:5-65 HTRI-S "J/L5/JE/4F/MM65/Psg nr JE4090"
|      |      |-- 1:5-66 HTRI-S "J/L5/JE/4F/MM66/Psg nr JE4120"
|      |      |-- 1:5-67 HTRI-S "J/L5/JW/4F/MM67/Psg nr JW4160"
|      |      |-- 1:5-68 HTRI-S "J/L5/JW/4F/MM68/Psg nr JW4140"
|      |      |-- 1:5-69 HTRI-S "J/L5/JW/4F/MM69/Psg nr JW4110"
|      |      |-- 1:5-70 HTRI-S "J/L5/JW/4F/MM70/Psg nr JW4100"
|      |      |-- 1:5-71 HTRI-S "J/L5/JW/4F/MM71/Psg nr JW4080"
|      |      |-- 1:5-72 HTRI-S "J/L5/JW/4F/MM72/Psg nr JW4020"
|      |      |-- 1:5-73 HTRI-S "J/L5/JW/4F/MM73/Psg nr JW4050"
|      |      |-- 1:5-74 HTRI-S "J/L5/JE/4F/MM74/Psg nr JE4220"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

```
|      |      |-- 1:5-75 HTRI-S "J/L5/JE/4F/MM75/Psg nr JE4200"
|      |      |-- 1:5-76 HTRI-S "J/L5/JE/4F/MM76/Psg nr JE4270"
|      |      |-- 1:5-77 HTRI-S "J/L5/JE/4F/MM77/Psg nr JE4320"
|      |      |-- 1:5-78 HTRI-S "J/L5/JE/4F/MM78/Psg nr JE4330"
|      |      |-- 1:5-79 HTRI-S "J/L5/JE/4F/MM79/Psg nr JE4170"
|      |      |-- 1:5-80 HFP-11 "J/L5/JE4050/SD80/Entry dr Psg "
|      |      |-- 1:5-81 HFP-11 "J/L5/JE4050/SD81/Main cab"
|      |      |-- 1:5-82 HMS-S/D/M/SA "J/L5/JE4050/MCP82/Entry Psg"
|      |      |-- 1:5-83 HTRI-R "J/L5/JE4050/CM83/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-84 HFP-11 "J/L5/JE4130/SD84/Main cab"
|      |      |-- 1:5-85 HFP-11 "J/L5/JE4130/SD85/Recep.Psg"
|      |      |-- 1:5-86 HFP-11 "J/L5/JE4130/SD86/Pantry"
|      |      |-- 1:5-87 HFP-11 "J/L5/JE4130/SD87/Psg nr Pantry"
|      |      |-- 1:5-88 HFP-11 "J/L5/JE4130/SD88/Account cab"
|      |      |-- 1:5-89 HFP-11 "J/L5/JE4130/SD89/Assort. Cab1"
|      |      |-- 1:5-90 HFP-11 "J/L5/JE4130/SD90/Assort. Cab2"
|      |      |-- 1:5-91 HFP-11 "J/L5/JE4130/SD91/Assort. Cab 3"
|      |      |-- 1:5-92 HFP-11 "J/L5/JE4130/SD92/Assort. Cab 4"
|      |      |-- 1:5-93 HFP-11 "J/L5/JE4130/SD93/MD cab"
|      |      |-- 1:5-94 HTRI-R "J/L5/JE4130/CM94/Psg nr Entry"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-95 HMS-S/D/M/SA "J/L5/JE4130/MCP95/Psg nr Entry"
|      |      |-- 1:5-96 HFP-11 "J/L5/JE4080/SD96/Pantry"
|      |      |-- 1:5-97 HFP-11 "J/L5/JE4080/SD97/Main cab"
|      |      |-- 1:5-98 HTRI-R "J/L5/JE4080/CM98/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-99 HMS-S/D/M/SA "J/L5/JE4080/MCP99/Entry Psg"
|      |      |-- 1:5-100 HFP-11 "J/L5/JE4030/SD100/Main cab"
|      |      |-- 1:5-101 HFP-11 "J/L5/JE4030/SD101/Entry dr Psg "
|      |      |-- 1:5-102 HMS-S/D/M/SA "J/L5/JE4030/MCP102/Entry dr Psg "
|      |      |-- 1:5-103 HTRI-R "J/L5/JE4030/CM103/Entry dr Psg "
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-104 HFP-11 "J/L5/JE4110/SD104/Main cab"
|      |      |-- 1:5-105 HFP-11 "J/L5/JE4110/SD105/Main cab"
|      |      |-- 1:5-106 HFP-11 "J/L5/JE4110/SD106/Accounts cab"
|      |      |-- 1:5-107 HFP-11 "J/L5/JE4110/SD107/Pantry"
|      |      |-- 1:5-108 HFP-11 "J/L5/JE4110/SD108/Entry Psg"
|      |      |-- 1:5-109 HMS-S/D/M/SA "J/L5/JE4110/MCP109/Entry Psg"
|      |      |-- 1:5-110 HTRI-R "J/L5/JE4110/CM110/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-111 HFP-11 "J/L5/JW4180/SD111/Account 1"
|      |      |-- 1:5-112 HFP-11 "J/L5/JW4180/SD112/Main cab"
|      |      |-- 1:5-113 HFP-11 "J/L5/JW4180/SD113/Assorter cab"
|      |      |-- 1:5-114 HFP-11 "J/L5/JW4180/SD114/Main cab1"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

```
|      |      |-- 1:5-115 HFP-11 "J/L5/JW4180/SD115/Main cab1"
|      |      |-- 1:5-116 HFP-11 "J/L5/JW4180/SD116/Account cab"
|      |      |-- 1:5-117 HFPT-11 "J/L5/JW4180/HD117/Pantry"
|      |      |-- 1:5-118 HFP-11 "J/L5/JW4180/SD118/Psg nr Pantry"
|      |      |-- 1:5-119 HFP-11 "J/L5/JW4180/SD119/Reception"
|      |      |-- 1:5-120 HFP-11 "J/L5/JW4180/SD120/Entry Psg"
|      |      |-- 1:5-121 HTRI-R "J/L5/JW4180/CM121/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-122 HMS-S/D/M/SA "J/L5/JW4180/MCP122/Entry Psg"
|      |      |-- 1:5-123 HFP-11 "J/L5/JW4170/SD123/Main cab"
|      |      |-- 1:5-124 HFP-11 "J/L5/JW4170/SD124/Account cab"
|      |      |-- 1:5-125 HFP-11 "J/L5/JW4170/SD125/Pantry"
|      |      |-- 1:5-126 HTRI-R "J/L5/JW4170/CM126/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-127 HMS-S/D/M/SA "J/L5/JW4170/MCP127/Entry Psg"
|      |      |-- 1:5-128 HFP-11 "J/L5/JW4060/SD128/cab1"
|      |      |-- 1:5-129 HFP-11 "J/L5/JW4060/SD129/cab2"
|      |      |-- 1:5-130 HFP-11 "J/L5/JW4060/SD130/cab3"
|      |      |-- 1:5-131 HFP-11 "J/L5/JW4060/SD131/Pantry Psg"
|      |      |-- 1:5-132 HFP-11 "J/L5/JW4060/SD132/Entry Psg"
|      |      |-- 1:5-133 HTRI-R "J/L5/JW4060/CM133/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-134 HMS-S/D/M/SA "J/L5/JW4060/MCP134/Entry Psg"
|      |      |-- 1:5-135 HFP-11 "J/L5/JW4130/SD135/Main cab"
|      |      |-- 1:5-136 HFP-11 "J/L5/JW4130/SD136/Assorter cab"
|      |      |-- 1:5-137 HFP-11 "J/L5/JW4130/SD137/Entry Psg"
|      |      |-- 1:5-138 HTRI-R "J/L5/JW4130/CM138/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-139 HMS-S/D/M/SA "J/L5/JW4130/MCP139/Entry Psg"
|      |      |-- 1:5-140 HFP-11 "J/L5/JW4040/SD140/Main cab"
|      |      |-- 1:5-141 HFP-11 "J/L5/JW4040/SD141/Assorter cab"
|      |      |-- 1:5-142 HFPT-11 "J/L5/JW4040/HD142/Pantry"
|      |      |-- 1:5-143 HTRI-R "J/L5/JW4040/CM143/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-144 HMS-S/D/M/SA "J/L5/JW4040/MCP144/Entry Psg"
|      |      |-- 1:5-145 HFP-11 "J/L5/JW4150/SD145/Assorter cab1"
|      |      |-- 1:5-146 HFP-11 "J/L5/JW4150/SD146/Assorter cab2"
|      |      |-- 1:5-147 HFP-11 "J/L5/JW4150/SD147/Main cab"
|      |      |-- 1:5-148 HFP-11 "J/L5/JW4150/SD148/Pantry"
|      |      |-- 1:5-149 HFP-11 "J/L5/JW4150/SD149/Entry Psg"
|      |      |-- 1:5-150 HTRI-R "J/L5/JW4150/CM150/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 1:5-151 HMS-S/D/M/SA "J/L5/JW4150/MCP151/Entry Psg"
|      |      |-- 1:5-152 HFP-11 "J/L5/JW4010/SD152/Account cab"
```


1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

```
|      |      |-- 1:5-153 HFP-11 "J/L5/JW4010/SD153/Assorter cab"
|      |      |-- 1:5-154 HFP-11 "J/L5/JW4010/SD154/Main cab"
|      |      |-- 1:5-155 HFP-11 "J/L5/JW4010/SD155/Entry Psg"
|      |      |-- 1:5-156 HTRI-R "J/L5/JW4010/CM156/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-157 HMS-S/D/M/SA "J/L5/JW4010/MCP157/Entry Psg"
|      |      |-- 1:5-158 HFP-11 "J/L5/JE4230/SD158/Account cab"
|      |      |-- 1:5-159 HFP-11 "J/L5/JE4230/SD159/Main cab"
|      |      |-- 1:5-160 HFP-11 "J/L5/JE4230/SD160/Cab 1"
|      |      |-- 1:5-161 HFP-11 "J/L5/JE4230/SD161/Entry Psg"
|      |      |-- 1:5-162 HTRI-R "J/L5/JE4230/CM162/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-163 HMS-S/D/M/SA "J/L5/JE4230/MCP163/Entry Psg"
|      |      |-- 1:5-164 HFP-11 "J/L5/JE4240/SD164/Main cab"
|      |      |-- 1:5-165 HFP-11 "J/L5/JE4240/SD165/Main cab"
|      |      |-- 1:5-166 HFP-11 "J/L5/JE4240/SD166/Staff cab"
|      |      |-- 1:5-167 HFPT-11 "J/L5/JE4240/HD167/Pantry"
|      |      |-- 1:5-168 HFP-11 "J/L5/JE4240/SD168/Entry Psg"
|      |      |-- 1:5-169 HTRI-R "J/L5/JE4240/CM169/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-170 HMS-S/D/M/SA "J/L5/JE4240/MCP170/Entry Psg"
|      |      |-- 1:5-171 HFP-11 "J/L5/JE4280/SD171/Main cab"
|      |      |-- 1:5-172 HFP-11 "J/L5/JE4280/SD172/Main cab"
|      |      |-- 1:5-173 HFPT-11 "J/L5/JE4280/HD173/Pantry"
|      |      |-- 1:5-174 HTRI-R "J/L5/JE4280/CM174/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-175 HMS-S/D/M/SA "J/L5/JE4280/MCP175/Entry Psg"
|      |      |-- 1:5-176 HFP-11 "J/L5/JE4210/SD176/Main cab"
|      |      |-- 1:5-177 HFP-11 "J/L5/JE4210/SD177/Cab 1"
|      |      |-- 1:5-178 HFP-11 "J/L5/JE4210/SD178/Psg nr cab1"
|      |      |-- 1:5-179 HFP-11 "J/L5/JE4210/SD179/Pantry Psg"
|      |      |-- 1:5-180 HTRI-R "J/L5/JE4210/CM180/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-181 HMS-S/D/M/SA "J/L5/JE4210/MCP181/Entry Psg"
|      |      |-- 1:5-188 HFP-11 "J/L5/JE4300/SD188/Main cab"
|      |      |-- 1:5-189 HFP-11 "J/L5/JE4300/SD189/Psg nr Main ca"
|      |      |-- 1:5-190 HFP-11 "J/L5/JE4300/SD190/Psg nr Main ca"
|      |      |-- 1:5-191 HTRI-R "J/L5/JE4300/CM191/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 1:5-192 HMS-S/D/M/SA "J/L5/JE4300/MCP192/Entry Psg"
|      |      |-- 1:5-193 HFP-11 "J/L5/JE4310/SD193/Main cab"
|      |      |-- 1:5-194 HFP-11 "J/L5/JE4310/SD194/Assorter cab"
|      |      |-- 1:5-195 HFP-11 "J/L5/JE4310/SD195/Entry Psg"
|      |      |-- 1:5-196 HTRI-R "J/L5/JE4310/CM196/Entry Psg"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:5 XDLC "XDLC @ address 5"

1:5-196 HTRI-R "J/L5/JE4310/CM196/Entry Psg"

```
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:5-197 HMS-S/D/M/SA "J/L5/JE4310/MCP197/Entry Psg"
|      |      | |-- 1:5-198 HFP-11 "J/L5/JE4290/SD198/Main Cabin"
|      |      | |-- 1:5-199 HFP-11 "J/L5/JE4290/SD199/Assortor Cabin"
|      |      | |-- 1:5-200 HFP-11 "J/L5/JE4290/SD200/Entry Psg."
|      |      | |-- 1:5-201 HTRI-R "J/L5/JE4290/CM201/Entry Psg. AFC"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:5-202 HMS-S/D/M/SA "J/L5/JE4290/MCP202/Entry Psg."
|      |      | |-- 1:5-203 HTRI-S "J/J/L5/4F/MM203/Psg. Nr. JW 4030"
|      |      | |-- 1:5-204 HTRI-S "J/L5/4F/MM204/Psg. Nr. JE 4120"
|      |      | |-- CC-5 "Card Cage 5 Slots"
|      |      | |-- 1:6 XDLC "XDLC @ address 6 L6"
|      |      | |-- 1:6-1 HTRI-R "J/L6/7B/5F/CM1/DR RELESE JE 501"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:6-2 HFP-11 "J/L6/7B/5F/SD2/CORR NR JE 5010"
|      |      | |-- 1:6-3 HFP-11 "J/L6/7B/5F/SD3/CORR NR JE5010 AF"
|      |      | |-- 1:6-4 HFP-11 "J/L6/7B/5F/SD4/CORR NR JE S/20"
|      |      | |-- 1:6-5 HFP-11 "J/L6/7B/5F/SD5/CORR NR JE 5040"
|      |      | |-- 1:6-6 HFP-11 "J/L6/7B/5F/SD6/CORR NR JE 5040 A"
|      |      | |-- 1:6-7 HFP-11 "J/L6/7B/5F/SD7/CORR NR JE5100"
|      |      | |-- 1:6-8 HMS-S/D/M/SA "J/L6/7B/5F/MCP8/FIRE ESC STR NR "
|      |      | |-- 1:6-9 HTRI-R "J/L6/7B/5F/CM9/FIRE ESC STR NR J"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:6-11 HFP-11 "J/L6/7B/5F/SD11/CORR NR JE 7B5/S"
|      |      | |-- 1:6-12 HFP-11 "J/L6/7B/5F/SD12/CorrNrJE7B5/S14A"
|      |      | |-- 1:6-13 HFP-11 "J/L6/7B/5F/SD13/CORR NR JE 5130"
|      |      | |-- 1:6-14 HFP-11 "J/L6/7B/5F/SD14/CORR NR JE5130 A"
|      |      | |-- 1:6-15 HFP-11 "J/L6/7B/5F/SD15/CORR NR JE 5110"
|      |      | |-- 1:6-16 HTRI-R "J/L7/7B/6F/CM16/AHU RM CM JW"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:6-17 HFP-11 "J/L7/7B/6F/SD17/AHU RM SD JW"
|      |      | |-- 1:6-18 HFP-11 "J/L6/7B/5F/SD18/CORR NR JW 5140"
|      |      | |-- 1:6-19 HFP-11 "J/L6/7B/5F/SD19/CORR NR JW 5140"
|      |      | |-- 1:6-20 HFP-11 "J/L6/7B/5F/SD20/CORR NR JW 5150"
|      |      | |-- 1:6-21 HTRI-R "J/L6/7B/5F/CM21/FIRE SHAFT L.L."
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:6-22 HMS-S/D/M/SA "J/L6/7B/5F/MCP22/FIRE SHAFT L.L."
|      |      | |-- 1:6-23 HTRI-S "J/L6/7B/5F/MM23/FIRE SHAFT L.L."
|      |      | |-- 1:6-24 HTRI-R "J/L6/7B/5F/CM24/DR RELESE L.L."
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 1:6-25 HFP-11 "J/L6/7B/5F/SD25/LIFT LOBBY SD"
|      |      | |-- 1:6-26 HFP-11 "J/L6/7B/5F/SD26/ELECT RM SD"
|      |      | |-- 1:6-27 HTRI-R "J/L6/7B/5F/CM27/DR RELESE L.L."
```

```
| | | | Switch ""
| | | | -- Relay
| | | | -- 1:6-28 HFP-11 "J/L6/7B/5F/SD28/CORR NR JW5060 A"
| | | | -- 1:6-29 HFP-11 "J/L6/7B/5F/SD29/CORR NR JW 5060"
| | | | -- 1:6-30 HFP-11 "J/L6/7B/5F/SD30/CORR NR JW5020 A"
| | | | -- 1:6-31 HFP-11 "J/L6/7B/5F/SD31/CORR NR JW 5020"
| | | | -- 1:6-32 HFP-11 "J/L6/7B/5F/SD32/CORR NR 7B S02"
| | | | -- 1:6-33 HTRI-R "J/L6/7B/5F/CM33/DR RELEASE 7B S0"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:6-34 HTRI-R "J/L6/7B/5F/CM34/DR RELEASE JE 51"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:6-35 HFP-11 "J/L6/7B/5F/SD35/CORR NR JE5170 A"
| | | | -- 1:6-36 HFP-11 "J/L6/7B/5F/SD36/CORR NR JE 5170"
| | | | -- 1:6-37 HFP-11 "J/L6/7B/5F/SD37/CORR NR JE 5200"
| | | | -- 1:6-38 HFP-11 "J/L6/7B/5F/SD38/CORR NR JE5200 A"
| | | | -- 1:6-39 HFP-11 "J/L6/7B/6F/SD39/AHU RM SD JW"
| | | | -- 1:6-40 HTRI-R "J/L6/7B/6F/CM40/AHU RM CM JW"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:6-41 HFP-11 "J/L6/7B/5F/SD41/CORR NR JE 5220"
| | | | -- 1:6-42 HMS-S/D/M/SA "J/L6/7B/5F/MCP42/FIRE ESC STR NR"
| | | | -- 1:6-43 HTRI-R "J/L6/7B/5F/CM43/FIRE ESC STR NR "
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:6-44 HTRI-S "J/L6/7B/5F/MM44/FIRE ESC STR NR "
| | | | -- 1:6-45 HFP-11 "J/L6/7B/5F/SD45/CORR NR JE 5230"
| | | | -- 1:6-46 HFP-11 "J/L6/7B/5F/SD46/CORR NR JE5230 A"
| | | | -- 1:6-47 HFP-11 "J/L6/7B/5F/SD47/CORR NR JE 5240"
| | | | -- 1:6-48 HFP-11 "J/L6/7B/5F/SD48/CORR NR JE 5130"
| | | | -- 1:6-49 HFP-11 "J/L6/7B/5F/SD49/CORR NR JE5130 A"
| | | | -- 1:6-50 HTRI-R "J/L6/7B/5F/CM50/DR RELEASE L.L."
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:6-51 HFP-11 "J/L6/JE5130/SD51/Assorter cab"
| | | | -- 1:6-52 HFP-11 "J/L6/JE5130/SD52/Main cab"
| | | | -- 1:6-53 HFPT-11 "J/L6/JE5130/HD53/Pantry"
| | | | -- 1:6-54 HFP-11 "J/L6/JE5130/SD54/Psg nr Entry"
| | | | -- 1:6-55 HTRI-R "J/L6/JE5130/CM55/Psg nr Entry"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:6-56 HMS-S/D/M/SA "J/L6/JE5130/MCP56/Psg nr Entry"
| | | | -- 1:6-57 HFP-11 "J/L6/JE5130/SD57/Accounts cab"
| | | | -- 1:6-58 HFP-11 "J/L6/7B/5F/SD58/ELECT RM SD"
| | | | -- 1:6-59 HFP-11 "J/L6/7B/5F/SD59/LIFT LOBBY SD"
| | | | -- 1:6-60 HTRI-S "J/L6/JE/5F/MM60/Psg nr JE5020"
| | | | -- 1:6-61 HTRI-S "J/L6/JE/5F/MM61/Psg nr JE5120"
| | | | -- 1:6-62 HTRI-S "J/L6/JE/5F/MM62/Psg nr JE5100"
| | | | -- 1:6-63 HTRI-S "J/L6/JW/5F/MM63/Psq nr JW5120"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:6 XDLC "XDLC @ address 6 L6"

```
|      |      |  |-- 1:6-64 HTRI-S "J/L6/JW/5F/MM64/Psg nr JW5110"
|      |      |  |-- 1:6-65 HTRI-S "J/L6/JW/5F/MM65/Psg nr JW5140"
|      |      |  |-- 1:6-66 HTRI-S "J/L6/JW/5F/MM66/Psg nr JW5150"
|      |      |  |-- 1:6-67 HTRI-S "J/L6/JW/5F/MM67/Psg nr JW5060"
|      |      |  |-- 1:6-68 HTRI-S "J/L6/JW/5F/MM68/Psg nr JW5010"
|      |      |  |-- 1:6-69 HTRI-S "J/L6/JE/5F/MM69/Psg nr JE5170"
|      |      |  |-- 1:6-70 HTRI-S "J/L6/JE/5F/MM70/Psg nr JE5200"
|      |      |  |-- 1:6-71 HTRI-S "J/L6/JE/5F/MM71/Psg nr JE5220"
|      |      |  |-- 1:6-72 HTRI-S "J/L6/JE/5F/MM72/Psg nr JE5230"
|      |      |  |-- 1:6-73 HTRI-S "J/L6/JE/5F/MM73/Psg nr JE5240"
|      |      |  |-- 1:6-74 HTRI-S "J/L6/JE/5F/MM74/Psg nr JE5150"
|      |      |  |-- 1:6-75 HFP-11 "J/L6/JE5010/SD75/Main cab"
|      |      |  |-- 1:6-76 HFP-11 "J/L6/JE5010/SD76/Assorter cab1"
|      |      |  |-- 1:6-77 HFP-11 "J/L6/JE5010/SD77/Assorter cab2"
|      |      |  |-- 1:6-78 HFP-11 "J/L6/JE5010/SD78/Pantry"
|      |      |  |-- 1:6-79 HFP-11 "J/L6/JE5010/SD79/Psg nr Pantry"
|      |      |  |-- 1:6-80 HTRI-R "J/L6/JE5010/CM80/Psg nr Entry"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:6-81 HMS-S/D/M/SA "J/L6/JE5010/MCP81/Psg nr Entry"
|      |      |  |-- 1:6-82 HFP-11 "J/L6/JE5030/SD82/Assorter cab"
|      |      |  |-- 1:6-83 HFP-11 "J/L6/JE5030/SD83/Main cab"
|      |      |  |-- 1:6-84 HFPT-11 "J/L6/JE5030/HD84/Pantry"
|      |      |  |-- 1:6-85 HFP-11 "J/L6/JE5030/SD85/Psg nr MC"
|      |      |  |-- 1:6-86 HFP-11 "J/L6/JE5030/SD86/Entry Psg"
|      |      |  |-- 1:6-87 HTRI-R "J/L6/JE5030/CM87/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:6-88 HMS-S/D/M/SA "J/L6/JE5030/MCP88/Entry Psg"
|      |      |  |-- 1:6-89 HFP-11 "J/L6/JE5050/SD89/Assorter cab"
|      |      |  |-- 1:6-90 HFP-11 "J/L6/JE5050/SD90/Main cab"
|      |      |  |-- 1:6-91 HFP-11 "J/L6/JE5050/SD91/Accounts cab"
|      |      |  |-- 1:6-92 HFP-11 "J/L6/JE5050/SD92/Pantry"
|      |      |  |-- 1:6-93 HFP-11 "J/L6/JE5050/SD93/Entry Psg"
|      |      |  |-- 1:6-94 HTRI-R "J/L6/JE5050/CM94/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:6-95 HMS-S/D/M/SA "J/L6/JE5050/MCP95/Entry Psg"
|      |      |  |-- 1:6-96 HFP-11 "J/L6/JE5060/SD96/Cab 1"
|      |      |  |-- 1:6-97 HFP-11 "J/L6/JE5060/SD97/Cab 2"
|      |      |  |-- 1:6-98 HFP-11 "J/L6/JE5060/SD98/Cab 3"
|      |      |  |-- 1:6-99 HFP-11 "J/L6/JE5060/SD99/Entry Psg"
|      |      |  |-- 1:6-100 HFPT-11 "J/L6/JE5060/HD100/Pantry"
|      |      |  |-- 1:6-101 HTRI-R "J/L6/JE5060/CM101/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:6-102 HMS-S/D/M/SA "J/L6/JE5060/MCP102/Entry Psg"
|      |      |  |-- 1:6-103 HFP-11 "J/L6/JW5020/SD103/Assorter Cab 1"
|      |      |  |-- 1:6-104 HFP-11 "J/L6/JW5020/SD104/Assorter Cab 2"
|      |      |  |-- 1:6-105 HFP-11 "J/L6/JW5020/SD105/Assorter Cab 2"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:6 XDLC "XDLC @ address 6 L6"

```
|      |      |      |-- 1:6-106 HFP-11 "J/L6/JW5020/SD106/Entry Psg"
|      |      |      |-- 1:6-107 HTRI-R "J/L6/JW5020/CM107/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-108 HMS-S/D/M/SA "J/L6/JW5020/MCP108/Entry Psg"
|      |      |      |-- 1:6-109 HFP-11 "J/L6/JW5130/SD109/Main cab"
|      |      |      |-- 1:6-110 HFP-11 "J/L6/JW5130/SD110/Accounts Cab"
|      |      |      |-- 1:6-111 HFP-11 "J/L6/JW5130/SD111/Pantry Psg"
|      |      |      |-- 1:6-112 HTRI-R "J/L6/JW5130/CM112/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-113 HMS-S/D/M/SA "J/L6/JW5130/MCP113/Entry Psg"
|      |      |      |-- 1:6-114 HFP-11 "J/L6/JW5040/SD114/Main cab"
|      |      |      |-- 1:6-115 HFP-11 "J/L6/JW5040/SD115/Cab 1"
|      |      |      |-- 1:6-116 HFP-11 "J/L6/JW5040/SD116/Accounts cab"
|      |      |      |-- 1:6-117 HFP-11 "J/L6/JW5040/SD117/Pantry Psg"
|      |      |      |-- 1:6-118 HFP-11 "J/L6/JW5040/SD118/Entry Psg"
|      |      |      |-- 1:6-119 HTRI-R "J/L6/JW5040/CM119/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-120 HMS-S/D/M/SA "J/L6/JW5040/MCP120/Entry Psg"
|      |      |      |-- 1:6-121 HFPT-11 "J/L6/JE5140/HD121/cab2"
|      |      |      |-- 1:6-122 HFP-11 "J/L6/JE5140/SD122/Main cab"
|      |      |      |-- 1:6-123 HTRI-R "J/L6/JE5140/CM123/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-124 HMS-S/D/M/SA "J/L6/JE5140/MCP124/Entry Psg"
|      |      |      |-- 1:6-125 HFP-11 "J/L6/JW5050/SD125/Main cab"
|      |      |      |-- 1:6-126 HFP-11 "J/L6/JW5050/SD126/Assorter cab"
|      |      |      |-- 1:6-127 HFP-11 "J/L6/JW5050/SD127/Psg nr Main ca"
|      |      |      |-- 1:6-128 HTRI-R "J/L6/JW5050/CM128/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-129 HMS-S/D/M/SA "J/L6/JW5050/MCP129/Entry Psg"
|      |      |      |-- 1:6-130 HFP-11 "J/L6/JE5190/SD130/Main cab"
|      |      |      |-- 1:6-131 HFP-11 "J/L6/JE5190/SD131/Pantry Psg"
|      |      |      |-- 1:6-132 HTRI-R "J/L6/JE5190/CM132/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-133 HMS-S/D/M/SA "J/L6/JE5190/MCP133/Entry Psg"
|      |      |      |-- 1:6-134 HFP-11 "J/L6/JE5110/SD134/Main cab"
|      |      |      |-- 1:6-135 HFP-11 "J/L6/JE5110/SD135/Assorter cab"
|      |      |      |-- 1:6-136 HTRI-R "J/L6/JE5110/CM136/Entry dr "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:6-137 HMS-S/D/M/SA "J/L6/JE5110/MCP137/Entry dr "
|      |      |      |-- 1:6-138 HFP-11 "J/L6/JW5030/SD138/Conference rm"
|      |      |      |-- 1:6-139 HFP-11 "J/L6/JW5030/SD139/Accounts cab"
|      |      |      |-- 1:6-140 HFP-11 "J/L6/JW5030/SD140/Entry Psg"
|      |      |      |-- 1:6-141 HFP-11 "J/L6/JW5030/SD141/Cab1"
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:6 XDLC "XDLC @ address 6 L6"
```

```
|      |      |      |-- 1:6-142 HTRI-R "J/L6/JW5030/CM142/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:6-143 HMS-S/D/M/SA "J/L6/JW5030/MCP143/Entry Psg"
|      |      |      |-- 1:6-144 HFP-11 "J/L6/JE5070/SD144/Account cab"
|      |      |      |-- 1:6-145 HFP-11 "J/L6/JE5070/SD145/Main cab"
|      |      |      |-- 1:6-146 HFP-11 "J/L6/JE5070/SD146/Assortor Cabin"
|      |      |      |-- 1:6-147 HFP-11 "J/L6/JE5070/SD147/Psg nr Pantry"
|      |      |      |-- 1:6-148 HFP-11 "J/L6/JE5070/SD148/Pantry"
|      |      |      |-- 1:6-149 HTRI-R "J/L6/JE5070/CM149/Entry dr"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:6-150 HMS-S/D/M/SA "J/L6/JE5070/MCP150/Entry dr"
|      |      |      |-- 1:6-154 HFP-11 "J/L6/JE5110/SD154/Accounts cab"
|      |      |      |-- 1:6-155 HFPT-11 "J/L6/JE5110/HD155/Pantry Psg"
|      |      |      |-- 1:6-156 HFP-11 "J/L6/JW5070/SD156/Main cab 1"
|      |      |      |-- 1:6-157 HFP-11 "J/L6/JW5070/SD157/Main cab 2"
|      |      |      |-- 1:6-158 HFP-11 "J/L6/JW5070/SD158/Account cab"
|      |      |      |-- 1:6-159 HFP-11 "J/L6/JW5070/SD159/Pantry"
|      |      |      |-- 1:6-160 HFP-11 "J/L6/JW5070/SD160/Entry Psg"
|      |      |      |-- 1:6-161 HTRI-R "J/L6/JW5070/CM161/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:6-162 HMS-S/D/M/SA "J/L6/JW5070/MCP162/Entry Psg"
|      |      |      |-- 1:6-163 HFP-11 "J/L6/JE5180/SD163/Accounts cab"
|      |      |      |-- 1:6-164 HFP-11 "J/L6/JE5180/SD164/Main Cab"
|      |      |      |-- 1:6-165 HFP-11 "J/L6/JE5180/SD165/Psg nr MC"
|      |      |      |-- 1:6-166 HFP-11 "J/L6/JE5180/SD166/Main Cab2"
|      |      |      |-- 1:6-167 HFPT-11 "J/L6/JE5180/HD167/Pantry"
|      |      |      |-- 1:6-168 HTRI-R "J/L6/JE5180/CM168/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:6-169 HMS-S/D/M/SA "J/L6/JE5180/MCP169/Entry Psg"
|      |      |  |-- 1:7 XDLC "XDLC @ address 7 L7"
|      |      |      |-- 1:7-1 HTRI-R "J/L7/6F/CM1/DR RELEASE CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:7-2 HFP-11 "J/L7/6F/SD2/CORR NR JE 6010"
|      |      |      |-- 1:7-3 HFP-11 "J/L7/6F/SD3/CORR NR JE6010 AFC"
|      |      |      |-- 1:7-4 HFP-11 "J/L7/6F/SD4/CORR NR JE 6030"
|      |      |      |-- 1:7-5 HFP-11 "J/L7/6F/SD5/CORR NR JE 6050"
|      |      |      |-- 1:7-6 HFP-11 "J/L7/6F/SD6/CORR NR JE6050 AFC"
|      |      |      |-- 1:7-7 HFP-11 "J/L7/6F/SD7/CORR NR 7B S15"
|      |      |      |-- 1:7-8 HFP-11 "J/L7/6F/SD8/CORR NR 7B S14"
|      |      |      |-- 1:7-9 HFP-11 "J/L7/6F/SD9/CORR NR 7B S14 AFC"
|      |      |      |-- 1:7-10 HMS-S/D/M/SA "J/L7/6F/MCP10/FIRE ESC STR"
|      |      |      |-- 1:7-11 HTRI-R "J/L7/6F/CM11/FIRE ESC STR"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 1:7-12 HTRI-S "J/L7/6F/MM12/FIRE ESC STR"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
1:7 XDLC "XDLC @ address 7 L7"

			-- 1:7-13 HFP-11 "J/L7/6F/SD13/CORR NR JE 6080"
			-- 1:7-14 HFP-11 "J/L7/6F/SD14/CORR NR 7B S11 AFC"
			-- 1:7-15 HFP-11 "J/L7/6F/SD15/CORR NR 7B S10"
			-- 1:7-16 HFP-11 "J/L7/6F/SD16/AHU RM SD JW"
			-- 1:7-17 HTRI-R "J/L7/6F/CM17/AHU RM CM JW"
			-- Switch ""
			-- Relay
			-- 1:7-18 HFP-11 "J/L7/6F/SD18/CORR NR JE 6190"
			-- 1:7-19 HFP-11 "J/L7/6F/SD19/CORR NR 7B S46 AFC"
			-- 1:7-20 HFP-11 "J/L7/6F/SD20/CORR NR 7B S08"
			-- 1:7-21 HFP-11 "J/L7/6F/SD21/CORR NR JW6110AFC"
			-- 1:7-22 HTRI-R "J/L7/6F/CM22/DR RELESE CM"
			-- Switch ""
			-- Relay
			-- 1:7-23 HMS-S/D/M/SA "J/L7/6F/MCP23/FIRE SHAFT L.L."
			-- 1:7-24 HTRI-R "J/L7/6F/CM24/FIRE SHAFT L.L."
			-- Switch ""
			-- Relay
			-- 1:7-25 HTRI-S "J/L7/6F/MM25/FIRE SHAFT L.L."
			-- 1:7-26 HFP-11 "J/L7/6F/SD26/LIFT LOBBY SD"
			-- 1:7-27 HFP-11 "J/L7/6F/SD27/ELECT RM SD JW"
			-- 1:7-28 HFP-11 "J/L7/6F/SD28/CORR NR JW 6060"
			-- 1:7-29 HFP-11 "J/L7/6F/SD29/CORR NR JW6010AFC"
			-- 1:7-30 HFP-11 "J/L7/6F/SD30/CORR NR JW 6010"
			-- 1:7-31 HTRI-R "J/L7/6F/CM31/DR RELESE CM"
			-- Switch ""
			-- Relay
			-- 1:7-32 HTRI-R "J/L7/6F/CM32/DR RELESE CM"
			-- Switch ""
			-- Relay
			-- 1:7-33 HFP-11 "J/L7/6F/SD33/CORR NR JE 6170"
			-- 1:7-34 HFP-11 "J/L7/6F/SD34/CORR NR JE6170 AFC"
			-- 1:7-35 HFP-11 "J/L7/6F/SD35/CORR NR 7B S25"
			-- 1:7-36 HFP-11 "J/L7/6F/SD36/CORR NR 7B S25 AFC"
			-- 1:7-37 HFP-11 "J/L7/6F/SD37/AHU RM SD JE"
			-- 1:7-38 HTRI-R "J/L7/6F/CM38/AHU RM CM JE"
			-- Switch ""
			-- Relay
			-- 1:7-39 HFP-11 "J/L7/6F/SD39/CORR NR JE 6242"
			-- 1:7-40 HMS-S/D/M/SA "J/L7/6F/MCP40/FIRE ESC STR"
			-- 1:7-41 HTRI-R "J/L7/6F/CM41/FIRE ESC STR"
			-- Switch ""
			-- Relay
			-- 1:7-42 HTRI-S "J/L7/6F/MM42/FIRE ESC STR"
			-- 1:7-43 HFP-11 "J/L7/6F/SD43/CORR NR JE 6252"
			-- 1:7-44 HFP-11 "J/L7/6F/SD44/CORR NR JE6252 AFC"
			-- 1:7-45 HFP-11 "J/L7/6F/SD45/CORR NR JE 6262"
			-- 1:7-46 HFP-11 "J/L7/6F/SD46/CORR NR JE 6140"
			-- 1:7-47 HFP-11 "J/L7/6F/SD47/CORR NR JE6140 AFC"
			-- 1:7-48 HTRI-R "J/L7/6F/CM48/ELECT RM SD"

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:7 XDLC "XDLC @ address 7 L7"

1:7-48 HTRI-R "J/L7/6F/CM48/ELECT RM SD"

```
|      |      |      |      |  |-- Switch ""
|      |      |      |      |  |-- Relay
|      |      |      |  |-- 1:7-49 HFP-11 "J/L7/6F/SD49/ELECT RM SD JE"
|      |      |      |  |-- 1:7-50 HFP-11 "J/L7/6F/SD50/LIFT LOBBY SD"
|      |      |      |  |-- 1:7-54 XTRI-S "J/L7/JE/6F/MM54/Psg nr JE6100"
|      |      |      |  |-- 1:7-55 HTRI-S "J/L7/JE/6F/MM55/Psg nr JE6060"
|      |      |      |  |-- 1:7-56 HTRI-S "J/L7/JW/6F/MM56/Psg nr JW6160"
|      |      |      |  |-- 1:7-57 HTRI-S "J/L7/JW/6F/MM57/Psg nr JW6150"
|      |      |      |  |-- 1:7-58 HTRI-S "J/L7/JW/6F/MM58/Psg nr JW6140"
|      |      |      |  |-- 1:7-59 HTRI-S "J/L7/JW/6F/MM59/Psg nr JW6190"
|      |      |      |  |-- 1:7-60 HTRI-S "J/L7/JW/6F/MM60/Psg nr JW6130"
|      |      |      |  |-- 1:7-61 HTRI-S "J/L7/JW/6F/MM61/Psg nr JW6090"
|      |      |      |  |-- 1:7-62 HTRI-S "J/L7/JW/6F/MM62/Psg nr JW6080"
|      |      |      |  |-- 1:7-63 HTRI-S "J/L7/JW/6F/MM63/Psg nr JW6060"
|      |      |      |  |-- 1:7-64 HTRI-S "J/L7/JW/6F/MM64/Psg nr JW6050"
|      |      |      |  |-- 1:7-65 HTRI-S "J/L7/JW/6F/MM65/Psg nr JW6040"
|      |      |      |  |-- 1:7-66 HTRI-S "J/L7/JW/6F/MM66/Psg nr JW6030"
|      |      |      |  |-- 1:7-67 HTRI-S "J/L7/JW/6F/MM67/Psg nr JW6010"
|      |      |      |  |-- 1:7-68 XTRI-S "J/L7/JE/6F/MM68/Psg nr JE6210"
|      |      |      |  |-- 1:7-69 XTRI-S "J/L7/JE/6F/MM69/Psg nr JE6230"
|      |      |      |  |-- 1:7-70 XTRI-S "J/L7/JE/6F/MM70/Psg nr JE6241"
|      |      |      |  |-- 1:7-71 XTRI-S "J/L7/JE/6F/MM71/Psg nr JE6242"
|      |      |      |  |-- 1:7-72 XTRI-S "J/L7/JE/6F/MM72/Psg nr JE6140"
|      |      |      |  |-- 1:7-74 HTRI-S "J/L7/6F/MM74/Psg. Nr. JE 6120"
|      |      |      |  |-- 1:7-75 HFP-11 "J/L7/JE6010/SD75/Main Cab 1"
|      |      |      |  |-- 1:7-76 HFP-11 "J/L7/JE6010/SD76/Main Cab 2"
|      |      |      |  |-- 1:7-77 HFP-11 "J/L7/JE6010/SD77/Assorter cab"
|      |      |      |  |-- 1:7-78 HFP-11 "J/L7/JE6010/SD78/Entry Psg"
|      |      |      |  |-- 1:7-79 HTRI-R "J/L7/JE6010/CM79/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |  |-- 1:7-80 HMS-S/D/M/SA "J/L7/JE6010/MCP80/Entry Psg"
|      |      |      |  |-- 1:7-81 HFP-11 "J/L7/JE6030/SD81/Assorter cab"
|      |      |      |  |-- 1:7-82 HFP-11 "J/L7/JE6030/SD82/Psg nr Main cab"
|      |      |      |  |-- 1:7-83 HFPT-11 "J/L7/JE6030/HD83/Entry Psg"
|      |      |      |  |-- 1:7-84 HFP-11 "J/L7/JE6030/SD84/Main cab"
|      |      |      |  |-- 1:7-85 HTRI-R "J/L7/JE6030/CM85/Entry Psg "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |  |-- 1:7-86 HMS-S/D/M/SA "J/L7/JE6030/MCP86/Entry Psg "
|      |      |      |  |-- 1:7-87 HFP-11 "J/L7/JE6130/SD87/Cab 1"
|      |      |      |  |-- 1:7-88 HFP-11 "J/L7/JE6130/SD88/Cab 2"
|      |      |      |  |-- 1:7-89 HFP-11 "J/L7/JE6130/SD89/Cab 3"
|      |      |      |  |-- 1:7-90 HFP-11 "J/L7/JE6130/SD90/Entry Psg"
|      |      |      |  |-- 1:7-91 HTRI-R "J/L7/JE6130/CM91/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |  |-- 1:7-92 HMS-S/D/M/SA "J/L7/JE6130/MCP92/Entry Psg"
|      |      |      |  |-- 1:7-93 HFP-11 "J/L7/JE6080/SD93/Cab 1"
|      |      |      |  |-- 1:7-94 HFP-11 "J/L7/JE6080/SD94/Cab 2"
```



```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:7 XDLC "XDLC @ address 7 L7"
```

```
|      |      |  |-- 1:7-95 HFP-11 "J/L7/JE6080/SD95/Assorter cab"
|      |      |  |-- 1:7-96 HFP-11 "J/L7/JE6080/SD96/Pantry"
|      |      |  |-- 1:7-97 HFP-11 "J/L7/JE6080/SD97/Psg nr Pantry"
|      |      |  |-- 1:7-98 HMS-S/D/M/SA "J/L7/JE6080/MCP98/Entry Psg"
|      |      |  |-- 1:7-99 HTRI-R "J/L7/JE6080/CM99/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:7-100 HFP-11 "J/L7/JW6170/SD100/Cab 1"
|      |      |  |-- 1:7-101 HFP-11 "J/L7/JW6170/SD101/Cab 2"
|      |      |  |-- 1:7-102 HFP-11 "J/L7/JW6170/SD102/Cab 3"
|      |      |  |-- 1:7-103 HFP-11 "J/L7/JW6170/SD103/Cab 4"
|      |      |  |-- 1:7-104 HFP-11 "J/L7/JW6170/SD104/Entry Psg"
|      |      |  |-- 1:7-105 HTRI-R "J/L7/JW6170/CM105/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:7-106 HMS-S/D/M/SA "J/L7/JW6170/MCP106/Entry Psg"
|      |      |  |-- 1:7-107 HFP-11 "J/L7/JW6120/SD107/Main cab"
|      |      |  |-- 1:7-108 HFP-11 "J/L7/JW6120/SD108/Pantry Psg"
|      |      |  |-- 1:7-109 HTRI-R "J/L7/JW6120/CM109/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:7-110 HMS-S/D/M/SA "J/L7/JW6120/MCP110/Entry Psg"
|      |      |  |-- 1:7-111 HFP-11 "J/L7/JW6100/SD111/Main cab"
|      |      |  |-- 1:7-112 HFP-11 "J/L7/JW6100/SD112/Entry Psg"
|      |      |  |-- 1:7-113 HTRI-R "J/L7/JW6100/CM113/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:7-114 HMS-S/D/M/SA "J/L7/JW6100/MCP114/Entry Psg"
|      |      |  |-- 1:7-115 HFP-11 "J/L7/JW6070/SD115/Cab 1"
|      |      |  |-- 1:7-116 HFP-11 "J/L7/JW6070/SD116/Cab 2"
|      |      |  |-- 1:7-117 HFP-11 "J/L7/JW6070/SD117/Psg nr Cab 2"
|      |      |  |-- 1:7-118 HFP-11 "J/L7/JW6070/SD118/Pantry Psg"
|      |      |  |-- 1:7-119 HTRI-R "J/L7/JW6070/CM119/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:7-120 HMS-S/D/M/SA "J/L7/JW6070/MCP120/Entry Psg"
|      |      |  |-- 1:7-121 HFP-11 "J/L7/JW6110/SD121/Main cab"
|      |      |  |-- 1:7-122 FDOT421 "J/L7/JW6110/SD122/Cab nr Pantry"
|      |      |  |-- 1:7-123 FDOT421 "J/L7/JW6110/SD123/Pantry"
|      |      |  |-- 1:7-124 HTRI-R "J/L7/JW6110/CM124/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 1:7-125 HMS-S/D/M/SA "J/L7/JW6110/MCP125/Entry Psg"
|      |      |  |-- 1:7-126 HFP-11 "J/L7/JE6040/SD126/Entry Psg"
|      |      |  |-- 1:7-127 HFP-11 "J/L7/JE6040/SD127/Accounts cab"
|      |      |  |-- 1:7-128 HFP-11 "J/L7/JE6040/SD128/Assorter cab"
|      |      |  |-- 1:7-129 HFP-11 "J/L7/JE6040/SD129/Main cab"
|      |      |  |-- 1:7-130 HTRI-R "J/L7/JE6040/CM130/Psg nr Entry"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
```

```
1 Desigo Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:7 XDLC "XDLC @ address 7 L7"
```

```
|      |      |  |-- 1:7-131 HMS-S/D/M/SA "J/L7/JE6040/MCP131/Psg nr Entry"
|      |      |  |-- 1:7-132 HFP-11 "J/L7/JE6160/SD132/Accounts cab"
|      |      |  |-- 1:7-133 HFP-11 "J/L7/JE6160/SD133/Main cab"
|      |      |  |-- 1:7-134 HFP-11 "J/L7/JE6160/SD134/Assorter cab"
|      |      |  |-- 1:7-135 HFP-11 "J/L7/JE6160/SD135/Pantry"
|      |      |  |-- 1:7-136 HTRI-R "J/L7/JE6160/CM136/Psg nr Entry"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:7-137 HMS-S/D/M/SA "J/L7/JE6160/MCP137/Psg nr Entry"
|      |      |  |-- 1:7-138 HFP-11 "J/L7/JE6261/SD138/Main cab"
|      |      |  |-- 1:7-139 HFP-11 "J/L7/JE6261/SD139/Entry Psg"
|      |      |  |-- 1:7-140 HMS-S/D/M/SA "J/L7/JE6261/MCP140/Entry Psg"
|      |      |  |-- 1:7-141 HTRI-R "J/L7/JE6261/CM141/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:7-142 HFP-11 "J/L7/JE6170/SD142/Accounts cab"
|      |      |  |-- 1:7-143 HFP-11 "J/L7/JE6170/SD143/Main cab"
|      |      |  |-- 1:7-144 HFP-11 "J/L7/JE6170/SD144/Assorter cab"
|      |      |  |-- 1:7-145 HFP-11 "J/L7/JE6170/SD145/Entry Psg"
|      |      |  |-- 1:7-146 HTRI-R "J/L7/JE6170/CM146/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:7-147 HMS-S/D/M/SA "J/L7/JE6170/MCP147/Entry dr Psg"
|      |      |  |-- 1:7-148 HTRI-S "J/L7/6F/MM148/Psg. Nr. JE 6190"
|      |      |  |-- 1:7-149 HTRI-S "J/L7/6F/MM149/Psg. Nr. JE 6252"
|      |      |  |-- 1:7-151 HTRI-S "J/L7/6F/MM151/Psg. Nr. JE 6270"
|      |      |  |-- 1:7-152 HTRI-S "J/L7/6F/MM152/Psg. Nr. JE 6280"
|      |      |  |-- 1:7-153 HTRI-S "J/L7/6F/MM153/Psg. Nr. JW 6020"
|      |      |  |-- 1:7-155 HFP-11 "J/L7/JE6090/SD155/Main cab 1"
|      |      |  |-- 1:7-156 HFP-11 "J/L7/JE6090/SD156/Main cab 2"
|      |      |  |-- 1:7-157 HFP-11 "J/L7/JE6090/SD157/Pantry Psg"
|      |      |  |-- 1:7-158 HTRI-R "J/L7/JE6090/CM158/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:7-159 HMS-S/D/M/SA "J/L7/JE6090/MCP159/Entry Psg"
|      |      |  |-- 1:7-160 HFP-11 "J/L7/JE6090/SD160/Entry Psg"
|      |      |  |-- 1:7-161 HFP-11 "J/L7/JE6200/SD161/Main cab "
|      |      |  |-- 1:7-162 HFP-11 "J/L7/JE6200/SD162/Assorter cab"
|      |      |  |-- 1:7-163 HFP-11 "J/L7/JE6200/SD163/Account cab"
|      |      |  |-- 1:7-164 HFP-11 "J/L7/JE6200/SD164/Psg nr acc.cab"
|      |      |  |-- 1:7-165 HFP-11 "J/L7/JE6200/SD165/Boss cab"
|      |      |  |-- 1:7-166 HFPT-11 "J/L7/JE6200/HD166/Pantry"
|      |      |  |-- 1:7-167 HTRI-R "J/L7/JE6200/CM167/AFC Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 1:7-168 HMS-S/D/M/SA "J/L7/JE6200/MCP168/Entry Psg"
|      |      |  |-- 1:7-169 HFP-11 "J/L7/JE6180/SD169/Main cab "
|      |      |  |-- 1:7-170 HFPT-11 "J/L7/JE6180/HD170/Pantry entrysi"
|      |      |  |-- 1:7-171 HTRI-R "J/L7/JE6180/CM171/Entry dr psg"
|      |      |  |-- Switch ""
```

[illegible]

1 Desigo Fire Safety Modular "BDB TOWER J" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
1:8 XDLC "XDLC @ address 8 L8"

				--	1:8-35	HFP-11	"J/L8/7B/7F/SD35/CORR NR 7B S35 A"
				--	1:8-36	HFP-11	"J/L8/7B/7F/SD36/CORR NR 7B S27"
				--	1:8-37	HFP-11	"J/L8/7B/7F/SD37/CORR NR JE7170AF"
				--	1:8-38	HFP-11	"J/L8/7B/7F/SD38/CORR NR JE7170"
				--	1:8-39	HFP-11	"J/L8/7B/7F/SD39/AHU RM SD JE"
				--	1:8-40	HTRI-R	"J/L8/7B/7F/CM40/AHU RM CM JE"
				--	Switch	"	"
				--	Relay		
				--	1:8-41	HFP-11	"J/L8/7B/7F/SD41/CORR NR WERWISE "
				--	1:8-42	HMS-S/D/M/SA	"J/L8/7B/7F/MCP42/FIRE ESC STR"
				--	1:8-43	HTRI-R	"J/L8/7B/7F/CM43/FIRE ESC STR"
				--	Switch	"	"
				--	Relay		
				--	1:8-44	HTRI-S	"J/L8/7B/7F/MM44/FIRE ESC STR"
				--	1:8-45	HFP-11	"J/L8/7B/7F/SD45/CORR NR JE 7190"
				--	1:8-46	HFP-11	"J/L8/7B/7F/SD46/CORR NR JE7190 A"
				--	1:8-47	HFP-11	"J/L8/7B/7F/SD47/CORR NR JE7140"
				--	1:8-48	HFP-11	"J/L8/7B/7F/SD48/CORR NR JE 7210"
				--	1:8-49	HFP-11	"J/L8/7B/7F/SD49/CORR NR JE7210 A"
				--	1:8-50	HTRI-R	"J/L8/7B/7F/CM50/DR RELESE CM"
				--	Switch	"	"
				--	Relay		
				--	1:8-51	HFP-11	"J/L8/7B/7F/SD51/JE ELECT RM SD"
				--	1:8-52	HFP-11	"J/L8/7B/7F/SD52/LIFT LOBBY SD JE"
				--	1:8-54	HTRI-S	"J/L8/JE/7F/MM54/Psg nr JE7010"
				--	1:8-55	HTRI-S	"J/L8/JE/7F/MM55/Psg nr JE7120"
				--	1:8-56	HTRI-S	"J/L8/JE/7F/MM56/Psg nr JE7110"
				--	1:8-57	HTRI-S	"J/L8/JE/7F/MM57/Psg nr JE7040"
				--	1:8-58	HTRI-S	"J/L8/JE/7F/MM58/Psg nr JE7070"
				--	1:8-59	HTRI-S	"J/L8/JW/7F/MM59/Psg nr JW7220"
				--	1:8-60	HTRI-S	"J/L8/JW/7F/MM60/Psg nr JW7210"
				--	1:8-61	HTRI-S	"J/L8/JW/7F/MM61/Psg nr JW7180"
				--	1:8-62	HTRI-S	"J/L8/JW/7F/MM62/Psg nr JW7160"
				--	1:8-63	HTRI-S	"J/L8/JW/7F/MM63/Psg nr JW7140"
				--	1:8-64	HTRI-S	"J/L8/JW/7F/MM64/Psg nr JW7130"
				--	1:8-65	HTRI-S	"J/L8/JW/7F/MM65/Psg nr JW7020"
				--	1:8-66	HTRI-S	"J/L8/JW/7F/MM66/Psg nr JW7100"
				--	1:8-67	HTRI-S	"J/L8/JW/7F/MM67/Psg nr JW7090"
				--	1:8-68	HTRI-S	"J/L8/JW/7F/MM68/Psg nr JW7040"
				--	1:8-69	HTRI-S	"J/L8/JW/7F/MM69/Psg nr JW7080"
				--	1:8-70	HTRI-S	"J/L8/JW/7F/MM70/Psg nr JW7060"
				--	1:8-71	HTRI-S	"J/L8/JW/7F/MM71/Psg nr JE7190"
				--	1:8-73	HTRI-S	"J/L8/JW/7F/MM73/Psg nr JW7190"
				--	1:8-75	HFP-11	"J/L8/JE7020/SD75/Assorter cab"
				--	1:8-76	HFP-11	"J/L8/JE7020/SD76/Main cab"
				--	1:8-77	HFP-11	"J/L8/JE7020/SD77/Main cab"
				--	1:8-78	HFP-11	"J/L8/JE7020/SD78/Entry Psg"
				--	1:8-79	HFPT-11	"J/L8/JE7020/HD79/Pantry"
				--	1:8-80	HTRI-R	"J/L8/JE7020/CM80/Entry Psg"
				--	Switch	"	"

```

1 Design Fire Safety Modular "BDB TOWER J" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      1:8 XDLC "XDLC @ address 8 L8"
        1:8-80 HTRI-R "J/L8/JE7020/CM80/Entry Psg"

```

```

| | | | | Relay
| | | | |
| | | | | |--- 1:8-81 HMS-S/D/M/SA "J/L8/JE7020/MCP81/Entry Psg"
| | | | | |--- 1:8-82 HFP-11 "J/L8/JE7030/SD82/Account cab"
| | | | | |--- 1:8-83 HFP-11 "J/L8/JE7030/SD83/Pantry"
| | | | | |--- 1:8-84 HFP-11 "J/L8/JE7030/SD84/Main cab"
| | | | | |--- 1:8-85 HFP-11 "J/L8/JE7030/SD85/Main cab"
| | | | | |--- 1:8-86 HTRI-R "J/L8/JE7030/CM86/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:8-87 HMS-S/D/M/SA "J/L8/JE7030/MCP87/Entry Psg"
| | | | | |--- 1:8-88 HFP-11 "J/L8/JE7030/SD88/AFC Main cab"
| | | | | |--- 1:8-89 HFP-11 "J/L8/JE7050/SD89/Pantry psg"
| | | | | |--- 1:8-90 HFP-11 "J/L8/JE7050/SD90/Main cab"
| | | | | |--- 1:8-91 HFP-11 "J/L8/JE7050/SD91/Account cab"
| | | | | |--- 1:8-92 HTRI-R "J/L8/JE7050/CM92/Entry psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:8-93 HMS-S/D/M/SA "J/L8/JE7050/MCP93/Entry psg"
| | | | | |--- 1:8-94 HFP-11 "J/L8/JE7060/SD94/Assorter cab"
| | | | | |--- 1:8-95 HFP-11 "J/L8/JE7060/SD95/Main cab"
| | | | | |--- 1:8-96 HFP-11 "J/L8/JE7060/SD96/Account cab"
| | | | | |--- 1:8-97 HFP-11 "J/L8/JE7060/SD97/Pantry"
| | | | | |--- 1:8-98 HTRI-R "J/L8/JE7060/CM98/Entry door"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:8-99 HMS-S/D/M/SA "J/L8/JE7060/MCP99/Entry door"
| | | | | |--- 1:8-100 HFP-11 "J/L8/JE7090/SD100/Main cab"
| | | | | |--- 1:8-101 HFP-11 "J/L8/JE7090/SD101/Cab 1"
| | | | | |--- 1:8-102 HFP-11 "J/L8/JE7090/SD102/Cab 2"
| | | | | |--- 1:8-103 HFP-11 "J/L8/JE7090/SD103/Cab 3"
| | | | | |--- 1:8-104 HFP-11 "J/L8/JE7090/SD104/Cab 4"
| | | | | |--- 1:8-105 HFP-11 "J/L8/JE7090/SD105/Pantry"
| | | | | |--- 1:8-106 HFP-11 "J/L8/JE7090/SD106/Entry Psg"
| | | | | |--- 1:8-107 HTRI-R "J/L8/JE7090/CM107/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:8-108 HMS-S/D/M/SA "J/L8/JE7090/MCP108/Entry Psg"
| | | | | |--- 1:8-109 HFP-11 "J/L8/JW7200/SD109/Assorter cab"
| | | | | |--- 1:8-110 HFP-11 "J/L8/JW7200/SD110/Main cab"
| | | | | |--- 1:8-111 HFP-11 "J/L8/JW7200/SD111/Account cab"
| | | | | |--- 1:8-112 HFP-11 "J/L8/JW7200/SD112/Pantry Psg"
| | | | | |--- 1:8-113 HTRI-R "J/L8/JW7200/CM113/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:8-114 HMS-S/D/M/SA "J/L8/JW7200/MCP114/Entry Psg"
| | | | | |--- 1:8-115 HFP-11 "J/L8/JW7170/SD115/cab 1"
| | | | | |--- 1:8-116 HFP-11 "J/L8/JW7170/SD116/cab 2"
| | | | | |--- 1:8-117 HFP-11 "J/L8/JW7170/SD117/cab 3"
| | | | | |--- 1:8-118 HFPT-11 "J/L8/JW7170/HD118/Account cab"
| | | | | |--- 1:8-119 HTRI-R "J/L8/JW7170/CM119/Entry Psg"

```

```
| | | | Switch ""
| | | | -- Relay
| | | | -- 1:8-120 HMS-S/D/M/SA "J/L8/JW7170/MCP120/Entry Psg"
| | | | -- 1:8-121 HFP-11 "J/L8/JE7170/SD121/Main cab"
| | | | -- 1:8-122 HFP-11 "J/L8/JE7170/SD122/Cab 1"
| | | | -- 1:8-123 HFP-11 "J/L8/JE7170/SD123/Cab 2"
| | | | -- 1:8-124 HFP-11 "J/L8/JE7170/SD124/Cab 3"
| | | | -- 1:8-125 HFP-11 "J/L8/JE7170/SD125/Cab 4"
| | | | -- 1:8-126 HTRI-R "J/L8/JE7170/CM126/Entry Psg "
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:8-127 HMS-S/D/M/SA "J/L8/JE7170/MCP127/Entry Psg "
| | | | -- 1:8-128 HFP-11 "J/L8/JE7180/SD128/Account cab"
| | | | -- 1:8-129 HFP-11 "J/L8/JE7180/SD129/Main cab"
| | | | -- 1:8-130 HFP-11 "J/L8/JE7180/SD130/Assorter cab"
| | | | -- 1:8-131 HFP-11 "J/L8/JE7180/SD131/Entry Psg"
| | | | -- 1:8-132 HTRI-R "J/L8/JE7180/CM132/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:8-133 HMS-S/D/M/SA "J/L8/JE7180/MCP133/Entry Psg"
| | | | -- 1:8-134 HFP-11 "J/L8/JE7160/SD134/Main cab"
| | | | -- 1:8-135 HFP-11 "J/L8/JE7160/SD135/Account cab"
| | | | -- 1:8-136 HFP-11 "J/L8/JE7160/SD136/Pantry Psg"
| | | | -- 1:8-137 HTRI-R "J/L8/JE7160/CM137/Psg nr Entry"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:8-138 HMS-S/D/M/SA "J/L8/JE7160/MCP138/Psg nr Entry"
| | | | -- 1:8-139 HFP-11 "J/L8/JW7030/SD139/Cab 1"
| | | | -- 1:8-140 HFP-11 "J/L8/JW7030/SD140/Cab 2"
| | | | -- 1:8-141 HFP-11 "J/L8/JW7030/SD141/Main cab"
| | | | -- 1:8-142 HFP-11 "J/L8/JW7030/SD142/Entry Psg"
| | | | -- 1:8-143 HTRI-R "J/L8/JW7030/CM143/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:8-144 HMS-S/D/M/SA "J/L8/JW7030/MCP144/Entry Psg"
| | | | -- 1:8-145 HFP-11 "J/L8/JE7130/SD145/Samarpan Jewel"
| | | | -- 1:8-146 HFP-11 "J/L8/JE7130/SD146/Sachin Jewels "
| | | | -- 1:8-147 HFP-11 "J/L8/JE7130/SD147/Basant Jewels "
| | | | -- 1:8-148 HFP-11 "J/L8/JE7130/SD148/Riya Jems"
| | | | -- 1:8-149 HFP-11 "J/L8/JE7130/SD149/Psg nr basant "
| | | | -- 1:8-150 HFP-11 "J/L8/JE7130/SD150/Entry dr Psg"
| | | | -- 1:8-151 HTRI-R "J/L8/JE7130/CM151/Entry dr Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | | -- 1:8-152 HMS-S/D/M/SA "J/L8/JE7130/MCP152/Entry dr Psg"
| | | | -- 1:8-153 HFP-11 "J/L8/JW7240/SD153/Main cab"
| | | | -- 1:8-154 HFP-11 "J/L8/JW7240/SD154/Main cab"
| | | | -- 1:8-155 HFP-11 "J/L8/JW7240/SD155/Assorter cab"
| | | | -- 1:8-156 HFP-11 "J/L8/JW7240/SD156/Assorter cab"
| | | | -- 1:8-157 HFP-11 "J/L8/JW7240/SD157/Pantrv"
```

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:8 XDLC "XDLC @ address 8 L8"

```
|      |      |  |-- 1:8-158 HFP-11 "J/L8/JW7240/SD158/Reception Psg"
|      |      |  |-- 1:8-159 HTRI-R "J/L8/JW7240/CM159/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:8-160 HMS-S/D/M/SA "J/L8/JW7240/MCP160/Entry dr Psg"
|      |      |  |-- 1:8-161 HTRI-S "J/L8/7F/MM161/JW7110"
|      |      |  |-- 1:8-162 HTRI-S "J/L8/7F/MM162/JW7010"
|      |      |  |-- 1:8-163 HTRI-S "J/L8/7F/MM163/JE7210"
|      |      |  |-- 1:8-166 HTRI-S "J/L8/7F/MM166/JW7070"
|      |      |  |-- 1:8-167 HFP-11 "J/L8/JE7050/SD167/Buyers cab"
|      |      |  |-- 1:8-171 HFP-11 "J/L8/JE7150/SD171/Account Cabin"
|      |      |  |-- 1:8-172 HFP-11 "J/L8/JE7150/SD172/Entry Psg."
|      |      |  |-- 1:8-173 HFP-11 "J/L8/JE7150/SD173/Assortor Cabin"
|      |      |  |-- 1:8-174 HFP-11 "J/L8/JE7150/SD174/Main Cabin"
|      |      |  |-- 1:8-175 HFP-11 "J/L8/JE7150/SD175/Assortor Cabin"
|      |      |  |-- 1:8-176 HTRI-R "J/L8/JE7150/CM176/Entry Psg. AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:8-177 HMS-S/D/M/SA "J/L8/JE7150/MCP177/Entry Psg."
|      |      |  |-- 1:8-178 HFPT-11 "J/L8/JW7030/HD178/PANTRY"
|      |      |  |-- 1:8-180 HFP-11 "J/L8/JE7180/SD180/Entry Psg"
|      |      |  |-- 1:8-181 HFPT-11 "J/L8/JE7180/SD181/Panty"
|      |      |  |-- 1:9 XDLC "XDLC @ address 9 L9"
|      |      |  |-- 1:9-1 HTRI-R "J/L9/7B/8F/CM1/DR RELESE CM JE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:9-2 HFP-11 "J/L9/7B/8F/SD2/CORR NR JE8010 AF"
|      |      |  |-- 1:9-3 HFP-11 "J/L9/7B/8F/SD3/CORR NR JE 8010"
|      |      |  |-- 1:9-4 HFP-11 "J/L9/7B/8F/SD4/CORR NR JE 8200"
|      |      |  |-- 1:9-5 HFP-11 "J/L9/7B/8F/SD5/COR NR JE 8/S18 A"
|      |      |  |-- 1:9-6 HFP-11 "J/L9/7B/8F/SD6/CORR NR JE 8170"
|      |      |  |-- 1:9-7 HFP-11 "J/L9/7B/8F/SD7/CORR NR JE 8080"
|      |      |  |-- 1:9-8 HTRI-R "J/L9/7B/8F/CM8/FIRE ESC STR NR J"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:9-9 HFP-11 "J/L9/7B/8F/SD9/CORR NR 7B S14"
|      |      |  |-- 1:9-10 HMS-S/D/M/SA "J/L9/7B/8F/MCP10/FIRE SHAFT L.L."
|      |      |  |-- 1:9-11 HTRI-S "J/L9/7B/8F/MM11/FIRE SHAFT L.L.J"
|      |      |  |-- 1:9-12 HFP-11 "J/L9/7B/8F/SD12/CORR NR JE 8110A"
|      |      |  |-- 1:9-13 HFP-11 "J/L9/7B/8F/SD13/CorNr JW7B8/S11A"
|      |      |  |-- 1:9-14 HFP-11 "J/L9/7B/8F/SD14/CORR NR JW 7B8/S"
|      |      |  |-- 1:9-15 HFP-11 "J/L9/7B/8F/SD15/CORR NR JW 8250"
|      |      |  |-- 1:9-16 HFP-11 "J/L9/7B/8F/SD16/AHU RM SD JW"
|      |      |  |-- 1:9-17 HTRI-R "J/L9/7B/8F/CM17/AHU RM CM JW"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 1:9-18 HFP-11 "J/L9/7B/8F/SD18/CORR NR 7B S09 A"
|      |      |  |-- 1:9-19 HFP-11 "J/L9/7B/8F/SD19/CORR NR 7B S09"
|      |      |  |-- 1:9-20 HFP-11 "J/L9/7B/8F/SD20/CORR NR 7B S08"
|      |      |  |-- 1:9-21 HTRI-R "J/L9/7B/8F/CM21/DR RELESE CM "
```

```
| | | | | Switch ""
| | | | | Relay
| | | | | -- 1:9-22 HMS-S/D/M/SA "J/L9/7B/8F/MCP22/FIRE SHAFT L.L."
| | | | | -- 1:9-23 HTRI-R "J/L9/7B/8F/CM23/FIRE SHAFT L.L."
| | | | | Switch ""
| | | | | Relay
| | | | | -- 1:9-24 HTRI-S "J/L9/7B/8F/MM24/FIRE SHAFT L.L.J"
| | | | | -- 1:9-25 HFP-11 "J/L9/7B/8F/SD25/LIFT LOBBY SD"
| | | | | -- 1:9-26 HFP-11 "J/L9/7B/8F/SD26/JW ELECT RM SD"
| | | | | -- 1:9-27 HTRI-R "J/L9/7B/8F/CM27/DR RELEASE CM"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 1:9-28 HFP-11 "J/L9/7B/8F/SD28/CORR NR DR JW AF"
| | | | | -- 1:9-29 HFP-11 "J/L9/7B/8F/SD29/CORR NR DR JW"
| | | | | -- 1:9-30 HFP-11 "J/L9/7B/8F/SD30/CORR NR JW 8150"
| | | | | -- 1:9-31 HFP-11 "J/L9/7B/8F/SD31/CORR NR 7B/S49 A"
| | | | | -- 1:9-32 HFP-11 "J/L9/7B/8F/SD32/CORR NR 7B/S49"
| | | | | -- 1:9-33 HFP-11 "J/L9/7B/8F/SD33/CORR NR JW 8030"
| | | | | -- 1:9-34 HFP-11 "J/L9/7B/8F/SD34/CORR NR 7B S27 A"
| | | | | -- 1:9-35 HFP-11 "J/L9/7B/8F/SD35/CORR NR JE 8090"
| | | | | -- 1:9-36 HFP-11 "J/L9/7B/8F/SD36/CORR NR 7B S27"
| | | | | -- 1:9-37 HFP-11 "J/L9/7B/8F/SD37/CORR NR JE 8270"
| | | | | -- 1:9-38 HFP-11 "J/L9/7B/8F/SD38/CORR NR JE 8270A"
| | | | | -- 1:9-39 HFP-11 "J/L9/7B/8F/SD39/AHU RM SD JE"
| | | | | -- 1:9-40 HTRI-R "J/L9/7B/8F/CM40/AHU RM CM JE"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 1:9-41 HFP-11 "J/L9/7B/8F/SD41/CORR NR AHU JE"
| | | | | -- 1:9-42 HMS-S/D/M/SA "J/L9/7B/8F/MCP42/FIRE SHAFT L.L."
| | | | | -- 1:9-43 HTRI-R "J/L9/7B/8F/CM43/FIRE SHAFT JE"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 1:9-44 HTRI-S "J/L9/7B/8F/MM44/FIRE SHAFT JE"
| | | | | -- 1:9-45 HFP-11 "J/L9/7B/8F/SD45/CORR NR JE 8320"
| | | | | -- 1:9-46 HFP-11 "J/L9/7B/8F/SD46/CORR NR JE 8320A"
| | | | | -- 1:9-47 HFP-11 "J/L9/7B/8F/SD47/CORR NR JE 8240/"
| | | | | -- 1:9-48 HFP-11 "J/L9/7B/8F/SD48/CORR NR JE 8220"
| | | | | -- 1:9-49 HFP-11 "J/L9/7B/8F/SD49/CORR NR JE8220 A"
| | | | | -- 1:9-50 HTRI-R "J/L9/7B/8F/CM50/DR RELEASE CM JE"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 1:9-51 HFP-11 "J/L9/7B/8F/SD51/JE ELECT RM SD"
| | | | | -- 1:9-52 HFP-11 "J/L9/7B/8F/SD52/JE LIFT LOBBY SD"
| | | | | -- 1:9-53 HFP-11 "J/L9/JW/9F/SD53/Psg AFCnr9010/B1"
| | | | | -- 1:9-54 HFP-11 "J/L9/JW/9F/SD54/Psg BFC nr9010/B"
| | | | | -- 1:9-55 HFP-11 "J/L9/JW/9F/SD55/Psg AFC nr9010/B"
| | | | | -- 1:9-56 HFP-11 "J/L9/JW/9F/SD56/PsgBFCnr9010B10-"
| | | | | -- 1:9-57 HFP-11 "J/L9/JW/9F/SD57/PsgAFcnr9010B16-"
| | | | | -- 1:9-58 HFP-11 "J/L9/JW/9F/SD58/Psg BFC nr 9010/"
| | | | | -- 1:9-59 HMS-S/D/M/SA "J/L9/JW/9F/MCP-59/Psg nr Fire st
```


1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:9 XDLC "XDLC @ address 9 L9"

```
|      |      |      | 1:9-60 HTRI-R "J/L9/JW/9F/CM-60/Psg AFC nr Fire"
|      |      |      |      | 1:9-61 HTRI-S "J/L9/JW/9F/MM-61/Psg AFC nr Fire"
|      |      |      |      | 1:9-62 HFP-11 "J/L9/JW/9F/SD62/Psg AFC nr 9010/"
|      |      |      |      | 1:9-63 HFP-11 "J/L9/JW/9F/SD63/Psg BFC nr 9010/"
|      |      |      |      | 1:9-64 HFP-11 "J/L9/JW/9F/SD64/Psg AFC nr 9010/"
|      |      |      |      | 1:9-65 HFP-11 "J/L9/JW/9F/SD65/Psg BFC nr 9010/"
|      |      |      |      | 1:9-66 HFP-11 "J/L9/JW/9F/SD66/Psg AFC nr 9010/"
|      |      |      |      | 1:9-67 HFP-11 "J/L9/JW/9F/SD67/Psg BFC nr 9010/"
|      |      |      |      | 1:9-68 HFP-11 "J/L9/JW/9F/SD68/Psg AFC nr 9010/"
|      |      |      |      | 1:9-69 HFP-11 "J/L9/JW/9F/SD69/Psg BFC nr 9010/"
|      |      |      |      | 1:9-70 HFP-11 "J/L9/JW/9F/SD70/Psg AFC nr 9010/"
|      |      |      |      | 1:9-71 HFP-11 "J/L9/JW/9F/SD71/Psg BFC nr 9010/"
|      |      |      |      | 1:9-72 HFP-11 "J/L9/JW/9F/SD72/Psg AFC nr 9010/"
|      |      |      |      | 1:9-73 HTRI-S "J/L9/JW/9F/MM73/JW9010/B15"
|      |      |      |      | 1:9-74 HFP-11 "J/L9/JE8080/SD74/Main Cab"
|      |      |      |      | 1:9-75 HTRI-S "J/L9/JE/8F/MM75/Psg nr JE8190"
|      |      |      |      | 1:9-76 XTRI-S "J/L9/JE/8F/MM76/Psg nr JE8040"
|      |      |      |      | 1:9-77 XTRI-S "J/L9/JE/8F/MM77/Psg nr JE8050"
|      |      |      |      | 1:9-78 HTRI-S "J/L9/JE/8F/MM78/Psg nr JE8090"
|      |      |      |      | 1:9-79 HTRI-S "J/L9/JE/8F/MM79/Psg nr JE8100"
|      |      |      |      | 1:9-80 HTRI-S "J/L9/JW/8F/MM80/Psg nr JW8280"
|      |      |      |      | 1:9-81 HTRI-S "J/L9/JW/8F/MM81/Psg nr JW8290"
|      |      |      |      | 1:9-82 HTRI-S "J/L9/JW/8F/MM82/Psg nr JW8170"
|      |      |      |      | 1:9-83 HTRI-S "J/L9/JW/8F/MM83/Psg nr JW8130"
|      |      |      |      | 1:9-84 HTRI-S "J/L9/JW/8F/MM84/Psg nr JW8020"
|      |      |      |      | 1:9-85 HTRI-S "J/L9/JW/8F/MM85/Psg nr JW8100"
|      |      |      |      | 1:9-86 HTRI-S "J/L9/JW/8F/MM86/Psg nr JW8030"
|      |      |      |      | 1:9-87 HTRI-S "J/L9/JW/8F/MM87/Psg nr JW8040"
|      |      |      |      | 1:9-88 HTRI-S "J/L9/JW/8F/MM88/Psg nr JW8060"
|      |      |      |      | 1:9-89 HTRI-S "J/L9/JE/8F/MM89/Psg nr JE8320"
|      |      |      |      | 1:9-90 HTRI-S "J/L9/JE/8F/MM90/Psg nr JE8330"
|      |      |      |      | 1:9-91 HTRI-S "J/L9/JE/8F/MM91/Psg nr JE8220"
|      |      |      |      | 1:9-92 HTRI-S "J/L9/JE/8F/MM92/JE8310"
|      |      |      |      | 1:9-93 XTRI-S "J/L9/JE/8F/MM93/JE8150"
|      |      |      |      | 1:9-94 HFP-11 "J/L9/JE8130/SD94/Main cab"
|      |      |      |      | 1:9-95 HFP-11 "J/L9/JE8130/SD95/Accounts cab"
|      |      |      |      | 1:9-96 HFP-11 "J/L9/JE8130/SD96/Entry Psg"
|      |      |      |      | 1:9-97 HMS-S/D/M/SA "J/L9/JE8130/MCP97/Entry Psg"
|      |      |      |      | 1:9-98 HTRI-R "J/L9/JE8130/CM98/Entry Psg"
|      |      |      |      |      | 1:9-99 HFP-11 "J/L9/JE8160/SD99/Main cab"
|      |      |      |      |      | 1:9-100 HFP-11 "J/L9/JE8160/SD100/Entry Psg"
|      |      |      |      |      | 1:9-101 HTRI-R "J/L9/JE8160/CM101/Entry Psg"
|      |      |      |      |      |      | 1:9-102 HMS-S/D/M/SA "J/L9/JE8160/MCP102/Entry Psg"
|      |      |      |      |      |      | 1:9-103 HFP-11 "J/L9/JE8080/SD103/Account Cab"
```

				--	1:9-104	HTRI-S	"J/L9/JE/9F/MM104/Psg nr JW9010B\"
				--	1:9-105	HTRI-S	"J/L9/JE/9F/MM105/Psg nr JW9010B\"
				--	1:9-106	HTRI-S	"J/L9/JE/9F/MM106/Psg nr JW9010B\"
				--	1:9-107	HTRI-S	"J/L9/JE/9F/MM107/Psg nr JW9010B\"
				--	1:9-108	HTRI-S	"J/L9/JE/9F/MM108/Psg nr JW9010B\"
				--	1:9-109	HFP-11	"J/L9/JE8170/SD109/Main cab"
				--	1:9-110	HFP-11	"J/L9/JE8170/SD110/Account cab"
				--	1:9-111	HFP-11	"J/L9/JE8170/SD111/Psg nr Pantry"
				--	1:9-112	HTRI-R	"J/L9/JE8170/CM112/Entry dr Psg"
				--	Switch	""	
				--	Relay		
				--	1:9-113 HMS-S/D/M/SA "J/L9/JE8170/MCP113/Entry dr Psg"		
				--	1:9-114	HFP-11	"J/L9/JE8120/SD114/Main cab"
				--	1:9-115	HFP-11	"J/L9/JE8120/SD115/Account cab"
				--	1:9-116	HFP-11	"J/L9/JE8120/SD116/Assorter cab"
				--	1:9-117	HFP-11	"J/L9/JE8120/SD117/Pantry"
				--	1:9-118	HTRI-R	"J/L9/JE8120/CM118/Entry dr Psg"
				--	Switch	""	
				--	Relay		
				--	1:9-119 HMS-S/D/M/SA "J/L9/JE8120/MCP119/Entry dr Psg"		
				--	1:9-120	HFP-11	"J/L9/JE8210/SD120/Main cab"
				--	1:9-121	HFP-11	"J/L9/JE8210/SD121/Entry dr Psg "
				--	1:9-122	HTRI-R	"J/L9/JE8210/CM122/Entry dr Psg"
				--	Switch	""	
				--	Relay		
				--	1:9-123 HMS-S/D/M/SA "J/L9/JE8210/MCP123/Entry dr Psg"		
				--	1:9-124	HFP-11	"J/L9/JE8260/SD124/Main cab"
				--	1:9-125	HFP-11	"J/L9/JE8260/SD125/Assorter cab"
				--	1:9-126	HFP-11	"J/L9/JE8260/SD126/Entry Psg"
				--	1:9-127	HFP-11	"J/L9/JE8260/SD127/Entry Psg"
				--	1:9-128	HTRI-R	"J/L9/JE8260/CM128/Entry Psg"
				--	Switch	""	
				--	Relay		
				--	1:9-129 HMS-S/D/M/SA "J/L9/JE8260/MCP129/Entry Psg"		
				--	1:9-130	HFP-11	"J/L9/JE8280/SD130/Assorter cab"
				--	1:9-131	HFP-11	"J/L9/JE8280/SD131/Account cab"
				--	1:9-132	HFP-11	"J/L9/JE8280/SD132/Sales cab"
				--	1:9-133	HFP-11	"J/L9/JE8280/SD133/Psg nr Entry"
				--	1:9-134	HTRI-R	"J/L9/JE8280/CM134/Psg nr Entry"
				--	Switch	""	
				--	Relay		
				--	1:9-135 HMS-S/D/M/SA "J/L9/JE8280/MCP135/Psg nr Entry"		
				--	1:9-136	HFP-11	"J/L9/JW8080/SD136/Cab 1"
				--	1:9-137	HFP-11	"J/L9/JW8080/SD137/Cab 2"
				--	1:9-138	HFP-11	"J/L9/JW8080/SD138/Cab 3"
				--	1:9-139	HFP-11	"J/L9/JW8080/SD139/Pantry"
				--	1:9-140	HFP-11	"J/L9/JW8080/SD140/Entry Psg"
				--	1:9-141	HMS-S/D/M/SA	"J/L9/JW8080/MCP141/Entry Psg"
				--	1:9-142	HTRI-R	"J/L9/JW8080/CM142/Entry Psg"
				--	Switch	""	

```

| | | | | Relay
| | | | |
| | | | | |--- 1:9-143 HFP-11 "J/L9/JE8350/SD143/Main cab"
| | | | | |--- 1:9-144 HFP-11 "J/L9/JE8350/SD144/Entry Psg"
| | | | | |--- 1:9-145 HTRI-R "J/L9/JE8350/CM145/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:9-146 HMS-S/D/M/SA "J/L9/JE8350/MCP146/Entry Psg"
| | | | | |--- 1:9-147 HFP-11 "J/L9/JW8110/SD147/Entry Psg"
| | | | | |--- 1:9-148 HFP-11 "J/L9/JW8110/SD148/Cab 1"
| | | | | |--- 1:9-149 HFP-11 "J/L9/JW8110/SD149/Cab 2"
| | | | | |--- 1:9-150 HFP-11 "J/L9/JW8110/SD150/Accounts cab"
| | | | | |--- 1:9-151 HTRI-R "J/L9/JW8110/CM151/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:9-152 HMS-S/D/M/SA "J/L9/JW8110/MCP152/Entry Psg"
| | | | | |--- 1:9-153 HFP-11 "J/L9/JE8340/SD153/Main cab"
| | | | | |--- 1:9-154 HFP-11 "J/L9/JE8340/SD154/Accounts cab"
| | | | | |--- 1:9-155 HFP-11 "J/L9/JE8340/SD155/Entry Psg"
| | | | | |--- 1:9-156 HTRI-R "J/L9/JE8340/CM156/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:9-157 HMS-S/D/M/SA "J/L9/JE8340/MCP157/Entry Psg"
| | | | | |--- 1:9-158 HFP-11 "J/L9/JW8120/SD158/Cab 1"
| | | | | |--- 1:9-159 HFP-11 "J/L9/JW8120/SD159/Cab 2"
| | | | | |--- 1:9-160 HFP-11 "J/L9/JW8120/SD160/Cab 3"
| | | | | |--- 1:9-161 HFP-11 "J/L9/JW8120/SD161/Pantry Psg"
| | | | | |--- 1:9-162 HTRI-R "J/L9/JW8120/CM162/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:9-163 HMS-S/D/M/SA "J/L9/JW8120/MCP163/Entry Psg"
| | | | | |--- 1:9-164 HFP-11 "J/L9/JW8150/SD164/Main cab"
| | | | | |--- 1:9-165 HFP-11 "J/L9/JW8150/SD165/Account cab"
| | | | | |--- 1:9-166 HFP-11 "J/L9/JW8150/SD166/Entry Psg"
| | | | | |--- 1:9-167 HTRI-R "J/L9/JW8150/CM167/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:9-168 HMS-S/D/M/SA "J/L9/JW8150/MCP168/Entry Psg"
| | | | | |--- 1:9-169 HFP-11 "J/L9/JW8160/SD169/Main cab"
| | | | | |--- 1:9-170 HFP-11 "J/L9/JW8160/SD170/Psg Main cab"
| | | | | |--- 1:9-171 HFP-11 "J/L9/JW8160/SD171/Assorter cab"
| | | | | |--- 1:9-172 HFP-11 "J/L9/JW8160/SD172/Pantry Psg"
| | | | | |--- 1:9-173 HTRI-R "J/L9/JW8160/CM173/Entry Psg"
| | | | | | |--- Switch ""
| | | | | | |--- Relay
| | | | | |--- 1:9-174 HMS-S/D/M/SA "J/L9/JW8160/MCP174/Entry Psg"
| | | | | |--- 1:9-175 HFP-11 "J/L9/JW8210/SD175/Main cab"
| | | | | |--- 1:9-176 HFP-11 "J/L9/JW8210/SD176/Assorter cab"
| | | | | |--- 1:9-177 HFP-11 "J/L9/JW8210/SD177/Entry Psg"
| | | | | |--- 1:9-178 HTRI-R "J/L9/JW8210/CM178/Entry Psg"
| | | | | | |--- Switch ""

```

		-- Relay
		-- 1:9-179 HMS-S/D/M/SA "J/L9/JW8210/MCP179/Entry Psg"
		-- 1:9-180 HFP-11 "J/L9/JW8070/SD180/Main cab"
		-- 1:9-181 HFP-11 "J/L9/JW8070/SD181/Pantry"
		-- 1:9-182 HTRI-R "J/L9/JW8070/CM182/Entry dr Psg"
		-- Switch ""
		-- Relay
		-- 1:9-183 HMS-S/D/M/SA "J/L9/JW8070/MCP183/Entry dr Psg"
		-- 1:9-184 HTRI-S "J/L9/JE/9F/MM184/PsgNr JW9010A-7"
		-- 1:9-185 HTRI-S "J/L9/JE/9F/MM185/Psg nr JW9010\A"
		-- 1:9-186 HTRI-S "J/L9/JE/9F/MM186/Psg nr JW9010\A"
		-- 1:9-187 FDOT421 "J/L9/JE8080/SD187/Entry Psg"
		-- 1:9-188 HTRI-S "J/L9/9F/MM188/JW9010 A4"
		-- 1:9-189 HTRI-S "J/L9/9F/MM189/JW9010 A5"
		-- 1:9-190 HTRI-S "J/L9/9F/MM190/JW9010 A6"
		-- 1:9-191 HTRI-S "J/L9/9F/MM191/JW9010 A8"
		-- 1:9-192 HTRI-S "J/L9/9F/MM192/JW9010 B"
		-- 1:9-193 HTRI-S "J/L9/9F/MM193/JW9010 B5"
		-- 1:9-194 HTRI-S "J/L9/9F/MM194/JW9010 B6"
		-- 1:9-195 HTRI-S "J/L9/9F/MM195/JW9010 B8"
		-- 1:9-196 HTRI-S "J/L9/9F/MM196/JW9010 B9"
		-- 1:9-197 HTRI-S "J/L9/9F/MM197/JW9010 B13"
		-- 1:9-198 HTRI-S "J/L9/8F/MM198/JW8270"
		-- 1:9-199 HFP-11 "J/L9/JW8230/SD199/Main Cab"
		-- 1:9-200 HFP-11 "J/L9/JW8230/SD200/Account Cab"
		-- 1:9-201 HTRI-S "J/L9/9F/MM201/JW9010 A9"
		-- 1:9-202 HFP-11 "J/L9/JE8180/SD202/MAIN CABIN"
		-- 1:9-203 HFP-11 "J/L9/JE8180/SD203/ACCOUNT CABIN"
		-- 1:9-204 HFP-11 "J/L9/JE8180/SD204/ENTRY PSG"
		-- 1:9-205 HFP-11 "J/L9/JE8180/SD205/PANTRY"
		-- 1:9-206 HTRI-R "J/L9/JE8180/CM206/ENTRY PSG AFC"
		-- Switch ""
		-- Relay
		-- 1:9-207 HMS-S/D/M/SA "J/L9/JE8180/MCP207/ENTRY PSG"
		-- 1:9-208 HFP-11 "J/L9/JW8230/SD208/Account Cabl"
		-- 1:9-209 HTRI-S "J/L9/9F/MM209/JW9010 B10-12"
		-- 1:9-210 HFP-11 "J/L9/JW8230/SD210/Account Cab2"
		-- 1:9-211 HTRI-S "J/L9/8F/MM211/JE8010"
		-- 1:9-212 HTRI-S "J/L9/8F/MM212/JE8030"
		-- 1:9-213 HTRI-S "J/L9/8F/MM213/JE8060"
		-- 1:9-214 HTRI-S "J/L9/8F/MM214/JE8110"
		-- 1:9-215 HTRI-S "J/L9/8F/MM215/JE8140"
		-- 1:9-216 HFPT-11 "J/L9/JW8230/SD216/Pantry"
		-- 1:9-217 HTRI-S "J/L9/8F/MM217/JE8200"
		-- 1:9-218 HTRI-R "J/L9/JW8230/MCP218/ENTRY PSG AFC"
		-- Switch ""
		-- Relay
		-- 1:9-219 HMS-S/D/M/SA "J/L9/JW8230/MCP219/PANTRY PSG"
		-- 1:9-220 HTRI-S "J/L9/8F/MM220/JE8270"
		-- 1:9-221 HTRI-S "J/L9/8F/MM221/JE8290"

1 Desigo Fire Safety Modular "BDB TOWER J" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

1:9 XDLC "XDLC @ address 9 L9"

```
|      |      |      |-- 1:9-222 HTRI-S "J/L9/8F/MM222/JE8300"
|      |      |      |-- 1:9-223 XTRI-R "J/L9/JE8080/CM223/Entry AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:9-224 HTRI-S "J/L9/8F/MM224/JW8090"
|      |      |      |-- 1:9-225 HTRI-S "J/L9/8F/MM225/JW8140"
|      |      |      |-- 1:9-226 HTRI-S "J/L9/8F/MM226/JW8010"
|      |      |      |-- 1:9-227 HTRI-S "J/L9/8F/MM227/JW8220"
|      |      |      |-- 1:9-228 HTRI-S "J/L9/8F/MM228/JW8260"
|      |      |      |-- 1:9-230 HFP-11 "J/L9/JE8020/SD230/Main cab 1"
|      |      |      |-- 1:9-231 HFP-11 "J/L9/JE8020/SD231/Main cab 2"
|      |      |      |-- 1:9-232 HFP-11 "J/L9/JE8020/SD232/Entry Psg"
|      |      |      |-- 1:9-233 HTRI-R "J/L9/JE8020/CM233/AFC Pantry "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:9-234 HMS-S/D/M/SA "J/L9/JE8020/MCP234/Main Entry"
|      |      |      |-- 1:9-235 HFP-11 "J/L9/JW8190/SD235/Main cab 1"
|      |      |      |-- 1:9-236 HFP-11 "J/L9/JW8190/SD236/Main cab 2"
|      |      |      |-- 1:9-237 HFP-11 "J/L9/JW8190/SD237/Assorter cab"
|      |      |      |-- 1:9-238 HFP-11 "J/L9/JW8190/SD238/Entry Psg"
|      |      |      |-- 1:9-239 HFP-11 "J/L9/JW8190/SD239/Pantry rm"
|      |      |      |-- 1:9-240 HTRI-R "J/L9/JW8190/CM240/AFC Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:9-241 HMS-S/D/M/SA "J/L9/JW8190/MCP241/Entry Psg"
|      |      |      |-- 1:9-242 HTRI-S "J/L9/9F/MM242/JE9010A"
|      |      |      |-- 1:9-243 HFP-11 "J/L9/JW8200/SD243/Assorter cab "
|      |      |      |-- 1:9-244 HFP-11 "J/L9/JW8200/SD244/Main cab "
|      |      |      |-- 1:9-245 HFP-11 "J/L9/JW8200/SD245/Entry Psg"
|      |      |      |-- 1:9-246 HMS-S/D/M/SA "J/L9/JW8200/MCP246/Entry Psg"
|      |      |      |-- 1:9-247 HTRI-R "J/L9/JW8200/CM247/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 1:9-248 HFP-11 "J/L9/JW8070/SD248/Account Cabin"
|      |      |      |-- 1:9-249 HFP-11 "J/L9/JW8070/SD249/Entry Psg."
|      |      |      |-- 1:9-250 HFP-11 "J/L9/JE8340/SD250/MAIN CABIN AFC"
|      |      |      |-- 1:9-251 HFP-11 "J/L9/JE8340/SD251/MAIN CABIN AFC"
|      |      |      |-- 1:9-252 HMS-S/D/M/SA "J/L9/JE8080/MCP252/Nr Account ca"
|      |      |      |-- 1:10 NIC-C(XNet) "NIC_Xnet @ address 10"
|      |      |      |-- 1:249 PSC-12 "PSC-12 @ address 249"
|      |      |      |-- 1:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      |      |      |-- 1:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      |      |      |-- Inner Door
|      |      |      |-- 1:253 PMI-D "PMI-D Tower J -10"
|-- 2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
```

2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local

```
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-1 "CAB-1 Enclosure #1"
|      |-- CC-5 "Card Cage 5 Slots"
|          |-- 2:1 DLC "DLC @LOOP 1"
|              |-- 2:1-1 HFP-11 "DC1/L1/PR-SD-AFC-1"
|              |-- 2:1-2 HFP-11 "DC1/L1/PR-SD-2"
|              |-- 2:1-3 HTRI-R "DC1/L1/PR-CM ACS-3"
|              |   |-- Switch ""
|              |   |-- Relay
|              |   |-- 2:1-4 HFP-11 "DC1/L1/PR-CM ACS-3"
|              |-- 2:1-5 HFP-11 "DC1/L1/OP-SD-5"
|              |-- 2:1-6 HFP-11 "DC1/L1/OP-SD-AFC-6"
|              |-- 2:1-7 HFP-11 "DC1/L1/OP-SD-AFC-7"
|              |-- 2:1-8 HFP-11 "DC1/L1/OP-SD-AFC-8"
|              |-- 2:1-9 HFP-11 "DC1/L1/ME-SD-AFC-9"
|              |-- 2:1-10 HFP-11 "DC1/L1/ME-SD-10"
|              |-- 2:1-11 HTRI-S "DC1/L2/RECP-MM "
|              |-- 2:1-12 HTRI-R "DC1/L2/RECP-CM HTR-12"
|              |   |-- Switch ""
|              |   |-- Relay
|              |   |-- 2:1-13 HMS-S/D/M/SA "DC1/L1/RECP-MCP-13"
|              |-- 2:1-14 HFP-11 "DC1/L1/RECP-SD-14"
|              |-- 2:1-15 HFP-11 "DC1/L1/RECP-SD-AFC-15"
|              |-- 2:1-16 HFP-11 "DC1/L1/TP-SD-16"
|              |-- 2:1-17 HFP-11 "DC1/L1/TP-SD-AFC-17"
|              |-- 2:1-18 HFP-11 "DC1/L1/PNTY-SD-18"
|              |-- 2:1-19 HFPT-11 "DC1/L1/PNTY-HD-19"
|              |-- 2:1-20 HTRI-S "DC1/PNTY-MM LSA-20"
|              |-- 2:1-21 HFP-11 "DC1/L2/RR-SD-BFT-21"
|              |-- 2:1-22 HFP-11 "DC1/L1/PNTY-SD-AFC-22"
|              |-- 2:1-23 HMS-S/D/M/SA "DC1/L1/NOC R-MCP-23"
|              |-- 2:1-24 HTRI-R "DC1/L1/NOC R-CM HTR-24"
|              |   |-- Switch ""
|              |   |-- Relay
|              |   |-- 2:1-25 HFP-11 "DC1/L1/NOC R-SD-AFC-25"
|              |-- 2:1-26 HFP-11 "DC1/L1/INOC R-SD-26"
|              |-- 2:1-27 HFP-11 "DC1/L1/NOC R-SD-AFC-27"
|              |-- 2:1-28 HFP-11 "DC1/L1/RRP-SD-AFC-28"
|              |-- 2:1-29 HFP-11 "DC1/L1/IBMS R-SD-AFC-29"
|              |-- 2:1-30 HFP-11 "DC1/L1/IBMS R-SD-30"
|              |-- 2:1-31 HFP-11 "DC1/L1/RRP-SD-31"
|              |-- 2:1-33 HTRI-R "DC1/L1/ NOC R-CM ACS-33"
|              |   |-- Switch ""
|              |   |-- Relay
|              |   |-- 2:1-34 HTRI-R "DC1/L1/ IBMS R-CM ACS-34"
|              |   |-- Switch ""
|              |   |-- Relay
|              |   |-- 2:1-35 HTRI-R "DC1/L1/PNTY-CM ACS-35"
|              |   |-- Switch ""
```

```

2 Designo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local
  CAB-1 "CAB-1 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      2:1 DLC "DLC @LOOP 1"
        2:1-35 HTRI-R "DC1/L1/PNTY-CM ACS-35"

```

			-- Relay
			-- 2:1-36 HTRI-R "DC1/L1/ME-CM ACS-36"
			-- Switch ""
			-- Relay
			-- 2:1-37 HFP-11 "DC1/L2/COMCP-SD-37"
			-- 2:1-38 HFP-11 "DC1/L2/COMCP-SD-38"
			-- 2:1-39 HMS-S/D/M/SA "DC1/L2/OER-MCP-39"
			-- 2:1-40 HTRI-R "DC1/L2/OER-CM-HTR-40"
			-- Switch ""
			-- Relay
			-- 2:1-41 HFP-11 "DC1/L2/ELE-SD-41"
			-- 2:1-42 HTRI-S "DC1/L2/ELE-MM LSA-42"
			-- 2:1-43 HTRI-R "DC1/L2/ELE-CM HTR-43"
			-- Switch ""
			-- Relay
			-- 2:1-44 HMS-S/D/M/SA "DC1/L2/ELE-MCP-44"
			-- 2:1-45 HMS-S/D/M/SA "DC1/L2/RRE-MCP-45"
			-- 2:1-46 HFP-11 "DC1/L2/RRE-SD-46"
			-- 2:1-47 HFP-11 "DC1/L2/RRE-SD-AFC-47"
			-- 2:1-48 HTRI-S "DC1/L2/RRE-MM LSA-48"
			-- 2:1-49 HTRI-R "DC1/L2/RR-CM HTR-49"
			-- Switch ""
			-- Relay
			-- 2:1-50 HFP-11 "DC1/L2/RR-SD-50"
			-- 2:1-51 HFP-11 "DC1/L2/RR-SD-AFC-51"
			-- 2:1-52 HMS-S/D/M/SA "DC1/L2/RR-MCP-52"
			-- 2:1-53 HTRI-R "DC1/L2/RR-CM HTR-53"
			-- Switch ""
			-- Relay
			-- 2:1-54 HFP-11 "DC1/L2/RR-SD-54"
			-- 2:1-55 HFP-11 "DC1/L2/RR-SD-AFC-55"
			-- 2:1-56 HFP-11 "DC1/L2/RR-SD-BFT-56"
			-- 2:1-57 HFP-11 "DC1/L1/PNTY-SD-AFC-57"
			-- 2:1-58 HFP-11 "DC1/L2/RR-SD-BFT-58"
			-- 2:1-59 HFP-11 "DC1/L2/ELR-SD-BFT-59"
			-- 2:1-60 HFP-11 "DC1/L2/ELR-SD-BFT-60"
			-- 2:1-61 HFP-11 "DC1/L2/BTR-SD-BFT-61"
			-- 2:1-62 HFP-11 "DC1/L2/OMR-SD-BFT-62"
			-- 2:1-63 HFP-11 "DC1/L2.MR-SD-BFT-63"
			-- 2:1-64 HMS-S/D/M/SA "DC1/L2/MR-MCP-64"
			-- 2:1-65 HFP-11 "DC1/L2/MR-SD-65"
			-- 2:1-66 HFP-11 "DC1/L2/BTR-SD-66"
			-- 2:1-67 HMS-S/D/M/SA "DC1/L2/BTR-MCP-67"
			-- 2:1-68 HTRI-R "DC1/L2/O BTR-CM ASC-68"
			-- Switch ""
			-- Relay
			-- 2:1-69 HFP-11 "DC1/L2/0 BTR-SD-AFC-69"
			-- 2:1-70 HFP-11 "DC1/L2/ELR-SD-70"
			-- 2:1-71 HFP-11 "DC1/L2/ELR-SD-71"
			-- 2:1-72 HFP-11 "DC1/L2/AHU-SD-72"

2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local
CAB-1 "CAB-1 Enclosure #1"
CC-5 "Card Cage 5 Slots"
2:1 DLC "DLC @LOOP 1"

				-- 2:1-73 HFP-11 "DC1/L2/AHU-SD-73"
				-- 2:1-74 HTRI-R "DC1/L2/AHU-CM AHU1 TRIP-74"
				-- Switch ""
				-- Relay
				-- 2:1-75 HTRI-R "DC1/L2/AHU-CM AHU2 TRIP-75"
				-- Switch ""
				-- Relay
				-- 2:1-76 HTRI-S "DC1/L2/AHU-MM LSA-76"
				-- 2:1-77 HMS-S/D/M/SA "DC1/L2/AHU-MCP-77"
				-- 2:1-78 HTRI-R "DC1/L2/AHU-CM HTR-78"
				-- Switch ""
				-- Relay
				-- 2:1-79 HFP-11 "DC1/L2/AHU-SD-79"
				-- 2:1-80 HFP-11 "DC1/L2/AHU-SD-80"
				-- 2:1-81 HTRI-R "DC1/L2/AHU-CM HTR-81"
				-- Switch ""
				-- Relay
				-- 2:1-82 HMS-S/D/M/SA "DC1/L2/AHU-MCP-82"
				-- 2:1-83 HTRI-R "DC1/L2/AHU-CM AHU3 TRIP-83"
				-- Switch ""
				-- Relay
				-- 2:1-84 HTRI-R "DC1/L2/AHU-CM AHU4 TRIP-84"
				-- Switch ""
				-- Relay
				-- 2:1-85 HTRI-S "DC1/L2/AHU-MM LSA-85"
				-- 2:1-86 HMS-S/D/M/SA "DC1/L2/AHU-MCP-86"
				-- 2:1-87 HTRI-R "DC1/L2/OMR-CM HTR-87"
				-- Switch ""
				-- Relay
				-- 2:1-88 HFP-11 "DC1/L2/OMR-SD-88"
				-- 2:1-89 HFP-11 "DC1/L2/COMC-SD-89"
				-- 2:1-90 HFP-11 "DC1/L2/COMC-SD-AFC-90"
				-- 2:1-91 HTRI-S "DC1/L2/BE-MM LSA-91"
				-- 2:1-92 HFP-11 "DC1/L2/BE-SD-92"
				-- 2:1-93 HMS-S/D/M/SA "DC1/L2/COMC-MCP-93"
				-- 2:1-94 HTRI-R "DC1/L2/COMC-CM HTR-94"
				-- Switch ""
				-- Relay
				-- 2:1-95 HFP-11 "DC1/L2/COMC-SD-AFC-95"
				-- 2:1-96 HFP-11 "DC1/L2/COMC-SD-96"
				-- 2:1-97 HFP-11 "DC1/L2/COMC-SD-AFC-97"
				-- 2:1-98 HFP-11 "DC1/L2/COMC-SD-98"
				-- 2:1-99 HFP-11 "DC1/L2/COMC-SD-AFC-99"
				-- 2:1-100 HFP-11 "DC1/L2/COMC-SD-AFC-100"
				-- 2:1-101 HFP-11 "DC1/L2/COMC-SD-101"
				-- 2:1-102 HTRI-R "DC1/L2/COMC-CM HTR-102"
				-- Switch ""
				-- Relay
				-- 2:1-103 HFP-11 "DC1/L2/COMC-SD-AFC-103"
				-- 2:1-104 HFP-11 "DC1/L2/COMC-SD-104"

2 Desigo Fire Safety Modular "BDB DC-1 MAIN PANEL" Local

CAB-1 "CAB-1 Enclosure #1"

CC-5 "Card Cage 5 Slots"

2:1 DLC "DLC @LOOP 1"

```
|      |      |  |-- 2:1-105 HMS-S/D/M/SA "DC1/L2/COMC-MCP-105"
|      |      |  |-- 2:1-106 HFP-11 "DC1/L2/COMC-SD-BFT-106"
|      |      |  |-- 2:1-107 HFP-11 "DC1/L2/COMC-SD-BFT-107"
|      |      |  |-- 2:1-108 HFP-11 "DC1/L2/COMC-SD-BFT-108"
|      |      |  |-- 2:1-109 HFP-11 "DC1/L2/COMC-SD-BFT-109"
|      |      |  |-- 2:1-110 HFP-11 "DC1/L2/COMC-SD-BFT-110"
|      |      |  |-- 2:1-111 HFP-11 "DC1/L2/COMC-SD-BFT-111"
|      |      |  |-- 2:1-112 HFP-11 "DC1/L2/COMC-SD-BFT-112"
|      |      |  |-- 2:1-113 HFP-11 "DC1/L2/IBMS R-SD-BFT-113"
|      |      |  |-- 2:1-114 HFP-11 "DC1/L2/INOC R-SD-BFT-114"
|      |      |  |-- 2:1-115 HFP-11 "DC1/L2/RPB-SD-BFT-115"
|      |      |  |-- 2:1-116 HFP-11 "DC1/L2/OBTR-SD-AFC-116"
|      |      |  |-- 2:1-117 HFP-11 "DC1/L2/OBTR-SD-117"
|      |      |  |-- 2:1-118 HTRI-R "DC1/L2/PW-CM GSS CYL 1-118"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 2:1-119 HTRI-S "DC1/L2/PW-MM RACK RM VESDA-119"
|      |      |  |-- 2:1-120 HTRI-S "DC1/L2/PW-MM ELEC RM VESDA-120"
|      |      |  |-- 2:1-121 HTRI-R "DC1/L2/PW-CM GSS CLY 2-121"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 2:1-122 HTRI-S "DC1/L2/PW-MM GSS CLY 2-122"
|      |      |  |-- 2:1-123 HTRI-S "DC1/L2/PW-MM GSS CLY 2-123"
|      |      |  |-- 2:1-124 HTRI-R "DC1/L2/PW-CM GSS CYL 1-124"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 2:1-125 HTRI-R "DC1/L2/PW-CM GSS CYL 1-125"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 2:2 NIC-C(XNet) "NIC_Xnet @ address 2"
|      |      |  |-- 2:249 PSC-12 "POWER SUPPLY"
|      |      |  |-- 2:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      |      |  |-- 2:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      |      |  |-- Inner Door
|      |      |  |-- 2:253 PMI-D "PMI-D @ address 253"
|-- 3 Desigo Fire Safety Modular "BDB DC-1 GLOBAL PANEL" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-1 "CAB-1 Enclosure #1"
|      |-- CC-5 "Card Cage 5 Slots"
|      |  |-- 3:1 NIC-C(XNet) "NIC_Xnet @ address 1"
|      |-- 3:249 PSC-12 "POWER SUPPLY"
|      |  |-- 3:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      |  |-- 3:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      |  |-- 3:249-3 Relay "Relay -3"
```

3 Desigo Fire Safety Modular "BDB DC-1 GLOBAL PANEL" Local
CAB-1 "CAB-1 Enclosure #1"

```
|      |-- Inner Door
|      |-- 3:253 PMI-D "PMI-D Global Panel -1"
|
|-- 4 Desigo Fire Safety Modular "BDB TOWER B" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-2 "CAB-2 Enclosure #1"
|      |-- CC-5 "Card Cage 5 Slots"
|          |-- 4:1 DLC "DLC @ address 1 L1 "
|              |-- 4:1-1 FDOT421 "B/L1/CC/1F/SD4/LIFT LOBBY"
|              |-- 4:1-2 FDOT421 "B/L1/CC/1F/SD2/COR NR BC1010AFC"
|              |-- 4:1-3 FDOT421 "B/L1/CC/1F/SD3/CORR BC-1010"
|              |-- 4:1-4 FDOT421 "B/L1/CC/1F/SD4/LIFT LOBBY"
|              |-- 4:1-5 FDOT421 "B/L1/CC/1F/SD5/LIFT LOBBY"
|              |-- 4:1-6 HMS-S/D/M/SA "B/L1/CC/1F/MCP6/LIFT LOBBY STR"
|              |-- 4:1-7 HTRI-R "B/L1/CC/1F/CM7/FIRE HYD SHAFT"
|              |-- Switch ""
|              |-- Relay
|              |-- 4:1-8 HTRI-S "B/L1/CC/1F/MM8/FIRE HYD SHAFT"
|              |-- 4:1-9 HTRI-R "B/L1/CC/1F/CM9/DOOR RELEASE UNIT"
|              |-- Switch ""
|              |-- Relay
|              |-- 4:1-10 FDOT421 "B/L1/EC/1F/SD10/AFC Cor Nr AHURM"
|              |-- 4:1-11 FDOT421 "B/L1/EC/1F/SD11/CORR Nr BE1100"
|              |-- 4:1-12 FDOT421 "B/L1/EC/1F/SD12/CORR Nr BE 1110 "
|              |-- 4:1-13 FDOT421 "B/L1/EC/1F/SD13/CorrNr BE1120AFC"
|              |-- 4:1-14 FDOT421 "B/L1/EC/1F/SD14/CORR Nr BE1120"
|              |-- 4:1-15 FDOT421 "B/L1/EC/1F/SD15/CORR NR BE1130"
|              |-- 4:1-16 FDOT421 "B/L1/EC/1F/SD16/CorrNrElectRmAfc"
|              |-- 4:1-17 FDOT421 "B/L1/EC/1F/SD17/ELECT RM"
|              |-- 4:1-18 FDOT421 "B/L1/EC/1F/SD18/AHU RM"
|              |-- 4:1-19 HTRI-R "B/L1/EC/1F/CM19/AHU RM"
|              |-- Switch ""
|              |-- Relay
|              |-- 4:1-20 HTRI-R "B/L1/EC/1F/CM20/DOOR RELEASE UN"
|              |-- Switch ""
|              |-- Relay
|              |-- 4:1-21 FDOT421 "B/L1/EC/1F/SD21/LIFT LOBBY"
|              |-- 4:1-22 HMS-S/D/M/SA "B/L1/EC/1F/MCP22/FIRE ESCAPE ST"
|              |-- 4:1-23 HTRI-R "B/L1/EC/1F/CM23/FIRE HYD SHAFT"
|              |-- Switch ""
|              |-- Relay
|              |-- 4:1-24 HTRI-S "B/L1/EC/1F/MM24/FIRE HYD SHAFT"
|              |-- 4:1-27 HMS-S/D/M/SA "B/L1/EC/GND/MCP27/LIFT LOBBY"
|              |-- 4:1-28 HTRI-R "B/L1/EC/GND/CM28/LIFT LOBBY"
|              |-- Switch ""
```

4:1-28 HTRI-R "B/L1/EC/GND/CM28/LIFT LOBBY"

			-- Relay
			-- 4:1-29 HTRI-S "B/L1/EC/GND/MM29/LIFT LOBBY"
			-- 4:1-30 FDOT421 "B/L1/EC/GND/SD30/ELECT RM"
			-- 4:1-31 FDOT421 "B/L1/EC/GND/SD31/LIFT LOBBY"
			-- 4:1-32 FDOT421 "B/L1/EC/GND/SD32/LIFT LOBBY"
			-- 4:1-33 HTRI-R "B/L1/EC/GND/CM33/AHU RM"
			-- Switch ""
			-- Relay
			-- 4:1-34 FDOT421 "B/L1/EC/GND/SD34/AHU RM"
			-- 4:1-35 HMS-S/D/M/SA "B/L1/CC/GND/MCP35/LIFT LOBBY"
			-- 4:1-36 HTRI-R "B/L1/CC/GND/CM36/LIFT LOBBY"
			-- Switch ""
			-- Relay
			-- 4:1-37 HTRI-S "B/L1/CC/GND/MM37/LIFT LOBBY"
			-- 4:1-38 FDOT421 "B/L1/CC/GND/SD38/ELECT RM"
			-- 4:1-39 FDOT421 "B/L1/CC/GND/SD39/LIFT LOBBY"
			-- 4:1-40 FDOT421 "B/L1/CC/GND/SD40/LIFT LOBBY"
			-- 4:1-41 HTRI-R "B/L1/CC/GND/CM41/AHU RM"
			-- Switch ""
			-- Relay
			-- 4:1-42 FDOT421 "B/L1/CC/GND/SD42/B DTC AHU RM"
			-- 4:1-43 HMS-S/D/M/SA "B/L1/WC/GND/MCP43/LIFT LOBBY"
			-- 4:1-44 HTRI-R "B/L1/WC/GND/CM44/LIFT LOBBY"
			-- Switch ""
			-- Relay
			-- 4:1-45 HTRI-S "B/L1/WC/GND/MM45/LIFT LOBBY"
			-- 4:1-46 FDOT421 "B/L1/WC/GND/SD46/ELECTRIC RM"
			-- 4:1-47 FDOT421 "B/L1/WC/GND/SD47/LIFT LOBBY"
			-- 4:1-48 FDOT421 "B/L1/WC/GND/SD48/BW SECURITY Cab"
			-- 4:1-49 FDOT421 "B/L1/WC/GND/SD49/LIFT LOBBY"
			-- 4:1-50 FDOT421 "B/L1/WC/GND/SD50/LIFT LOBBY"
			-- 4:1-51 FDOT421 "B/L1/WC/GND/SD51/LIFT LOBBY"
			-- 4:1-52 HTRI-R "B/L1/WC/GND/CM52/AHU RM"
			-- Switch ""
			-- Relay
			-- 4:1-53 FDOT421 "B/L1/WC/GND/SD53/AHU RM"
			-- 4:1-55 HTRI-R "B/L1/CC/1F/CM55/AHU RM"
			-- Switch ""
			-- Relay
			-- 4:1-56 FDOT421 "B/L1/CC/1F/SD56/AHU RM"
			-- 4:1-75 HTRI-S "B/L1/1F/MM75/BE1010"
			-- 4:1-77 HTRI-S "B/L1/1F/MM77/BE1130"
			-- 4:1-78 HTRI-S "B/L1/1F/MM78/BE1120"
			-- 4:1-79 HTRI-S "B/L1/1F/MM79/BE1110"
			-- 4:1-81 HTRI-S "B/L1/1F/MM81/BE1090"
			-- 4:1-82 HTRI-S "B/L1/1F/MM82/BE1080"
			-- 4:1-83 HTRI-S "B/L1/1F/MM83/BC1010"
			-- 4:1-101 HTRI-S "B/L1/CC/UB/MM101/ELEC ROOM"
			-- 4:1-102 HTRI-S "B/L1/WC/UB/MM102/ELEC ROOM"
			-- 4:1-103 HTRI-R "B/L1/WC/UB/CM103/STAIRCASE"

4:1-103 HTRI-R "B/L1/WC/UB/CM103/STAIRCASE"

```
| | | Switch ""
| | | |-- Relay
| | | |-- 4:1-104 HMS-S/D/M/SA "B/L1/WC/UB/MCP104/STAIRCASE"
| | | |-- 4:1-105 HTRI-R "B/L1/WC/UB/CM105/STAIRCASE"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 4:1-106 HMS-S/D/M/SA "B/L1/WC/UB/MCP106/STAIRCASE"
| | | |-- 4:1-107 HMS-S/D/M/SA "B/L1/WC/UB/MCP107/RAMP NO. 2"
| | | |-- 4:1-108 HTRI-R "B/L1/WC/UB/CM108/RAMP NO. 2"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 4:1-109 HTRI-R "B/L1/CC/UB/CM109/COLUMN NO. 156"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 4:1-110 HTRI-R "B/L1/CC/UB/CM110/COLUMN NO. 156"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 4:1-111 FDOT421 "B/L1/CC/UB/SD111/ELEC ROOM"
| | | |-- 4:1-114 FDOT421 "B/L1/WC/UB/SD114/FAN ROOM"
| | | |-- 4:1-115 FDOT421 "B/L1/CC/UB/SD115/O/S BMS ROOM"
| | | |-- 4:1-116 FDOT421 "B/L1/CC/UB/SD116/BMS ROOM"
| | | |-- 4:1-117 FDOT421 "B/L1/CC/UB/SD117/ELEC RM BW"
| | | |-- 4:1-118 FDOT421 "B/L1/EC/UB/SD118/ELEC ROOM"
| | | |-- 4:1-119 FDOT421 "B/L1/EC/UB/SD119/Legal Record rm"
| | | |-- 4:1-120 FDOT421 "B/L1/EC/UB/SD120/Legal Record rm"
| | | |-- 4:1-121 FDOT421 "B/L1/EC/UB/SD121/Electric Store "
| | | |-- 4:1-122 HTRI-R "B/L1/EC/UB/CM122/"NR BC ELE RM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 4:1-123 HMS-S/D/M/SA "B/L1/EC/UB/MCP123/NR BC ELE RM"
| | | |-- 4:1-124 HMS-S/D/M/SA "B/L1/EC/UB/MCP124/NR BC ELE RM"
| | | |-- 4:1-125 HTRI-S "B/L1/EC/UB/MM125/BE ELE RM"
| | | |-- 4:1-126 FDOT421 "B/L1/B-DTC/SD-126/Cabin1"
| | | |-- 4:1-127 FDOT421 "B/L1/B-DTC/SD-127/Cabin2"
| | | |-- 4:1-128 FDOT421 "B/L1/B-DTC/SD-128/Cabin3"
| | | |-- 4:1-129 FDOT421 "B/L1/B-DTC/SD-129/Cabin4"
| | | |-- 4:1-130 FDOT421 "B/L1/B-DTC/SD-130/Cabin5"
| | | |-- 4:1-131 FDOT421 "B/L1/B-DTC/SD-131/Cabin6"
| | | |-- 4:1-132 FDOT421 "B/L1/B-DTC/SD-132/Cabin7"
| | | |-- 4:1-133 FDOT421 "B/L1/B-DTC/SD-133/Cabin8"
| | | |-- 4:1-134 FDOT421 "B/L1/B-DTC/SD-134/Cabin9"
| | | |-- 4:1-135 FDOT421 "B/L1/B-DTC/SD-135/Cabin10"
| | | |-- 4:1-136 FDOT421 "B/L1/B-DTC/SD-136/Cabin11"
| | | |-- 4:1-137 FDOT421 "B/L1/B-DTC/SD-137/Cabin12"
| | | |-- 4:1-138 FDOT421 "B/L1/B-DTC/SD-138/Cabin13"
| | | |-- 4:1-139 FDOT421 "B/L1/B-DTC/SD-139/Cabin14"
| | | |-- 4:1-140 FDOT421 "B/L1/B-DTC/SD-140/Cabin15"
| | | |-- 4:1-141 FDOT421 "B/L1/B-DTC/SD-141/Cabin16"
| | | |-- 4:1-142 FDOT421 "B/L1/B-DTC/SD-142/Cabin17"
| | | |-- 4:1-143 FDOT421 "B/L1/B-DTC/SD-143/Cabin19"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:1 DLC "DLC @ address 1 L1 "

```
|      |      |  |-- 4:1-144 FDOT421 "B/L1/B-DTC/SD-144/Cabin19"
|      |      |  |-- 4:1-145 FDOT421 "B/L1/B-DTC/SD-145/Cabin20"
|      |      |  |-- 4:1-146 FDOT421 "B/L1/B-DTC/SD-146/Cabin21"
|      |      |  |-- 4:1-147 FDOT421 "B/L1/B-DTC/SD-147/Cabin22"
|      |      |  |-- 4:1-148 FDOT421 "B/L1/B-DTC/SD-148/Cabin23"
|      |      |  |-- 4:1-149 FDOT421 "B/L1/B-DTC/SD-149/Cabin24"
|      |      |  |-- 4:1-150 FDOT421 "B/L1/B-DTC/SD-150/Cabin25"
|      |      |  |-- 4:1-151 FDOT421 "B/L1/B-DTC/SD-151/Cabin26"
|      |      |  |-- 4:1-152 FDOT421 "B/L1/B-DTC/SD-152/Cabin27"
|      |      |  |-- 4:1-153 FDOT421 "B/L1/B-DTC/SD-153/Cabin28"
|      |      |  |-- 4:1-154 FDOT421 "B/L1/B-DTC/SD-154/Cabin29"
|      |      |  |-- 4:1-155 FDOT421 "B/L1/B-DTC/SD-155/Security Recep"
|      |      |  |-- 4:1-156 FDOT421 "B/L1/B-DTC/SD-156/Psg nr Cabin 1"
|      |      |  |-- 4:1-157 FDOT421 "B/L1/B-DTC/SD-157/Psg nr cabin 5"
|      |      |  |-- 4:1-158 FDOT421 "B/L1/B-DTC/SD-158/Psg nr Cabin 9"
|      |      |  |-- 4:1-159 FDOT421 "B/L1/B-DTC/SD-159/Psg nr Cabin11"
|      |      |  |-- 4:1-160 FDOT421 "B/L1/B-DTC/SD-160/Psg nr cabin14"
|      |      |  |-- 4:1-161 FDOT421 "B/L1/B-DTC/SD-161/Psg nr cabin15"
|      |      |  |-- 4:1-162 FDOT421 "BL1/B-DTC/SD-162/Psg nr cabin16"
|      |      |  |-- 4:1-163 FDOT421 "B/L1/B-DTC/SD-163/Psg nr cabin24"
|      |      |  |-- 4:1-164 FDOT421 "B/L1/B-DTC/SD-164/Psg nr cabin21"
|      |      |  |-- 4:1-165 FDOT421 "B/L1/B-DTC/SD-165/Psg nr cabin27"
|      |      |  |-- 4:1-166 FDOT421 "B/L1/B-DTC/SD-166/Psg nr cabin29"
|      |      |  |-- 4:1-167 FDOT421 "B/L1/B-DTC/SD-167/Psg nr Pantry"
|      |      |  |-- 4:1-168 FDOT421 "B/L1/B-DTC/SD-168/AHU Room"
|      |      |  |-- 4:1-170 HMS-S/D/M/SA "B/L1/B-DTC/MCP-170/Psg NrCabin8 "
|      |      |  |-- 4:1-171 HMS-S/D/M/SA "B/L1/B-DTC/MCP-171/PsgNrCabin17 "
|      |      |  |-- 4:1-172 HMS-S/D/M/SA "B/L1/B-DTC/MCP-172/PsgNrCabin19"
|      |      |  |-- 4:1-173 HMS-S/D/M/SA "B/L1/B-DTC/MCP-173/PsgNrCabin24 "
|      |      |  |-- 4:1-174 HMS-S/D/M/SA "B/L1/B-DTC/MCP-174/Psg Nr Cabin "
|      |      |  |-- 4:1-175 HTRI-R "B/L1/B-DTC/CM-175/Psg nr Cab 27"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-176 FDOT421 "B/L1/B-DTC/SD-176/Cabin 20"
|      |      |  |-- 4:1-177 HTRI-R "B/L1/B-DTC/CM-177/PsgNrCab19"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-178 HTRI-R "B/L1/B-DTC/CM-178/PsgNrCab17"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-179 FDOT421 "B/L1/B-DTC/SD-179/AFC Psg Nr Cab"
|      |      |  |-- 4:1-180 FDOT421 "B/L1/B-DTC/SD-180/AFC PsgNrCab29"
|      |      |  |-- 4:1-181 FDOT421 "B/L1/B-DTC/SD-181/AFC PsgNrCab15"
|      |      |  |-- 4:1-182 FDOT421 "B/L1/B-DTC/SD-182/AFC PsgNrCab14"
|      |      |  |-- 4:1-185 FDOT421 "B/L1/B-DTC/SD-185/AFC PsgNrCab25"
|      |      |  |-- 4:1-186 HTRI-R "B/L1/B-DTC/CM-186/AFC PsgNrCab24"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:1-187 FDOT421 "B/L1/B-DTC/SD-187/AFC Psg WashRm"
|      |      |  |-- 4:1-188 FDOT421 "B/L1/B-DTC/SD-188/AFC PsgNrCab13"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:1 DLC "DLC @ address 1 L1 "

			-- 4:1-189	FDOT421	"B/L1/B-DTC/SD-189/AFC	PsgNrCab7"
			-- 4:1-191	FDOT421	"B/L1/B-DTC/SD-191/AFC	PsgNrCab9"
			-- 4:1-192	FDOT421	"B/L1/B-DTC/SD-192/AFC	PsgNrAHU R"
			-- 4:1-193	FDOT421	"B/L1/B-DTC/SD-193/AFC	PsgNrCab4"
			-- 4:1-194	FDOT421	"B/L1/B-DTC/SD-194/AFC	Reception "
			-- 4:1-195	FDOT421	"B/L1/B-DTC/SD-195/AFC	Cab 1"
			-- 4:1-196	FDOT421	"B/L1/B-DTC/SD-196/AFC	Cab 2"
			-- 4:1-197	FDOT421	"B/L1/B-DTC/SD-198/AFC	Cab 4"
			-- 4:1-198	FDOT421	"B/L1/B-DTC/SD-198/AFC	Cab 4"
			-- 4:1-199	FDOT421	"B/L1/B-DTC/SD-199/AFC	Cab 5"
			-- 4:1-200	FDOT421	"B/L1/B-DTC/SD-200/AFC	Cab 6"
			-- 4:1-201	FDOT421	"B/L1/B-DTC/SD-201/AFC	Cab 7"
			-- 4:1-202	FDOT421	"B/L1/B-DTC/SD-202/AFC	Cab 8"
			-- 4:1-203	FDOT421	"B/L1/B-DTC/SD-203/AFC	Cab 9"
			-- 4:1-204	FDOT421	"B/L1/B-DTC/SD-204/AFC	Cab 10"
			-- 4:1-205	FDOT421	"B/L1/B-DTC/SD-205/AFC	Cab 11"
			-- 4:1-206	FDOT421	"B/L1/B-DTC/SD-206/AFC	Cab 12"
			-- 4:1-207	FDOT421	"B/L1/B-DTC/SD-207/AFC	Cab 13"
			-- 4:1-208	FDOT421	"B/L1/B-DTC/SD-208/AFC	Cab 14"
			-- 4:1-209	FDOT421	"B/L1/B-DTC/SD-209/AFC	Cab 15"
			-- 4:1-210	FDOT421	"B/L1/B-DTC/SD-210/AFC	Cab 16"
			-- 4:1-211	FDOT421	"B/L1/B-DTC/SD-211/AFC	Cab 17"
			-- 4:1-212	FDOT421	"B/L1/B-DTC/SD-212/AFC	Cab 18"
			-- 4:1-213	FDOT421	"B/L1/B-DTC/SD-213/AFC	Cab 19"
			-- 4:1-215	FDOT421	"B/L1/B-DTC/SD-215/AFC	Cab 21"
			-- 4:1-216	FDOT421	"B/L1/B-DTC/SD-216/AFC	Cab 22"
			-- 4:1-217	FDOT421	"B/L1/B-DTC/SD-217/AFC	Cab 23"
			-- 4:1-218	FDOT421	"B/L1/B-DTC/SD-218/AFC	Cab 24"
			-- 4:1-219	FDOT421	"B/L1/EC/UB/SD119/Legal	Record RM"
			-- 4:1-220	FDOT421	"B/L1/EC/UB/SD120/Legal	Record RM"
			-- 4:1-221	FDOT421	"B/L1/EC/UB/SD121/Elect	Store"
			-- 4:1-222	HFP-11	"B/L1/BE1100/SD222/Cabin	1"
			-- 4:1-223	HFP-11	"B/L1/BE1100/SD223/Cabin	2"
			-- 4:1-224	HFP-11	"B/L1/BE1100/SD224/Cabin	3"
			-- 4:1-225	HFP-11	"B/L1/BE1100/SD225/Cabin	4"
			-- 4:1-226	HFP-11	"B/L1/BE1100/SD226/Psg	near Cabin"
			-- 4:1-227	HMS-S/D/M/SA	"B/L1/BE1100/MCP227/Entry	Dr"
			-- 4:1-228	HTRI-R	"B/L1/BE1100/CM228/Entry	Dr"
				-- Switch	"	
				-- Relay		
			-- 4:1-229	HFP-11	"B/L1/BE1140/SD229/Pantry"	
			-- 4:1-230	HFP-11	"B/L1/BE1140/SD230/Accounts	cabin"
			-- 4:1-231	HFP-11	"B/L1/BE1140/SD231/Buyer	cabin"
			-- 4:1-232	HFP-11	"B/L1/BE1140/SD232/Main	cabin"
			-- 4:1-233	HFP-11	"B/L1/BE1140/SD233/Psg	near Main "
			-- 4:1-234	HMS-S/D/M/SA	"B/L1/BE1140/MCP234/Psg	near Entr"
			-- 4:1-235	HTRI-R	"B/L1/BE1140/CM235/Psg	near Entry"
				-- Switch	"	
				-- Relay		
			-- 4:1-236	FDOT421	"B/L1/B-DTC/SD-236/AFC	Cab 28"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:1 DLC "DLC @ address 1 L1 "

```
|      |      |      |-- 4:1-237 FDOT421 "B/L1/B-DTC/SD-237/AFC Cab 29"
|      |      |      |-- 4:2 DLC "DLC @ address 2 L2"
|      |      |      |-- 4:2-1 FDOT421 "B/L2/WC/1F/SD1/CORR NR BW1110"
|      |      |      |-- 4:2-2 FDOT421 "B/L2/WC/1F/SD2/CorrNr BW1110 AFC"
|      |      |      |-- 4:2-3 FDOT421 "B/L2/WC/1F/SD3/CORR NR BW1070"
|      |      |      |-- 4:2-4 FDOT421 "B/L2/WC/1F/SD4/CORR NR AHU RM"
|      |      |      |-- 4:2-5 FDOT421 "B/L2/WC/1F/SD5/CorrNr AHU AFC"
|      |      |      |-- 4:2-6 FDOT421 "B/L2/WC/1F/SD6/AHU ROOM SD"
|      |      |      |-- 4:2-7 HTRI-R "B/L2/WC/1F/CM7/AHU ROOM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:2-8 FDOT421 "B/L2/WC/1F/SD8/CorrNr BW1/S18AFC"
|      |      |      |-- 4:2-10 FDOT421 "B/L2/WC/1F/SD10/CORR NR BW 1160"
|      |      |      |-- 4:2-11 FDOT421 "B/L2/WC/1F/SD11/CorrNrBW1/S19AFC"
|      |      |      |-- 4:2-12 HTRI-R "B/L2/WC/1F/CM12/DOOR RELESE CM N"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:2-13 FDOT421 "B/L2/WC/1F/SD13/LIFT LOBBY SD"
|      |      |      |-- 4:2-14 FDOT421 "B/L2/WC/1F/SD14/LIFT LOBBY SD"
|      |      |      |-- 4:2-15 FDOT421 "B/L2/WC/1F/SD15/ELECTRICAL ROOM "
|      |      |      |-- 4:2-16 FDOT421 "B/L2/WC/1F/SD16/AFC SD Nr BW1010"
|      |      |      |-- 4:2-17 FDOT421 "B/L2/WC/1F/SD17/CORR NR BW1010"
|      |      |      |-- 4:2-18 FDOT421 "B/L2/WC/1F/SD18/CORR NR BW 1020"
|      |      |      |-- 4:2-19 FDOT421 "B/L2/WC/1F/SD19/CorrNr BW1030AFC"
|      |      |      |-- 4:2-20 FDOT421 "B/L2/WC/1F/SD20/CORR NR BW 1040"
|      |      |      |-- 4:2-21 HMS-S/D/M/SA "B/L2/WC/1F/MCP21/StrCaseNrBW1040"
|      |      |      |-- 4:2-22 HTRI-R "B/L2/WC/1F/CM22/STR NR BW1040"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:2-23 FDOT421 "B/L2/WC/1F/SD23/AFC CorrNrBW1060"
|      |      |      |-- 4:2-24 FDOT421 "B/L2/WC/1F/SD24/CORR NR BW 1050"
|      |      |      |-- 4:2-25 FDOT421 "B/L2/WC/2F/SD25/ELECTRICAL ROOM "
|      |      |      |-- 4:2-26 FDOT421 "B/L2/WC/2F/SD26/CORR NR AW 2100"
|      |      |      |-- 4:2-27 FDOT421 "B/L2/WC/2F/SD27/COR NR AW2100AFC"
|      |      |      |-- 4:2-28 FDOT421 "B/L2/WC/2F/SD28/CORR NR AW 2070"
|      |      |      |-- 4:2-29 FDOT421 "B/L2/WC/2F/SD29/CorrNr AW2120AFC"
|      |      |      |-- 4:2-30 FDOT421 "B/L2/WC/2F/SD30/CORR NR AW 2120"
|      |      |      |-- 4:2-31 FDOT421 "B/L2/WC/2F/SD31/CORR NR BW2/S09"
|      |      |      |-- 4:2-32 FDOT421 "B/L2/WC/2F/SD32/LIFT LOBBY SD"
|      |      |      |-- 4:2-33 FDOT421 "B/L2/WC/2F/SD33/LIFT LOBBY SD"
|      |      |      |-- 4:2-34 FDOT421 "B/L2/WC/2F/SD34/CORR NR BW2251 A"
|      |      |      |-- 4:2-35 FDOT421 "B/L2/WC/2F/SD35/CORR NR BW 2251"
|      |      |      |-- 4:2-37 FDOT421 "B/L2/WC/2F/SD37/AFC CorrNrBW2230"
|      |      |      |-- 4:2-38 FDOT421 "B/L2/WC/2F/SD38/CORR NR BW 2230"
|      |      |      |-- 4:2-39 FDOT421 "B/L2/WC/2F/SD39/CORR NR BW 2010"
|      |      |      |-- 4:2-40 FDOT421 "B/L2/WC/2F/SD40/CorrNr BW2200AFC"
|      |      |      |-- 4:2-41 FDOT421 "B/L2/WC/2F/SD41/CORR NR BW 2200"
|      |      |      |-- 4:2-42 FDOT421 "B/L2/WC/2F/SD42/CORR NR BW 2060"
|      |      |      |-- 4:2-43 FDOT421 "B/L2/WC/2F/SD43/CorrNr BW2070AFC"
|      |      |      |-- 4:2-44 FDOT421 "B/L2/WC/2F/SD44/CORR NR BW 2070"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:2 DLC "DLC @ address 2 L2"

				--	4:2-45	FDOT421	"B/L2/WC/2F/SD45/CORR NR BW 2080"
				--	4:2-46	FDOT421	"B/L2/WC/2F/SD46/AHU ROOM SD"
				--	4:2-47	HTRI-R	"B/L2/WC/2F/CM47/AHU ROOM CM"
							-- Switch ""
							-- Relay
				--	4:2-48	HMS-S/D/M/SA	"B/L2/WC/2F/MCP48/STR NR BW 2060"
				--	4:2-49	HTRI-R	"B/L2/WC/2F/CM49/STR NR BW 2060"
							-- Switch ""
							-- Relay
				--	4:2-50	HTRI-R	"B/L2/WC/2F/CM50/DOOR R CM NR AHU"
							-- Switch ""
							-- Relay
				--	4:2-51	HMS-S/D/M/SA	"B/L2/WC/2F/MCP51/FIRE SHAFT L.L."
				--	4:2-52	HTRI-R	"B/L2/WC/2F/CM52/FIRE SHAFT L.L."
							-- Switch ""
							-- Relay
				--	4:2-53	HTRI-S	"B/L2/WC/2F/MM53/FIRE SHAFT L.L."
				--	4:2-54	HTRI-R	"B/L2/WC/2F/CM54/DOOR RELESE NR E"
							-- Switch ""
							-- Relay
				--	4:2-55	HTRI-R	"B/L2/WC/2F/CM55/STR NR AW 2023"
							-- Switch ""
							-- Relay
				--	4:2-56	HMS-S/D/M/SA	"B/L2/WC/2F/MCP56/STR NR AW 2023"
				--	4:2-57	HMS-S/D/M/SA	"B/L2/WC/1F/MCP57/FIRE SHAFT NR L"
				--	4:2-58	HTRI-R	"B/L2/WC/1F/CM58/FIRE SHAFT NR L."
							-- Switch ""
							-- Relay
				--	4:2-59	HTRI-S	"B/L2/WC/1F/MM59/FIRE SHAFT NR L."
				--	4:2-60	HFP-11	"B/L2/BW 2020/SD60/Account cab"
				--	4:2-61	HMS-S/D/M/SA	"B/L2/BW 2020/MCP61/Entry Door"
				--	4:2-64	HFP-11	"B/L2/BW2080/SD64/Cab 1"
				--	4:2-65	HFP-11	"B/L2/BW2080/SD65/Cab 1"
				--	4:2-66	HFP-11	"B/L2/BW2080/SD66/Cab 2"
				--	4:2-67	HFP-11	"B/L2/BW2080/SD67/Psg nr ent"
				--	4:2-68	HTRI-R	"B/L2/BW2080/CM68/Psg nr ent"
							-- Switch ""
							-- Relay
				--	4:2-69	HMS-S/D/M/SA	"B/L2/BW2080/MCP69/Psg nr ent"
				--	4:2-75	HTRI-S	"B/L2/1F/MM75/BW1100"
				--	4:2-77	HTRI-S	"B/L2/1F/MM77/BW1090"
				--	4:2-78	HTRI-S	"B/L2/1F/MM78/BW1121"
				--	4:2-80	HTRI-S	"B/L2/1F/MM80/BW1080"
				--	4:2-81	HTRI-S	"B/L2/1F/MM81/BW1070"
				--	4:2-82	HTRI-S	"B/L2/1F/MM82/BW1160"
				--	4:2-83	HTRI-S	"B/L2/1F/MM83/BW1130"
				--	4:2-84	HTRI-S	"B/L2/1F/MM84/BW1140"
				--	4:2-88	HTRI-S	"B/L2/1F/MM88/BW1060"
				--	4:2-90	HTRI-S	"B/L2/1F/MM90/BW1010"
				--	4:2-92	HTRI-S	"B/L2/1F/MM92/BW1030"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:2 DLC "DLC @ address 2 L2"

			-- 4:2-94 HTRI-S "B/L2/1F/MM94/BW1040"
			-- 4:2-95 HTRI-S "B/L2/2F/MM95/AW2140"
			-- 4:2-96 HTRI-S "B/L2/2F/MM96/AW2023"
			-- 4:2-97 HTRI-S "B/L2/2F/MM97/AW/2030"
			-- 4:2-98 HTRI-S "B/L2/2F/MM98/AW2130"
			-- 4:2-99 HTRI-S "B/L2/2F/MM99/AW2040"
			-- 4:2-103 HTRI-S "B/L2/2F/MM103/AW2112"
			-- 4:2-104 HTRI-S "B/L2/2F/MM104/AW2070"
			-- 4:2-107 HTRI-S "B/L2/2F/MM107/AW2111"
			-- 4:2-108 HTRI-S "B/L2/2F/MM108/AW2100"
			-- 4:2-111 HTRI-S "B/L2/2F/MM111/BW2230"
			-- 4:2-112 HTRI-S "B/L2/2F/MM112/BW2220"
			-- 4:2-113 HTRI-S "B/L2/2F/MM113/BW2010"
			-- 4:2-115 HTRI-S "B/L2/2F/MM115/BW2210"
			-- 4:2-119 HTRI-S "B/L2/2F/MM119/BW2050"
			-- 4:2-121 HTRI-S "B/L2/2F/MM121/BW2060"
			-- 4:2-123 HTRI-S "B/L2/2F/MM123/BW2180"
			-- 4:2-124 HFP-11 "B/L2/AW2120/SD124/Main Cabin"
			-- 4:2-125 HFP-11 "B/L2/AW2120/SD125/Accounts Depar"
			-- 4:2-126 HFP-11 "B/L2/AW2120/SD126/Passage Area"
			-- 4:2-127 HTRI-R "B/L2/AW2120/CM127/Passage Area"
			-- Switch ""
			-- Relay
			-- 4:2-128 HMS-S/D/M/SA "B/L2/AW2120/MCP128/Entry Door"
			-- 4:2-129 HFP-11 "B/L2/AW2060/SD129/Main Cabin"
			-- 4:2-130 HFP-11 "B/L2/AW2060/SD130/Accounts Depar"
			-- 4:2-131 HFP-11 "B/L2/AW2060/SD131/Store Room"
			-- 4:2-132 HFP-11 "B/L2/AW2060/SD132/Passage Area"
			-- 4:2-133 HFPT-11 "B/L2/AW2060/SD133/Pantry"
			-- 4:2-134 HMS-S/D/M/SA "B/L2/AW2060/MCP134/Entry Door"
			-- 4:2-135 HTRI-R "B/L2/AW2060/CM135/Entry Door"
			-- Switch ""
			-- Relay
			-- 4:2-136 HFP-11 "B/L2/AW2090/SD136/Main Cabin"
			-- 4:2-137 HFP-11 "B/L2/AW2090/SD137/Buyers Cabin"
			-- 4:2-138 HFP-11 "B/L2/AW2090/SD138/Passage Area"
			-- 4:2-139 HFP-11 "B/L2/AW2090/SD139/Pantry"
			-- 4:2-140 HMS-S/D/M/SA "B/L2/AW2090/MCP140/Entry Door"
			-- 4:2-142 HFP-11 "B/L2/AW2080/SD142/Pantry Area"
			-- 4:2-143 HFP-11 "B/L2/AW2080/SD143/Passage Area"
			-- 4:2-144 HFP-11 "B/L2/AW2080/SD144/Cabin 1"
			-- 4:2-145 HFP-11 "B/L2/AW2080/SD145/Cabin 2"
			-- 4:2-146 HTRI-R "B/L2/AW2080/CM146/Entry Door"
			-- Switch ""
			-- Relay
			-- 4:2-147 HMS-S/D/M/SA "B/L2/AW2080/MCP147/Entry Door"
			-- 4:2-148 FDOT421 "B/L2/BW2251/SD148/Psg nr Pantry"
			-- 4:2-149 FDOT421 "B/L2/BW2251/SD149/Cabin 2"
			-- 4:2-150 HFP-11 "B/L2/BW 2251/SD150/Cabin 3"
			-- 4:2-151 HFP-11 "B/L2/BW 2251/SD151/Main cabin"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:2 DLC "DLC @ address 2 L2"

				--	4:2-152	HFP-11	"B/L2/BW 2251/SD152/Main cabin"
				--	4:2-153	FDOT421	"B/L2/BW2251/SD153/ConferenceRM"
				--	4:2-154	HMS-S/D/M/SA	"B/L2/BW 2251/MCP154/Main Entranc"
				--	4:2-155	HTRI-R	"B/L2/BW 2251/CM155/Entrance door"
					--	Switch	" "
					--	Relay	
				--	4:2-156	HFP-11	"B/L2/BW 1110/SD156/Main cabin"
				--	4:2-157	HFP-11	"B/L2/BW 1110/SD157/Main cabin"
				--	4:2-158	HTRI-R	"B/L2/BW 1110/CM158/Entrance door"
					--	Switch	" "
					--	Relay	
				--	4:2-159	HMS-S/D/M/SA	"B/L2/BW 1110/MCP159/Main Entranc"
				--	4:2-160	HFP-11	"B/L2/BW 1130 A/SD160/Psg near En"
				--	4:2-161	HFP-11	"B/L2/BW 1130 A/SD161/Cabin 1"
				--	4:2-162	HFP-11	"B/L2/BW 1130 A/SD162/Cabin 2"
				--	4:2-163	HFP-11	"B/L2/BW2240/SD163/Entry Psg"
				--	4:2-173	HFP-11	"B/L2/BW 1150/SD173/Cab 4"
				--	4:2-174	HMS-S/D/M/SA	"B/L2/BW 1150/MCP174/Entry Dr"
				--	4:2-175	HFP-11	"B/L2/BW 1170/SD175/Psg near Pant"
				--	4:2-176	HFPT-11	"B/L2/BW1170/HD176/Pantry"
				--	4:2-177	HFP-11	"B/L2/BW 1170/SD177/Cab 1"
				--	4:2-178	HFP-11	"B/L2/BW 1170/SD178/Cab 2"
				--	4:2-179	HFP-11	"B/L2/BW 1170/SD179/Cab 3"
				--	4:2-180	HMS-S/D/M/SA	"B/L2/BW 1170/MCP180/Main Entry"
				--	4:2-181	HTRI-R	"B/L2/BW 1170/CM181/Main Entry"
					--	Switch	" "
					--	Relay	
				--	4:2-182	HFP-11	"B/L2/BW 2200/SD182/Psg near Entr"
				--	4:2-183	HFP-11	"B/L2/BW 2200/SD183/Cab 1"
				--	4:2-184	HFP-11	"B/L2/BW 2200/SD184/Cab 2"
				--	4:2-185	HMS-S/D/M/SA	"B/L2/BW 2200/MCP185/Entry Dr"
				--	4:2-186	HTRI-R	"B/L2/BW 2200/CM186/ Entry Dr"
					--	Switch	" "
					--	Relay	
				--	4:2-187	HTRI-R	"B/L2/BW 1130 A/CM187/Psg near En"
					--	Switch	" "
					--	Relay	
				--	4:2-188	HMS-S/D/M/SA	"B/L2/BW 1130 A/MCP188/Psg near E"
				--	4:2-189	HTRI-R	"B/L2/BW 1150/CM189/Entry Dr"
					--	Switch	" "
					--	Relay	
				--	4:2-190	HFP-11	"B/L2/BW 2190/SD190/Cab 1"
				--	4:2-191	HFP-11	"B/L2/BW 2190/SD191/Cab 2"
				--	4:2-192	HFP-11	"B/L2/BW 2190/SD192/Cab 3"
				--	4:2-193	HFP-11	"B/L2/BW 2190/SD193/Cab 4"
				--	4:2-194	HTRI-R	"B/L2/BW 2190/CM194/Entry Dr"
					--	Switch	" "
					--	Relay	
				--	4:2-195	HMS-S/D/M/SA	"B/L2/BW 2190/MCP195/Entry Dr"
				--	4:2-196	HTRI-R	"B/L2/AW2090/CM196/Entry Door"

```
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:2-197 HFP-11 "B/L2/BW 2040/HD197/Pantry"
| | | |-- 4:2-198 HFP-11 "B/L2/BW 2040/SD198/Psg near Pant"
| | | |-- 4:2-199 HFP-11 "B/L2/BW 2040/SD199/Cab 1"
| | | |-- 4:2-200 HFP-11 "B/L2/BW 2040/SD200/Cab 1"
| | | |-- 4:2-201 HMS-S/D/M/SA "B/L2/BW 2040/MCP201/Entry Dr"
| | | |-- 4:2-202 HTRI-R "B/L2/BW 2040/CM202/Entry Dr"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:2-210 HFP-11 "B/L2/BW 1020/SD210/Pantry"
| | | |-- 4:2-211 HFP-11 "B/L2/BW 1020/SD211/Main Cab"
| | | |-- 4:2-212 HFP-11 "B/L2/BW 1020/SD212/Cab 1"
| | | |-- 4:2-213 HTRI-R "B/L2/BW 1020/CM213/Entry Dr"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:2-214 HMS-S/D/M/SA "B/L2/BW 1020/MCP214/Entry Dr"
| | | |-- 4:2-215 HFP-11 "B/L2/BW 1122/SD215/Cab 3"
| | | |-- 4:2-216 HFP-11 "B/L2/BW 1122/SD216/Cab 2"
| | | |-- 4:2-217 HFP-11 "B/L2/BW 1122/SD217/Cab 1"
| | | |-- 4:2-218 HFP-11 "B/L2/BW 1122/SD218/Psg near Cab "
| | | |-- 4:2-219 HTRI-R "B/L2/BW 1122/CM219/Entry Dr"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:2-220 HMS-S/D/M/SA "B/L2/BW 1122/MCP220/Entry Dr"
| | | |-- 4:2-221 HFP-11 "B/L2/BW2240/SD221/Psg near confe"
| | | |-- 4:2-222 HFP-11 "B/L2/BW2240/SD222/Conference Roo"
| | | |-- 4:2-223 HFP-11 "B/L2/BW2240/SD223/Main cabin"
| | | |-- 4:2-224 HFP-11 "B/L2/BW2240/SD224/Psg near Main "
| | | |-- 4:2-225 HFP-11 "B/L2/BW2240/SD225/Pantry"
| | | |-- 4:2-226 HTRI-R "B/L2/BW2240/CM226/Entry Door"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:2-227 HMS-S/D/M/SA "B/L2/BW2240/MCP227/Entry Door"
| | | |-- 4:2-228 HFP-11 "B/L2/BW2251/SD228//Reception""
| | | |-- 4:2-229 HFP-11 "B/L2/BW2251/SD229/Psg near Rece"
| | | |-- 4:2-230 HFP-11 "B/L2/BW2251/SD230/Account Cabin"
| | | |-- 4:2-231 HFP-11 "B/L2/BW2251/SD231/Assorter cabi"
| | | |-- 4:2-232 HFP-11 "B/L2/BW2251/SD232/Assorter cabi"
| | | |-- 4:2-233 FDOT421 "B/L2/BW2251/SD233/Cabin 1"
| | | |-- 4:2-234 FDOT421 "B/L2/BW2251/SD234/Pantry"
| | | |-- 4:2-235 HFP-11 "B/L2/BW 2070/SD235/Main Cab"
| | | |-- 4:2-236 HFP-11 "B/L2/BW 2070/SD236/Cab 1"
| | | |-- 4:2-237 HFP-11 "B/L2/BW 2070/SD237/Psg near Cab"
| | | |-- 4:2-238 HFP-11 "B/L2/BW 2070/SD238/Entry Dr "
| | | |-- 4:2-239 HFP-11 "B/L2/BW 2070/SD239/Pantry"
| | | |-- 4:2-240 HTRI-R "B/L2/BW 2070/CM240/Entry Dr"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:2-241 HMS-S/D/M/SA "B/L2/BW 2070/MCP241/Entry Dr"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:2 DLC "DLC @ address 2 L2"

```
|      |      |      |-- 4:2-243 HFP-11 "B/L2/BW 2020/SD243/Waiting Area"
|      |      |      |-- 4:2-244 FDOT421 "B/L2/BW 2020/SD244/Psg nr waitin"
|      |      |      |-- 4:2-245 HFP-11 "B/L2/BW 2020/SD245/Psg near Acct"
|      |      |      |-- 4:2-246 HFP-11 "B/L2/BW 2020/SD246/Assts Room"
|      |      |      |-- 4:2-247 HFP-11 "B/L2/BW 2020/SD247/Executive Cab"
|      |      |      |-- 4:2-248 HFP-11 "B/L2/BW 2020/SD248/Main Cab"
|      |      |      |-- 4:2-249 FDOT421 "B/L2/BW 2020/SD249/SalesCab"
|      |      |      |-- 4:2-250 HFP-11 "B/L2/BW1110/SD250/Pantry"
|      |      |      |-- 4:2-251 HFP-11 "B/L2/BW 2020/SD251/Conferece rm"
|      |      |      |-- 4:2-252 HTRI-R "B/L2/BW 2020/CM252/Entry DoorAFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3 DLC "DLC @ address 3 L3"
|      |      |      |-- 4:3-1 FDOT421 "B/L3/CC/3F/SD1/ELECT RM"
|      |      |      |-- 4:3-2 FDOT421 "B/L3/CC/3F/SD2/OutsideElectRmAFC"
|      |      |      |-- 4:3-3 FDOT421 "B/L3/CC/3F/SD3/OUTSIDE ELECT RM"
|      |      |      |-- 4:3-4 FDOT421 "B/L3/CC/3F/SD4/CORR BC 3012"
|      |      |      |-- 4:3-5 FDOT421 "B/L3/CC/3F/SD5/CORR BC 3021AFC"
|      |      |      |-- 4:3-6 FDOT421 "B/L3/CC/3F/SD6/CORR BC 3021"
|      |      |      |-- 4:3-7 FDOT421 "B/L3/CC/3F/SD7/LIFT LOBBY"
|      |      |      |-- 4:3-8 FDOT421 "B/L3/CC/3F/SD8/LIFT LOBBY"
|      |      |      |-- 4:3-9 HMS-S/D/M/SA "B/L3/CC/3F/MCP9/FIRE ESCAPE STR "
|      |      |      |-- 4:3-10 HTRI-R "B/L3/CC/3F/CM10/FIRE HYD SHAFT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-11 HTRI-S "B/L3/CC/3F/MM11/FIRE HYD SHAFT"
|      |      |      |-- 4:3-12 HTRI-R "B/L3/CC/3F/CM12/DOOR RELEASE UNI"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-13 FDOT421 "B/L3/CC/3F/SD13/PsgNr AFC AHU RM"
|      |      |      |-- 4:3-14 FDOT421 "B/L3/CC/3F/SD14/PSG NR AHU RM"
|      |      |      |-- 4:3-15 FDOT421 "B/L3/EC/3F/SD15/AFC CorrNrELE RM"
|      |      |      |-- 4:3-16 FDOT421 "B/L3/EC/3F/SD16/CORR NR ELE RM"
|      |      |      |-- 4:3-17 FDOT421 "B/L3/EC/3F/SD17/AHU RM"
|      |      |      |-- 4:3-18 HTRI-R "B/L3/EC/3F/CM18/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-19 FDOT421 "B/L3/EC/3F/SD19/ELECT RM"
|      |      |      |-- 4:3-20 FDOT421 "B/L3/EC/3F/SD20/LIFT LOBBY"
|      |      |      |-- 4:3-21 HMS-S/D/M/SA "B/L3/EC/3F/MCP21/FIRE ESCAPE STA"
|      |      |      |-- 4:3-22 HTRI-R "B/L3/BE/3F/CM22/FIRE HYD SHAFT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-23 HTRI-S "B/L3/EC/3F/MM23/FIRE HYD SHAFT"
|      |      |      |-- 4:3-24 HMS-S/D/M/SA "B/L3/3F/MCP24/BC FIRE STR"
|      |      |      |-- 4:3-25 FDOT421 "B/L3/CC/2F/SD25/ELECT RM"
|      |      |      |-- 4:3-26 FDOT421 "B/L3/CC/2F/SD26/CorrNrElectRMAFC"
|      |      |      |-- 4:3-27 FDOT421 "B/L3/CC/2F/SD27/CORR NR ELECT RM"
|      |      |      |-- 4:3-28 FDOT421 "B/L3/CC/2F/SD28/CORR BC 2010"
|      |      |      |-- 4:3-29 FDOT421 "B/L3/CC/2F/SD29/CORR BC2031 AFC"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:3 DLC "DLC @ address 3 L3"

			-- 4:3-30 FDOT421 "B/L3/CC/2F/SD30/CORR BC 2031"
			-- 4:3-31 FDOT421 "B/L3/CC/2F/SD31/CORR NR BC 2050"
			-- 4:3-32 FDOT421 "B/L3/CC/2F/SD32/CORR BC2042AFC"
			-- 4:3-33 FDOT421 "B/L3/CC/2F/SD33/CORR BC2/S20"
			-- 4:3-34 FDOT421 "B/L3/CC/2F/SD34/CORR NR BC 2041"
			-- 4:3-35 FDOT421 "B/L3/CC/2F/SD35/CORR NR BC-2S/20"
			-- 4:3-36 FDOT421 "B/L3/CC/2F/SD36/CORR BC-2S/20A"
			-- 4:3-37 HMS-S/D/M/SA "B/L3/CC/2F/MCP37/FIRE ESCAPE STR"
			-- 4:3-38 HTRI-R "B/L3/CC/2F/CM38/FIRE ESCAPE STR "
			-- Switch ""
			-- Relay
			-- 4:3-39 HMS-S/D/M/SA "B/L3/CC/2F/MCP39/FIRE ESCAPE STR"
			-- 4:3-40 HTRI-R "B/L3/CC/2F/CM40/FIRE HYD SHAFT"
			-- Switch ""
			-- Relay
			-- 4:3-41 HTRI-S "B/L3/CC/2F/MM41/FIRE HYD SHAFT"
			-- 4:3-42 FDOT421 "B/L3/CC/2F/SD42/LIFT LOBBY"
			-- 4:3-43 FDOT421 "B/L3/CC/2F/SD43/LIFT LOBBY"
			-- 4:3-44 FDOT421 "B/L3/CC/2F/SD44/CorrNrBC2091AFC"
			-- 4:3-45 FDOT421 "B/L3/CC/2F/SD45/CORR NR BC 2091"
			-- 4:3-46 FDOT421 "B/L3/EC/2F/SD46/AFC CORNR AHU RM"
			-- 4:3-47 FDOT421 "B/L3/EC/2F/SD47/CORR BE 2010"
			-- 4:3-48 FDOT421 "B/L3/EC/2F/SD48/ELECT RM"
			-- 4:3-49 FDOT421 "B/L3/EC/2F/SD49/AHU RM"
			-- 4:3-50 HTRI-R "B/L3/2F/CM50/BE AHU RM"
			-- Switch ""
			-- Relay
			-- 4:3-51 FDOT421 "B/L3/EC/2F/SD51/LIFT LOBBY"
			-- 4:3-52 HMS-S/D/M/SA "B/L3/EC/2F/MCP52/LIFT LOBBY"
			-- 4:3-53 HTRI-R "B/L3/EC/2F/CM53/FIRE HYD SHAFT"
			-- Switch ""
			-- Relay
			-- 4:3-54 HTRI-S "B/L3/EC/2F/MM54/FIRE HYD SHAFT"
			-- 4:3-55 HTRI-R "B/L3/CC/3F/CM55/FIRE STR"
			-- Switch ""
			-- Relay
			-- 4:3-57 HTRI-R "B/L3/CC/2F/CM57/AHU RM"
			-- Switch ""
			-- Relay
			-- 4:3-58 FDOT421 "B/L3/CC/2F/SD58/AHU RM"
			-- 4:3-59 FDOT421 "B/L3/CC/3F/SD59/AHU RM"
			-- 4:3-60 HTRI-R "B/L3/CC/3F/CM60/AHU RM"
			-- Switch ""
			-- Relay
			-- 4:3-75 HTRI-S "B/L3/2F/MM75/BC2033"
			-- 4:3-76 HTRI-S "B/L3/2F/MM76/BC2041"
			-- 4:3-77 HTRI-S "B/L3/2F/MM77/BC2042"
			-- 4:3-78 HTRI-S "B/L3/2F/MM78/BC2050"
			-- 4:3-79 HTRI-S "B/L3/2F/MM79/BC2032"
			-- 4:3-80 HTRI-S "B/L3/2F/MM80/BC2031"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:3 DLC "DLC @ address 3 L3"

```
|      |      |      |-- 4:3-81 HFPT-11 "B/L3/HD81/BC2060/Pantry"
|      |      |      |-- 4:3-82 HTRI-S "B/L3/2F/MM82/BC2020"
|      |      |      |-- 4:3-83 HTRI-S "B/L3/2F/MM83/BC2010"
|      |      |      |-- 4:3-84 HTRI-S "B/L3/2F/MM84/BC2071"
|      |      |      |-- 4:3-86 HTRI-S "B/L3/2F/MM86/BC2091"
|      |      |      |-- 4:3-87 HTRI-S "B/L3/2F/MM87/BC2090"
|      |      |      |-- 4:3-92 HTRI-S "B/L3/3F/MM92/BC3022"
|      |      |      |-- 4:3-94 HTRI-S "B/L3/3F/MM94/BC3012"
|      |      |      |-- 4:3-96 HTRI-S "B/L3/3F/MM96/BC3050"
|      |      |      |-- 4:3-97 HTRI-S "B/L3/3F/MM97/BC3040"
|      |      |      |-- 4:3-98 HTRI-S "B/L3/2F/MM98/BE2010"
|      |      |      |-- 4:3-100 HTRI-S "B/L3/3F/MM100/BE3011"
|      |      |      |-- 4:3-101 HFP-11 "B/L3/BC2080/SD101/Assorter cab"
|      |      |      |-- 4:3-102 HFP-11 "B/L3/BC2080/SD102/Main cab"
|      |      |      |-- 4:3-103 HFP-11 "B/L3/BC2080/SD103/Pantry"
|      |      |      |-- 4:3-104 HFP-11 "B/L3/BC2080/SD104/Entry psg"
|      |      |      |-- 4:3-105 HTRI-R "B/L3/BC2080/CM105/ Entry psg AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-106 HMS-S/D/M/SA "B/L3/BC2080/MCP106/ Entry psg"
|      |      |      |-- 4:3-109 HFP-11 "B/L3/BC3030/SD109/Waiting Area"
|      |      |      |-- 4:3-110 HFP-11 "B/L3/BC3030/SD110/Pantry"
|      |      |      |-- 4:3-111 HFP-11 "B/L3/BC3030/SD111/Psg near Pantr"
|      |      |      |-- 4:3-112 HFP-11 "B/L3/BC3030/SD112/Main Cab"
|      |      |      |-- 4:3-113 HFP-11 "B/L3/BC3030/SD113/Cab 1"
|      |      |      |-- 4:3-114 HFP-11 "B/L3/BC3030/SD114/Cab 2"
|      |      |      |-- 4:3-115 HFP-11 "B/L3/BC3030/SD115/Cab 3"
|      |      |      |-- 4:3-116 HFP-11 "B/L3/BC3030/SD116/Asst Cab"
|      |      |      |-- 4:3-117 HFP-11 "B/L3/BC3030/SD117/Weighting corn"
|      |      |      |-- 4:3-118 HFP-11 "B/L3/BC3030/SD118/Accts Cab"
|      |      |      |-- 4:3-119 HFP-11 "B/L3/BC3030/SD119/Cab 4"
|      |      |      |-- 4:3-120 HFP-11 "B/L3/BC3030/SD120/Psg near Cab 4"
|      |      |      |-- 4:3-121 HTRI-R "B/L3/BC3030/CM121/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:3-122 HMS-S/D/M/SA "B/L3/BC3030/MCP122/Entry Dr"
|      |      |      |-- 4:3-123 HFP-11 "B/L3/BW3010/SD123/Cab13"
|      |      |      |-- 4:3-124 HFP-11 "B/L3/BW3010/SD124/Cab 11"
|      |      |      |-- 4:3-125 HFP-11 "B/L3/BW3010/SD125/Cab 11"
|      |      |      |-- 4:3-126 HFP-11 "B/L3/BW3010/SD126/Cab 10"
|      |      |      |-- 4:3-127 HFP-11 "B/L3/BW3010/SD127/Cab 12"
|      |      |      |-- 4:3-128 HFP-11 "B/L3/BW3010/SD128/cab 9"
|      |      |      |-- 4:3-129 HFP-11 "B/L3/BW3010/SD129/Psg nr Pantry"
|      |      |      |-- 4:3-130 HFP-11 "B/L3/BW3010/SD130/Pantry"
|      |      |      |-- 4:3-131 HMS-S/D/M/SA "B/L3/BW3010/MCP131/Psg nr Entry "
|      |      |      |-- 4:3-132 HFP-11 "B/L3/BW3010/SD132/Psg nr cab 12"
|      |      |      |-- 4:3-133 HFP-11 "B/L3/BW3010/SD133/cab 9"
|      |      |      |-- 4:3-134 HFP-11 "B/L3/BW3010/SD134/Psg nr Pantry "
|      |      |      |-- 4:3-135 HFP-11 "B/L3/BW3010/SD135/cab 7"
|      |      |      |-- 4:3-136 HFP-11 "B/L3/BW3010/SD136/cab 8"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:3 DLC "DLC @ address 3 L3"

```
|      |      |  |-- 4:3-137 HFP-11 "B/L3/BW3010/SD137/Cab 6"
|      |      |  |-- 4:3-138 HFP-11 "B/L3/BW3010/SD138/Psg nr Confere"
|      |      |  |-- 4:3-139 HFP-11 "B/L3/BW3010/SD139/Conference roo"
|      |      |  |-- 4:3-140 HFP-11 "B/L3/BW3010/SD140/Cab 5"
|      |      |  |-- 4:3-141 HFP-11 "B/L3/BW3010/SD141/Psg nr cab 5"
|      |      |  |-- 4:3-142 HFP-11 "B/L3/BW3010/SD142/Cab 1"
|      |      |  |-- 4:3-143 HFP-11 "B/L3/BW3010/SD143/Main cab"
|      |      |  |-- 4:3-144 HFP-11 "B/L3/BW3010/SD144/Main cab"
|      |      |  |-- 4:3-145 HFP-11 "B/L3/BW3010/SD145/Psg nr Main ca"
|      |      |  |-- 4:3-146 HFP-11 "B/L3/BW3010/SD146/Cab 2"
|      |      |  |-- 4:3-147 HFP-11 "B/L3/BW3010/SD147/Psg nr cab 3"
|      |      |  |-- 4:3-148 HFP-11 "B/L3/BW3010/SD148/Cab 4"
|      |      |  |-- 4:3-149 HTRI-R "B/L3/BW3010/CM149/Psg nr Entry D"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:3-150 HFP-11 "B/L3/BW3010/SD150/Reception"
|      |      |  |-- 4:3-151 HFP-11 "B/L3/BC2060/SD151/Assorter cab"
|      |      |  |-- 4:3-152 HFP-11 "B/L3/BC2060/SD152/Reception cab"
|      |      |  |-- 4:3-153 HFP-11 "B/L3/BC2060/SD153/Accounts cab"
|      |      |  |-- 4:3-154 HFP-11 "B/L3/BC2060/SD154/Main cab"
|      |      |  |-- 4:3-155 HFP-11 "B/L3/BC2060/SD155/Main cab"
|      |      |  |-- 4:3-156 HMS-S/D/M/SA "B/L3/BC2060/MCP156/Psg nr Entry "
|      |      |  |-- 4:3-157 HTRI-R "B/L3/BC2060/CM157/Psg nr Entry D"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:3-158 HFP-11 "B/L3/BC3011/SD158/cab 1"
|      |      |  |-- 4:3-159 HFP-11 "B/L3/BC3011/SD159/cab 2"
|      |      |  |-- 4:3-160 HFP-11 "B/L3/BC3011/SD160/cab 3"
|      |      |  |-- 4:3-161 HFP-11 "B/L3/BC3011/SD161/cab 4"
|      |      |  |-- 4:3-162 HFP-11 "B/L3/BC3011/SD162/cab 5"
|      |      |  |-- 4:3-165 HTRI-R "B/L3/BC3011/CM165/Psg nr Entry D"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:3-166 HMS-S/D/M/SA "B/L3/BC3011/MCP166/Psg nr Entry "
|      |      |  |-- 4:3-167 HFP-11 "B/L3/BC3021/SD167/MAIN CABIN"
|      |      |  |-- 4:3-168 HFP-11 "B/L3/BC3021/SD168/ASSORTOR CABIN"
|      |      |  |-- 4:3-169 HFP-11 "B/L3/BC3021/SD169/PSG. NR.ASSORT"
|      |      |  |-- 4:3-170 HFPT-11 "B/L3/BC3021/HD170/PANTRY"
|      |      |  |-- 4:3-171 HTRI-R "B/L3/BC3021/CM171/ENTRY PSG AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:3-172 HMS-S/D/M/SA "B/L3/BC3021/MCP172/ENTRY PSG"
|      |      |  |-- 4:3-197 HFP-11 "B/L3/BW3010/SD197/Lunch room"
|      |      |  |-- 4:4 DLC "DLC @ address 4 L4"
|      |      |  |-- 4:4-1 FDOT421 "B/L4/WC/3F/SD1/ELECT RM SD"
|      |      |  |-- 4:4-2 FDOT421 "B/L4/WC/3F/SD2/Corr Nr AW3061AFC"
|      |      |  |-- 4:4-3 FDOT421 "B/L4/WC/3F/SD3/CORR NR AW 3061"
|      |      |  |-- 4:4-4 FDOT421 "B/L4/WC/3F/SD4/CORR NR AW3041"
|      |      |  |-- 4:4-5 FDOT421 "B/L4/WC/3F/SD5/CorrNr AW3042 AFC"
|      |      |  |-- 4:4-6 FDOT421 "B/L4/WC/3F/SD6/CORR NR AW 3042"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 4:4-7 FDOT421 "B/L4/WC/3F/SD7/CORR NR AW 3032"
|      |      |      |-- 4:4-8 FDOT421 "B/L4/WC/3F/SD8/CORR NR AW 3100"
|      |      |      |-- 4:4-9 FDOT421 "B/L4/WC/3F/SD9/CORR NR AW 3100"
|      |      |      |-- 4:4-10 FDOT421 "B/L4/WC/3F/SD10/LIFT LOBBY SD"
|      |      |      |-- 4:4-11 FDOT421 "B/L4/WC/3F/SD11/LIFT LOBBY SD"
|      |      |      |-- 4:4-12 FDOT421 "B/L4/WC/3F/SD12/CorrNrAHU RM"
|      |      |      |-- 4:4-13 FDOT421 "B/L4/WC/3F/SD13/CorrNrAHU RM"
|      |      |      |-- 4:4-14 FDOT421 "B/L4/WC/3F/SD14/CorrNr BW3022"
|      |      |      |-- 4:4-15 FDOT421 "B/L4/WC/3F/SD15/CORR NR BW 3022"
|      |      |      |-- 4:4-16 FDOT421 "B/L4/WC/3F/SD16/CORR NR BW 3032"
|      |      |      |-- 4:4-17 FDOT421 "B/L4/WC/3F/SD17/CORR NR BW 3050"
|      |      |      |-- 4:4-18 FDOT421 "B/L4/WC/3F/SD18/CORR NR BW 3050"
|      |      |      |-- 4:4-19 FDOT421 "B/L4/WC/3F/SD19/AHU RM SD"
|      |      |      |-- 4:4-20 HTRI-R "B/L4/WC/3F/CM20/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-21 HTRI-R "B/L4/WC/3F/CM21/STR NR BW 3050"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-22 HMS-S/D/M/SA "B/L4/WC/3F/MCP22/STR NR BW 3050"
|      |      |      |-- 4:4-23 HTRI-R "B/L4/WC/3F/CM23/DoorReleaseCmNrAH"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-24 HMS-S/D/M/SA "B/L4/WC/3F/MCP24/FIRE SHAFT NRL."
|      |      |      |-- 4:4-25 HTRI-R "B/L4/WC/3F/CM25/FIRE SHAFT NRL.L"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-26 HTRI-S "B/L4/WC/3F/MM26/FIRE SHAFT NRL.L"
|      |      |      |-- 4:4-27 HTRI-R "B/L4/WC/3F/CM27/DOOR RELESE CM N"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-28 HTRI-R "B/L4/WC/3F/CM28/STR NR AW 3100"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:4-29 HMS-S/D/M/SA "B/L4/WC/3F/MCP29/STR NR AW 3100"
|      |      |      |-- 4:4-30 FDOT421 "B/L4/WC/4F/SD30/BW ELECT RM"
|      |      |      |-- 4:4-31 FDOT421 "B/L4/WC/4F/SD31/CORR NR AW 4080"
|      |      |      |-- 4:4-32 FDOT421 "B/L4/WC/4F/SD32/CORR NR AW 4080"
|      |      |      |-- 4:4-33 FDOT421 "B/L4/WC/4F/SD33/CORR NR AW 4101"
|      |      |      |-- 4:4-34 FDOT421 "B/L4/WC/4F/SD34/CORR NR AW 4060"
|      |      |      |-- 4:4-35 FDOT421 "B/L4/WC/4F/SD35/CORR NR AW 4060"
|      |      |      |-- 4:4-36 FDOT421 "B/L4/WC/4F/SD36/CORR NR AW 4120"
|      |      |      |-- 4:4-37 FDOT421 "B/L4/WC/4F/SD37/CORR NR AW 4130"
|      |      |      |-- 4:4-38 FDOT421 "B/L4/WC/4F/SD38/CORR NR AW 4130"
|      |      |      |-- 4:4-39 FDOT421 "B/L4/WC/4F/SD39/LIFT LOBBY SD"
|      |      |      |-- 4:4-40 FDOT421 "B/L4/WC/4F/SD40/LIFT LOBBY SD"
|      |      |      |-- 4:4-41 FDOT421 "B/L4/WC/4F/SD41/CORR NrBW4220AFC"
|      |      |      |-- 4:4-42 FDOT421 "B/L4/WC/4F/SD42/CORR NR BW 4210"
|      |      |      |-- 4:4-43 FDOT421 "B/L4/WC/4F/SD43/CORR NR BW 4/S18"
|      |      |      |-- 4:4-44 FDOT421 "B/L4/WC/4F/SD44/CORR NrBW4201AFC"
```


4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

				--	4:4-45	FDOT421	"B/L4/WC/4F/SD45/CORR NR BW 4201"
				--	4:4-46	FDOT421	"B/L4/WC/4F/SD46/CORR NR BW 4011"
				--	4:4-47	FDOT421	"B/L4/WC/4F/SD47/CORR NrBW4180AFC"
				--	4:4-48	FDOT421	"B/L4/WC/4F/SD48/CORR NR BW 4180"
				--	4:4-49	FDOT421	"B/L4/WC/4F/SD49/CORR NR BW 4170"
				--	4:4-50	FDOT421	"B/L4/WC/4F/SD50/CORR NrBW4051AFC"
				--	4:4-51	FDOT421	"B/L4/WC/4F/SD51/CORR NR BW 4051"
				--	4:4-52	HTRI-R	"B/L4/WC/4F/CM52/STR NR BW 4051"
				--	Switch	" "	
				--	Relay		
				--	4:4-53	HMS-S/D/M/SA	"B/L4/WC/4F/MCP53/STR NR BW 4051"
				--	4:4-54	FDOT421	"B/L4/WC/4F/SD54/AHU RM SD"
				--	4:4-55	HTRI-R	"B/L4/WC/4F/CM55/AHU RM CM"
				--	Switch	" "	
				--	Relay		
				--	4:4-56	HTRI-R	"B/L4/WC/4F/CM56/DOOR RELESE CM N"
				--	Switch	" "	
				--	Relay		
				--	4:4-57	HMS-S/D/M/SA	"B/L4/WC/4F/MCP57/FIRE SHAFT NRL."
				--	4:4-58	HTRI-S	"B/L4/WC/4F/MM58/FIRE SHAFT NRL.L"
				--	4:4-59	HTRI-R	"B/L4/WC/4F/CM59/FIRE SHAFT NRL.L"
				--	Switch	" "	
				--	Relay		
				--	4:4-60	HTRI-R	"B/L4/WC/4F/CM60/DOOR RELESE CM N"
				--	Switch	" "	
				--	Relay		
				--	4:4-61	HTRI-R	"B/L4/WC/4F/CM61/STR NR AW 4130"
				--	Switch	" "	
				--	Relay		
				--	4:4-62	HMS-S/D/M/SA	"B/L4/WC/4F/MCP62/STR NR AW 4130"
				--	4:4-75	HTRI-S	"B/L4/4F/MM75/BW3062"
				--	4:4-76	HTRI-S	"B/L4/4F/MM76/BW3130"
				--	4:4-77	HTRI-S	"B/L4/4F/MM77/BW3061"
				--	4:4-82	HTRI-S	"B/L4/4F/MM82/BW3150"
				--	4:4-83	HTRI-S	"B/L4/4F/MM83/BW3160"
				--	4:4-85	HTRI-S	"B/L4/4F/MM85/BW3170"
				--	4:4-88	HTRI-S	"B/L4/4F/MM88/BW3182"
				--	4:4-90	HTRI-S	"B/L4/4F/MM90/AW3062"
				--	4:4-91	HTRI-S	"B/L4/4F/MM91/AW3061"
				--	4:4-93	HTRI-S	"B/L4/4F/MM93/AW3051"
				--	4:4-95	HTRI-S	"B/L4/4F/MM95/AW3070"
				--	4:4-97	HTRI-S	"B/L4/4F/MM97/AW3080"
				--	4:4-98	HTRI-S	"B/L4/4F/MM98/AW3032"
				--	4:4-100	HTRI-S	"B/L4/4F/MM100/AW3031"
				--	4:4-103	HTRI-S	"B/L4/4F/MM103/AW4023"
				--	4:4-104	HTRI-S	"B/L4/4F/MM104/AW4130"
				--	4:4-107	HTRI-S	"B/L4/4F/MM107/AW4040"
				--	4:4-108	HTRI-S	"B/L4/4F/MM108/AW4110"
				--	4:4-109	HTRI-S	"B/L4/4F/MM109/AW4050"
				--	4:4-110	HTRI-S	"B/L4/4F/MM110/AW4060"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

			-- 4:4-111	HTRI-S	"B/L4/4F/MM111/AW4102"
			-- 4:4-112	HTRI-S	"B/L4/4F/MM112/AW4101"
			-- 4:4-113	HTRI-S	"B/L4/4F/MM113/AW4070"
			-- 4:4-114	HTRI-S	"B/L4/4F/MM114/AW4080"
			-- 4:4-117	HTRI-S	"B/L4/4F/MM117/BW4220"
			-- 4:4-118	HTRI-S	"B/L4/4F/MM118/BW4210"
			-- 4:4-120	HTRI-S	"B/L4/4F/MM120/BW4201"
			-- 4:4-121	HTRI-S	"B/L4/4F/MM121/BW4011"
			-- 4:4-124	HTRI-S	"B/L4/4F/MM124/BW4021"
			-- 4:4-125	HTRI-S	"B/L4/4F/MM125/BW4180"
			-- 4:4-126	HTRI-S	"B/L4/4F/MM126/BW4022"
			-- 4:4-127	HTRI-S	"B/L4/4F/MM127/BW4030"
			-- 4:4-128	HTRI-S	"B/L4/4F/MM128/BW4170"
			-- 4:4-131	HTRI-S	"B/L4/4F/MM131/BW4160"
			-- 4:4-132	HTRI-S	"B/L4/4F/MM132/BW4052"
			-- 4:4-133	HFP-11	"B/L4/AW4030/SD133/Account Depart"
			-- 4:4-134	HFP-11	"B/L4/AW4030/SD134/Main cabin"
			-- 4:4-135	HFP-11	"B/L4/AW4030/SD135/Passage Area"
			-- 4:4-136	HTRI-R	"B/L4/AW4030/CM136/Passage Area"
				-- Switch	" "
				-- Relay	
			-- 4:4-137	HMS-S/D/M/SA	"B/L4/AW4030/MCP137/Entry Door"
			-- 4:4-138	HFP-11	"B/L4/AW4120/SD138/Main Cabin"
			-- 4:4-139	HFP-11	"B/L4/AW4120/SD139/Passage Area"
			-- 4:4-140	HFP-11	"B/L4/AW4120/SD140/Account Depart"
			-- 4:4-141	HFP-11	"B/L4/AW4120/SD141/Pantry"
			-- 4:4-142	HMS-S/D/M/SA	"B/L4/AW4120/MCP142/Entry Door"
			-- 4:4-143	HTRI-R	"B/L4/AW4120/CM143/Entry Door"
				-- Switch	" "
				-- Relay	
			-- 4:4-144	HFP-11	"B/L4/AW4090/SD144/Main Cabin"
			-- 4:4-145	HFP-11	"B/L4/AW4090/SD145/Managers Cabin"
			-- 4:4-146	HFP-11	"B/L4/AW4090/SD146/Assorter Room"
			-- 4:4-147	HFP-11	"B/L4/AW4090/SD147/Account Cabin"
			-- 4:4-148	HFP-11	"B/L4/AW4090/SD148/Passage Area"
			-- 4:4-149	HFP-11	"B/L4/AW4090/SD149/Pantry"
			-- 4:4-150	HTRI-R	"B/L4/AW4090/CM150/Entry Door"
				-- Switch	" "
				-- Relay	
			-- 4:4-151	HMS-S/D/M/SA	"B/L4/AW4090/MCP151/Entry Door"
			-- 4:4-152	HFP-11	"B/L4/AW3090/SD152/Main Cabin"
			-- 4:4-153	HFP-11	"B/L4/AW3090/SD153/Assorter Room"
			-- 4:4-154	HFP-11	"B/L4/AW3090/SD154/Pantry"
			-- 4:4-155	HTRI-R	"B/L4/AW3090/CM155/Entry door"
				-- Switch	" "
				-- Relay	
			-- 4:4-156	HMS-S/D/M/SA	"B/L4/AW3090/MCP156/Entry door"
			-- 4:4-157	HFP-11	"B/L4/AW3022/SD157/Pantry Area"
			-- 4:4-158	HFP-11	"B/L4/AW3022/SD158/Passage Area"
			-- 4:4-159	HFP-11	"B/L4/AW3022/SD159/Cabin 1 "

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

```
|      |      |      |-- 4:4-160 HFP-11 "B/L4/AW3022/SD160/Cabin 2"
|      |      |      |-- 4:4-161 HTRI-R "B/L4/AW3022/CM161/Entry Door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-162 HMS-S/D/M/SA "B/L4/AW3022/MCP162/Entry Door"
|      |      |      |-- 4:4-163 HFP-11 "B/L4/AW3100/SD163/Passage Area"
|      |      |      |-- 4:4-164 HFPT-11 "B/L4/AW3100/SD164/Pantry Area"
|      |      |      |-- 4:4-165 HFP-11 "B/L4/AW3100/SD165/Assorter Cabin"
|      |      |      |-- 4:4-166 HFP-11 "B/L4/AW3100/SD166/Buyer Cabin"
|      |      |      |-- 4:4-167 HFP-11 "B/L4/AW3100/SD167/Main Cabin"
|      |      |      |-- 4:4-168 HTRI-R "B/L4/AW3100/CM168/Entry Door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-169 HMS-S/D/M/SA "B/L4/AW3100/MCP169/Entry Door"
|      |      |      |-- 4:4-170 HFP-11 "B/L4/BW3140/SD170/Pantry"
|      |      |      |-- 4:4-171 HFP-11 "B/L4/BW3140/SD171/Main Cab"
|      |      |      |-- 4:4-172 HFP-11 "B/L4/BW3140/SD172/Psg near Main "
|      |      |      |-- 4:4-173 HFP-11 "B/L4/BW3140/SD173/Cab 1"
|      |      |      |-- 4:4-174 HFP-11 "B/L4/BW3140/SD174/Cab 1"
|      |      |      |-- 4:4-175 HMS-S/D/M/SA "B/L4/BW3140/MCP175/Entry Dr"
|      |      |      |-- 4:4-176 HTRI-R "B/L4/BW3140/CM176/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-177 HFP-11 "B/L4/BW3050/SD177/Psg near Pantr"
|      |      |      |-- 4:4-178 HFP-11 "B/L4/BW3050/SD178/Pantry"
|      |      |      |-- 4:4-179 HFP-11 "B/L4/BW3050/SD179/Asst Cab"
|      |      |      |-- 4:4-180 HFP-11 "B/L4/BW3050/SD180/Cab 1"
|      |      |      |-- 4:4-181 HFP-11 "B/L4/BW3050/SD181/Cab 2"
|      |      |      |-- 4:4-182 HTRI-R "B/L4/BW3050/CM182/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-183 HMS-S/D/M/SA "B/L4/BW3050/MCP183/Entry Dr"
|      |      |      |-- 4:4-193 HFP-11 "B/L4/BW3040/SD193/Pantry"
|      |      |      |-- 4:4-194 HFP-11 "B/L4/BW3040/SD194/Cab 1"
|      |      |      |-- 4:4-195 HFP-11 "B/L4/BW3040/SD195/Asst Cab"
|      |      |      |-- 4:4-196 HFP-11 "B/L4/BW3040/SD196/Main Cab"
|      |      |      |-- 4:4-197 HFP-11 "B/L4/BW3040/SD197/Psg near Cab 1"
|      |      |      |-- 4:4-198 HTRI-R "B/L4/BW3040/CM198/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-199 HMS-S/D/M/SA "B/L4/BW3040/MCP199/Entry Dr"
|      |      |      |-- 4:4-200 HFP-11 "B/L4/BW3021/SD200/Pantry"
|      |      |      |-- 4:4-201 HFP-11 "B/L4/BW3021/SD201/Cab 1"
|      |      |      |-- 4:4-202 HFP-11 "B/L4/BW3021/SD202/Cab 2"
|      |      |      |-- 4:4-203 HFP-11 "B/L4/BW3021/SD203/Cab 3"
|      |      |      |-- 4:4-204 HFP-11 "B/L4/BW3021/SD204/Psg near Cab 2"
|      |      |      |-- 4:4-205 HTRI-R "B/L4/BW3021/CM205/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:4-206 HMS-S/D/M/SA "B/L4/BW3021/MCP206/Entry Dr"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:4 DLC "DLC @ address 4 L4"

```
|      |      |  |-- 4:4-207 HFP-11 "B/L4/BW3031/SD207/Pantry "
|      |      |  |-- 4:4-208 HFP-11 "B/L4/BW3031/SD208/Cab 1"
|      |      |  |-- 4:4-209 HFP-11 "B/L4/BW3031/SD209/Cab 2"
|      |      |  |-- 4:4-210 HFP-11 "B/L4/BW3031/SD210/Cab 3"
|      |      |  |-- 4:4-211 HFP-11 "B/L4/BW3031/SD211/Cab 4"
|      |      |  |-- 4:4-212 HFP-11 "B/L4/BW3031/SD212/Cab 5"
|      |      |  |-- 4:4-213 HFP-11 "B/L4/BW3031/SD213/Recp"
|      |      |  |-- 4:4-214 HTRI-R "B/L4/BW3031/CM214/Entry Dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:4-215 HMS-S/D/M/SA "B/L4/BW3031/MCP215/Entry Dr"
|      |      |  |-- 4:4-217 HFP-11 "B/L4/BW4190/SD217/Cab 2"
|      |      |  |-- 4:4-218 HFP-11 "B/L4/BW4190/SD218/Cab 1"
|      |      |  |-- 4:4-220 HTRI-R "B/L4/BW4190/CM220/Entry Dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:4-221 HMS-S/D/M/SA "B/L4/BW4190/MCP221/Entry Dr"
|      |      |  |-- 4:4-222 HFP-11 "B/L4/BW3022/SD222/Pantry "
|      |      |  |-- 4:4-223 HFP-11 "B/L4/BW3022/SD223/Psg near Pantr"
|      |      |  |-- 4:4-224 HFP-11 "B/L4/BW3022/SD224/Director Cab"
|      |      |  |-- 4:4-225 HFP-11 "B/L4/BW3022/SD225/Psg near Accts"
|      |      |  |-- 4:4-226 HTRI-R "B/L4/BW3022/CM226/Entry Dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:4-227 HMS-S/D/M/SA "B/L4/BW3022/MCP227/Entry Dr"
|      |      |  |-- 4:5 DLC "DLC @ address 5 L5"
|      |      |  |-- 4:5-1 FDOT421 "B/L5/CC/5F/SD1/ELECTRICAL RM"
|      |      |  |-- 4:5-2 FDOT421 "B/L5/CC/5F/SD2/AFC NR ELE RM"
|      |      |  |-- 4:5-3 FDOT421 "B/L5/CC/5F/SD3/CORR NR BC5025"
|      |      |  |-- 4:5-4 HMS-S/D/M/SA "B/L5/CC/5F/MCP4/FIRE ESCAPE STR"
|      |      |  |-- 4:5-5 HTRI-R "B/L5/CC/5F/CM5/FIRE HYD SHAFT"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:5-6 HTRI-S "B/L5/CC/5F/MM6/FIRE HYD SHAFT"
|      |      |  |-- 4:5-7 FDOT421 "B/L5/CC/5F/SD7/LIFT LOBBY"
|      |      |  |-- 4:5-8 FDOT421 "B/L5/CC/5F/SD8/LIFT LOBBY"
|      |      |  |-- 4:5-9 FDOT421 "B/L5/CC/5F/SD9/COR NR BC5022 AFC"
|      |      |  |-- 4:5-10 FDOT421 "B/L5/CC/5F/SD10/CORR NR BC5022"
|      |      |  |-- 4:5-11 FDOT421 "B/L5/EC/5F/SD11/CorrNr BE5021/22"
|      |      |  |-- 4:5-12 FDOT421 "B/L5/EC/5F/SD12/CorNr ELE RM AFC"
|      |      |  |-- 4:5-13 FDOT421 "B/L5/EC/5F/SD13/ELECTRICAL RM"
|      |      |  |-- 4:5-14 FDOT421 "B/L5/EC/5F/SD14/AHU RM"
|      |      |  |-- 4:5-15 HTRI-R "B/L5/EC/5F/CM15/AHU RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:5-16 FDOT421 "B/L5/EC/5F/SD16/LIFT LOBBY"
|      |      |  |-- 4:5-17 HMS-S/D/M/SA "B/L5/EC/5F/MCP17/FIRE ESCAPE STR"
|      |      |  |-- 4:5-18 HTRI-R "B/L5/EC/5F/CM18/FIRE HYD SHAFT"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:5 DLC "DLC @ address 5 L5"

		-- 4:5-19 HTRI-S "B/L5/EC/5F/MM19/FIRE HYD SHAFT"
		-- 4:5-24 FDOT421 "B/L5/CC/4F/SD24/ELECTRICAL RM"
		-- 4:5-25 FDOT421 "B/L5/CC/4F/SD25/CorrNr BC4011AFC"
		-- 4:5-26 FDOT421 "B/L5/CC/4F/SD26/CORR NR BC 4011"
		-- 4:5-27 HTRI-R "B/L5/CC/4F/CM27/FIRE HYD SHAFT"
		-- Switch ""
		-- Relay
		-- 4:5-28 HTRI-S "B/L5/CC/4F/MM28/FIRE HYD SHAFT"
		-- 4:5-29 HMS-S/D/M/SA "B/L5/CC/4F/MCP29/FIRE ESCAPE STR"
		-- 4:5-30 FDOT421 "B/L5/CC/4F/SD30/LIFT LOBBY"
		-- 4:5-31 FDOT421 "B/L5/CC/4F/SD31/LIFT LOBBY"
		-- 4:5-32 FDOT421 "B/L5/CC/4F/SD32/CorrNrBC4022bAFC"
		-- 4:5-33 FDOT421 "B/L5/CC/4F/SD33/CORR NR BC 4022B"
		-- 4:5-34 FDOT421 "B/L5/EC/4F/SD34/CORR NR BE AHU R"
		-- 4:5-35 FDOT421 "B/L5/EC/4F/SD35/CORR NR AHU RM"
		-- 4:5-36 FDOT421 "B/L5/EC/4F/SD36/AHU RM"
		-- 4:5-37 HTRI-R "B/L5/EC/4F/CM37/AHU RM"
		-- Switch ""
		-- Relay
		-- 4:5-38 FDOT421 "B/L5/EC/4F/SD38/ELECTRICAL RM"
		-- 4:5-39 FDOT421 "B/L5/EC/4F/SD39/LIFT LOBBY"
		-- 4:5-40 HTRI-R "B/L5/EC/4F/CM40/FIRE HYD SHAFT L"
		-- Switch ""
		-- Relay
		-- 4:5-41 FDOT421 "B/L5/CC/5F/SD41/BC AHU RM"
		-- 4:5-42 HTRI-S "B/L5/EC/4F/MM42/FIRE HYD SHAFT"
		-- 4:5-43 HMS-S/D/M/SA "B/L5/EC/4F/MCP43/LIFT LOBBY"
		-- 4:5-44 HTRI-R "B/L5/CC/5F/CM44/BC AHU RM"
		-- Switch ""
		-- Relay
		-- 4:5-45 HTRI-R "B/L5/CC/4F/CM45/AHU RM"
		-- Switch ""
		-- Relay
		-- 4:5-46 FDOT421 "B/L5/CC/4F/SD46/AHU RM"
		-- 4:5-63 HTRI-S "B/L5/4F/MM63/BC4011"
		-- 4:5-64 HTRI-S "B/L5/4F/MM64/BC4022B"
		-- 4:5-65 HTRI-S "B/L5/4F/MM65/BC4022A"
		-- 4:5-67 HTRI-S "B/L5/5F/MM67/BE5021"
		-- 4:5-68 HTRI-S "B/L5/5F/MM68/BE5010"
		-- 4:5-69 HTRI-S "B/L5/5F/MM69/BC5010-B2"
		-- 4:5-70 HTRI-S "B/L5/5F/MM70/BC5022"
		-- 4:5-71 HTRI-S "B/L5/5F/MM71/BC5010"
		-- 4:5-72 HTRI-S "B/L5/5F/MM72/BC5025"
		-- 4:5-73 HFP-11 "B/L5/BC4012/SD73/Recp"
		-- 4:5-74 HFP-11 "B/L5/BC4012/SD74/Cab 2"
		-- 4:5-75 HFP-11 "B/L5/BC4012/SD75/Assorter Cab"
		-- 4:5-76 HFP-11 "B/L5/BC4012/SD76/Psg Nr Assorter"
		-- 4:5-77 HFP-11 "B/L5/BC4012/SD77/Main Cab"
		-- 4:5-80 HFP-11 "B/L5/BC4012/SD80/Pntry"
		-- 4:5-81 HTRI-R "B/L5/BC4012/CM81/Psg Nr En Door"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:5 DLC "DLC @ address 5 L5"

4:5-81 HTRI-R "B/L5/BC4012/CM81/Psg Nr En Door"

```
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:5-82 HMS-S/D/M/SA "B/L5/BC4012/MCP82/Psg Nr En Door"
|      |      |  |-- 4:5-83 HFP-11 "B/L5/BE4011/SD83/Reception"
|      |      |  |-- 4:5-84 HFP-11 "B/L5/BE4011/SD84/Psg near cabin "
|      |      |  |-- 4:5-85 HFP-11 "B/L5/BE4011/SD85/Psg near cabin "
|      |      |  |-- 4:5-86 HFP-11 "B/L5/BE4011/SD86/Cabin 1"
|      |      |  |-- 4:5-87 HFP-11 "B/L5/BE4011/SD87/Cabin 2"
|      |      |  |-- 4:5-88 HFP-11 "B/L5/BE4011/SD88/Cabin 3"
|      |      |  |-- 4:5-89 HFP-11 "B/L5/BE4011/SD89/Sales cabin 1"
|      |      |  |-- 4:5-90 HFP-11 "B/L5/BE4011/SD90/Sales cabin 2"
|      |      |  |-- 4:5-91 HFP-11 "B/L5/BE4011/SD91/Sales cabin 3"
|      |      |  |-- 4:5-93 HFP-11 "B/L5/BE4011/SD93/Conference Room"
|      |      |  |-- 4:5-94 HFP-11 "B/L5/BE4011/SD94/Psg near confer"
|      |      |  |-- 4:5-95 HFP-11 "B/L5/BE4011/SD95/Cabin 4"
|      |      |  |-- 4:5-96 HFP-11 "B/L5/BE4011/SD96/Accounts cabin "
|      |      |  |-- 4:5-97 HFP-11 "B/L5/BE4011/SD97/stock cabin"
|      |      |  |-- 4:5-98 HFP-11 "B/L5/BE4011/SD98/cabin 5"
|      |      |  |-- 4:5-99 HFP-11 "B/L5/BE4011/SD99/Pantry 1"
|      |      |  |-- 4:5-100 HFP-11 "B/L5/BE4011/SD100/Pantry 2"
|      |      |  |-- 4:5-101 HFP-11 "B/L5/BE4011/SD101/Stock cabin 1"
|      |      |  |-- 4:5-102 FDOT421 "B/L5/BE4011/SD102/Stock Cabin 2"
|      |      |  |-- 4:5-103 HFP-11 "B/L5/BE4011/SD103/Assorters cabi"
|      |      |  |-- 4:5-104 HFP-11 "B/L5/BE4011/SD104/Assorter cabin"
|      |      |  |-- 4:5-105 HFP-11 "B/L5/BE4011/SD105/Psg near Pantr"
|      |      |  |-- 4:5-106 HFP-11 "B/L5/BE4011/SD106/BE Reception"
|      |      |  |-- 4:5-107 HFP-11 "B/L5/BE4011/SD107/Cabin 6"
|      |      |  |-- 4:5-108 HMS-S/D/M/SA "B/L5/BE4011/MCP108/BE Reception"
|      |      |  |-- 4:5-109 HMS-S/D/M/SA "B/L5/BE4011/MCP109/Psg near serv"
|      |      |  |-- 4:5-110 HTRI-R "B/L5/BE4011/SD110/Server rm AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:5-113 HFP-11 "B/L5/BC 5021/SD113/Guest Room"
|      |      |  |-- 4:5-114 HFP-11 "B/L5/BC 5021/SD114/Reception Are"
|      |      |  |-- 4:5-115 HFP-11 "B/L5/BC 5021/SD115/Pantry"
|      |      |  |-- 4:5-116 HFP-11 "B/L5/BC 5021/SD116/Polishing Dep"
|      |      |  |-- 4:5-117 HFP-11 "B/L5/BC 5021/SD117/Cabin 1"
|      |      |  |-- 4:5-118 HFP-11 "B/L5/BC 5021/SD118/Cabin 2"
|      |      |  |-- 4:5-119 HFP-11 "B/L5/BC 5021/SD119/Cabin 3"
|      |      |  |-- 4:5-120 HFP-11 "B/L5/BC 5021/SD120/Cabin 4"
|      |      |  |-- 4:5-121 HFP-11 "B/L5/BC 5021/SD121/Cabin 5"
|      |      |  |-- 4:5-122 HFP-11 "B/L5/BC 5021/SD122/Accounts Depa"
|      |      |  |-- 4:5-123 HFP-11 "B/L5/BC 5021/SD123/Store"
|      |      |  |-- 4:5-124 HFP-11 "B/L5/BC 5021/SD124/Cabin 6"
|      |      |  |-- 4:5-125 HTRI-R "B/L5/BC 5021/CM125/Entry Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:5-126 HMS-S/D/M/SA "B/L5/BC 5021/MCP126/Entry Door"
|      |      |  |-- 4:5-127 HFP-11 "B/L5/BE4011/SD127/Strong room"
|      |      |  |-- 4:5-128 HFP-11 "B/L5/BE4011/SD128/Account cab"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:5 DLC "DLC @ address 5 L5"

```
|      |      |-- 4:5-129 HFP-11 "B/L5/BE4011/SD129/Server room"
|      |      |-- 4:5-130 HFP-11 "B/L5/BE4011/SD130/psg nr Server "
|      |      |-- 4:5-131 HFP-11 "B/L5/BE4011/SD131/psg nr account"
|      |      |-- 4:5-132 HFP-11 "B/L5/BE4011/SD132/recep cab Entr"
|      |      |-- 4:5-133 HFP-11 "B/L5/BE4011/SD133/psg nr assorto"
|      |      |-- 4:5-134 HFP-11 "B/L5/BE4011/SD134/assortor cab"
|      |      |-- CC-5 "Card Cage 5 Slots"
|      |      |-- 4:6 DLC "DLC @ address 6 L6"
|      |      |-- 4:6-1 FDOT421 "B/L6/WC/5F/SD1/ELECTRICAL RM SD"
|      |      |-- 4:6-2 FDOT421 "B/L6/WC/5F/SD2/CorrNr BW5/S08AFC"
|      |      |-- 4:6-3 FDOT421 "B/L6/WC/5F/SD3/CORR NR AW 5061"
|      |      |-- 4:6-4 FDOT421 "B/L6/WC/5F/SD4/CORR NR BW5/S08"
|      |      |-- 4:6-5 FDOT421 "B/L6/WC/5F/SD5/CORR NR AW5052AFC"
|      |      |-- 4:6-6 FDOT421 "B/L6/WC/5F/SD6/CORR NR AW5051/52"
|      |      |-- 4:6-7 FDOT421 "B/L6/WC/5F/SD7/CORR NR AW5/S09AF"
|      |      |-- 4:6-8 FDOT421 "B/L6/WC/5F/SD8/Corr.Nr AW5042"
|      |      |-- 4:6-9 FDOT421 "B/L6/WC/5F/SD9/Corr.Nr AW5110"
|      |      |-- 4:6-10 FDOT421 "B/L6/WC/5F/SD10/LIFT LOBBY SD"
|      |      |-- 4:6-11 FDOT421 "B/L6/WC/5F/SD11/LIFT LOBBY SD"
|      |      |-- 4:6-12 FDOT421 "B/L6/WC/5F/SD12/CorrNr BW5154AFC"
|      |      |-- 4:6-13 FDOT421 "B/L6/WC/5F/SD13/CORR NR BW 5154"
|      |      |-- 4:6-14 FDOT421 "B/L6/WC/5F/SD14/CORR NR BW 5151"
|      |      |-- 4:6-15 FDOT421 "B/L6/WC/5F/SD15/CorrNrBW5/S18AFC"
|      |      |-- 4:6-16 FDOT421 "B/L6/WC/5F/SD16/CORR NR BW5/S18"
|      |      |-- 4:6-17 FDOT421 "B/L6/WC/5F/SD17/COR NR AHU RM AF"
|      |      |-- 4:6-18 FDOT421 "B/L6/WC/5F/SD18/CORR NR AHU RM "
|      |      |-- 4:6-19 FDOT421 "L6/B/WC/5F/SD19/CORR NR BW5011AF"
|      |      |-- 4:6-20 FDOT421 "B/L6/WC/5F/SD20/CORR NR BW 5011"
|      |      |-- 4:6-21 FDOT421 "B/L6/WC/5F/SD21/CorrNr BW5130AFC"
|      |      |-- 4:6-22 FDOT421 "B/L6/WC/5F/SD22/CORR NR BW 5130"
|      |      |-- 4:6-23 FDOT421 "B/L6/WC/5F/SD23/Corr Nr BW5032"
|      |      |-- 4:6-24 FDOT421 "B/L6/WC/5F/SD24/CorrNr BW5032AFC"
|      |      |-- 4:6-25 FDOT421 "B/L6/WC/5F/SD25/Corr.Nr BW5051"
|      |      |-- 4:6-26 FDOT421 "B/L6/WC/5F/SD26/CorrNr BW5051AFC"
|      |      |-- 4:6-27 FDOT421 "B/L6/WC/5F/SD27/AHU RM SD"
|      |      |-- 4:6-28 HTRI-R "B/L6/WC/5F/CM28/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 4:6-29 HTRI-R "B/L6/WC/5F/CM29/DOOR R NR AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 4:6-30 HMS-S/D/M/SA "B/L6/WC/5F/MCP30/FIRE SHAFT L.L."
|      |      |-- 4:6-31 HTRI-R "B/L6/WC/5F/CM31/FIRE SHAFT L/L"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 4:6-32 HTRI-S "B/L6/WC/5F/MM32/FIRE SHAFT L.L."
|      |      |-- 4:6-33 HTRI-R "B/L6/WC/5F/CM33/DOOR R NR E.R."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 4:6-34 HMS-S/D/M/SA "B/L6/WC/5F/MCP34/STR NR AW 5030"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:6 DLC "DLC @ address 6 L6"

```
|      |      |      |  -- 4:6-35 HTRI-R "B/L6/WC/5F/CM35/STR NR AW 5030"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:6-36 HMS-S/D/M/SA "B/L6/WC/5F/MCP36/STR NR BW5032"
|      |      |      |  -- 4:6-37 HTRI-R "B/L6/WC/5F/CM37/STR NR BW5032"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:6-38 FDOT421 "B/L6/WC/6F/SD38/Electric room"
|      |      |      |  -- 4:6-39 FDOT421 "B/L6/WC/6F/SD39/CorrNr AW6190AFC"
|      |      |      |  -- 4:6-40 FDOT421 "B/L6/WC/6F/SD40/CORR NR AW 6190"
|      |      |      |  -- 4:6-41 FDOT421 "B/L6/WC/6F/SD41/CorrNr A6/S11AFC"
|      |      |      |  -- 4:6-42 FDOT421 "B/L6/WC/6F/SD42/CORR NR BW6/S11"
|      |      |      |  -- 4:6-43 FDOT421 "B/L6/WC/6F/SD43/CORR NR AW6220"
|      |      |      |  -- 4:6-44 FDOT421 "B/L6/WC/6F/SD44/CorrNr AW6220AFC"
|      |      |      |  -- 4:6-45 FDOT421 "B/L6/WC/6F/SD45/CORR NR AW6240"
|      |      |      |  -- 4:6-46 FDOT421 "B/L6/WC/6F/SD46/LIFT LOBBY SD"
|      |      |      |  -- 4:6-47 FDOT421 "B/L6/WC/6F/SD47/LIFT LOBBY SD"
|      |      |      |  -- 4:6-48 FDOT421 "B/L6/WC/6F/SD48/CORR NR BW S/19"
|      |      |      |  -- 4:6-49 FDOT421 "B/L6/WC/6F/SD49/AFC SD Nr BW6081"
|      |      |      |  -- 4:6-50 FDOT421 "B/L6/WC/6F/SD50/CORR NR BW6081"
|      |      |      |  -- 4:6-51 FDOT421 "B/L6/WC/6F/SD51/CorrNrBW6/S18AFC"
|      |      |      |  -- 4:6-52 FDOT421 "B/L6/WC/6F/SD52/Corr Nr BW6-S/18"
|      |      |      |  -- 4:6-53 FDOT421 "B/L6/WC/6F/SD53/AFC CORR NR AHU "
|      |      |      |  -- 4:6-54 FDOT421 "B/L6/WC/6F/SD54/CORR NR BW6070"
|      |      |      |  -- 4:6-55 FDOT421 "B/L6/WC/6F/SD55/CORR NR BW6060"
|      |      |      |  -- 4:6-56 FDOT421 "B/L6/WC/6F/SD56/CorrNr BW6040AFC"
|      |      |      |  -- 4:6-57 FDOT421 "B/L6/WC/6F/SD57/CORR NR BW6040"
|      |      |      |  -- 4:6-58 FDOT421 "B/L6/WC/6F/SD58/AHU RM SD"
|      |      |      |  -- 4:6-59 HTRI-R "B/L6/WC/6F/CM59/AHU RM CM"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:6-60 HTRI-R "B/L6/WC/6F/CM60/DOOR R CM NR AHU"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:6-61 HMS-S/D/M/SA "B/L6/WC/6F/MCP61/FIRE SHAFT L.L."
|      |      |      |  -- 4:6-62 HTRI-R "B/L6/WC/6F/CM62/FIRE SHAFT L.L."
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:6-63 HTRI-S "B/L6/WC/6F/MM63/FIRE SHAFT L.L."
|      |      |      |  -- 4:6-64 HTRI-R "B/L6/WC/6F/CM64/DOOR R NR E.R. W"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:6-65 HMS-S/D/M/SA "B/L6/WC/6F/MCP65/STR NR AW6120"
|      |      |      |  -- 4:6-66 HTRI-R "B/L6/WC/6F/CM66/STR NR AW6120"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 4:6-67 HTRI-S "B/L6/5F/MM67/BC5010A"
|      |      |      |  -- 4:6-68 HTRI-S "B/L6/5F/MM68/BW5110"
|      |      |      |  -- 4:6-75 HTRI-S "B/L6/5F/MM75/BW5041"
|      |      |      |  -- 4:6-76 HTRI-S "B/L6/5F/MM76/BW5032"
```


4 Desigo Fire Safety Modular "BDB TOWER B" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
4:6 DLC "DLC @ address 6 L6"

			-- 4:6-77 HTRI-S "B/L6/5F/MM77/BW5120"
			-- 4:6-78 HTRI-S "B/L6/5F/MM78/BW5031"
			-- 4:6-80 HTRI-S "B/L6/5F/MM80/BW5130"
			-- 4:6-87 HTRI-S "B/L6/5F/MM87/BW5151"
			-- 4:6-94 HTRI-S "B/L6/5F/MM94/AW5080"
			-- 4:6-95 HTRI-S "B/L6/5F/MM95/AW5051/52"
			-- 4:6-96 HTRI-S "B/L6/5F/MM96/AW5042"
			-- 4:6-97 HTRI-S "B/L6/5F/MM97/AW5090"
			-- 4:6-99 HTRI-S "B/L6/5F/MM99/AW5041"
			-- 4:6-102 HTRI-S "B/L6/6F/MM102/AW6120"
			-- 4:6-104 HTRI-S "B/L6/6F/MM104/AW6130"
			-- 4:6-105 HTRI-S "B/L6/6F/MM105/AW6230"
			-- 4:6-106 HTRI-S "B/L6/6F/MM106/AW6140"
			-- 4:6-107 HTRI-S "B/L6/6F/MM107/AW6150"
			-- 4:6-108 HTRI-S "B/L6/6F/MM108/AW6220"
			-- 4:6-112 HTRI-S "B/L6/6F/MM112/AW6180"
			-- 4:6-116 HTRI-S "B/L6/6F/MM116/BW6091"
			-- 4:6-117 HTRI-S "B/L6/6F/MM117/BW6020A"
			-- 4:6-119 HTRI-S "B/L6/6F/MM119/BW6081"
			-- 4:6-120 HTRI-S "B/L6/6F/MM120/BW6070"
			-- 4:6-124 HTRI-S "B/L6/6F/MM124/BW6012"
			-- 4:6-128 HTRI-S "B/L6/5F/MM128/BW5011"
			-- 4:6-130 HFP-11 "B/L6/BW6050/SD130/Assortor cabin"
			-- 4:6-131 HFP-11 "B/L6/AW6210/SD131/Main cabin"
			-- 4:6-132 HFP-11 "B/L6/AW6210/SD132/Passage Area"
			-- 4:6-133 HFP-11 "B/L6/AW6210/SD133/Reception"
			-- 4:6-134 HTRI-R "B/L6/AW6210/CM134/Passage Area"
			-- Switch ""
			-- Relay
			-- 4:6-135 HMS-S/D/M/SA "B/L6/AW6210/MCP135/Passage Area"
			-- 4:6-136 HFP-11 "B/L6/AW6190/SD136/Main cabin"
			-- 4:6-137 HFP-11 "B/L6/AW6190/SD137/Account Depart"
			-- 4:6-138 HFP-11 "B/L6/AW6190/SD138/Reception"
			-- 4:6-139 HFP-11 "B/L6/AW6190/SD139/Pantry"
			-- 4:6-140 HTRI-R "B/L6/AW6190/CM140/Passage Area"
			-- Switch ""
			-- Relay
			-- 4:6-141 HMS-S/D/M/SA "B/L6/AW6190/MCP141/Passage Area"
			-- 4:6-142 HFP-11 "B/L6/AW6200/SD142/Main cabin"
			-- 4:6-143 HFP-11 "B/L6/AW6200/SD143/Account Depart"
			-- 4:6-144 HFP-11 "B/L6/AW6200/SD144/Reception"
			-- 4:6-145 HFP-11 "B/L6/AW6200/SD145/Pantry"
			-- 4:6-146 HTRI-R "B/L6/AW6200/CM146/Passage Area"
			-- Switch ""
			-- Relay
			-- 4:6-147 HMS-S/D/M/SA "B/L6/AW6200/MCP147/Passage Area"
			-- 4:6-148 HFP-11 "B/L6/AW5061/SD148/Main cabin"
			-- 4:6-149 HFP-11 "B/L6/AW5061/SD149/Conference Roo"
			-- 4:6-150 HFP-11 "B/L6/AW5061/SD150/Store Room"
			-- 4:6-151 HFP-11 "B/L6/AW5061/SD151/Account Depart"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:6 DLC "DLC @ address 6 L6"

```
|      |      |      |-- 4:6-152 HFP-11 "B/L6/AW5061/SD152/Pantry"
|      |      |      |-- 4:6-153 HFP-11 "B/L6/AW5061/SD153/Passage Area"
|      |      |      |-- 4:6-154 HFP-11 "B/L6/AW5061/SD154/Reception"
|      |      |      |-- 4:6-155 HTRI-R "B/L6/AW5061/CM155/Passage Area"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-156 HMS-S/D/M/SA "B/L6/AW5061/MCP156/Entry door"
|      |      |      |-- 4:6-157 HFP-11 "B/L6/AW5100/SD157/Passage Area 1"
|      |      |      |-- 4:6-158 HFP-11 "B/L6/AW5100/SD158/Passage Area 2"
|      |      |      |-- 4:6-159 HFP-11 "B/L6/AW5100/SD159/Account Depart"
|      |      |      |-- 4:6-160 HFP-11 "B/L6/AW5100/SD160/Store Room"
|      |      |      |-- 4:6-161 HFP-11 "B/L6/AW5100/SD161/Main cabin"
|      |      |      |-- 4:6-162 HTRI-R "B/L6/AW5100/CM162/Entry Door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-163 HMS-S/D/M/SA "B/L6/AW5100/MCP163/Entry Door"
|      |      |      |-- 4:6-164 HFP-11 "B/L6/AW5110/SD164/Main Cabin"
|      |      |      |-- 4:6-165 HFP-11 "B/L6/AW5110/SD165/Assorter Room"
|      |      |      |-- 4:6-166 HFP-11 "B/L6/AW5110/SD166/Pantry"
|      |      |      |-- 4:6-167 HTRI-R "B/L6/AW5110/CM167/Main Cabin"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-168 HMS-S/D/M/SA "B/L6/AW5110/MCP168/Main Cabin"
|      |      |      |-- 4:6-169 HFP-11 "B/L6/BW6092/SD169/STAFF CAB"
|      |      |      |-- 4:6-170 HFP-11 "B/L6/SD170/BW6092/STAFF CAB"
|      |      |      |-- 4:6-171 HTRI-R "B/L6/CM171/BW6092/AFC ENTRY PSG"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-172 HMS-S/D/M/SA "B/L6/MCP172/BW6092/ENTRY DOOR PS"
|      |      |      |-- 4:6-189 HFP-11 "B/L6/BW6040/SD189/Psg near Ptry"
|      |      |      |-- 4:6-190 HFP-11 "B/L6/BW6040/SD190/Cab 1"
|      |      |      |-- 4:6-191 HFP-11 "B/L6/BW6040/SD191/Cab 2"
|      |      |      |-- 4:6-192 HFP-11 "B/L6/BW6040/SD192/Cab 2"
|      |      |      |-- 4:6-193 HMS-S/D/M/SA "B/L6/BW6040/MCP193/Psg near Entr"
|      |      |      |-- 4:6-199 HFP-11 "B/L6/BW 6011/SD199/Psg Nr Assort"
|      |      |      |-- 4:6-200 HFP-11 "B/L6/BW 6011/SD200/Assortor Cab1"
|      |      |      |-- 4:6-201 HFP-11 "B/L6/BW 6011/SD201/Assortor Cab2"
|      |      |      |-- 4:6-202 HFP-11 "B/L6/BW 6011/SD202/Main Cab"
|      |      |      |-- 4:6-203 HTRI-R "B/L6/BW 6011/CM203/Entry Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-204 HMS-S/D/M/SA "B/L6/BW 6011/MCP204/Entry Dr"
|      |      |      |-- 4:6-205 HTRI-R "B/L6/BW6040/CM205/Psg near Entry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 4:6-215 HFP-11 "B/L6/BW6030B/SD215/Main cabin"
|      |      |      |-- 4:6-216 HFP-11 "B/L6/BW6030B/SD216/Main cabin"
|      |      |      |-- 4:6-217 HFP-11 "B/L6/BW6030B/SD217/Assorter cab"
|      |      |      |-- 4:6-218 HMS-S/D/M/SA "B/L6/BW6030B/MCP218/Psg nr Entry"
|      |      |      |-- 4:6-219 HTRI-R "B/L6/BW6030B/CM219/Psg nr Entry "
```

```
| | | Switch ""
| | | |-- Relay
| | | |-- 4:6-224 HFP-11 "B/L6/BW6060/SD224/Main cabin"
| | | |-- 4:6-225 HFP-11 "B/L6/BW6060/SD225/Assorter cabin"
| | | |-- 4:6-226 HFP-11 "B/L6/BW6060/SD226/Psg nr Entranc"
| | | |-- 4:6-227 HMS-S/D/M/SA "B/L6/BW6060/MCP227/Psg nr Entry "
| | | |-- 4:6-228 HTRI-R "B/L6/BW6060/CM228/Psg nr Entry "
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:6-229 HFP-11 "B/L6/BW6030B/SD229/AFC Entry dr "
| | | |-- 4:6-230 HFP-11 "B/L6/BW6030B/SD230/AFC Entry dr "
| | | |-- 4:6-231 HTRI-R "B/L6/BW6050/CM231/AFC Entry Psg"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:6-232 HMS-S/D/M/SA "B/L6/BW6050/MCP232/Entry Psg"
| | | |-- 4:6-233 HFP-11 "B/L6/BW6050/SD233/Main cabin"
| | | |-- 4:6-234 HFP-11 "B/L6/BW6050/SD234/Entry Psg"
| | | |-- 4:6-240 HFP-11 "B/L6/BW5141-42/SD240/Main CAB"
| | | |-- 4:6-241 HFP-11 "B/L6/BW5141-42/SD241/Main CAB"
| | | |-- 4:6-242 HFP-11 "B/L6/BW5141-42/SD242/Account CAB"
| | | |-- 4:6-243 HFP-11 "B/L6/BW5141-42/SD243/Psg NR Acco"
| | | |-- 4:6-244 HFP-11 "B/L6/BW5141-42/SD244/Buyer CAB"
| | | |-- 4:6-245 HFP-11 "B/L6/BW5141-42/SD245/Assortor Ca"
| | | |-- 4:6-246 HFP-11 "B/L6/BW5141-42/SD246/Pantry"
| | | |-- 4:6-247 HFP-11 "B/L6/BW5141-42/SD247/Enyrt Psg"
| | | |-- 4:6-248 HTRI-R "B/L6/BW5141-42/CM248/Enyrt Psg A"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:6-249 HMS-S/D/M/SA "B/L6/BW5141-42/MCP249/Enyrt Psg"
| | |-- 4:7 DLC "DLC @ address 7 L7"
| | | |-- 4:7-1 FDOT421 "B/L7/CC/7F/SD1/ELECTRICAL RM SD"
| | | |-- 4:7-2 FDOT421 "B/L7/CC/7F/SD2/CORR NR BC 7012AF"
| | | |-- 4:7-3 FDOT421 "B/L7/CC/7F/SD3/CORR NR BC 7012"
| | | |-- 4:7-4 HTRI-R "B/L7/CC/7F/CM4/FIRE SHAFT L.L."
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:7-5 HTRI-S "B/L7/CC/7F/MM5/FIRE SHAFT L.L."
| | | |-- 4:7-6 HMS-S/D/M/SA "B/L7/CC/7F/MCP6/FIRE SHAFT L.L."
| | | |-- 4:7-7 FDOT421 "B/L7/CC/7F/SD7/LIFT LOBBY SD"
| | | |-- 4:7-8 FDOT421 "B/L7/CC/7F/SD8/LIFT LOBBY SD"
| | | |-- 4:7-9 FDOT421 "B/L7/EC/7F/SD9/CORR NR AHU AFC"
| | | |-- 4:7-10 FDOT421 "B/L7/EC/7F/SD10/CORR NR AHU"
| | | |-- 4:7-11 FDOT421 "B/L7/EC/7F/SD11/ELECTRICAL RM SD"
| | | |-- 4:7-12 FDOT421 "B/L7/EC/7F/SD12/AHU RM SD"
| | | |-- 4:7-13 HTRI-R "B/L7/EC/7F/CM13/AHU RM CM"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 4:7-14 FDOT421 "B/L7/EC/7F/SD14/LIFT LOBBY SD"
| | | |-- 4:7-15 HMS-S/D/M/SA "B/L7/EC/7F/MCP15/FIRE SHAFT L.L."
| | | |-- 4:7-16 HTRI-R "B/L7/EC/7F/CM16/FIRE SHAFT L.L."
```

4:7-16 HTRI-R "B/L7/EC/7F/CM16/FIRE SHAFT L.L."

```

| | | | | Switch ""
| | | | | Relay
| | | | | -- 4:7-17 HTRI-S "B/L7/EC/7F/MM17/FIRE SHAFT L.L."
| | | | | -- 4:7-20 FDOT421 "B/L7/CC/6F/SD20/ELECTRICAL RM"
| | | | | -- 4:7-23 HTRI-R "B/L7/CC/6F/CM23/FIRE HYD SHAFT"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 4:7-24 HTRI-S "B/L7/CC/6F/MM24/FIRE HYD SHAFT"
| | | | | -- 4:7-25 HMS-S/D/M/SA "B/L7/CC/6F/MCP25/FIRE ESCAPE STR"
| | | | | -- 4:7-26 FDOT421 "B/L7/CC/6F/SD26/LIFT LOBBY"
| | | | | -- 4:7-27 FDOT421 "B/L7/CC/6F/SD27/LIFT LOBBY"
| | | | | -- 4:7-29 FDOT421 "B/L7/CC/6F/SD29/AFC CorrNr AHU R"
| | | | | -- 4:7-30 FDOT421 "B/L7/CC/6F/SD30/ Corr NR AHU RM"
| | | | | -- 4:7-31 FDOT421 "B/L7/EC/6F/SD31/AFC CorrNr ELE R"
| | | | | -- 4:7-32 FDOT421 "B/L7/EC/6F/SD32/ Corr NR ELE RM"
| | | | | -- 4:7-33 FDOT421 "B/L7/EC/6F/SD33/ELECTRICAL RM"
| | | | | -- 4:7-34 FDOT421 "B/L7/EC/6F/SD34/AHU RM"
| | | | | -- 4:7-35 HTRI-R "B/L7/EC/6F/CM35/AHU RM"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 4:7-36 FDOT421 "B/L7/EC/6F/SD36/LIFT LOBBY"
| | | | | -- 4:7-37 HMS-S/D/M/SA "B/L7/EC/6F/MCP37/FIRE ESCAPE STR"
| | | | | -- 4:7-38 HTRI-R "B/L7/EC/6F/CM38/FIRE HYD SHAFT"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 4:7-39 HTRI-S "B/L7/EC/6F/MM39/FIRE HYD SHAFT"
| | | | | -- 4:7-42 HTRI-R "B/L7/CC/6F/CM42/AHU RM"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 4:7-43 FDOT421 "B/L7/CC/6F/SD43/AHU RM"
| | | | | -- 4:7-46 HTRI-R "B/L7/CC/6F/CM46/Corr.Nr Fire Esc"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 4:7-56 HMS-S/D/M/SA "B/L7/CC/7F/MCP56/Corr.Nr Fire Es"
| | | | | -- 4:7-59 FDOT421 "B/L7/CC/7F/SD59/AHU RM SD"
| | | | | -- 4:7-60 HTRI-R "B/L7/CC/7F/CM60/AHU RM CM"
| | | | | Switch ""
| | | | | Relay
| | | | | -- 4:7-72 HTRI-R "B/L7/EC/7F/CM72/FIRE ESCAPE STR "
| | | | | Switch ""
| | | | | Relay
| | | | | -- 4:7-77 HTRI-S "B/L7/6F/MM77/BE6011"
| | | | | -- 4:7-79 HTRI-S "B/L7/6F/MM79/BC6021A"
| | | | | -- 4:7-80 HTRI-S "B/L7/6F/MM80/BC6021B"
| | | | | -- 4:7-81 HTRI-S "B/L7/6F/MM81/BC6021C"
| | | | | -- 4:7-98 HFP-11 "B/L7/BC7011/SD98/Psg nr Main Ent"
| | | | | -- 4:7-99 HFP-11 "B/L7/BC7011/SD99/AFC Conf 1"
| | | | | -- 4:7-100 HFP-11 "B/L7/BC7011/SD100/Export Dept"
| | | | | -- 4:7-101 HFP-11 "B/L7/BC7011/SD101/Bank Dept"
| | | | | -- 4:7-102 HFP-11 "B/L7/BC7011/SD102/AFC Bank Dept"

```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:7 DLC "DLC @ address 7 L7"

				--	4:7-103	HFP-11	"B/L7/BC7011/SD103/Psg nr Export "
				--	4:7-104	HFP-11	"B/L7/BC7011/SD104/AFC Export Dep"
				--	4:7-105	HFP-11	"B/L7/BC7011/SD105/Psg nr Bank De"
				--	4:7-106	HFP-11	"B/L7/BC7011/SD106/Accounts Dept"
				--	4:7-107	HFP-11	"B/L7/BC7011/SD107/AFC Accounts D"
				--	4:7-108	HFP-11	"B/L7/BC7011/SD108/Server Rm"
				--	4:7-109	HFP-11	"B/L7/BC7011/SD109/AFC Server Rm"
				--	4:7-110	HFP-11	"B/L7/BC7011/SD110/Asst cab1"
				--	4:7-111	HFP-11	"B/L7/BC7011/SD111/AFC Asst cab 1"
				--	4:7-112	HFP-11	"B/L7/BC7011/SD112/Psg nr Asst ca"
				--	4:7-113	HFP-11	"B/L7/BC7011/SD113/Psg nr Asst ca"
				--	4:7-114	HFP-11	"B/L7/BC7011/SD114/Psg near Pantr"
				--	4:7-115	HFP-11	"B/L7/BC7011/SD115/Pantry"
				--	4:7-116	HFP-11	"B/L7/BC7011/SD116/Pantry"
				--	4:7-117	HFP-11	"B/L7/BC7011/SD117/AFC Pantry"
				--	4:7-118	HTRI-R	"B/L7/BC7011/CM118/AFC Recp Areal"
				--	Switch	"	
				--	Relay		
				--	4:7-119	HFP-11	"B/L7/BC7011/SD119/Electric rm"
				--	4:7-120	HFP-11	"B/L7/BC7011/SD120/Asst cab 2"
				--	4:7-121	HFP-11	"B/L7/BC7011/SD121/AFC Asst cab 2"
				--	4:7-122	FDOT421	"B/L7/BC7011/SD122/Secreatory sta"
				--	4:7-123	HFP-11	"B/L7/BC7011/SD123/AFC secreatory"
				--	4:7-124	HFP-11	"B/L7/BC7011/SD124/Audit cab"
				--	4:7-125	HFP-11	"B/L7/BC7011/SD125/AFC Audit cab"
				--	4:7-126	HFP-11	"B/L7/BC7011/SD126/CS Cab"
				--	4:7-127	HFP-11	"B/L7/BC7011/SD127/AFC CS Cab"
				--	4:7-128	HFP-11	"B/L7/BC7011/SD128/Manager cab"
				--	4:7-129	HFP-11	"B/L7/BC7011/SD129/AFC Manger cab"
				--	4:7-130	HFP-11	"B/L7/BC7011/SD130/Psg nr CS Cab"
				--	4:7-131	HFP-11	"B/L7/BC7011/SD131/Psg nr Manager"
				--	4:7-132	HFP-11	"B/L7/BC7011/SD132/Reception Area"
				--	4:7-133	HFP-11	"B/L7/BC7011/SD133/Admin cab"
				--	4:7-134	HFP-11	"B/L7/BC7011/SD134/AFC Admin cab"
				--	4:7-135	HFP-11	"B/L7/BC7011/SD135/AFC Conf 1"
				--	4:7-136	HFP-11	"B/L7/BC7011/SD136/Boiling Rm"
				--	4:7-137	HFP-11	"B/L7/BC7011/SD137/Psg nr Entry D"
				--	4:7-138	HFP-11	"B/L7/BC7011/SD138/Psg nr Assort "
				--	4:7-139	HFP-11	"B/L7/BC7011/SD139/Asst cab 3"
				--	4:7-140	HFP-11	"B/L7/BC7011/SD140/AFC Asst cab 3"
				--	4:7-141	HFP-11	"B/L7/BC7011/SD141/Asst cab 4"
				--	4:7-142	HFP-11	"B/L7/BC7011/SD142/AFC Asst cab 4"
				--	4:7-143	HFP-11	"B/L7/BC7011/SD143/Boss cab 1"
				--	4:7-144	HFP-11	"B/L7/BC7011/SD144/AFC Boss cab 1"
				--	4:7-145	HFP-11	"B/L7/BC7011/SD145/Boss cab 2"
				--	4:7-146	HFP-11	"B/L7/BC7011/SD146/Boss cab3"
				--	4:7-147	HFP-11	"B/L7/BC7011/SD147/AFC Boss cab 3"
				--	4:7-148	HFP-11	"B/L7/BC7011/SD148/Boss Cab 4"
				--	4:7-149	HMS-S/D/M/SA	"B/L7/BC 7011/MCP149/Main Entry A"
				--	4:7-150	HFP-11	"B/L7/BC7011/SD150/Pantry 2"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:7 DLC "DLC @ address 7 L7"

			-- 4:7-151 HMS-S/D/M/SA "B/L7/BC 7011/MCP151/Staff Entry"
			-- 4:7-152 HFP-11 "B/L7/BC7011/SD152/Psg nr pantry "
			-- 4:7-153 HMS-S/D/M/SA "B/L7/BC 7011/MCP153/Recp Area 1"
			-- 4:7-156 HFP-11 "B/L7/BC6010/SD156/cab 1"
			-- 4:7-157 HFP-11 "B/L7/BC6010/SD157/cab 1"
			-- 4:7-158 HFP-11 "B/L7/BC6010/SD158/cab 1"
			-- 4:7-159 HFP-11 "B/L7/BC6010/SD159/cab 2"
			-- 4:7-160 HFP-11 "B/L7/BC6010/SD160/cab 3"
			-- 4:7-161 HFP-11 "B/L7/BC6010/SD161/cab 3"
			-- 4:7-162 HFP-11 "B/L7/BC6010/SD162/Psg near cab 3"
			-- 4:7-163 HFP-11 "B/L7/BC6010/SD163/cab 4"
			-- 4:7-164 HFP-11 "B/L7/BC6010/SD164/cab 4"
			-- 4:7-165 HFP-11 "B/L7/BC6010/SD165/cab 5"
			-- 4:7-166 HFP-11 "B/L7/BC6010/SD166/cab 6"
			-- 4:7-167 HFP-11 "B/L7/BC6010/SD167/cab 7"
			-- 4:7-168 HFP-11 "B/L7/BC6010/SD168/cab 7"
			-- 4:7-169 HFP-11 "B/L7/BC6010/SD169/Psg near cab 7"
			-- 4:7-170 HFP-11 "B/L7/BC6010/SD170/Psg near cab 8"
			-- 4:7-171 HFP-11 "B/L7/BC6010/SD171/cab 8"
			-- 4:7-172 HFP-11 "B/L7/BC6010/SD172/cab 8"
			-- 4:7-173 HFP-11 "B/L7/BC6010/SD173/Psg nr Kitchen"
			-- 4:7-174 HFP-11 "B/L7/BC6010/SD174/Cab 9"
			-- 4:7-175 HFP-11 "B/L7/BC6010/SD175/Cab 9"
			-- 4:7-176 HFP-11 "B/L7/BC6010/SD176/Psg near cabin"
			-- 4:7-177 HFP-11 "B/L7/BC6010/SD177/Psg near cabin"
			-- 4:7-178 HFP-11 "B/L7/BC6010/SD178/Cabin 16"
			-- 4:7-179 HFP-11 "B/L7/BC6010/SD179/Cabin 17"
			-- 4:7-180 HFP-11 "B/L7/BC6010/SD180/Psg near cab 1"
			-- 4:7-181 HFP-11 "B/L7/BC6010/SD181/cab 10"
			-- 4:7-182 HFP-11 "B/L7/BC6010/SD182/cab 11"
			-- 4:7-183 HFP-11 "B/L7/BC6010/SD183/cab 18"
			-- 4:7-184 HFP-11 "B/L7/BC6010/SD184/Psg near cab 1"
			-- 4:7-185 HFP-11 "B/L7/BC6010/SD185/cab 12"
			-- 4:7-186 HFP-11 "B/L7/BC6010/SD186/Psg near cab 1"
			-- 4:7-187 HFP-11 "B/L7/BC6010/SD187/cab 14"
			-- 4:7-188 HFP-11 "B/L7/BC6010/SD188/cab 15"
			-- 4:7-189 HFP-11 "B/L7/BC6010/SD189/Psg nr cab 15"
			-- 4:7-190 HFP-11 "B/L7/BC6010/SD190/Lunch room"
			-- 4:7-191 HFP-11 "B/L7/BC6010/SD191/Lunch room"
			-- 4:7-192 HFP-11 "B/L7/BC6010/SD192/cab 20"
			-- 4:7-193 HFP-11 "B/L7/BC6010/SD193/cab 20"
			-- 4:7-194 HFP-11 "B/L7/BC6010/SD194/cab 20"
			-- 4:7-195 HFP-11 "B/L7/BC6010/SD195/cab 21"
			-- 4:7-196 HFP-11 "B/L7/BC6010/SD196/cab 22"
			-- 4:7-197 HFP-11 "B/L7/BC6010/SD197/cab 23"
			-- 4:7-198 HFP-11 "B/L7/BC6010/SD198/cab 23"
			-- 4:7-199 HFP-11 "B/L7/BC6010/SD199/cab 23"
			-- 4:7-200 HFP-11 "B/L7/BC6010/SD200/Psg near cab 3"
			-- 4:7-201 HFP-11 "B/L7/BC6010/SD201/Psg near cab 3"
			-- 4:7-202 HFP-11 "B/L7/BC6010/SD202/cab 24"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:7 DLC "DLC @ address 7 L7"

```
|      |      |  |-- 4:7-203 HFP-11 "B/L7/BC6010/SD203/cab 24"
|      |      |  |-- 4:7-204 HFP-11 "B/L7/BC6010/SD204/cab 26"
|      |      |  |-- 4:7-205 HFP-11 "B/L7/BC6010/SD205/Psg near cab 5"
|      |      |  |-- 4:7-206 HFP-11 "B/L7/BC6010/SD206/cab 25"
|      |      |  |-- 4:7-207 HMS-S/D/M/SA "B/L7/BC6010/MCP207/Psg nr cab 15"
|      |      |  |-- 4:7-208 HMS-S/D/M/SA "B/L7/BC6010/MCP208/Psg nr cab 17"
|      |      |  |-- 4:7-209 HTRI-R "B/L7/BC6010/CM209/Psg near BC En"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:7-210 HFP-11 "B/L7/BC7011/SD210/Reception 2"
|      |      |  |-- 4:7-211 HFP-11 "B/L7/BC7011/SD211/AFC Reception "
|      |      |  |-- 4:7-212 HFP-11 "B/L7/BC7011/SD212/Reception 2"
|      |      |  |-- 4:7-213 HFP-11 "B/L7/BC7011/SD213/Conference 2"
|      |      |  |-- 4:7-214 HFP-11 "B/L7/BC7011/SD214/Aditya cab"
|      |      |  |-- 4:7-215 HFP-11 "B/L7/BC7011/SD215/AFC Aditya cab"
|      |      |  |-- 4:7-216 HFP-11 "B/L7/BC7011/SD216/AFC Reception "
|      |      |  |-- 4:7-217 HFP-11 "B/L7/BC7011/SD217/AFC Darpan cab"
|      |      |  |-- 4:7-218 HFP-11 "B/L7/BC7011/SD218/AFC Darpan cab"
|      |      |  |-- 4:7-219 HFP-11 "B/L7/BC7011/SD219/Shreyashbhai c"
|      |      |  |-- 4:7-220 HFP-11 "B/L7/BC7011/SD220/AFC Shreyasbha"
|      |      |  |-- 4:7-221 HFP-11 "B/L7/BC7011/SD221/File store"
|      |      |  |-- 4:7-222 HFP-11 "B/L7/BC7011/SD222/Psg nr File st"
|      |      |  |-- 4:7-223 HFP-11 "B/L7/BC7011/SD223/Psg AFC file s"
|      |      |  |-- 4:7-224 FDOT421 "B/L7/BC7011/SD224/Filling room"
|      |      |  |-- 4:7-225 FDOT421 "B/L7/BC7011/SD225/AFC filling ro"
|      |      |  |-- 4:7-226 HTRI-R "B/L7/BC6010/CM226/Psg nr BW Entr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 4:7-227 HMS-S/D/M/SA "B/L7/BC6010/MCP227/BC Entry"
|      |      |  |-- 4:7-228 HFPT-11 "B/L7/BC6010/HD228/BC Pantry"
|      |      |  |-- 4:7-229 HFP-11 "B/L7/BC6010/SD229/Psg nr BC Pant"
|      |      |  |-- 4:7-230 HFP-11 "B/L7/BC6010/SD230/BW Pantry"
|      |      |  |-- 4:7-231 HMS-S/D/M/SA "B/L7/BC6010/MCP231/BW Entry"
|      |      |  |-- 4:7-232 HFP-11 "B/L7/BC6010/SD232/BC Reception"
|      |      |  |-- 4:7-236 HMS-S/D/M/SA "B/L7/BC6010/MCP236/FIRE STR "
|      |      |  |-- 4:8 DLC "DLC @ address 8 L8"
|      |      |  |-- 4:8-1 FDOT421 "B/L8/WC/7F/SD1/ELECTRICAL RM"
|      |      |  |-- 4:8-2 FDOT421 "B/L8/WC/7F/SD2/CorrNr BW7030 AFC"
|      |      |  |-- 4:8-3 FDOT421 "B/L8/WC/7F/SD3/CorrNr BW7030"
|      |      |  |-- 4:8-4 FDOT421 "B/L8/WC/7F/SD4/CorrNr BW7012AFC"
|      |      |  |-- 4:8-5 FDOT421 "B/L8/WC/7F/SD5/CORR NR BW7012"
|      |      |  |-- 4:8-6 FDOT421 "B/L8/WC/7F/SD6/LIFT LOBBY SD"
|      |      |  |-- 4:8-7 FDOT421 "B/L8/WC/7F/SD7/LIFT LOBBY SD"
|      |      |  |-- 4:8-8 FDOT421 "B/L8/WC/7F/SD8/CorrNr BW9/S19AFC"
|      |      |  |-- 4:8-9 FDOT421 "B/L8/WC/7F/SD9/CORR NR BW7/S19"
|      |      |  |-- 4:8-10 FDOT421 "B/L8/WC/7F/SD10/CORR NR BW7/S18"
|      |      |  |-- 4:8-11 FDOT421 "B/L8/WC/7F/SD11/CORR NR DC2 AFC"
|      |      |  |-- 4:8-12 FDOT421 "B/L8/WC/7F/SD12/CORR NR AHU RM"
|      |      |  |-- 4:8-14 HTRI-S "B/L8/9F/MM14/BW9010"
|      |      |  |-- 4:8-15 FDOT421 "B/L8/WC/7F/SD15/AHU RM SD"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:8 DLC "DLC @ address 8 L8"

```
|      |      |      |-- 4:8-16 HTRI-R "B/L8/WC/7F/CM16/AHU RM CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 4:8-17 HMS-S/D/M/SA "B/L8/WC/7F/MCP17/FIRE SHAFT L.L."
|      |      |      |-- 4:8-18 HTRI-R "B/L8/WC/7F/CM18/FIRE SHAFT L.L."
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 4:8-19 HTRI-S "B/L8/WC/7F/MM19/FIRE SHAFT L.L."
|      |      |      |-- 4:8-20 HTRI-R "B/L8/WC/7F/CM20/DOOR R NR L.L."
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 4:8-21 FDOT421 "B/L8/WC/8F/SD21/ELECTRICAL RM SD"
|      |      |      |-- 4:8-22 FDOT421 "B/L8/WC/8F/SD22/CorrNr BW8030AFC"
|      |      |      |-- 4:8-23 FDOT421 "B/L8/WC/8F/SD23/CORR NR BW8030"
|      |      |      |-- 4:8-24 FDOT421 "B/L8/WC/8F/SD24/LIFT LOBBY SD"
|      |      |      |-- 4:8-25 FDOT421 "B/L8/WC/8F/SD25/LIFT LOBBY SD"
|      |      |      |-- 4:8-26 FDOT421 "B/L8/WC/8F/SD26/CORR NR BW 8013"
|      |      |      |-- 4:8-27 FDOT421 "B/L8/WC/8F/SD27/CorrNr BW8012AFC"
|      |      |      |-- 4:8-28 FDOT421 "B/L8/WC/8F/SD28/AHU RM SD"
|      |      |      |-- 4:8-29 HTRI-R "B/L8/WC/8F/CM29/AHU RM CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 4:8-30 HMS-S/D/M/SA "B/L8/WC/8F/MCP30/FIRE SHAFT L.L."
|      |      |      |-- 4:8-31 HTRI-R "B/L8/WC/8F/CM31/FIRE SHAFT L.L."
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 4:8-32 HTRI-S "B/L8/WC/8F/MM32/FIRE SHAFT L.L."
|      |      |      |-- 4:8-33 FDOT421 "B/L8/WC/9F/SD33/ELECTRICAL RM SD"
|      |      |      |-- 4:8-34 FDOT421 "B/L8/WC/9F/SD34/CorrNr BW9022AFC"
|      |      |      |-- 4:8-35 FDOT421 "B/L8/WC/9F/SD35/CORR NR BW9021"
|      |      |      |-- 4:8-36 FDOT421 "B/L8/WC/9F/SD36/LIFT LOBBY SD"
|      |      |      |-- 4:8-37 FDOT421 "B/L8/WC/9F/SD37/LIFT LOBBY SD"
|      |      |      |-- 4:8-38 HMS-S/D/M/SA "B/L8/WC/9F/MCP38/FIRE SHAFT L.L."
|      |      |      |-- 4:8-39 HTRI-R "B/L8/WC/9F/CM39/FIRE SHAFT L.L."
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 4:8-40 HTRI-S "B/L8/WC/9F/MM40/FIRE SHAFT L.L."
|      |      |      |-- 4:8-41 FDOT421 "B/L8/WC/9F/SD41/AHU RM SD"
|      |      |      |-- 4:8-42 HTRI-R "B/L8/WC/9F/CM42/AHU RM CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 4:8-43 FDOT421 "B/L8/WC/SD43/TERACE LIFT RM BW"
|      |      |      |-- 4:8-44 FDOT421 "B/L8/WC/SD44/TERACE LIFT RM BW"
|      |      |      |-- 4:8-45 FDOT421 "B/L8/WC/SD45/TERACE LIFT RM BW"
|      |      |      |-- 4:8-46 FDOT421 "B/L8/WC/SD46/TERACE LIFT RM BW"
|      |      |      |-- 4:8-47 FDOT421 "B/L8/WC/SD47/TERACE LIFT RM BW"
|      |      |      |-- 4:8-48 HTRI-R "B/L8/WC/CM48/TERACE LIFT RM BW"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 4:8-55 HTRI-S "B/L8/7F/MM55/BW7020A"
```


4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:8 DLC "DLC @ address 8 L8"

			-- 4:8-60 HTRI-S "B/L8/7F/MM60/BW7030"
			-- 4:8-61 HTRI-S "B/L8/8F/MM61/BW8012"
			-- 4:8-62 HTRI-S "B/L8/8F/MM62/BW8013"
			-- 4:8-63 HTRI-S "B/L8/8F/MM63/BW8011"
			-- 4:8-64 HTRI-S "B/L8/8F/MM64/BW8030"
			-- 4:8-65 HTRI-S "B/L8/8F/MM65/BW8020"
			-- 4:8-66 HTRI-S "B/L8/8F/MM66/BW8012"
			-- 4:8-67 HTRI-S "B/L8/9F/MM67/BW9022"
			-- 4:8-68 HTRI-S "B/L8/9F/MM68/BW9030"
			-- 4:8-70 HFP-11 "B/L8/BW7012/SD70/Reception"
			-- 4:8-71 HFP-11 "B/L8/BW7012/SD71/Psg near Recept"
			-- 4:8-72 HFP-11 "B/L8/BW7012/SD72/Cab 1"
			-- 4:8-73 HFP-11 "B/L8/BW7012/SD73/Cab 2"
			-- 4:8-74 HFP-11 "B/L8/BW7012/SD74/Cab 3"
			-- 4:8-75 HFP-11 "B/L8/BW7012/SD75/Psg nr cab 2"
			-- 4:8-76 HFP-11 "B/L8/BW7012/SD76/Assorter cab 1"
			-- 4:8-77 HFP-11 "B/L8/BW7012/SD77/Assorter cab 2"
			-- 4:8-78 HFP-11 "B/L8/BW7012/SD78/Cab 4"
			-- 4:8-79 HFP-11 "B/L8/BW7012/SD79/Cab 5"
			-- 4:8-80 HFP-11 "B/L8/BW7012/SD80/Cab 6"
			-- 4:8-81 HFP-11 "B/L8/BW7012/SD81/Accounts cab"
			-- 4:8-82 HFP-11 "B/L8/BW7012/SD82/Cab 7"
			-- 4:8-83 HFP-11 "B/L8/BW7012/SD83/Psg nr cab 7"
			-- 4:8-84 HFP-11 "B/L8/BW7012/SD84/Psg nr cab 7"
			-- 4:8-85 HFP-11 "B/L8/BW7012/SD85/Cab 8"
			-- 4:8-86 HFP-11 "B/L8/BW7012/SD86/Conference rm 1"
			-- 4:8-87 HFP-11 "B/L8/BW7012/SD87/Conference rm 2"
			-- 4:8-88 HFP-11 "B/L8/BW7012/SD88/Pantry"
			-- 4:8-89 HFP-11 "B/L8/BW7012/SD89/Main cab 1"
			-- 4:8-90 HFP-11 "B/L8/BW7012/SD90/Main cab 2"
			-- 4:8-91 HFP-11 "B/L8/BW7012/SD91/Cab 9"
			-- 4:8-92 HMS-S/D/M/SA "B/L8/BW7012/MCP92/Reception"
			-- 4:8-93 HMS-S/D/M/SA "B/L8/BW7012/MCP93/Psg nr Account"
			-- 4:8-94 HTRI-R "B/L8/BW7012/CM94/Psg nr Receptio"
			-- Switch ""
			-- Relay
			-- 4:8-103 HFP-11 "B/L8/BW7011/SD103/Psg Nr Cab1"
			-- 4:8-104 HFP-11 "B/L8/BW7011/SD104/Pantry Psg Are"
			-- 4:8-105 HFP-11 "B/L8/BW7011/SD105/Recp Area"
			-- 4:8-106 HFP-11 "B/L8/BW7011/SD106/Accts Departme"
			-- 4:8-107 HFP-11 "B/L8/BW7011/SD107/Cab 1"
			-- 4:8-108 HFP-11 "B/L8/BW7011/SD108/Cab 2"
			-- 4:8-109 HFP-11 "B/L8/BW7011/SD109/Cab 3"
			-- 4:8-110 HFP-11 "B/L8/BW7011/SD110/Grad Del "
			-- 4:8-111 HFP-11 "B/L8/BW7011/SD111/Grad De 2"
			-- 4:8-112 HFP-11 "B/L8/BW7011/SD112/Grad De 3"
			-- 4:8-113 HFP-11 "B/L8/BW7011/SD113/Head Cab"
			-- 4:8-114 HFP-11 "B/L8/BW7011/SD114/Grading Depart"
			-- 4:8-115 HFP-11 "B/L8/BW7011/SD115/Cab 4"
			-- 4:8-116 HFP-11 "B/L8/BW7011/SD116/Main Cab 1"

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:8 DLC "DLC @ address 8 L8"

```
|      |      |      |-- 4:8-117 HFP-11 "B/L8/BW7011/SD117/Main Cab 2"
|      |      |      |-- 4:8-118 HFP-11 "B/L8/BW7011/SD118/Conf Room"
|      |      |      |-- 4:8-119 HFP-11 "B/L8/BW7011/SD119/Conf Room"
|      |      |      |-- 4:8-120 HFP-11 "B/L8/BW7011/SD120/Psg nr entry"
|      |      |      |-- 4:8-121 HTRI-R "B/L8/BW7011/CM121/Entry Dr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:8-122 HMS-S/D/M/SA "B/L8/BW7011/MCP122/Entry Dr"
|      |      |      |-- 4:8-123 HFP-11 "B/L8/BW9010A/SD123/Recp"
|      |      |      |-- 4:8-124 HFP-11 "B/L8/BW9010A/SD124/Accts Cab"
|      |      |      |-- 4:8-125 HFP-11 "B/L8/BW9010A/SD125/Main Cab"
|      |      |      |-- 4:8-126 HFP-11 "B/L8/BW9010A/SD126/Main Cab"
|      |      |      |-- 4:8-127 HFP-11 "B/L8/BW9010A/SD127/Cab 1"
|      |      |      |-- 4:8-128 HFP-11 "B/L8/BW9010A/SD128/Asst Cab"
|      |      |      |-- 4:8-129 HFP-11 "B/L8/BW9010A/SD129/Pantry"
|      |      |      |-- 4:8-130 HFP-11 "B/L8/BW9010A/SD130/Cab 2"
|      |      |      |-- 4:8-132 HTRI-R "B/L8/BW9010A/CM132/Entry Dr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:8-133 HMS-S/D/M/SA "B/L8/BW9010A/MCP133/Entry Dr"
|      |      |      |-- 4:8-151 HFP-11 "DC2/L8/SD151/SERVER RM"
|      |      |      |-- 4:8-152 HFP-11 "DC2/L8/SD152/SERVER RM"
|      |      |      |-- 4:8-153 HFP-11 "DC2/L8/SD153/SERVER RM"
|      |      |      |-- 4:8-154 HFP-11 "DC2/L8/SD154/SERVER RM"
|      |      |      |-- 4:8-155 HFP-11 "DC2/L8/SD155/SERVER RM/BFF"
|      |      |      |-- 4:8-156 HFP-11 "DC2/L8/SD156/SERVER RM/BFF"
|      |      |      |-- 4:8-157 HFP-11 "DC2/L8/SD157/SERVER RM/BFF"
|      |      |      |-- 4:8-158 HFP-11 "DC2/L8/SD158/SERVER RM/BFF"
|      |      |      |-- 4:8-159 HFP-11 "DC2/L8/SD159/NR MAIN ENTRANCE"
|      |      |      |-- 4:8-160 HFP-11 "DC2/L8/SD160/NOC RM"
|      |      |      |-- 4:8-161 HFP-11 "DC2/L8/SD161/ELECTRICAL RM"
|      |      |      |-- 4:8-162 HFP-11 "DC2/L8/SD162/ELECTRICAL RM"
|      |      |      |-- 4:8-163 HFP-11 "DC2/L8/SD163/ELECTRICAL RM"
|      |      |      |-- 4:8-164 HFP-11 "DC2/L8/SD164/ELECTRICAL RM/BFF"
|      |      |      |-- 4:8-165 HFP-11 "DC2/L8/SD165/ELECTRICAL RM/BFF"
|      |      |      |-- 4:8-166 HTRI-S "DC2/L8/MM166/BUILDING FAS INPUT"
|      |      |      |-- 4:8-167 HTRI-R "DC2/L8/CM167/ FAS INPUT TO BUILD"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:8-168 HTRI-R "DC2/L8/CM168/GSS/Z2"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:8-169 HTRI-S "DC2/L8/MM169/VESDA INPUT"
|      |      |      |-- 4:8-170 HTRI-R "DC2/L8/CM170/GSS/Z1"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:8-171 HTRI-R "DC2/L2/CM171/SERVER RM HOOTER"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:8-172 HMS-S/D/M/SA "DC2/L8/MCP172/SER RM/NR FIRE EXI"
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:8 DLC "DLC @ address 8 L8"

```
|      |      |      |-- 4:8-173 HTRI-S "B/L8/9F/MM173/BW9021"
|      |      |      |-- 4:9 DLC "DLC @ address 9 L9"
|      |      |      |-- 4:9-18 FDOT421 "B/L9/CC/8F/SD18/ELECT RM SD"
|      |      |      |-- 4:9-19 FDOT421 "B/L9/CC/8F/SD19/CORR NR E.R.AFC"
|      |      |      |-- 4:9-20 FDOT421 "B/L9/CC/8F/SD20/CORR NR E.R."
|      |      |      |-- 4:9-21 HTRI-R "B/L9/CC/8F/CM21/FIRE SHAFT L.L."
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-22 HTRI-S "B/L9/CC/8F/MM22/FIRE SHAFT L.L."
|      |      |      |-- 4:9-23 HMS-S/D/M/SA "B/L9/CC/8F/MCP23/FIRE SHAFT L.L."
|      |      |      |-- 4:9-24 FDOT421 "B/L9/CC/8F/SD24/LIFT LOBBY SD"
|      |      |      |-- 4:9-25 FDOT421 "B/L9/CC/8F/SD25/LIFT LOBBY SD"
|      |      |      |-- 4:9-26 FDOT421 "B/L9/CC/8F/SD26/CorrNrBC8/S04AFC"
|      |      |      |-- 4:9-27 FDOT421 "B/L9/CC/8F/SD27/CORR NR BC8/S04"
|      |      |      |-- 4:9-28 FDOT421 "B/L9/EC/8F/SD28/CORR NR BE8/S23"
|      |      |      |-- 4:9-29 FDOT421 "B/L9/EC/8F/SD29/CORR NR BE8/S23"
|      |      |      |-- 4:9-30 FDOT421 "B/L9/EC/8F/SD30/AHU RM SD"
|      |      |      |-- 4:9-31 HTRI-R "B/L9/EC/8F/CM31/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-32 FDOT421 "B/L9/EC/8F/SD32/ELECT RM SD"
|      |      |      |-- 4:9-33 FDOT421 "B/L9/EC/8F/SD33/LIFT LOBBY SD"
|      |      |      |-- 4:9-34 HMS-S/D/M/SA "B/L9/EC/8F/MCP34/FIRE SHAFT L.L."
|      |      |      |-- 4:9-35 HTRI-R "B/L9/EC/8F/CM35/FIRE SHAFT L.L."
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-36 HTRI-S "B/L9/EC/8F/MM36/FIRE SHAFT L.L."
|      |      |      |-- 4:9-37 HTRI-R "B/L9/CC/9F/CM37/FIRE SHAFT L.L."
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-38 HTRI-S "B/L9/CC/9F/MM38/FIRE SHAFT L.L."
|      |      |      |-- 4:9-39 HMS-S/D/M/SA "B/L9/CC/9F/MCP39/FIRE SHAFT L.L."
|      |      |      |-- 4:9-40 FDOT421 "B/L9/CC/9F/SD40/CORR NR E.R.AFC"
|      |      |      |-- 4:9-41 FDOT421 "B/L9/CC/9F/SD41/CORR NR E.R."
|      |      |      |-- 4:9-42 FDOT421 "B/L9/CC/9F/SD42/ELECT RM SD"
|      |      |      |-- 4:9-43 FDOT421 "B/L9/CC/9F/SD43/LIFT LOBBY SD"
|      |      |      |-- 4:9-44 FDOT421 "B/L9/CC/9F/SD44/LIFT LOBBY SD"
|      |      |      |-- 4:9-45 FDOT421 "B/L9/CC/9F/SD45/AHU RM SD"
|      |      |      |-- 4:9-46 HTRI-R "B/L9/CC/9F/CM46/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-47 FDOT421 "B/L9/EC/9F/SD47/ELECT RM SD"
|      |      |      |-- 4:9-48 FDOT421 "B/L9/EC/9F/SD48/CORR NR E.R."
|      |      |      |-- 4:9-49 FDOT421 "B/L9/EC/9F/SD49/AHU RM SD"
|      |      |      |-- 4:9-50 HTRI-R "B/L9/EC/9F/CM50/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 4:9-51 FDOT421 "B/L9/EC/9F/SD51/LIFT LOBBY SD"
|      |      |      |-- 4:9-52 HMS-S/D/M/SA "B/L9/EC/9F/MCP52/FIRE SHAFT L.L."
|      |      |      |-- 4:9-53 HTRI-R "B/L9/EC/9F/CM53/FIRE SHAFT L.L."
```

4 Desigo Fire Safety Modular "BDB TOWER B" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

4:9 DLC "DLC @ address 9 L9"

4:9-53 HTRI-R "B/L9/EC/9F/CM53/FIRE SHAFT L.L."

```
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 4:9-54 HTRI-S "B/L9E/9F/MM 54/FIRE SHAFT "
|      | | | |-- 4:9-55 HMS-S/D/M/SA "B/L9/EC/9F/MCP55/FIRE ESCP STR C"
|      | | | |-- 4:9-56 FDOT421 "B/L9/CC/8F/SD56/AHU RM SD"
|      | | | |-- 4:9-57 HTRI-R "B/L9/CC/8F/CM57/AHU RM CM"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 4:9-60 HTRI-S "B/L9/8F/MM60/BE8020"
|      | | | |-- 4:9-61 HTRI-S "B/L9/8F/MM61/BE8030"
|      | | | |-- 4:9-62 HTRI-S "B/L9/9F/MM62/BC9010"
|      | | | |-- 4:9-63 FDOT421 "B/L9/BC/SD63/BC Lift RM Terrace"
|      | | | |-- 4:9-64 FDOT421 "B/L9/BC/SD64/BC Lift RM Terrace"
|      | | | |-- 4:9-65 FDOT421 "B/L9/BC/SD65/BC Lift RM Terrace"
|      | | | |-- 4:9-66 FDOT421 "B/L9/BC/SD66/BC Lift RM Terrace"
|      | | | |-- 4:9-67 HTRI-R "B/L9/BC/CM67/BC lift RM Terrace"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 4:9-68 FDOT421 "B/L9/BE/SD68/BE Lift RM Terrace"
|      | | | |-- 4:9-69 HTRI-R "B/L9/BE/CM69/BE LIFT RM Terrace"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 4:9-70 HTRI-R "B/L9/EC/9F/CM70/FIRE ESCP STR CA"
|      | | | | |-- Switch ""
|      | | | | |-- Relay
|      | | | |-- 4:9-71 HTRI-S "B/L9/8F/MM71/BC8010 B/C"
|      | | | |-- 4:10 NIC-C(XNet) "NIC_Xnet @ address 10"
|      | | | |-- 4:249 PSC-12 "PSC-12 @ address 1"
|      | | | |-- 4:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      | | | |-- 4:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      | | | |-- Inner Door
|      | | | |-- 4:253 PMI-D "PMI-D Tower B -4"
```

|-- 5 Desigo Fire Safety Modular "BDB TOWER C" Local

```
| |-- System Flags
| |-- History Log
| |-- Behavior
| |-- Voice
| |-- Maintenance
| |-- Field Devices
| |-- Miscellaneous
| |-- CAB-2 "CAB-2 Enclosure #1"
| | |-- CC-5 "Card Cage 5 Slots"
| | | |-- 5:1 DLC "DLC @ address 1 L1"
| | | | |-- 5:1-1 HMS-S/D/M/SA "C/L1/CE/GND/MCP1/LIFT LOBBY"
| | | | |-- 5:1-2 HTRI-R "C/L1/CE/GND/CM2/SHAFT"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 5:1-3 HTRI-S "C/L1/CE/GND/MM3/SHAFT"
| | | |-- 5:1-4 HFP-11 "C/L1/CE/GND/SD4/ELEC ROOM"
| | | |-- 5:1-5 HFP-11 "C/L1/CE/SD 5/LIFT LOBBY"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:1 DLC "DLC @ address 1 L1"

					-- 5:1-6 HFP-11 "C/L1/CE/SD 6/LIFT LOBBY"
					-- 5:1-7 HFP-11 "C/L1/CE/SD 7/LIFT LOBBY"
					-- 5:1-8 HFP-11 "C/L1/CE/SD 8/LIFT LOBBY"
					-- 5:1-9 HFP-11 "C/L1/CE/SD 9/LIFT LOBBY"
					-- 5:1-10 HTRI-R "C/L1/CE/GND/CM10/AHU RM"
					-- Switch ""
					-- Relay
					-- 5:1-11 HFP-11 "C/L1/CE/GND/SD11/AHU RM"
					-- 5:1-12 HMS-S/D/M/SA "C/L1/CC/GND/MCP12/LIFT LOBBY"
					-- 5:1-13 HTRI-R "C/L1/CC/GND/CM13/SHAFT"
					-- Switch ""
					-- Relay
					-- 5:1-14 HTRI-S "C/L1/CC/GND/MM14/SHAFT"
					-- 5:1-15 HFP-11 "C/L1/CC/GND/SD15/ELEC ROOM"
					-- 5:1-16 HFP-11 "C/L1/CC/SD 16/LIFT LOBBY"
					-- 5:1-17 HFP-11 "C/L1/CC/SD 17/LIFT LOBBY"
					-- 5:1-18 HTRI-R "C/L1/CC/GND/CM18/AHU RM"
					-- Switch ""
					-- Relay
					-- 5:1-19 HFP-11 "C/L1/CC/GND/SD19/AHU RM"
					-- 5:1-20 HMS-S/D/M/SA "C/L1/CW/GND/MCP20/LIFT LOBBY"
					-- 5:1-21 HTRI-R "C/L1/CW/GND/CM21/SHAFT"
					-- Switch ""
					-- Relay
					-- 5:1-22 HTRI-S "C/L1/CW/GND/MM22/SHAFT"
					-- 5:1-23 HFP-11 "C/L1/CW/GND/SD23/ELEC ROOM"
					-- 5:1-24 HFP-11 "C/L1/CW/SD24/LIFT LOBBY"
					-- 5:1-25 HFP-11 "C/L1/CW/SD25/LIFT LOBBY"
					-- 5:1-26 HFP-11 "C/L1/CW/SD26/GND/LIFT LOBBY"
					-- 5:1-27 HTRI-R "C/L1/CW/GND/CM27/AHU RM"
					-- Switch ""
					-- Relay
					-- 5:1-28 HFP-11 "C/L1/CW/GND/SD28/AHU RM"
					-- 5:1-29 HFP-11 "C/L1/C-DTC/SD-29/Cabin 1"
					-- 5:1-30 HFP-11 "C/L1/C-DTC/SD-30/Cabin 2"
					-- 5:1-31 HFP-11 "C/L1/C-DTC/SD-31/Cabin 3"
					-- 5:1-32 HFP-11 "C/L1/C-DTC/SD-32/Cabin 4"
					-- 5:1-33 HFP-11 "C/L1/C-DTC/SD-33/Cabin 5"
					-- 5:1-34 HFP-11 "C/L1/C-DTC/SD-34/Cabin 6"
					-- 5:1-35 HFP-11 "C/L1/C-DTC/SD-35/Cabin 7"
					-- 5:1-36 HFP-11 "C/L1/C-DTC/SD-36/Cabin 8"
					-- 5:1-37 HFP-11 "C/L1/C-DTC/SD-37/Cabin 9"
					-- 5:1-38 HFP-11 "C/L1/C-DTC/SD-38/Cabin 10"
					-- 5:1-39 HFP-11 "C/L1/C-DTC/SD-39/Cabin 11"
					-- 5:1-40 HFP-11 "C/L1/C-DTC/SD-40/Cabin 12"
					-- 5:1-41 HFP-11 "C/L1/C-DTC/SD-41/Cabin 13"
					-- 5:1-42 HFP-11 "C/L1/C-DTC/SD-42/Cabin 14"
					-- 5:1-43 HFP-11 "C/L1/C-DTC/SD-43/Cabin 15"
					-- 5:1-44 HFP-11 "C/L1/C-DTC/SD-44/Cabin 16"
					-- 5:1-45 HFP-11 "C/L1/C-DTC/SD-45/Cabin 17"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:1 DLC "DLC @ address 1 L1"

					-- 5:1-46 HFP-11 "C/L1/C-DTC/SD-46/Cabin 18"
					-- 5:1-47 HFP-11 "C/L1/C-DTC/SD-47/Cabin 19"
					-- 5:1-48 HFP-11 "C/L1/C-DTC/SD-48/Cabin 20"
					-- 5:1-49 HFP-11 "C/L1/C-DTC/SD-49/Cabin 21"
					-- 5:1-50 HFP-11 "C/L1/C-DTC/SD-50/Cabin 22"
					-- 5:1-51 HFP-11 "C/L1/C-DTC/SD-51/Cabin 23"
					-- 5:1-52 HFP-11 "C/L1/C-DTC/SD-52/Cabin 24"
					-- 5:1-53 HFP-11 "C/L1/C-DTC/SD-53/Cabin 25"
					-- 5:1-54 HFP-11 "C/L1/C-DTC/SD-54/Cabin 26"
					-- 5:1-55 HFP-11 "C/L1/C-DTC/SD-55/Cabin 27"
					-- 5:1-56 HFP-11 "C/L1/C-DTC/SD-56/Cabin 28"
					-- 5:1-57 HFP-11 "C/L1/C-DTC/SD-57/Cabin 29"
					-- 5:1-58 HFP-11 "C/L1/C-DTC/SD-58/Cabin 30"
					-- 5:1-59 HFP-11 "C/L1/C-DTC/SD-59/Cabin 31"
					-- 5:1-60 HFP-11 "C/L1/C-DTC/SD-60/Cabin 32"
					-- 5:1-61 HFP-11 "C/L1/C-DTC/SD-61/Cabin 33"
					-- 5:1-62 HFP-11 "C/L1/C-DTC/SD-62/Cabin 34"
					-- 5:1-63 HFP-11 "C/L1/C-DTC/SD-63/Cabin 35"
					-- 5:1-64 FDOT421 "C/L1/C-DTC/SD-64/Cabin 36"
					-- 5:1-65 HFP-11 "C/L1/C-DTC/SD-65/Cabin 37"
					-- 5:1-66 HFP-11 "C/L1/C-DTC/SD-66/Cabin 38"
					-- 5:1-67 HFP-11 "C/L1/C-DTC/SD-67/Cabin 39"
					-- 5:1-68 HFP-11 "C/L1/C-DTC/SD-68/Cabin 40"
					-- 5:1-69 HFP-11 "C/L1/C-DTC/SD-69/Cabin 41"
					-- 5:1-70 HFP-11 "C/L1/C-DTC/SD-70/Cabin 42"
					-- 5:1-71 HFP-11 "C/L1/C-DTC/SD-71/Cabin 43"
					-- 5:1-72 HFP-11 "C/L1/C-DTC/SD-72/Cabin 44"
					-- 5:1-73 HFP-11 "C/L1/C-DTC/SD-73/Cabin 45"
					-- 5:1-74 FDOT421 "C/L1/C-DTC/SD-74/Cabin 46"
					-- 5:1-75 FDOT421 "C/L1/C-DTC/SD-75/Cabin 47"
					-- 5:1-76 HFP-11 "C/L1/C-DTC/SD-76/Cabin 48"
					-- 5:1-77 FDOT421 "C/L1/C-DTC/SD-77/Cabin 49"
					-- 5:1-78 FDOT421 "C/L1/C-DTC/SD-78/Cabin 50"
					-- 5:1-79 FDOT421 "C/L1/C-DTC/SD-79/Cabin 51"
					-- 5:1-80 HFP-11 "C/L1/C-DTC/SD-80/Cabin 52"
					-- 5:1-81 FDOT421 "C/L1/C-DTC/SD-81/Cabin 53"
					-- 5:1-82 FDOT421 "C/L1/C-DTC/SD-82/Cabin 54"
					-- 5:1-83 HFP-11 "C/L1/C-DTC/SD-83/Cabin 55"
					-- 5:1-84 FDOT421 "C/L1/C-DTC/SD-84/Cabin 56"
					-- 5:1-85 HFP-11 "C/L1/C-DTC/SD-85/Cabin 57"
					-- 5:1-86 FDOT421 "C/L1/C-DTC/SD-86/Cabin 58"
					-- 5:1-87 FDOT421 "C/L1/C-DTC/SD-87/Cabin 59"
					-- 5:1-88 HFP-11 "C/L1/C-DTC/SD-88/Cabin 60"
					-- 5:1-89 FDOT421 "C/L1/C-DTC/SD-89/Cabin 61"
					-- 5:1-90 FDOT421 "C/L1/C-DTC/SD-90/Cabin 62"
					-- 5:1-91 FDOT421 "C/L1/C-DTC/SD-91/Cabin 63"
					-- 5:1-92 HFP-11 "C/L1/C-DTC/SD-92/Psg Nr Cab 5"
					-- 5:1-93 HFP-11 "C/L1/C-DTC/SD-93/Psg Nr Cab 8"
					-- 5:1-94 HFP-11 "C/L1/C-DTC/SD-94/Psg Nr server R"
					-- 5:1-95 HFP-11 "C/L1/C-DTC/SD-95/Psg Nr Cab 12"

5 Desigo Fire Safety Modular "BDB TOWER C" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
5:1 DLC "DLC @ address 1 L1"

					-- 5:1-96 HFP-11 "C/L1/C-DTC/SD-96/Psg Nr Cab 19"
					-- 5:1-97 HFP-11 "C/L1/C-DTC/SD-97/Psg Nr Cab 39"
					-- 5:1-98 HFP-11 "C/L1/C-DTC/SD-98/Psg Nr Cab 34"
					-- 5:1-99 HFP-11 "C/L1/C-DTC/SD-99/Psg Nr Cab 24"
					-- 5:1-100 HFP-11 "C/L1/C-DTC/SD-100/Psg Nr Cab 22"
					-- 5:1-101 HFP-11 "C/L1/C-DTC/SD-101/Psg Nr Cab 36"
					-- 5:1-102 HFP-11 "C/L1/C-DTC/SD-102/Psg Nr Cab 45"
					-- 5:1-103 HTRI-S "C/L1/CC/UB/MM103/ELEC ROOM"
					-- 5:1-104 HMS-S/D/M/SA "C/L1/W/UB/MCP104/EMG EXIT PC268"
					-- 5:1-105 HTRI-R "C/L1/W/UB/CM105/EMG EXIT PC268"
					-- Switch ""
					-- Relay
					-- 5:1-106 HTRI-S "C/L1/WC/UB/MM106/ELEC ROOM PC220"
					-- 5:1-107 HTRI-R "C/L1/WC/UB/CM107/EX NR RAMP 3"
					-- Switch ""
					-- Relay
					-- 5:1-108 HMS-S/D/M/SA "C/L1/W/UB/MCP108/EX NrRAMP3 P222"
					-- 5:1-109 HTRI-R "C/L1/WC/UB/CM109/EX NR RAMP 3"
					-- Switch ""
					-- Relay
					-- 5:1-110 HMS-S/D/M/SA "C/L1/WC/UB/MCP110/EX NR RAMP 3"
					-- 5:1-111 HTRI-R "C/L1/WC/LB/CM111/NR RAMP 3 PD307"
					-- Switch ""
					-- Relay
					-- 5:1-112 HMS-S/D/M/SA "C/L1/C/UB/MCP112/NR RAMP 3"
					-- 5:1-113 HMS-S/D/M/SA "C/L1/WC/UB/MCP113/NR RAMP 3 C190"
					-- 5:1-114 HTRI-R "C/L1/WC/UB/CM114/GF NR RAMP 3"
					-- Switch ""
					-- Relay
					-- 5:1-115 HTRI-R "C/L1/CC/UB/CM115/ST NR C-BMS"
					-- Switch ""
					-- Relay
					-- 5:1-116 HMS-S/D/M/SA "C/L1/CC/UB/MCP116/ST NR C-BMS"
					-- 5:1-117 HTRI-R "C/L1/CC/UB/CM117/EXIT DOOR C245"
					-- Switch ""
					-- Relay
					-- 5:1-118 HMS-S/D/M/SA "C/L1/CC/UB/MCP118/EXIT DOOR C245"
					-- 5:1-119 HTRI-S "C/L1/EC/UB/MM119/ELEC ROOM"
					-- 5:1-120 HTRI-S "C/L1/EC/UB/MM120/LIFT MC ROOM"
					-- 5:1-121 HTRI-R "C/L1/EC/UB/CM121/EM EXIT DOOR 2"
					-- Switch ""
					-- Relay
					-- 5:1-122 HMS-S/D/M/SA "C/L1/E/UB/MCP122/NR LIILY OFFIC"
					-- 5:1-123 HFP-11 "C/L1/EC/UB/SD123/ELEC ROOM"
					-- 5:1-124 HFP-11 "C/L1/WC/UB/SD124/ELEC ROOM"
					-- 5:1-125 HFP-11 "C/L1/EC/UB/SD125/ELEC ROOM"
					-- 5:1-126 HFP-11 "C/L1/EC/UB/SD126/LIFT MC RM"
					-- 5:1-127 HFP-11 "C/L1/EC/UB/SD127/LIFT MC RM"
					-- 5:1-128 HFP-11 "C/L1/E/UB/SD128/NR RAMP 3"
					-- 5:1-129 HFP-11 "C/L1/CC/UB/SD129/BMS ROOM"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:1 DLC "DLC @ address 1 L1"

					-- 5:1-130 HFP-11 "C/L1/C-DTC/SD-130/Psg Nr Cab 41"
					-- 5:1-131 HFP-11 "C/L1/C-DTC/SD-131/Psg Nr Cab 38"
					-- 5:1-132 HFP-11 "C/L1/C-DTC/SD-132/Psg Nr Cab 46"
					-- 5:1-133 HFP-11 "C/L1/C-DTC/SD-133/Server room"
					-- 5:1-134 HFP-11 "C/L1/C-DTC/SD-134/Psg afc at Ser"
					-- 5:1-135 HFP-11 "C/L1/C-DTC/SD-135/Psg Nr fire ex"
					-- 5:1-136 HFP-11 "C/L1/C-DTC/SD-136/Psg Nr Cab 56"
					-- 5:1-137 HFP-11 "C/L1/C-DTC/SD-137/Psg Nr Cab 60"
					-- 5:1-138 HFP-11 "C/L1/C-DTC/SD-138/Electric Rm"
					-- 5:1-139 HMS-S/D/M/SA "C/L1/C-DTC/MCP-139/Main Exit"
					-- 5:1-140 HTRI-R "C/L1/C-DTC/CM-140/abv ceil Main "
					-- Switch ""
					-- Relay
					-- 5:1-141 HMS-S/D/M/SA "C/L1/C-DTC/MCP-141/Nr Cab 6"
					-- 5:1-142 HTRI-R "C/L1/C-DTC/CM-142/Psg Nr Cab 6"
					-- Switch ""
					-- Relay
					-- 5:1-143 HMS-S/D/M/SA "C/L1/C-DTC/MCP-143/Nr Cab 11"
					-- 5:1-144 HFP-11 "C/L1/E/UB/SD144/NR RAMP 3"
					-- 5:1-145 HMS-S/D/M/SA "C/L1/C-DTC/MCP-145/Nr Cab 14"
					-- 5:1-146 HTRI-R "C/L1/C-DTC/CM-146/Psg Nr Cab 14"
					-- Switch ""
					-- Relay
					-- 5:1-147 HMS-S/D/M/SA "C/L1/C-DTC/MCP-147/Nr Cab 34"
					-- 5:1-148 HTRI-R "C/L1/C-DTC/CM-148/Psg Nr Cab 34"
					-- Switch ""
					-- Relay
					-- 5:1-149 HMS-S/D/M/SA "C/L1/C-DTC/MCP/-149/Nr Cab 31"
					-- 5:1-150 HFP-11 "C/L1/E/UB/SD150/NR RAMP 3"
					-- 5:1-151 HMS-S/D/M/SA "C/L1/C-DTC/MCP-151/Nr Cab 42"
					-- 5:1-152 HTRI-R "C/L1/C-DTC/CM-152/Psg Nr Cab 42"
					-- Switch ""
					-- Relay
					-- 5:1-153 HMS-S/D/M/SA "C/L1/C-DTC/MCP-153/Nr Cab 38"
					-- 5:1-154 HTRI-R "C/L1/C-DTC/CM-154/Psg Nr Cab 38"
					-- Switch ""
					-- Relay
					-- 5:1-155 HMS-S/D/M/SA "C/L1/C-DTC/MCP-155/Nr Cab 57"
					-- 5:1-156 HTRI-R "C/L1/C-DTC/CM-156/Psg Nr Cab 57"
					-- Switch ""
					-- Relay
					-- 5:1-157 HMS-S/D/M/SA "C/L1/C-DTC/MCP-157/Nr by pantry"
					-- 5:1-158 HTRI-R "C/L1/C-DTC/CM-158/Psg Nr Pantry"
					-- Switch ""
					-- Relay
					-- 5:1-159 HMS-S/D/M/SA "C/L1/C-DTC/MCP-159/Nr Cab 55"
					-- 5:1-161 HFP-11 "C/L1/C-DTC/SD-161/Pantry"
					-- 5:1-168 HFP-11 "C/L1/C-DTC/SD-168/Psg afc Cab 1"
					-- 5:1-169 HFP-11 "C/L1/C-DTC/SD-169/Psg afc Cab 2"
					-- 5:1-170 HFP-11 "C/L1/C-DTC/SD-170/Psg afc Cab 3"

5 Desigo Fire Safety Modular "BDB TOWER C" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
5:1 DLC "DLC @ address 1 L1"

					-- 5:1-171 HFP-11 "C/L1/C-DTC/SD-171/Psg afc Cab 4"
					-- 5:1-172 HFP-11 "C/L1/C-DTC/SD-172/Psg afc Cab 5"
					-- 5:1-173 HFP-11 "C/L1/C-DTC/SD-173/Psg afc Cab 6"
					-- 5:1-174 HFP-11 "C/L1/C-DTC/SD-174/Psg afc Cab 7"
					-- 5:1-175 HFP-11 "C/L1/C-DTC/SD-175/Psg afc Cab 8"
					-- 5:1-176 HFP-11 "C/L1/C-DTC/SD-176/Psg afc Cab 9"
					-- 5:1-177 HFP-11 "C/L1/C-DTC/SD-177/Psg afc Cab 10"
					-- 5:1-178 HFP-11 "C/L1/C-DTC/SD-178/Psg afc Cab 11"
					-- 5:1-179 HFP-11 "C/L1/C-DTC/SD-179/Psg afc Cab 12"
					-- 5:1-180 HFP-11 "C/L1/C-DTC/SD-180/Psg afc Cab 13"
					-- 5:1-181 HFP-11 "C/L1/C-DTC/SD-181/Psg afc Cab 14"
					-- 5:1-182 HFP-11 "C/L1/C-DTC/SD-182/Psg afc Cab 15"
					-- 5:1-183 HFP-11 "C/L1/C-DTC/SD-183/Psg afc Cab 16"
					-- 5:1-184 HFP-11 "C/L1/C-DTC/SD-184/Psg afc Cab 17"
					-- 5:1-185 HFP-11 "C/L1/C-DTC/SD-185/Psg afc Cab 18"
					-- 5:1-186 HFP-11 "C/L1/C-DTC/SD-186/Psg afc Cab 19"
					-- 5:1-187 HFP-11 "C/L1/C-DTC/SD-187/Psg afc Cab 20"
					-- 5:1-188 HFP-11 "C/L1/C-DTC/SD-188/Psg afc Cab 21"
					-- 5:1-189 HFP-11 "C/L1/C-DTC/SD-189/Psg afc Cab 22"
					-- 5:1-190 HFP-11 "C/L1/C-DTC/SD-190/Psg afc Cab 23"
					-- 5:1-191 HFP-11 "C/L1/C-DTC/SD-191/Psg afc Cab 24"
					-- 5:1-192 HFP-11 "C/L1/C-DTC/SD-192/Psg afc Cab 25"
					-- 5:1-193 HFP-11 "C/L1/C-DTC/SD-193/Psg afc Cab 26"
					-- 5:1-194 HFP-11 "C/L1/C-DTC/SD-194/Psg afc Cab 27"
					-- 5:1-195 HFP-11 "C/L1/C-DTC/SD-195/Psg afc Cab 28"
					-- 5:1-196 HFP-11 "C/L1/C-DTC/SD-196/Psg afc Cab 29"
					-- 5:1-197 HFP-11 "C/L1/C-DTC/SD-197/Psg afc Cab 30"
					-- 5:1-198 HFP-11 "C/L1/C-DTC/SD-198/Psg afc Cab 31"
					-- 5:1-199 HFP-11 "C/L1/C-DTC/SD-199/Psg afc Cab 32"
					-- 5:1-200 HFP-11 "C/L1/C-DTC/SD-200/Psg afc Cab 33"
					-- 5:1-201 HFP-11 "C/L1/C-DTC/SD-201/Psg afc Cab 35"
					-- 5:1-202 HFP-11 "C/L1/C-DTC/SD-202/Psg afc Cab 34"
					-- 5:1-203 HFP-11 "C/L1/C-DTC/SD-203/Psg afc Cab 36"
					-- 5:1-204 HFP-11 "C/L1/C-DTC/SD-204/Psg afc Cab 37"
					-- 5:1-205 HFP-11 "C/L1/C-DTC/SD-205/Psg afc Cab 38"
					-- 5:1-206 HFP-11 "C/L1/C-DTC/SD-206/Psg afc Cab 39"
					-- 5:1-207 HFP-11 "C/L1/C-DTC/SD-207/Psg afc Cab 40"
					-- 5:1-208 HFP-11 "C/L1/C-DTC/SD-208/Psg afc Cab 41"
					-- 5:1-209 HFP-11 "C/L1/C-DTC/SD-209/Psg afc Cab 42"
					-- 5:1-210 HFP-11 "C/L1/C-DTC/SD-210/Psg afc Cab 43"
					-- 5:1-211 HFP-11 "C/L1/C-DTC/SD-211/Psg afc Cab 44"
					-- 5:1-212 HFP-11 "C/L1/C-DTC/SD-212/Psg afc Cab 45"
					-- 5:1-213 HFP-11 "C/L1/C-DTC/SD-213/Psg afc Cab 46"
					-- 5:1-214 HFP-11 "C/L1/C-DTC/SD-214/Psg afc Cab 47"
					-- 5:1-215 HFP-11 "C/L1/C-DTC/SD-215/Psg afc Cab 48"
					-- 5:1-216 HFP-11 "C/L1/C-DTC/SD-216/Psg afc Cab 49"
					-- 5:1-217 HFP-11 "C/L1/C-DTC/SD-217/Psg afc Cab 50"
					-- 5:1-218 HFP-11 "C/L1/C-DTC/SD-218/Psg afc Cab 51"
					-- 5:1-219 HFP-11 "C/L1/C-DTC/SD-219/Psg afc Cab 52"
					-- 5:1-220 HFP-11 "C/L1/C-DTC/SD-220/Psg afc Cab 53"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:1 DLC "DLC @ address 1 L1"

					-- 5:1-221 HFP-11 "C/L1/C-DTC/SD-221/Psg afc Cab 54"
					-- 5:1-222 HFP-11 "C/L1/C-DTC/SD-222/Psg afc Cab 55"
					-- 5:1-223 HFP-11 "C/L1/C-DTC/SD-223/Psg afc Cab 56"
					-- 5:1-224 HFP-11 "C/L1/C-DTC/SD-224/Psg afc Cab 57"
					-- 5:1-225 HFP-11 "C/L1/C-DTC/SD-225/Psg afc Cab 58"
					-- 5:1-226 HFP-11 "C/L1/C-DTC/SD-226/Psg afc Cab 59"
					-- 5:1-227 HFP-11 "C/L1/C-DTC/SD-227/Psg afc Cab 60"
					-- 5:1-228 HFP-11 "C/L1/C-DTC/SD-228/Psg afc Cab 61"
					-- 5:1-229 HFP-11 "C/L1/C-DTC/SD-229/Psg afc Cab 62"
					-- 5:1-230 HFP-11 "C/L1/C-DTC/SD-230/Psg afc Cab 63"
					-- 5:1-231 HFP-11 "C/L1/C-DTC/SD-231/Psg Nr afc Cab"
					-- 5:1-232 HFP-11 "C/L1/C-DTC/SD-232/Psg Nr afc Cab"
					-- 5:1-233 HFP-11 "C/L1/C-DTC/SD-233/Psg Nr afc ser"
					-- 5:1-234 HFP-11 "C/L1/C-DTC/SD-234/Psg Nr afc Cab"
					-- 5:1-235 HFP-11 "C/L1/C-DTC/SD-235/Psg Nr afc Cab"
					-- 5:1-236 HFP-11 "C/L1/C-DTC/SD236/PsgNr afcCab39"
					-- 5:1-237 HFP-11 "C/L1/C-DTC/SD-237/Psg Nr afc Cab"
					-- 5:1-238 HFP-11 "C/L1/C-DTC/SD-238/Psg Nr afc Cab"
					-- 5:1-240 HFP-11 "C/L1/C-DTC/SD-240/Psg Nr afc Cab"
					-- 5:1-241 HFP-11 "C/L1/C-DTC/SD-241/Psg Nr afc Cab"
					-- 5:1-243 HFP-11 "C/L1/C-DTC/SD-243/Psg Nr afc Cab"
					-- 5:1-244 HFP-11 "C/L1/C-DTC/SD-244/Psg Nr afc Cab"
					-- 5:1-245 HFP-11 "C/L1/C-DTC/SD-245/Psg Nr afc fir"
					-- 5:1-246 HFP-11 "C/L1/C-DTC/SD-246/Psg afc Nr Cab"
					-- 5:1-247 HFP-11 "C/L1/C-DTC/SD-247/Psg afc Nr Cab"
					-- 5:1-248 HFP-11 "C/L1/C-DTC/SD-248/afc at Electri"
					-- 5:1-249 HFP-11 "C/L1/C-DTC/SD-249/Psg afc Nr Re"
					-- 5:1-251 HFP-11 "C/L1/C-DTC/SD-251/Psg afc Nr Cab"
					-- 5:2 DLC "DLC @ address 2 L2"
					-- 5:2-1 HFP-11 " C/L2/WC/2F/SD1/CORR NR BW 2101"
					-- 5:2-2 HFP-11 "C/L2/WC/2F/SD2/CORR NR BW 2101"
					-- 5:2-3 HFP-11 "C/L2/WC/2F/SD3/CORR NR CW2/S13"
					-- 5:2-4 HFP-11 "C/L2/WC/2F/SD4/CORR NR E.R."
					-- 5:2-5 HFP-11 "C/L2/WC/2F/SD5/CORR NR E.R."
					-- 5:2-6 HFP-11 "C/L2/WC/2F/SD6/ELECT RM"
					-- 5:2-7 HTRI-R "C/L2/WC/2F/CM7/DR RELSE CM"
					-- Switch ""
					-- Relay
					-- 5:2-8 HFP-11 "C/L2/WC/2F/SD8/LIFT LOBBY"
					-- 5:2-9 HFP-11 "C/L2/WC/2F/SD9/LIFT LOBBY"
					-- 5:2-10 HMS-S/D/M/SA "C/L2/WC/2F/MCP10/FIRE SHAFT L.L."
					-- 5:2-11 HTRI-R "C/L2/WC/2F/CM11/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:2-12 HTRI-S "C/L2/WC/2F/MM12/FIRE SHAFT L.L."
					-- 5:2-13 HTRI-R "C/L2/WC/2F/CM13/DR RELSE NR 3TO4"
					-- Switch ""
					-- Relay
					-- 5:2-14 HFP-11 "C/L2/WC/2F/SD14/CORR NR CC 2082"
					-- 5:2-15 HFP-11 "C/L2/WC/2F/SD15/AHU RM SD W/C"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:2 DLC "DLC @ address 2 L2"

```
| | | | | -- 5:2-16 HTRI-R "C/L2/WC/2F/CM16/AHU RM CM W/C"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:2-17 HFP-11 "C/L2/WC/2F/SD17/CORR NR CW 2230"
| | | | | -- 5:2-18 HFP-11 "C/L2/WC/2F/SD18/CORR NR CW 2230"
| | | | | -- 5:2-19 HFP-11 "C/L2/WC/2F/SD19/CORR NR CW 2210"
| | | | | -- 5:2-20 HFP-11 "C/L2/WC/2F/SD20/CORR NR CW 2200"
| | | | | -- 5:2-21 HFP-11 "C/L2/WC/2F/SD21/CORR NR CW 2200"
| | | | | -- 5:2-22 HTRI-R "C/L2/WC/2F/CM22/FIRE ESCAPE STR"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:2-23 HMS-S/D/M/SA "C/L2/WC/2F/MCP23/FIRE ESCAPE STR"
| | | | | -- 5:2-24 HFP-11 "C/L2/WC/2F/SD24/CORR NR CW 2070"
| | | | | -- 5:2-25 HFP-11 " C/L2/WC/1F/SD25/CORR NR CW 1050"
| | | | | -- 5:2-26 HFP-11 "C/L2/WC/1F/SD26/CORR NR CW1/S11"
| | | | | -- 5:2-27 HFP-11 "C/L2/WC/1F/SD27/CORR NR CW1/S13"
| | | | | -- 5:2-28 HFP-11 "C/L2/WC/1F/SD28/CORR NR E.R."
| | | | | -- 5:2-29 HFP-11 "C/L2/WC/1F/SD29/CORR NR E.R."
| | | | | -- 5:2-30 HFP-11 "C/L2/WC/1F/SD30/ELECT RM SD"
| | | | | -- 5:2-31 HTRI-R "C/L2/WC/1F/CM31/DR R CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:2-32 HFP-11 "C/L2/WC/1F/SD32/LIFT LOBBY"
| | | | | -- 5:2-33 HFP-11 "C/L2/WC/1F/SD33/LIFT LOBBY"
| | | | | -- 5:2-34 HMS-S/D/M/SA "C/L2/WC/1F/MCP34/FIRE SHAFT L.L."
| | | | | -- 5:2-35 HTRI-R "C/L2/WC/1F/CM35/FIRE SHAFT L.L."
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:2-36 HTRI-S "C/L2/WC/1F/MM36/FIRE SHAFT L.L."
| | | | | -- 5:2-37 HTRI-R "C/L2/WC/1F/CM37/DR R CM NR 3 TO "
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:2-38 HFP-11 "C/L2/WC/1F/SD38/CORR NR CW1/S20"
| | | | | -- 5:2-39 HFP-11 "C/L2/WC/1F/SD39/CORR NR CW1/S20"
| | | | | -- 5:2-40 HFP-11 "C/L2/WC/1F/SD40/CORR NR CW1250"
| | | | | -- 5:2-41 HFP-11 "C/L2/WC/1F/SD41/CORR NR CW 1250"
| | | | | -- 5:2-42 HFP-11 "C/L2/WC/1F/SD42/AHU RM SD"
| | | | | -- 5:2-43 HTRI-R "C/L2/WC/1F/CM43/AHU RM CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:2-44 HFP-11 "C/L2/WC/1F/SD44/CORR NR CW 1210"
| | | | | -- 5:2-45 HFP-11 "C/L2/WC/1F/SD45/CORR NR CW 1140"
| | | | | -- 5:2-46 HFP-11 "C/L2/WC/1F/SD46/CORR NR CW 1200"
| | | | | -- 5:2-47 HFP-11 "C/L2/CW 1140/SD47/Main cab"
| | | | | -- 5:2-48 HFP-11 "C/L2/CW 1140/SD48/Cab 1"
| | | | | -- 5:2-49 HFP-11 "C/L2/CW 1140/SD49/Cab 2"
| | | | | -- 5:2-50 HFP-11 "C/L2/CW 1140/SD50/Psg nr cab 2"
| | | | | -- 5:2-51 HFP-11 "C/L2/CW 1140/SD51/Pantry"
| | | | | -- 5:2-52 HMS-S/D/M/SA "C/L2/CW 1140/MCP52/Psg nr Entry "
| | | | | -- 5:2-53 HTRI-R "C/L2/CW 1140/CM53/Psg nr Entry D"
```


5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:2 DLC "DLC @ address 2 L2"

					-- 5:2-110	HTRI-S	"C/L2/2F/MM110/CW2230"
					-- 5:2-111	HTRI-S	"C/L2/2F/MM111/CW2010"
					-- 5:2-113	HTRI-S	"C/L2/2F/MM113/CW2220"
					-- 5:2-116	HTRI-S	"C/L2/2F/MM116/CW2040"
					-- 5:2-119	HTRI-S	"C/L2/2F/MM119/CW2060"
					-- 5:2-128	HFP-11	"C/L2/BW2110/SD128/Pantry"
					-- 5:2-129	HFP-11	"C/L2/BW2110/SD129/Assorter cabin"
					-- 5:2-130	HFP-11	"C/L2/BW2110/SD130/Main cabin"
					-- 5:2-131	HFP-11	"C/L2/BW2110/SD131/Psg near Assor"
					-- 5:2-132	HTRI-R	"C/L2/BW2110/CM132/Entry Door"
					--	Switch	" "
					--	Relay	
					-- 5:2-133	HMS-S/D/M/SA	"C/L2/BW2110/MCP133/Entry Door"
					-- 5:2-142	HFP-11	"C/L2/BW2101/SD142/Pantry"
					-- 5:2-143	HFP-11	"C/L2/BW2101/SD143/Assorter cabin"
					-- 5:2-144	HFP-11	"C/L2/BW2101/SD144/Main cabin"
					-- 5:2-145	HFP-11	"C/L2/BW2101/SD145/Main cabin"
					-- 5:2-146	HFP-11	"C/L2/BW2101/SD146/Main cabin"
					-- 5:2-147	HMS-S/D/M/SA	"C/L2/BW2101/MCP147/Entry Door"
					-- 5:2-148	HTRI-R	"C/L2/BW2101/CM148/Entry Door"
					--	Switch	" "
					--	Relay	
					-- 5:2-149	HFP-11	"C/L2/BW2101/SD149/Accounts cabin"
					-- 5:2-150	HFP-11	"C/L2/BW2101/SD150/Psg near Entry"
					-- 5:2-151	HFP-11	"C/L2/CW 2210/SD151/Main Cabin"
					-- 5:2-152	HFPT-11	"C/L2/CW 2210/HD152/Pantry"
					-- 5:2-153	HFP-11	"C/L2/CW 2210/SD153/Reception Are"
					-- 5:2-154	HTRI-R	"C/L2/CW 2210/CM154/Main Entry"
					--	Switch	" "
					--	Relay	
					-- 5:2-155	HMS-S/D/M/SA	"C/L2/CW 2210/MCP155/Main Entry"
					-- 5:2-156	HFP-11	"C/L2/CW2020/SD156/Pantry"
					-- 5:2-157	HFP-11	"C/L2/CW2020/SD157/Psg nr Assorte"
					-- 5:2-158	HFP-11	"C/L2/CW2020/SD158/Assorter cab"
					-- 5:2-159	HFP-11	"C/L2/CW2020/SD159/Main cab"
					-- 5:2-160	HTRI-R	"C/L2/CW2020/CM160/Psg nr Entry D"
					--	Switch	" "
					--	Relay	
					-- 5:2-161	HMS-S/D/M/SA	"C/L2/CW2020/MCP161/Psg nr Entry "
					-- 5:2-162	HFP-11	"C/L2/CW2080/SD162/Pantry"
					-- 5:2-163	HFP-11	"C/L2/CW2080/SD163/Psg nr Pantry"
					-- 5:2-164	HFP-11	"C/L2/CW2080/SD164/Main cab"
					-- 5:2-165	HFP-11	"C/L2/CW2080/SD165/Assorter cab"
					-- 5:2-166	HFP-11	"C/L2/CW2080/SD166/Accounts cab"
					-- 5:2-167	HTRI-R	"C/L2/CW2080/CM167/Psg nr Entry D"
					--	Switch	" "
					--	Relay	
					-- 5:2-168	HMS-S/D/M/SA	"C/L2/CW2080/MCP168/Psg nr Entry "
					-- 5:2-169	HFP-11	"C/L2/CW1050/SD169/Pantry"
					-- 5:2-170	HFP-11	"C/L2/CW1050/SD170/Cab 1"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:2 DLC "DLC @ address 2 L2"

```
| | | | |-- 5:2-171 HFP-11 "C/L2/CW1050/SD171/Cab 2"
| | | | |-- 5:2-172 HTRI-R "C/L2/CW1050/CM172/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:2-173 HMS-S/D/M/SA "C/L2/CW1050/MCP173/Psg nr Entry "
| | | | |-- 5:2-174 HFP-11 "C/L2/CW1170/SD174/Pantry"
| | | | |-- 5:2-175 HFP-11 "C/L2/CW1170/SD175/Account cab"
| | | | |-- 5:2-176 HFP-11 "C/L2/CW1170/SD176/Psg Nr Accnt c"
| | | | |-- 5:2-177 HFP-11 "C/L2/CW1170/SD177/MD Cab"
| | | | |-- 5:2-178 HFP-11 "C/L2/CW1170/SD178/Psg nr Assorte"
| | | | |-- 5:2-179 HTRI-R "C/L2/CW1170/CM179/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:2-180 HMS-S/D/M/SA "C/L2/CW1170/MCP180/Psg nr Entry "
| | | | |-- 5:2-181 HFP-11 "C/L2/CW1040/SD181/Main Cab"
| | | | |-- 5:2-182 HFP-11 "C/L2/CW1040/SD182/Cab 1"
| | | | |-- 5:2-184 HTRI-R "C/L2/CW1040/CM184/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:2-185 HMS-S/D/M/SA "C/L2/CW1040/MCP185/Psg nr Entry "
| | | | |-- 5:2-186 HFP-11 "C/L2/CW1180/SD186/Pantry"
| | | | |-- 5:2-187 HFP-11 "C/L2/CW1180/SD187/Assorter cab"
| | | | |-- 5:2-188 HFP-11 "C/L2/CW1180/SD188/Main cab"
| | | | |-- 5:2-189 HFP-11 "C/L2/CW1180/SD189/Accounts cab"
| | | | |-- 5:2-190 HTRI-R "C/L2/CW1180/CM190/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:2-191 HMS-S/D/M/SA "C/L2/CW1180/MCP191/Psg nr Entry "
| | | | |-- 5:2-193 HFPT-11 "C/L2/CW2030/HD193/Pantry"
| | | | |-- 5:2-194 HFP-11 "C/L2/CW2030/SD194/Psg nr Main ca"
| | | | |-- 5:2-195 HFP-11 "C/L2/CW2030/SD195/Main cab"
| | | | |-- 5:2-196 HFP-11 "C/L2/CW2030/SD196/Psg nr Entry D"
| | | | |-- 5:2-197 HTRI-R "C/L2/CW2030/CM197/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:2-198 HMS-S/D/M/SA "C/L2/CW2030/MCP198/Psg nr Entry "
| | | | |-- 5:2-199 HFP-11 "C/L2/CW1060/SD199/Pantry"
| | | | |-- 5:2-200 HFP-11 "C/L2/CW1060/SD200/Cab 2"
| | | | |-- 5:2-201 HFP-11 "C/L2/CW1060/SD201/Cab 1"
| | | | |-- 5:2-202 HFP-11 "C/L2/CW1060/SD202/Director cab"
| | | | |-- 5:2-203 HFP-11 "C/L2/CW1060/SD203/Psg nr Directo"
| | | | |-- 5:2-204 HTRI-R "C/L2/CW1060/CM204/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:2-205 HTRI-R "C/L2/CW1120/CM205/Psg nr Entry "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:2-206 HFP-11 "C/L2/CW1120/SD206/ASSORTER CAB"
| | | | |-- 5:2-207 HFP-11 "C/L2/CW1120/SD207/Buyers cab"
| | | | |-- 5:2-208 HFPT-11 "C/L2/CW1120/HD208/PANTRY"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:2 DLC "DLC @ address 2 L2"

					-- 5:2-209 HFP-11 "C/L2/CW1120/SD209/Main cab"
					-- 5:2-210 HFP-11 "C/L2/CW1120/SD210/Psg nr Assorte"
					-- 5:2-211 HFP-11 "C/L2/CW1120/SD211/Psg nr ent"
					-- 5:2-212 HMS-S/D/M/SA "C/L2/CW1120/MCP212/Psg nr entry"
					-- 5:2-213 HFP-11 "C/L2/CW1230/SD213/Main Cab"
					-- 5:2-214 HFP-11 "C/L2/CW1230/SD214/Assort Cab"
					-- 5:2-216 HFPT-11 "C/L2/CW1230/HD216/Entry Psg "
					-- 5:2-217 HTRI-R "C/L2/CW1230/CM217/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 5:2-218 HMS-S/D/M/SA "C/L2/CW1230/MCP218/Psg nr Entry "
					-- 5:2-219 HFP-11 "C/L2/CW 1210/SD219/Main cab"
					-- 5:2-220 HFP-11 "C/L2/CW 1210/SD220/Cab 1"
					-- 5:2-221 HFP-11 "C/L2/CW 1210/SD221/Cab 1"
					-- 5:2-222 HFP-11 "C/L2/CW 1210/SD222/Cab 1"
					-- 5:2-223 HFP-11 "C/L2/CW1220/SD223/Psg nr Entry"
					-- 5:2-224 HFP-11 "C/L2/CW1220/SD224/Cab 1"
					-- 5:2-225 FDOT421 "C/L2/CW1220/SD225/Cab 2"
					-- 5:2-226 HFP-11 "C/L2/CW1220/SD226/Cab 3"
					-- 5:2-227 HFP-11 "C/L2/CW1220/SD227/Pantry"
					-- 5:2-228 HTRI-R "C/L2/CW1220/CM228/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 5:2-229 HMS-S/D/M/SA "C/L2/CW1220/MCP229/Psg nr Entry "
					-- 5:2-230 HFP-11 "C/L2/CW1070/SD230/Main Cab 1"
					-- 5:2-233 HFP-11 "C/L2/CW1070/SD233/Main Cab2"
					-- 5:2-234 HFP-11 "C/L2/CW1070/SD234/PANTRY"
					-- 5:2-235 HTRI-R "C/L2/CW1070/CM235/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 5:2-236 HMS-S/D/M/SA "C/L2/CW1070/MCP236/Psg nr Entry "
					-- 5:2-237 HFP-11 "C/L2/CW 2190/SD237/Pantry"
					-- 5:2-238 HFP-11 "C/L2/CW 2190/SD238/Assort cab"
					-- 5:2-239 HFP-11 "C/L2/CW 2190/SD239/Main cab"
					-- 5:2-241 HTRI-R "C/L2/CW 2190/CM241/Psg nr Entry "
					-- Switch ""
					-- Relay
					-- 5:2-242 HMS-S/D/M/SA "C/L2/CW 2190/MCP242/Psg nr Entry"
					-- 5:2-243 HFP-11 "C/L2/CW1080/SD243/Pantry"
					-- 5:2-244 HFP-11 "C/L2/CW1080/SD244/Account cab"
					-- 5:2-245 HFP-11 "C/L2/CW1080/SD245/Assorter cab"
					-- 5:2-246 HFP-11 "C/L2/CW1080/SD246/Main cab"
					-- 5:2-247 HFP-11 "C/L2/CW1080/SD247/Psg nr Account"
					-- 5:2-248 HTRI-R "C/L2/CW1080/CM248/Psg nr Entry d"
					-- Switch ""
					-- Relay
					-- 5:2-249 HMS-S/D/M/SA "C/L2/CW1080/MCP249/Psg nr Entry "
					-- 5:2-251 HTRI-S "C/L2/1F/MM251/CW1110"
					-- 5:2-252 HTRI-S "C/L2/1F/MM252/CW1100"
					-- 5:3 DLC "DLC @ address 3 L3"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:3 DLC "DLC @ address 3 L3"

```
| | | | | -- 5:3-1 HTRI-R "C/L3/CC/3F/CM1/DR RELESE CW3/S22"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:3-2 HFP-11 "C/L3/CC/3F/SD2/CORR NR CW3/S22"
| | | | | -- 5:3-3 HFP-11 "C/L3/CC/3F/SD3/CORR NR CW3/S22"
| | | | | -- 5:3-4 HFP-11 "C/L3/CC/3F/SD4/CORR NR CC 3090"
| | | | | -- 5:3-5 HFP-11 "C/L3/CC/3F/SD5/CORR NR CC3081"
| | | | | -- 5:3-6 HFP-11 "C/L3/CC/3F/SD6/CORR NR CC 3070"
| | | | | -- 5:3-7 HFP-11 "C/L3/CC/3F/SD7/CORR NR CC 3070"
| | | | | -- 5:3-8 HMS-S/D/M/SA "C/L3/CC/3F/MCP8/FIRE ESC C TO W"
| | | | | -- 5:3-9 HTRI-R "C/L3/CC/3F/CM9/FIRE ESC C TO W"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:3-10 HFP-11 "C/L3/CC/3F/SD10/CORR NR CC 3122"
| | | | | -- 5:3-11 HFP-11 "C/L3/CC/3F/SD11/CORR NR CC3/S08"
| | | | | -- 5:3-12 HFP-11 "C/L3/CC/3F/SD12/CORR NR CC 3040"
| | | | | -- 5:3-13 HFP-11 "C/L3/CC/3F/SD13/CORR NR CC 3020"
| | | | | -- 5:3-14 HFP-11 "C/L3/CC/3F/SD14/CORR NR CC 3020"
| | | | | -- 5:3-15 HFP-11 "C/L3/CC/3F/SD15/CORR NR CC 3171"
| | | | | -- 5:3-16 HFP-11 "C/L3/CC/3F/SD16/CORR NR CC 3171"
| | | | | -- 5:3-17 HTRI-R "C/L3/CC/3F/CM17/FIRE SHAFT L.L."
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:3-18 HTRI-S "C/L3/CC/3F/MM18/FIRE SHAFT L.L."
| | | | | -- 5:3-19 HMS-S/D/M/SA "C/L3/CC/3F/MCP19/FIRE SHAFT L.L."
| | | | | -- 5:3-20 HFP-11 "C/L3/CC/3F/SD20/LIFT LOBBY SD"
| | | | | -- 5:3-21 HFP-11 "C/L3/CC/3F/SD21/LIFT LOBBY SD"
| | | | | -- 5:3-22 HTRI-R "C/L3/CC/3F/CM22/DR RELESE C TO E"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:3-23 HFP-11 "C/L3/CC/3F/SD23/AHU RM"
| | | | | -- 5:3-24 HTRI-R "C/L3/CC/3F/CM24/AHU RM CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:3-25 HFP-11 "C/L3/CC/3F/SD25/CORR NR CC 3260"
| | | | | -- 5:3-26 HFP-11 "C/L3/CC/3F/SD26/CORR NR CC 3260"
| | | | | -- 5:3-27 HFP-11 "C/L3/CC/3F/SD27/CORR NR CC 3240"
| | | | | -- 5:3-28 HFP-11 "C/L3/CC/3F/SD28/CORR NR CC3/S04"
| | | | | -- 5:3-29 HFP-11 "C/L3/CC/3F/SD29/CORR NR CC 3220"
| | | | | -- 5:3-30 HMS-S/D/M/SA "C/L3/CC/3F/MCP30/FIRE ESC C TO E"
| | | | | -- 5:3-31 HTRI-R "C/L3/CC/3F/CM31/FIRE ESC C TO E"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:3-32 HFP-11 "C/L3/CC/3F/SD32/CORR NR CC 3211"
| | | | | -- 5:3-33 HFP-11 "C/L3/CC/3F/SD33/CORR NR CC 3012"
| | | | | -- 5:3-34 FDOT421 "C/L3/EC/3F/SD34/Corr Nr CE3011"
| | | | | -- 5:3-35 HFP-11 "C/L3/EC/3F/SD35/LIFT LOBBY"
| | | | | -- 5:3-36 HMS-S/D/M/SA "C/L3/EC/3F/MCP36/FIRE SHAFT L.L."
| | | | | -- 5:3-37 HTRI-R "C/L3/EC/3F/CM37/FIRE SHAFT L.L."
| | | | | | -- Switch ""
```



```

5 Desigo Fire Safety Modular "BDB TOWER C" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      5:3 DLC "DLC @ address 3 L3"
        5:3-37 HTRI-R "C/L3/EC/3F/CM37/FIRE SHAFT L.L."

```

```

5 Desigo Fire Safety Modular "BDB TOWER C" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      5:3 DLC "DLC @ address 3 L3"
        5:3-76 HTRI-R "C/L3/C/1F/CM76/FIRE ESC STR"

```

5 Desigo Fire Safety Modular "BDB TOWER C" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
5:3 DLC "DLC @ address 3 L3"

					-- 5:3-115 HFP-11 "C/L3/E/1F/SD115/AHU RM SD "
					-- 5:3-116 HTRI-R "C/L3/E/1F/CM116/AHU RM CM "
					-- Switch ""
					-- Relay
					-- 5:3-117 HTRI-R "C/L3/C/3F/CM117/DR RELSE "
					-- Switch ""
					-- Relay
					-- 5:3-118 HFP-11 "C/L3/C/2F/SD118/AHU RM SD"
					-- 5:3-119 HTRI-R "C/L3/2F/CM119/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 5:3-120 HTRI-R "C/L3/1F/CM120/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 5:3-121 HTRI-S "C/L3/2F/MM121/CC2201"
					-- 5:3-122 HTRI-S "C/L3/2F/MM122/CC2022"
					-- 5:3-123 HTRI-S "C/L3/2F/MM123/CC2021"
					-- 5:3-124 HTRI-S "C/L3/2F/MM124/CC2170"
					-- 5:3-125 HTRI-S "C/L3/2F/MM125/CC2010"
					-- 5:3-126 FDOT421 "C/L3/EC/SD126/Conv Hall Server "
					-- 5:3-127 FDOT421 "C/L3/EC/SD127/Conv Hall Psg Nr "
					-- 5:3-128 FDOT421 "C/L3/EC/SD128/Conv Hall DE side"
					-- 5:3-129 HTRI-S "C/L3/2F/MM129/CC2160"
					-- 5:3-130 HTRI-S "C/L3/2F/MM130/CC2203"
					-- 5:3-132 HTRI-S "C/L3/3F/MM132/CE3011"
					-- 5:3-133 HTRI-S "C/L3/3F/MM133/CC3012"
					-- 5:3-134 HTRI-S "C/L3/3F/MM134/CC3211/12"
					-- 5:3-135 FDOT421 "C/L3/EC/SD135/Conv Hall DE side"
					-- 5:3-137 HTRI-S "C/L3/3F/MM137/CC3220"
					-- 5:3-138 FDOT421 "C/L3/EC/SD138/Conv Hall DE side"
					-- 5:3-139 FDOT421 "C/L3/EC/SD139/Conv Hall Electri"
					-- 5:3-140 FDOT421 "C/L3/EC/SD140/Conv Hall Psg Nr "
					-- 5:3-141 FDOT421 "C/L3/EC/SD141/Conv Hall DE Side"
					-- 5:3-142 FDOT421 "C/L3/EC/SD142/Conv Hall DE Side"
					-- 5:3-143 HTRI-S "C/L3/3F/MM143/CC3181"
					-- 5:3-144 HTRI-S "C/L3/3F/MM144/CC3260"
					-- 5:3-145 HTRI-S "C/L3/3F/MM145/CC3172"
					-- 5:3-146 HTRI-S "C/L3/3F/MM146/CC3171"
					-- 5:3-147 HTRI-S "C/L3/3F/MM147/CC3010"
					-- 5:3-148 FDOT421 "C/L3/EC/SD148/Conv Hall Mn Ent "
					-- 5:3-149 FDOT421 "C/L3/EC/SD149/Conv Hall Mid Psg"
					-- 5:3-151 HTRI-S "C/L3/3F/MM151/CC3140"
					-- 5:3-152 HTRI-S "C/L3/3F/MM152/CC3031"
					-- 5:3-154 HTRI-S "C/L3/3F/MM154/CC3090"
					-- 5:3-155 HTRI-S "C/L3/3F/MM155/CC3132"
					-- 5:3-159 FDOT421 "C/L3/EC/SD159/Conv Hall Mid PSG"
					-- 5:3-161 FDOT421 "C/L3/EC/SD161/Conv Hall Mid Psg"
					-- 5:3-162 HTRI-S "C/L3/3F/MM162/CC3081"
					-- 5:3-164 FDOT421 "C/L3/EC/SD164/Conv Hall CE Side"
					-- 5:3-165 HTRI-S "C/L3/3F/MM165/CC3050"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:3 DLC "DLC @ address 3 L3"

					-- 5:3-166	FDOT421	"C/L3/EC/SD166/Conv Hall CE Side"
					-- 5:3-167	HTRI-S	"C/L3/1F/MM167/CC1231"
					-- 5:3-168	FDOT421	"C/L3/EC/SD168/Conv Hall CE Side"
					-- 5:3-169	HTRI-S	"C/L3/1F/MM169/CC1220"
					-- 5:3-170	HTRI-S	"C/L3/1F/MM170/CC1210"
					-- 5:3-171	FDOT421	"C/L3/EC/SD171/Conv Hall CE Side"
					-- 5:3-172	HTRI-S	"C/L3/1F/MM172/CC1200"
					-- 5:3-173	HTRI-S	"C/L3/1F/MM173/CC1190"
					-- 5:3-174	HTRI-S	"C/L3/1F/MM174/CC1030"
					-- 5:3-175	FDOT421	"C/L3/EC/SD175/Conv Hall Cafeter"
					-- 5:3-176	HTRI-S	"C/L3/1F/MM176/CC1050"
					-- 5:3-177	FDOT421	"C/L3/EC/SD177/Conv Hall Cafeter"
					-- 5:3-178	HTRI-S	"C/L3/1F/MM178/CC1060"
					-- 5:3-180	FDOT421	"C/L3/EC/SD177/Conv Hall Cafeter"
					-- 5:3-181	HTRI-S	"C/L3/1F/MM181/CC1080"
					-- 5:3-182	HMS-S/D/M/SA	"C/L3/EC/MCP182/Conv Hall Cafete"
					-- 5:3-183	HMS-S/D/M/SA	"C/L3/EC/MCP183/Conv Hall Psg Nr"
					-- 5:3-184	HTRI-S	"C/L3/1F/MM184/CC1150"
					-- 5:3-185	HMS-S/D/M/SA	"C/L3/EC/MCP185/Conv Hall Psg Nr"
					-- 5:3-186	HMS-S/D/M/SA	"C/L3/EC/MCP186/Conv Hall Psg Nr"
					-- 5:3-187	HTRI-R	"C/L3/EC/CM187/Conv Hall Cafe AF"
					--	Switch	" "
					--	Relay	" "
					-- 5:3-189	HTRI-S	"C/L3/1F/MM189/CC1120"
					-- 5:3-190	HTRI-S	"C/L3/1F/MM190/CE1130"
					-- 5:3-191	HTRI-S	"C/L3/1F/MM191/CE1140"
					-- 5:3-192	HTRI-S	"C/L3/1F/MM192/CE1150"
					-- 5:3-193	HTRI-S	"C/L3/1F/MM193/CE1010"
					-- 5:3-194	HTRI-S	"C/L3/2F/MM194/CE2020"
					-- 5:3-195	HTRI-S	"C/L3/2F/MM195/CE2010"
					-- 5:3-196	HTRI-S	"C/L3/2F/MM196/CC2070A"
					-- 5:3-198	HTRI-S	"C/L3/2F/MM198/CC2081"
					-- 5:3-200	HTRI-S	"C/L3/2F/MM200/CC2062"
					-- 5:3-204	HTRI-S	"C/L3/2F/MM204/CC2100"
					-- 5:3-205	HTRI-S	"C/L3/2F/MM205/CC2110"
					-- 5:3-207	HTRI-S	"C/L3/2F/MM207/CC2120"
					-- 5:3-208	HTRI-S	"C/L3/2F/MM208/CC2130"
					-- 5:3-209	HTRI-S	"C/L3/2F/MM209/CC2040"
					-- 5:3-212	HTRI-S	"C/L3/2F/MM212/CC2150"
					-- 5:3-214	HFP-11	"C/L3/CC2091/SD214/Reception"
					-- 5:3-215	HFP-11	"C/L3/CC2091/SD215/Pantry"
					-- 5:3-216	HFP-11	"C/L3/CC2091/SD216/Accounts Cabin"
					-- 5:3-217	HFP-11	"C/L3/CC2091/SD217/Accounts Lobby"
					-- 5:3-218	HFP-11	"C/L3/CC2091/SD218/Passage Area "
					-- 5:3-219	HFP-11	"C/L3/CC2091/SD219/Stock Room"
					-- 5:3-220	HFP-11	"C/L3/CC2091/SD220/Marketing cabi"
					-- 5:3-221	HFP-11	"C/L3/CC2091/SD221/Marketing Cabi"
					-- 5:3-222	HFP-11	"C/L3/CC2091/SD222/Main cabin"
					-- 5:3-223	HFP-11	"C/L3/CC2091/SD223/Main Cabin"
					-- 5:3-224	HFP-11	"C/L3/CC2091/SD224/Backside Lobby"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:3 DLC "DLC @ address 3 L3"

					-- 5:3-225 HFP-11 "C/L3/CC2091/SD225/Buyer 1 Area"
					-- 5:3-226 HFP-11 "C/L3/CC2091/SD226/Buyer 2 Area"
					-- 5:3-227 HFP-11 "C/L3/CC2091/SD227/Hitesh Cabin"
					-- 5:3-228 HFP-11 "C/L3/CC2091/SD228/Stock Room"
					-- 5:3-229 HTRI-R "C/L3/CC2091/CM229/Entry Door"
					-- Switch ""
					-- Relay
					-- 5:3-230 HMS-S/D/M/SA "C/L3/CC2091/MCP230/Entry Door"
					-- 5:3-231 HFP-11 "C/L3/CC1130/SD231/Assorter Cab"
					-- 5:3-232 HFP-11 "C/L3/CC1130/SD232/Assorter Cab"
					-- 5:3-233 HFP-11 "C/L3/CC1130/SD233/Entry Psg"
					-- 5:3-234 HTRI-R "C/L3/CC1130/CM234/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 5:3-235 HMS-S/D/M/SA "C/L3/CC1130/MCP235/Psg nr Entry "
					-- 5:3-236 HFP-11 "C/L3/CC1240/SD236/Main Cab"
					-- 5:3-237 HFP-11 "C/L3/CC1240/SD237/Cab 1"
					-- 5:3-238 HFP-11 "C/L3/CC1240/SD238/Entry Psg"
					-- 5:3-239 HFP-11 "C/L3/CC1240/SD239/Pantry"
					-- 5:3-241 HTRI-R "C/L3/CC1240/CM241/Psg nr ent"
					-- Switch ""
					-- Relay
					-- 5:3-242 HMS-S/D/M/SA "C/L3/CC1240/MCP242/Psg nr ent"
					-- 5:3-243 HFP-11 "C/L3/CC3060/SD243/Pantry"
					-- 5:3-244 HFP-11 "C/L3/CC3060/SD244/Cabin 2"
					-- 5:3-245 HFP-11 "C/L3/CC3060/SD245/Cabin 1"
					-- 5:3-246 HFP-11 "C/L3/CC3060/SD246/Assorter Cabin"
					-- 5:3-247 HFP-11 "C/L3/CC3060/SD247/Main Cab"
					-- 5:3-248 HFP-11 "C/L3/CC3060/SD248/Psg nr Pantry"
					-- 5:3-249 HTRI-R "C/L3/CC3060/CM249/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 5:3-250 HMS-S/D/M/SA "C/L3/CC3060/MCP250/Psg nr Entry "
					-- 5:4 DLC "DLC @ address 4 L4"
					-- 5:4-1 HTRI-R "C/L4/CC/5F/CM1/DR RELSE CM"
					-- Switch ""
					-- Relay
					-- 5:4-2 FDOT421 "C/L4/CC/5F/SD2/CORR NR CW5/S22"
					-- 5:4-3 HFP-11 "C/L4/CC/5F/SD3/CORR NR CW5/S22"
					-- 5:4-4 HMS-S/D/M/SA "C/L4/CC/5F/MCP4/FIRE ESC STR "
					-- 5:4-5 FDOT421 "C/L4/CC/5F/SD5/CORR NR CC 5042"
					-- 5:4-6 HFP-11 "C/L4/CC/5F/SD6/CORR NR CC 5041"
					-- 5:4-7 HFP-11 "C/L4/CC/5F/SD7/CORR NR CW5/S23"
					-- 5:4-8 HFP-11 "C/L4/CC/5F/SD8/CORR NR CC 5030"
					-- 5:4-9 FDOT421 "C/L4/CC/5F/SD9/CORR NR CC 5062"
					-- 5:4-10 FDOT421 "C/L4/CC/5F/SD10/CORR NR CC 5020"
					-- 5:4-11 HFP-11 "C/L4/CC/5F/SD11/CORR NR CC 5011"
					-- 5:4-12 HFP-11 "C/L4/CC/5F/SD12/CORR NR CC 5011"
					-- 5:4-13 HFP-11 "C/L4/CC/5F/SD13/CORR NR CC 5074"
					-- 5:4-14 HFP-11 "C/L4/CC/5F/SD14/CORR NR ELECT RM"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:4 DLC "DLC @ address 4 L4"

```
| | | | | -- 5:4-15 HTRI-R "C/L4/CC/5F/CM15/FIRE ESC STR "
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-16 HTRI-R "C/L4/CC/5F/CM16/DR RELSE CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-17 HFP-11 "C/L4/CC/5F/SD17/ELECT RM SD"
| | | | | -- 5:4-18 HFP-11 "C/L4/SD18/CC 5F LIFT LOBBY"
| | | | | -- 5:4-19 HFP-11 "C/L4/SD19/CC 5F LIFT LOBBY"
| | | | | -- 5:4-20 HTRI-R "C/L4/CC/5F/CM20/FIRE SHAFT L.L."
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-21 HTRI-S "C/L4/CC/5F/MM21/FIRE SHAFT L.L."
| | | | | -- 5:4-22 HMS-S/D/M/SA "C/L4/CC/5F/MCP22/FIRE SHAFT L.L."
| | | | | -- 5:4-23 HFP-11 "C/L4/CC/5F/SD23/AHU RM SD"
| | | | | -- 5:4-24 HTRI-R "C/L4/CC/5F/CM24/AHU RM CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-27 HFP-11 "C/L4/EC/5F/SD27/CORR NR CE 5030"
| | | | | -- 5:4-28 HFP-11 "C/L4/EC/5F/SD28/CORR NR CE 5030"
| | | | | -- 5:4-29 HFP-11 "C/L4/EC/5F/SD29/CORR NR CE 5010"
| | | | | -- 5:4-30 HFP-11 "C/L4/EC/5F/SD30/CORR NR CE 5010"
| | | | | -- 5:4-31 HFP-11 "C/L4/EC/5F/SD31/ELECT RM SD"
| | | | | -- 5:4-32 HFP-11 "C/L4/EC/5F/SD32/AHU RM SD"
| | | | | -- 5:4-33 HTRI-R "C/L4/EC/5F/CM33/AHU RM CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-34 HFP-11 "C/L4/EC/5F/SD34/LIFT LOBBY SD"
| | | | | -- 5:4-35 HMS-S/D/M/SA "C/L4/EC/5F/MCP35/FIRE SHAFT L.L."
| | | | | -- 5:4-36 HTRI-R "C/L4/EC/5F/CM36/FIRE SHAFT L.L."
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-37 HTRI-S "C/L4/EC/5F/MM37/FIRE SHAFT L.L."
| | | | | -- 5:4-38 HTRI-R "C/L4/CC/4F/CM38/DR RELSE CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-39 HFP-11 "C/L4/CC/4F/SD39/CORR NR CW4/S22"
| | | | | -- 5:4-40 HFP-11 "C/L4/CC/4F/SD40/CORR NR CW4/S22"
| | | | | -- 5:4-41 HFP-11 "C/L4/CC/4F/SD41/CORR NR CW4/S09"
| | | | | -- 5:4-42 HFP-11 "C/L4/CC/4F/SD42/CORR NR CC 4060"
| | | | | -- 5:4-43 HFP-11 "C/L4/CC/4F/SD43/CORR NR CC 4060"
| | | | | -- 5:4-44 HMS-S/D/M/SA "C/L4/CC/4F/MCP44/FIRE ESC STR "
| | | | | -- 5:4-45 HTRI-R "C/L4/CC/4F/CM45/FIRE ESC STR "
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-46 HFP-11 "C/L4/CC/4F/SD46/CORR NR CC4/S08"
| | | | | -- 5:4-47 FDOT421 "C/L4/CC/4F/SD47/CORR NR CC 4040"
| | | | | -- 5:4-48 HFP-11 "C/L4/CC/4F/SD48/CORR NR CC 4040"
| | | | | -- 5:4-49 HFP-11 "C/L4/CC/4F/SD49/CORR NR CC 4021"
| | | | | -- 5:4-50 FDOT421 "C/L4/CC/4F/SD50/COR CC4112 AFC"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
5:4 DLC "DLC @ address 4 L4"

					-- 5:4-51 HFP-11 "C/L4/SD51/CC 4F COR NR ELECT RM"
					-- 5:4-52 HTRI-R "C/L4/CC/4F/CM52/DR RELSE NR E.R."
					-- Switch ""
					-- Relay
					-- 5:4-53 FDOT421 "C/L4/CC/4F/SD53/LIFT LOBBY SD"
					-- 5:4-54 HFP-11 "C/L4/CC/4F/SD54/LIFT LOBBY SD"
					-- 5:4-55 HMS-S/D/M/SA "C/L4/CC/4F/MCP55/FIRE SHAFT L.L."
					-- 5:4-56 HTRI-R "C/L4/CC/4F/CM56/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:4-57 HTRI-S "C/L4/CC/4F/MM57/FIRE SHAFT L.L."
					-- 5:4-58 FDOT421 "C/L4/CC/4F/SD58/ELECT RM SD"
					-- 5:4-59 HFP-11 "C/L4/CC/4F/SD59/AHU RM SD"
					-- 5:4-60 HTRI-R "C/L4/CC/4F/CM60/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 5:4-61 HFP-11 "C/L4/CC/4F/SD61/CORR NR CC 4170"
					-- 5:4-62 FDOT421 "C/L4/CC/4F/SD62/CORR NR CC 4172"
					-- 5:4-63 FDOT421 "C/L4/CC/4F/SD63/CORR NR CC 4150"
					-- 5:4-64 FDOT421 "C/L4/CC/4F/SD64/COR CC4141 AFC"
					-- 5:4-65 HFP-11 "C/L4/CC/4F/SD65/CORR NR CC 4141"
					-- 5:4-66 HMS-S/D/M/SA "C/L4/CC/4F/MCP66/FIRE ESC STR "
					-- 5:4-67 HTRI-R "C/L4/CC/4F/CM67/FIRE ESC STR "
					-- Switch ""
					-- Relay
					-- 5:4-68 HTRI-R "C/L4/CC/4F/CM68/FIRE ESC STR "
					-- Switch ""
					-- Relay
					-- 5:4-69 HFP-11 "C/L4/EC/4F/SD69/ELECT RM SD"
					-- 5:4-70 HFP-11 "C/L4/EC/4F/SD70/AHU RM SD"
					-- 5:4-71 HTRI-R "C/L4/EC/4F/CM71/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 5:4-72 HFP-11 "C/L4/EC/4F/SD72/LIFT LOBBY SD"
					-- 5:4-73 HMS-S/D/M/SA "C/L4/EC/4F/MCP73/FIRE SHAFT L.L."
					-- 5:4-74 HTRI-R "C/L4/EC/4F/CM74/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:4-75 HTRI-S "C/L4/EC/4F/MM75/FIRE SHAFT L.L."
					-- 5:4-76 HTRI-R "C/L4/EC/5F/CM76/DR RELSE CM"
					-- Switch ""
					-- Relay
					-- 5:4-77 HTRI-S "C/L4/4F/MM77/CC4082"
					-- 5:4-79 HTRI-S "C/L4/4F/MM79/CC4052"
					-- 5:4-80 HTRI-S "C/L4/4F/MM80/CC4090"
					-- 5:4-85 HTRI-S "C/L4/4F/MM85/CC4021"
					-- 5:4-86 HTRI-S "C/L4/4F/MM86/CC4111"
					-- 5:4-87 HTRI-S "C/L4/4F/MM87/CC4010"
					-- 5:4-89 HTRI-S "C/L4/4F/MM89/CC4011"
					-- 5:4-90 HTRI-S "C/L4/4F/MM90/CC4013"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:4 DLC "DLC @ address 4 L4"

```
| | | | |-- 5:4-96 HTRI-S "C/L4/4F/MM96/CC4120"
| | | | |-- 5:4-97 HTRI-S "C/L4/4F/MM97/CC4171"
| | | | |-- 5:4-100 HTRI-S "C/L4/5F/MM100/CC5012"
| | | | |-- 5:4-101 HTRI-S "C/L4/5F/MM101/CE5052"
| | | | |-- 5:4-102 HTRI-S "C/L4/5F/MM102/CE5051"
| | | | |-- 5:4-103 HTRI-S "C/L4/5F/MM103/CE5040"
| | | | |-- 5:4-104 HTRI-S "C/L4/5F/MM104/CE5030"
| | | | |-- 5:4-105 HTRI-S "C/L4/5F/MM105/CE5020"
| | | | |-- 5:4-110 HTRI-S "C/L4/5F/MM110/CC5090"
| | | | |-- 5:4-111 HTRI-S "C/L4/5F/MM111/CC5080"
| | | | |-- 5:4-113 HTRI-S "C/L4/5F/MM113/CC5011"
| | | | |-- 5:4-118 HTRI-S "C/L4/5F/MM118/CC5062"
| | | | |-- 5:4-120 HTRI-S "C/L4/5F/MM120/CC5061B"
| | | | |-- 5:4-122 HTRI-S "C/L4/5F/MM122/CC5061A"
| | | | |-- 5:4-123 HTRI-S "C/L4/5F/MM123/CC5042"
| | | | |-- 5:4-124 HTRI-S "C/L4/5F/MM124/CC5050"
| | | | |-- 5:4-125 HTRI-S "C/L4/5F/MM125/CC5043"
| | | | |-- 5:4-126 HTRI-S "C/L4/4F/MM126/CC4070"
| | | | |-- 5:4-127 HTRI-S "C/L4/4F/MM127/CC4081"
| | | | |-- 5:4-128 HFP-11 "C/L4/CC5030/SD128/Psg nr Entry D"
| | | | |-- 5:4-129 HFP-11 "C/L4/CC5030/SD129/Cab 1"
| | | | |-- 5:4-130 HFP-11 "C/L4/CC5030/SD130/Cab 2"
| | | | |-- 5:4-131 HFP-11 "C/L4/CC5030/SD131/Main Cabin"
| | | | |-- 5:4-132 HTRI-R "C/L4/CC5030/CM132/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:4-133 HMS-S/D/M/SA "C/L4/CC5030/MCP133/Psg nr Entry "
| | | | |-- 5:4-134 HFP-11 "C/L4/CC5020/SD134/Main cab 1"
| | | | |-- 5:4-135 HFP-11 "C/L4/CC5020/SD135/Main cab 2"
| | | | |-- 5:4-136 HFP-11 "C/L4/CC5020/SD136/Accounts cab"
| | | | |-- 5:4-137 HFP-11 "C/L4/CC5020/SD137/Buyers cab"
| | | | |-- 5:4-138 HFP-11 "C/L4/CC5020/SD138/Assorter cab"
| | | | |-- 5:4-139 HFP-11 "C/L4/CC5020/SD139/Psg nr Entry"
| | | | |-- 5:4-140 HFP-11 "C/L4/CC5020/SD140/Pantry"
| | | | |-- 5:4-141 HTRI-R "C/L4/CC5020/CM141/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:4-142 HMS-S/D/M/SA "C/L4/CC5020/MCP142/Psg nr EntryD"
| | | | |-- 5:4-143 HFP-11 "C/L4/CC4040/SD143/Psg nr Entry D"
| | | | |-- 5:4-144 HFP-11 "C/L4/CC4040/SD144/cab 2"
| | | | |-- 5:4-145 HFP-11 "C/L4/CC4040/SD145/Cab 3"
| | | | |-- 5:4-146 HFP-11 "C/L4/CC4040/SD146/Cab 1"
| | | | |-- 5:4-147 HTRI-R "C/L4/CC4040/CM147/Psg nr Entry D"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:4-148 HMS-S/D/M/SA "C/L4/CC4040/MCP148/Psg nr Entry "
| | | | |-- 5:4-149 HFP-11 "C/L4/CC4101/SD149/Pantry"
| | | | |-- 5:4-150 HFP-11 "C/L4/CC4101/SD150/Reception Lobb"
| | | | |-- 5:4-151 HFP-11 "C/L4/CC4101/SD151/Cab 1"
| | | | |-- 5:4-152 HFP-11 "C/L4/CC4101/SD152/Psg nr cab 2"
```


5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:4 DLC "DLC @ address 4 L4"

					-- 5:4-153 HFP-11 "C/L4/CC4101/SD153/cab 2"
					-- 5:4-154 HFP-11 "C/L4/CC4101/SD154/cab 3"
					-- 5:4-155 HFP-11 "C/L4/CC4101/SD155/cab 4"
					-- 5:4-156 HFP-11 "C/L4/CC4101/SD156/cab 5"
					-- 5:4-157 HFP-11 "C/L4/CC4101/SD157/cab 6"
					-- 5:4-158 HFP-11 "C/L4/CC4101/SD158/cab 7"
					-- 5:4-159 HFP-11 "C/L4/CC4101/SD159/cab 8"
					-- 5:4-160 HTRI-R "C/L4/CC4101/CM160/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 5:4-161 HMS-S/D/M/SA "C/L4/CC4101/MCP161/Psg nr Entry "
					-- 5:4-162 HFPT-11 "C/L4/CE5060/HD162/Pantry"
					-- 5:4-163 HFP-11 "C/L4/CE5060/SD163/Main Cab"
					-- 5:4-164 HFP-11 "C/L4/CE5060/SD164/Cab 1"
					-- 5:4-165 HFP-11 "C/L4/CE5060/SD165/Cab 2"
					-- 5:4-166 HFP-11 "C/L4/CE5060/SD166/asst Cab"
					-- 5:4-167 HFP-11 "C/L4/CE5060/SD167/Psg nr Pnty"
					-- 5:4-168 HFP-11 "C/L4/CE5060/SD168/Reception"
					-- 5:4-169 HFP-11 "C/L4/CE5060/SD169/Account cabin"
					-- 5:4-170 HFP-11 "C/L4/CE5060/SD170/Psg nr Cab 1"
					-- 5:4-171 HTRI-R "C/L4/CE5060/CM171/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 5:4-172 HMS-S/D/M/SA "C/L4/CE5060/MCP172/Psg nr Entry "
					-- 5:4-173 HFP-11 "C/L4/CC4030/SD173/Pnty"
					-- 5:4-174 HFP-11 "C/L4/CC4030/SD174/Cab 1"
					-- 5:4-175 HFP-11 "C/L4/CC4030/SD175/Cab 2"
					-- 5:4-176 HTRI-R "C/L4/CC4030/CM176/Psg nr Pnty Dr"
					-- Switch ""
					-- Relay
					-- 5:4-177 HMS-S/D/M/SA "C/L4/CC4030/MCP177/Psg nr Pnty D"
					-- 5:4-185 HFP-11 "C/L4/CC5073/SD185/Main cab"
					-- 5:4-186 HFP-11 "C/L4/CC5073/SD186/Main cab "
					-- 5:4-187 HFP-11 "C/L4/CC5073/SD187/Marketing cab"
					-- 5:4-188 HFP-11 "C/L4/CC5073/SD188/Marketing cab"
					-- 5:4-189 HFP-11 "C/L4/CC5073/SD189/Buyer cab 1"
					-- 5:4-190 HFP-11 "C/L4/CC5073/SD190/Psg Nr Buyer c"
					-- 5:4-191 HFP-11 "C/L4/CC5073/SD191/Buyer cab 2"
					-- 5:4-192 HFP-11 "C/L4/CC5073/SD192/Buyer cab 3"
					-- 5:4-193 HFP-11 "C/L4/CC5073/SD193/asst cab"
					-- 5:4-194 HFPT-11 "C/L4/CC5073/HD194/Psg nr Buyer c"
					-- 5:4-195 HFP-11 "C/L4/CC5073/SD195/Accs cab "
					-- 5:4-196 HFP-11 "C/L4/CC5073/SD196/Tushar Bhai Ca"
					-- 5:4-197 HFP-11 "C/L4/CC5073/SD197/Dilip Bhai Cab"
					-- 5:4-198 HTRI-R "C/L4/CC5073/CM198/Psg nr Ent Dr"
					-- Switch ""
					-- Relay
					-- 5:4-199 HMS-S/D/M/SA "C/L4/CC5071/MCP199/Psg nr Ent Dr"
					-- 5:4-202 HFP-11 "C/L4/CC4051/SD202/Psg nr Ent Dr"
					-- 5:4-203 HFP-11 "C/L4/CC4051/SD203/Cab 1"

5 Desigo Fire Safety Modular "BDB TOWER C" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
5:4 DLC "DLC @ address 4 L4"

					-- 5:4-204 HFP-11 "C/L4/CC4051/SD204/Main cab"
					-- 5:4-205 HFP-11 "C/L4/CC4051/SD205/Cab 2"
					-- 5:4-206 HFP-11 "C/L4/CC4051/SD206/Pnty"
					-- 5:4-207 HTRI-R "C/L4/CC4051/CM207/Psg nr Ent Dr"
					-- Switch ""
					-- Relay
					-- 5:4-208 HMS-S/D/M/SA "C/L4/CC4051/MCP208/Psg nr Ent Dr"
					-- 5:4-209 HFP-11 "C/L4/CC4060/SD209/Cab1"
					-- 5:4-210 HFP-11 "C/L4/CC4060/SD210/Main Cab"
					-- 5:4-211 HFP-11 "C/L4/CC4060/SD211/Psg nr Main ca"
					-- 5:4-213 HTRI-R "C/L4/CC4060/CM213/Psg nr Ent Dr"
					-- Switch ""
					-- Relay
					-- 5:4-214 HMS-S/D/M/SA "C/L4/CC4060/MCP214/Psg nr Ent Dr"
					-- 5:4-215 HFP-11 "C/L4/CE5010/SD215/Psg nr Ent Dr"
					-- 5:4-216 HFPT-11 "C/L4/CE5010/HD216/Pnty"
					-- 5:4-217 FDOT421 "C/L4/CE5010/SD217/asst cab"
					-- 5:4-218 FDOT421 "C/L4/CE5010/SD218/Accs cab"
					-- 5:4-219 HFP-11 "C/L4/CE5010/SD219/Main cab"
					-- 5:4-220 HTRI-R "C/L4/CE5010/CM220/Psg nr Ent Dr"
					-- Switch ""
					-- Relay
					-- 5:4-221 HMS-S/D/M/SA "C/L4/CE5010/MCP221/Psg nr Ent Dr"
					-- 5:4-222 HFP-11 "C/L4/CC4141/SD222/Accounts cab"
					-- 5:4-223 HFP-11 "C/L4/CC4141/SD223/Assorter cab"
					-- 5:4-224 HFP-11 "C/L4/CC4141/SD224/Pantry"
					-- 5:4-225 HFP-11 "C/L4/CC4141/SD225/Psg nr Assorte"
					-- 5:4-226 HFP-11 "C/L4/CC4141/SD226/Main cab"
					-- 5:4-227 HTRI-R "C/L4/CC4141/CM227/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 5:4-228 HMS-S/D/M/SA "C/L4/CC4141/MCP228/Entry dr Psg"
					-- 5:4-229 HFP-11 "C/L4/CC4172/SD229/Main cab 2"
					-- 5:4-230 HFP-11 "C/L4/CC4172/SD230/Main cab 1"
					-- 5:4-231 HFP-11 "C/L4/CC4172/SD231/Account cab"
					-- 5:4-232 HFP-11 "C/L4/CC4172/SD232/Pantry"
					-- 5:4-233 HFP-11 "C/L4/CC4172/SD233/Entry dr Psg"
					-- 5:4-234 HTRI-R "C/L4/CC4172/CM234/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 5:4-235 HMS-S/D/M/SA "C/L4/CC4172/MCP235/Entry dr Psg"
					-- 5:4-236 HFP-11 "C/L4/CC4130/SD236/Conference rm"
					-- 5:4-237 HFP-11 "C/L4/CC4130/SD237/Pantry"
					-- 5:4-238 HFP-11 "C/L4/CC4130/SD238/Accounts cab"
					-- 5:4-239 HFP-11 "C/L4/CC4130/SD239/MIG rm"
					-- 5:4-240 HFP-11 "C/L4/CC4130/SD240/Sales cab"
					-- 5:4-241 HFP-11 "C/L4/CC4130/SD241/Sales cab"
					-- 5:4-242 HFP-11 "C/L4/CC4130/SD242/Assorter cab1"
					-- 5:4-243 HFP-11 "C/L4/CC4130/SD243/Assorter cab2"
					-- 5:4-244 HFP-11 "C/L4/CC4130/SD244/Entry Psg"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:4 DLC "DLC @ address 4 L4"

```
| | | | | -- 5:4-245 HTRI-R "C/L4/CC4130/CM245/Entry Psg"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-246 HMS-S/D/M/SA "C/L4/CC4130/MCP246/Entry Psg"
| | | | | -- 5:4-247 HFP-11 "C/L4/SD247/CC4150/MAIN CABIN"
| | | | | -- 5:4-248 HFP-11 "C/L4/SD248/CC4150/ASSORTOR CAB"
| | | | | -- 5:4-249 HFP-11 "C/L4/SD249/CC4150/ENTRY PSG"
| | | | | -- 5:4-250 HTRI-R "C/L4/CM250/CC4150/ENTRY PSG AFC"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:4-251 HMS-S/D/M/SA "C/L4/CC4150/MCP251/ENTRY PSG"
| | | | -- 5:5 DLC "DLC @ address 5 L5"
| | | | -- 5:5-1 HFP-11 "C/L5/WC/3F/SD1/CORR NR BW 3070"
| | | | -- 5:5-2 HFP-11 "C/L5/WC/3F/SD2/CORR NR BW 3110"
| | | | -- 5:5-3 HFP-11 "C/L5/WC/3F/SD3/CORR NR BW 3110"
| | | | -- 5:5-4 HFP-11 "C/L5/WC/3F/SD4/CORR NR BW 3091"
| | | | -- 5:5-5 HFP-11 "C/L5/WC/3F/SD5/CORR NR BW 3120"
| | | | -- 5:5-6 HFP-11 "C/L5/WC/3F/SD6/CORR NR BW 3101"
| | | | -- 5:5-7 HFP-11 "C/L5/WC/3F/SD7/ELECT RM"
| | | | -- 5:5-8 HTRI-R "C/L5/WC/3F/CM8/DR RELSE CM"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 5:5-9 HFP-11 "C/L5/WC/3F/SD9/LIFT LOBBY "
| | | | -- 5:5-10 HFP-11 "C/L5/WC/3F/SD10/LIFT LOBBY"
| | | | -- 5:5-11 HMS-S/D/M/SA "C/L5/WC/3F/MCP11/FIRE SHAFT L.L."
| | | | -- 5:5-12 HTRI-R "C/L5/WC/3F/CM12/FIRE SHAFT L.L."
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 5:5-13 HTRI-S "C/L5/WC/3F/MM13/FIRE SHAFT L.L."
| | | | -- 5:5-14 HTRI-R "C/L5/WC/3F/CM14/DR RELSE NR 3TO4"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 5:5-15 HFP-11 "C/L5/WC/3F/SD15/CORR NR CW 3200"
| | | | -- 5:5-16 HFP-11 "C/L5/WC/3F/SD16/AHU RM SD W/C"
| | | | -- 5:5-17 HTRI-R "C/L5/WC/3F/CM17/AHU RM SD W/C"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 5:5-18 HFP-11 "C/L5/WC/3F/SD18/CORR NR CW 3010"
| | | | -- 5:5-19 HFP-11 "C/L5/WC/3F/SD19/CORR NR CW 3010"
| | | | -- 5:5-20 HFP-11 "C/L5/WC/3F/SD20/CORR NR CW 3180"
| | | | -- 5:5-21 HFP-11 "C/L5/WC/3F/SD21/CORR NR CW 3050"
| | | | -- 5:5-22 HFP-11 "C/L5/WC/3F/SD22/CORR NR CW 3060"
| | | | -- 5:5-23 HTRI-R "C/L5/WC/3F/CM23/FIRE ESC STR CM"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | -- 5:5-24 HMS-S/D/M/SA "C/L5/WC/3F/MCP24/FIRE ESC STR CM"
| | | | -- 5:5-25 HFP-11 "C/L5/WC/3F/SD25/CORR NR CW 3080"
| | | | -- 5:5-26 HFP-11 "C/L5/WC/4F/SD26/CORR NR BW 4052"
| | | | -- 5:5-27 HFP-11 "C/L5/WC/4F/SD27/CORR NR CW 4/S11"
| | | | -- 5:5-28 HFP-11 "C/L5/WC/4F/SD28/CORR NR CW 4/S11"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:5 DLC "DLC @ address 5 L5"

				--	5:5-29	HFP-11	"C/L5/WC/4F/SD29/CORR NR BW4100"
				--	5:5-30	HFP-11	"C/L5/WC/4F/SD30/CORR NR BW 4030"
				--	5:5-31	HFP-11	"C/L5/WC/4F/SD31/CORR NR BW 4030"
				--	5:5-32	HFP-11	"C/L5/WC/4F/SD32/ELECT RM "
				--	5:5-33	HTRI-R	"C/L5/WC/4F/CM33/DR RELSE CM"
						--	Switch ""
						--	Relay
				--	5:5-34	HFP-11	"C/L5/WC/4F/SD34/LIFT LOBBY"
				--	5:5-35	HFP-11	"C/L5/WC/4F/SD35/LIFT LOBBY"
				--	5:5-36	HMS-S/D/M/SA	"C/L5/WC/4F/MCP36/LIFT LOBBY"
				--	5:5-37	HTRI-R	"C/L5/WC/4F/CM37/FIRE SHAFT L.L."
						--	Switch ""
						--	Relay
				--	5:5-38	HTRI-S	"C/L5/WC/4F/MM38/FIRE SHAFT L.L."
				--	5:5-39	HTRI-R	"C/L5/WC/4F/CM39/DR RELSE NR 3TO4"
						--	Switch ""
						--	Relay
				--	5:5-40	HFP-11	"C/L5/WC/4F/SD40/CORR NR CW 4230"
				--	5:5-41	HFP-11	"C/L5/WC/4F/SD41/CORR NR CW 4250"
				--	5:5-42	HFP-11	"C/L5/WC/4F/SD42/AHU RM"
				--	5:5-43	HTRI-R	"C/L5/WC/4F/CM43/AHU RM "
						--	Switch ""
						--	Relay
				--	5:5-44	HFP-11	"C/L5/WC/4F/SD44/CORR NR CW 4230"
				--	5:5-46	HFP-11	"C/L5/WC/4F/SD46/CORR NR CW 4210"
				--	5:5-47	HFP-11	"C/L5/WC/4F/SD47/CORR NR CW 4060"
				--	5:5-48	HFP-11	"C/L5/WC/4F/SD48/CORR NR CW4/S18"
				--	5:5-49	HFP-11	"C/L5/WC/4F/SD49/CORR NR CW4/S18"
				--	5:5-50	HMS-S/D/M/SA	"C/L5/WC/4F/MCP50/FIRE ESC STR"
				--	5:5-51	HTRI-R	"C/L5/WC/4F/CM51/FIRE ESC STR"
						--	Switch ""
						--	Relay
				--	5:5-52	HTRI-S	"C/L5/3F/MM52/CW3190"
				--	5:5-59	HTRI-S	"C/L5/3F/MM59/CW3160"
				--	5:5-60	HTRI-S	"C/L5/3F/MM60/CW3080"
				--	5:5-61	HTRI-S	"C/L5/3F/MM61/CW3070"
				--	5:5-62	HTRI-S	"C/L5/3F/MM62/CW3060"
				--	5:5-63	HTRI-S	"C/L5/3F/MM63/CW3170"
				--	5:5-65	HTRI-S	"C/L5/3F/MM65/CW3040"
				--	5:5-66	HTRI-S	"C/L5/3F/MM66/CW3180"
				--	5:5-68	HTRI-S	"C/L5/3F/MM68/CW3030"
				--	5:5-69	HTRI-S	"C/L5/3F/MM69/CW3020"
				--	5:5-70	HTRI-S	"C/L5/3F/MM70/CW3010"
				--	5:5-72	HTRI-S	"C/L5/3F/MM72/BW3102"
				--	5:5-76	HTRI-S	"C/L5/3F/MM76/BW3082"
				--	5:5-77	HTRI-S	"C/L5/3F/MM77/BW3120"
				--	5:5-79	HTRI-S	"C/L5/3F/MM79/BW3110"
				--	5:5-81	HTRI-S	"C/L5/4F/MM81/BW4060"
				--	5:5-82	HTRI-S	"C/L5/4F/MM82/BW4150"
				--	5:5-83	HTRI-S	"C/L5/4F/MM83/BW4140"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:5 DLC "DLC @ address 5 L5"

			-- 5:5-84 HTRI-S "C/L5/4F/MM84/BW4070"
			-- 5:5-85 HTRI-S "C/L5/4F/MM85/BW4080"
			-- 5:5-86 HTRI-S "C/L5/4F/MM86/BW4090"
			-- 5:5-89 HTRI-S "C/L5/4F/MM89/BW4110"
			-- 5:5-90 HTRI-S "C/L5/4F/MM90/BW4120"
			-- 5:5-91 HTRI-S "C/L5/4F/MM91/BW4130"
			-- 5:5-92 HTRI-S "C/L5/4F/MM92/CW4240"
			-- 5:5-93 HTRI-S "C/L5/4F/MM93/CW4010"
			-- 5:5-97 HTRI-S "C/L5/4F/MM97/CW4030"
			-- 5:5-99 HTRI-S "C/L5/4F/MM99/CW4040"
			-- 5:5-104 HTRI-S "C/L5/4F/MM104/CW4080"
			-- 5:5-112 HFP-11 "C/L5/BW3070/SD112/Reception"
			-- 5:5-113 HFP-11 "C/L5/BW3070/SD113/Cabin 1"
			-- 5:5-114 HFP-11 "C/L5/BW3070/SD114/Main cabin"
			-- 5:5-115 HFP-11 "C/L5/BW3070/SD115/Accounts cabin"
			-- 5:5-116 HFP-11 "C/L5/BW3070/SD116/Cabin 2"
			-- 5:5-117 HFP-11 "C/L5/BW3070/SD117/Psg near cabin"
			-- 5:5-118 HFP-11 "C/L5/BW3070/SD118/Assorter cabin"
			-- 5:5-119 HFP-11 "C/L5/BW3070/SD119/Pantry"
			-- 5:5-120 HTRI-R "C/L5/BW3070/CM120/Entry Door"
			-- Switch ""
			-- Relay
			-- 5:5-121 HMS-S/D/M/SA "C/L5/BW3070/MCP121/Entry Door"
			-- 5:5-150 HFP-11 "C/L5/CW 4050/SD150/Psg Nr Main C"
			-- 5:5-151 HFP-11 "C/L5/CW 4050/SD151/Main cab"
			-- 5:5-152 HFP-11 "C/L5/CW 4050/SD152/Main cab"
			-- 5:5-153 HFP-11 "C/L5/CW4050/SD153/Assort Cab"
			-- 5:5-154 HTRI-R "C/L5/CW 4050/CM154/Psg nr Ent Dr"
			-- Switch ""
			-- Relay
			-- 5:5-155 HMS-S/D/M/SA "C/L5/CW 4050/MCP155/Psg nr Ent D"
			-- 5:5-157 HFP-11 "C/L5/CW4200/SD157/Assort Cab"
			-- 5:5-158 HFP-11 "C/L5/CW4200/SD158/Account Cab1"
			-- 5:5-159 HFP-11 "C/L5/CW4200/SD159/Main Cab"
			-- 5:5-160 HFP-11 "C/L5/CW4200/SD160/Account Cab2"
			-- 5:5-161 HFP-11 "C/L5/CW4200/SD161/Pantry"
			-- 5:5-162 HMS-S/D/M/SA "C/L5/CW4200/MCP162/Entry Psg"
			-- 5:5-163 HTRI-R "C/L5/CW4200/CM163/Entry Psg AFC"
			-- Switch ""
			-- Relay
			-- 5:5-164 HFP-11 "C/L5/CW4060/SD164/Pnty"
			-- 5:5-165 HFP-11 "C/L5/CW4060/SD165/Cab 1"
			-- 5:5-166 HFP-11 "C/L5/CW4060/SD166/cab 2"
			-- 5:5-167 HFP-11 "C/L5/CW4060/SD167/Main cab"
			-- 5:5-168 HTRI-R "C/L5/CW4060/CM168/Psg nr Ent Dr"
			-- Switch ""
			-- Relay
			-- 5:5-169 HMS-S/D/M/SA "C/L5/CW4060/MCP169/Psg nr Ent Dr"
			-- 5:5-170 HFP-11 "C/L5/CW4220/SD170/Pnty"
			-- 5:5-171 HFP-11 "C/L5/CW4220/SD171/cab 1"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:5 DLC "DLC @ address 5 L5"

				-- 5:5-172 HFP-11 "C/L5/CW4220/SD172/cab 2"
				-- 5:5-173 HTRI-R "C/L5/CW4220/CM173/Psg nr Ent Dr"
				-- Switch ""
				-- Relay
				 -- 5:5-174 HMS-S/D/M/SA "C/L5/CW4220/MCP174/Psg nr Ent Dr"
				-- 5:5-175 HFP-11 "C/L5/CW4230/SD175/Psg nr Pnty"
				-- 5:5-176 HFP-11 "C/L5/CW4230/SD176/Director Cab"
				-- 5:5-177 HFP-11 "C/L5/CW4230/SD177/asst Cab"
				-- 5:5-178 HTRI-R "C/L5/CW4230/CM178/Psg nr Ent Dr"
				-- Switch ""
				-- Relay
				 -- 5:5-179 HMS-S/D/M/SA "C/L5/CW4230/MCP179/Psg nr Ent Dr"
				-- 5:5-186 HFP-11 "C/L5/CW4210/SD186/Cab 1"
				-- 5:5-187 HFP-11 "C/L5/CW4210/SD187/Cab2"
				-- 5:5-188 HFPT-11 "C/L5/HD188/CW4210/PANTRY"
				-- 5:5-189 HTRI-R "C/L5/CW4210/CM189/Psg nr Ent Dr"
				-- Switch ""
				-- Relay
				 -- 5:5-190 HMS-S/D/M/SA "C/L5/CW4210/MCP190/Psg nr Ent Dr"
				-- 5:5-191 HFP-11 "C/L5/CW4190/SD191/Pnty"
				-- 5:5-192 HFP-11 "C/L5/CW4190/SD192/Assort Cab"
				-- 5:5-193 HFP-11 "C/L5/CW4190/SD193/Assort"
				-- 5:5-194 HFP-11 "C/L5/CW4190/SD194/Main Cab"
				-- 5:5-195 HTRI-R "C/L5/CW4190/CM195/Psg nr Ent Dr"
				-- Switch ""
				-- Relay
				 -- 5:5-196 HMS-S/D/M/SA "C/L5/CW4190/MCP196/Psg nr Ent Dr"
				-- 5:5-198 HFP-11 "C/L5/CW4020/SD198/cab 1"
				-- 5:5-199 HFP-11 "C/L5/CW4020/SD199/Cab 2"
				-- 5:5-200 HFP-11 "C/L5/CW4020/SD200/Cab 3"
				-- 5:5-201 HFP-11 "C/L5/CW4020/SD201/Psg nr cab 2"
				-- 5:5-202 HTRI-R "C/L5/CW4020/CM202/Psg nr Entry D"
				-- Switch ""
				-- Relay
				 -- 5:5-203 HMS-S/D/M/SA "C/L5/CW4020/MCP203/Psg nr Entry "
				-- 5:5-204 HFP-11 "C/L5/BW3091/SD204/Psg nr Pantry"
				-- 5:5-205 HFP-11 "C/L5/BW3091/SD205/Pantry"
				-- 5:5-206 HFP-11 "C/L5/BW3091/SD206/Accounts cab"
				-- 5:5-207 HFP-11 "C/L5/BW3091/SD207/Assorter cab"
				-- 5:5-208 HFP-11 "C/L5/BW3091/SD208/Main cab"
				-- 5:5-209 HFP-11 "C/L5/BW3091/SD209/Assorter cab"
				-- 5:5-210 HMS-S/D/M/SA "C/L5/BW3091/MCP210/Psg nr Entry "
				-- 5:5-211 HTRI-R "C/L5/BW3091/CM211/Psg nr Entry D"
				-- Switch ""
				-- Relay
				 -- 5:5-212 HFP-11 "C/L5/BW4100/SD212/Main cab"
				-- 5:5-213 HFP-11 "C/L5/BW4100/SD213/Cab 1"
				-- 5:5-214 HFP-11 "C/L5/BW4100/SD214/Psg nr Entranc"
				-- 5:5-215 HTRI-R "C/L5/BW4100/CM215/Psg nr Entry D"
				-- Switch ""

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:5 DLC "DLC @ address 5 L5"

5:5-215 HTRI-R "C/L5/BW4100/CM215/Psg nr Entry D"

```
| | | | |-- Relay
| | | |-- 5:5-216 HMS-S/D/M/SA "C/L5/BW4100/MCP216/Psg nr Entry "
| | | |-- 5:5-223 HFPT-11 "C/L5/CW3050/HD223/Main Cab"
| | | |-- 5:5-224 HFP-11 "C/L5/CW3050/SD224/Cab 1"
| | | |-- 5:5-225 HFPT-11 "C/L5/CW3050/HD225/Psg nr cab 2"
| | | |-- 5:5-226 HTRI-R "C/L5/CW3050/CM226/Psg nr Ent Dr"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 5:5-227 HMS-S/D/M/SA "C/L5/CW3050/MCP227/Psg nr Ent Dr"
| | | |-- 5:5-228 HFPT-11 "C/L5/CW4020/HD228/Pantry"
| | | |-- 5:5-230 HFP-11 "C/L5/SD230/CW4070/MAIN CAB"
| | | |-- 5:5-231 HFP-11 "C/L5/SD231/CW4070/MAIN CAB"
| | | |-- 5:5-232 HFP-11 "C/L5/SD232/CW4070/ASSORTOR CAB"
| | | |-- 5:5-233 HFP-11 "C/L5/SD233/CW4070/ASSORTOR CAB"
| | | |-- 5:5-234 HTRI-R "C/L5/CM234/CW4070/ENTRY PSG AFC"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 5:5-235 HMS-S/D/M/SA "C/L5/MCP235/CW4070/ENTRY PSG"
| | |-- CC-5 "Card Cage 5 Slots"
| | | |-- 5:7 DLC "DLC @ address 7 L7"
| | | | |-- 5:7-1 HFP-11 "C/L7/CC9015B/SD1/Psg nr cab 2 "
| | | | |-- 5:7-2 HFP-11 "C/L7/CC9015B/SD2/Psg nr Exe. T"
| | | | |-- 5:7-3 HFP-11 "C/L7/CC9015B/SD3/Arjiv safe"
| | | | |-- 5:7-4 HFP-11 "C/L7/CC9015B/SD4/Psg nr Conf. "
| | | | |-- 5:7-5 HFP-11 "C/L7/CC9015B/SD5/Psg nr Strong"
| | | | |-- 5:7-6 HFP-11 "C/L7/CC9015B/SD6/Strong rm cab"
| | | | |-- 5:7-7 HFP-11 "C/L7/WC/9F/SD7/LIFT LOBBY"
| | | | |-- 5:7-8 HFP-11 "C/L7/WC/9F/SD8/LIFT LOBBY"
| | | | |-- 5:7-9 HMS-S/D/M/SA "C/L7/WC/9F/MCP9/FIRE SHAFT L.L."
| | | | |-- 5:7-10 HTRI-R "C/L7/WC/9F/CM10/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:7-11 HTRI-S "C/L7/WC/9F/MM11/FIRE SHAFT L.L."
| | | | |-- 5:7-12 HTRI-R "C/L7/WC/9F/CM12/AHU RM CM "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:7-13 HFP-11 "C/L7/WC/9F/SD13/AHU RM SD"
| | | | |-- 5:7-14 HFP-11 "C/L7/WC/9F/SD14/ELECT RM SD"
| | | | |-- 5:7-15 HTRI-R "C/L7/WC/9F/CM15/Fire Door"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 5:7-16 HFP-11 "C/L7/CC/9F/SD16/CORR NR CC 9051"
| | | | |-- 5:7-17 HFP-11 "C/L7/CC/9F/SD17/CORR NR CC 9051"
| | | | |-- 5:7-18 HFP-11 "C/L7/CC/9F/SD18/CORR NR CC 9060"
| | | | |-- 5:7-19 HFP-11 "C/L7/CC/9F/SD19/CORR NR CC 9030"
| | | | |-- 5:7-20 HFP-11 "C/L7/CC/9F/SD20/CORR NR CC 9030"
| | | | |-- 5:7-21 HMS-S/D/M/SA "C/L7/CC/9F/MCP21/FIRE ESC STR"
| | | | |-- 5:7-22 HTRI-R "C/L7/CC/9F/CM22/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:7 DLC "DLC @ address 7 L7"

					-- 5:7-23 HFP-11 "C/L7/CC/9F/SD23/CORR NR CC 9010"
					-- 5:7-24 HFP-11 "C/L7/CC/9F/SD24/CORR NR CC 9020"
					-- 5:7-25 HFP-11 "C/L7/CC/9F/SD25/CORR NR CC 9020"
					-- 5:7-26 HFP-11 "C/L7/CC/9F/SD26/CORR NR CC 9081"
					-- 5:7-27 HFP-11 "C/L7/CC/9F/SD27/CORR NR CC 9010"
					-- 5:7-28 HFP-11 "C/L7/CC/9F/SD28/CORR NR CC 9010"
					-- 5:7-29 HFP-11 "C/L7/CC/9F/SD29/ELECT RM SD"
					-- 5:7-30 HTRI-R "C/L7/CC/9F/CM30/DR RELSE CM"
					-- Switch ""
					-- Relay
					-- 5:7-31 HMS-S/D/M/SA "C/L7/CC/9F/MCP31/LIFT LOBBY MCP"
					-- 5:7-32 HTRI-R "C/L7/CC/9F/CM32/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:7-33 HTRI-S "C/L7/CC/9F/MM33/FIRE SHAFT L.L."
					-- 5:7-34 HFP-11 "C/L7/CC/9F/SD34/AHU RM SD"
					-- 5:7-35 HTRI-R "C/L7/CC/9F/CM35/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 5:7-36 HFP-11 "C/L7/CC/9F/SD36/LIFT LOBBY"
					-- 5:7-37 HFP-11 "C/L7/CC/9F/SD37/LIFT LOBBY"
					-- 5:7-38 HFP-11 "C/L7/WC/8F/SD38/LIFT LOBBY"
					-- 5:7-39 HFP-11 "C/L7/WC/8F/SD39/LIFT LOBBY"
					-- 5:7-40 HMS-S/D/M/SA "C/L7/WC/8F/MCP40/FIRE SHAFT L.L."
					-- 5:7-41 HTRI-R "C/L7/WC/8F/CM41/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:7-42 HTRI-S "C/L7/WC/8F/MM42/FIRE SHAFT L.L."
					-- 5:7-43 HTRI-R "C/L7/WC/8F/CM43/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 5:7-44 HFP-11 "C/L7/WC/8F/SD44/AHU RM SD"
					-- 5:7-45 HFP-11 "C/L7/WC/8F/SD45/ELECT RM SD"
					-- 5:7-46 HTRI-R "C/L7/WC/8F/CM46/DR RELSE SD"
					-- Switch ""
					-- Relay
					-- 5:7-47 HFP-11 "C/L7/WC/8F/SD47/CORR NR CW8/S22"
					-- 5:7-48 HFP-11 "C/L7/WC/8F/SD48/CORR NR CW 8023"
					-- 5:7-49 HTRI-R "C/L7/CC9015B/CM49/Electric pane"
					-- Switch ""
					-- Relay
					-- 5:7-52 HFP-11 "C/L7/CC/8F/SD52/CORR NR E.R."
					-- 5:7-53 HFP-11 "C/L7/CC/8F/SD53/ELECT RM SD"
					-- 5:7-54 HMS-S/D/M/SA "C/L7/CC/8F/MCP54/FIRE SHAFT L.L."
					-- 5:7-55 HTRI-R "C/L7/CC/8F/CM55/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:7-56 HTRI-S "C/L7/CC/8F/MM56/FIRE SHAFT L.L."
					-- 5:7-57 HFP-11 "C/L7/CC/8F/SD57/AHU RM"
					-- 5:7-58 HTRI-R "C/L7/CC/8F/CM58/AHU RM CM"

5:7-58 HTRI-R "C/L7/CC/8F/CM58/AHU RM CM"

```
| | | | | | Switch ""
| | | | | | |-- Relay
| | | | | | |-- 5:7-59 HFP-11 "C/L7/C/SD59/LIFT LOBBY"
| | | | | | |-- 5:7-60 HFP-11 "C/L7/CC/8F/SD60/LIFT LOBBY"
| | | | | | |-- 5:7-61 HFP-11 "C/L7/WC/7F/SD61/LIFT LOBBY"
| | | | | | |-- 5:7-62 HFP-11 "C/L7/WC/7F/SD62/LIFT LOBBY"
| | | | | | |-- 5:7-63 HMS-S/D/M/SA "C/L7/WC/7F/MCP63/FIRE SHAFT L.L."
| | | | | | |-- 5:7-64 HTRI-R "C/L7/WC/7F/CM64/FIRE SHAFT L.L."
| | | | | | | |-- Switch ""
| | | | | | | |-- Relay
| | | | | | |-- 5:7-65 HTRI-S "C/L7/WC/7F/MM65/FIRE SHAFT L.L."
| | | | | | |-- 5:7-66 HTRI-R "C/L7/WC/7F/CM66/AHU RM CM"
| | | | | | | |-- Switch ""
| | | | | | | |-- Relay
| | | | | | |-- 5:7-67 HFP-11 "C/L7/WC/7F/SD67/AHU RM SD"
| | | | | | |-- 5:7-68 HFP-11 "C/L7/WC/7F/SD68/ELECT RM SD"
| | | | | | |-- 5:7-69 HFP-11 "C/L7/WC/7F/SD69/CORR NR AHU"
| | | | | | |-- 5:7-70 HFP-11 "C/L7/WC/7F/SD70/CORR NR AHU"
| | | | | | |-- 5:7-71 HTRI-R "C/L7/CC/7F/CM71/DR RELSE CM"
| | | | | | | |-- Switch ""
| | | | | | | |-- Relay
| | | | | | |-- 5:7-73 HFP-11 "C/L7/CC/7F/SD73/CORR NR CC 7053"
| | | | | | |-- 5:7-74 HFP-11 "C/L7/CC/7F/SD74/CORR NR CC 7053"
| | | | | | |-- 5:7-75 HFP-11 "C/L7/CC/7F/SD75/CORR NR CW 7/S09"
| | | | | | |-- 5:7-76 HFP-11 "C/L7/CC/7F/SD76/CORR "
| | | | | | |-- 5:7-77 HFP-11 "C/L7/CC/7F/SD77/CORR NR CC 7051"
| | | | | | |-- 5:7-78 HMS-S/D/M/SA "C/L7/CC/7F/MCP78/FIRE ESC STR"
| | | | | | |-- 5:7-79 HTRI-R "C/L7/CC/7F/CM79/FIRE ESC STR"
| | | | | | | |-- Switch ""
| | | | | | | |-- Relay
| | | | | | |-- 5:7-80 HFP-11 "C/L7/CC/7F/SD80/CORR NR CC7/S08"
| | | | | | |-- 5:7-81 HFP-11 "C/L7/CC/7F/SD81/CORR NR CC 7030"
| | | | | | |-- 5:7-82 HFP-11 "C/L7/CC/7F/SD82/CORR NR CC7/S24"
| | | | | | |-- 5:7-83 HFP-11 "C/L7/CC/7F/SD83/CORR NR CC7/S07"
| | | | | | |-- 5:7-84 HFP-11 "C/L7/CC/7F/SD84/CORR NR CC 7085"
| | | | | | |-- 5:7-85 HFP-11 "C/L7/CC/7F/SD85/CORR NR CC 7085"
| | | | | | |-- 5:7-86 HFP-11 "C/L7/CC/7F/SD86/ELECT RM SD "
| | | | | | |-- 5:7-87 HTRI-R "C/L7/CC/7F/CM87/DR RELSE CM"
| | | | | | | |-- Switch ""
| | | | | | | |-- Relay
| | | | | | |-- 5:7-88 HMS-S/D/M/SA "C/L7/CC/7F/MCP88/FIRE SHAFT L.L."
| | | | | | |-- 5:7-89 HTRI-R "C/L7/CC/7F/CM89/FIRE SHAFT L.L."
| | | | | | | |-- Switch ""
| | | | | | | |-- Relay
| | | | | | |-- 5:7-90 HTRI-S "C/L7/CC/7F/MM90/FIRE SHAFT L.L."
| | | | | | |-- 5:7-91 HFP-11 "C/L7/CC/7F/SD91/AHU RM SD"
| | | | | | |-- 5:7-92 HTRI-R "C/L7/CC/7F/CM92/AHU RM CM"
| | | | | | | |-- Switch ""
| | | | | | | |-- Relay
| | | | | | |-- 5:7-93 HFP-11 "C/L7/CC/7F/SD93/LIFT LOBBY"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:7 DLC "DLC @ address 7 L7"

					-- 5:7-94 HFP-11 "C/L7/CC/7F/SD94/LIFT LOBBY"
					-- 5:7-95 HTRI-S "C/L7/8F/MM95/CW8011"
					-- 5:7-98 HTRI-S "C/L7/9F/MM98/CC9030"
					-- 5:7-99 HTRI-S "C/L7/CC/8F/MM99/CC8014/15"
					-- 5:7-105 HTRI-S "C/L7/9F/MM105/CC9060"
					-- 5:7-106 HTRI-S "C/L7/9F/MM106/CC9020A"
					-- 5:7-107 HTRI-S "C/L7/9F/MM107/CC9010"
					-- 5:7-108 HTRI-S "C/L7/9F/MM108/CC9082"
					-- 5:7-112 HTRI-S "C/L7/7F/MM112/CC7010"
					-- 5:7-113 HTRI-S "C/L7/7F/MM113/CC7084"
					-- 5:7-115 HTRI-S "C/L7/7F/MM115/CC7030"
					-- 5:7-116 HTRI-S "C/L7/7F/MM116/CC7081"
					-- 5:7-118 HTRI-S "C/L7/7F/MM118/CC7040"
					-- 5:7-122 HMS-S/D/M/SA "C/L7/CC7061/MCP122/Psg nr Entry"
					-- 5:7-124 HTRI-S "C/L7/7F/MM124/CC7053"
					-- 5:7-126 HTRI-S "C/L7/8F/MM126/CC8012"
					-- 5:7-130 HTRI-S "C/L7/8F/MM130/CW8012"
					-- 5:7-131 HFP-11 "C/L7/CC7020/SD131/Pnty"
					-- 5:7-132 HFP-11 "C/L7/CC7020/SD132/Psg nr Ent Dr"
					-- 5:7-133 HFP-11 "C/L7/CC7020/SD133/Waiting Area"
					-- 5:7-134 HFP-11 "C/L7/CC7020/SD134/asst Cab"
					-- 5:7-135 HFP-11 "C/L7/CC7020/SD135/cab 2"
					-- 5:7-136 HFP-11 "C/L7/CC7020/SD136/cab 1"
					-- 5:7-137 HFP-11 "C/L7/CC7020/SD137/Accs Cab"
					-- 5:7-138 HTRI-R "C/L7/CC7020/CM138/Psg nr Ent Dr"
					-- Switch ""
					-- Relay
					-- 5:7-139 HMS-S/D/M/SA "C/L7/CC7020/MCP139/Psg nr Ent Dr"
					-- 5:7-140 HFP-11 "C/L7/CC7061/SD140/Cab 1"
					-- 5:7-141 HFP-11 "C/L7/CC7061/SD141/Cab 2"
					-- 5:7-142 HFP-11 "C/L7/CC7061/SD142/Cab 3"
					-- 5:7-143 HFP-11 "C/L7/CC7061/SD143/Cab 3A"
					-- 5:7-144 HFP-11 "C/L7/CC7061/SD144/Cab 3B"
					-- 5:7-145 HFP-11 "C/L7/CC7061/SD145/Cab 3C"
					-- 5:7-146 HFP-11 "C/L7/CC7061/SD146/Cab 4"
					-- 5:7-147 HFP-11 "C/L7/CC7061/SD147/Cab 5"
					-- 5:7-148 HFP-11 "C/L7/CC7061/SD148/Cab 6A"
					-- 5:7-149 HFP-11 "C/L7/CC7061/SD149/Cab 6B"
					-- 5:7-150 HFP-11 "C/L7/CC7061/SD150/Cab 7"
					-- 5:7-151 HFP-11 "C/L7/CC7061/SD151/Cab 8"
					-- 5:7-152 HFP-11 "C/L7/CC7061/SD152/Cab 9"
					-- 5:7-153 HFP-11 "C/L7/CC7061/SD153/Cab 10"
					-- 5:7-154 HFP-11 "C/L7/CC7061/SD154/Cab 11A"
					-- 5:7-155 HFP-11 "C/L7/CC7061/SD155/Cab 11B"
					-- 5:7-156 HFP-11 "C/L7/CC7061/SD156/Cab 12"
					-- 5:7-157 HFP-11 "C/L7/CC7061/SD157/Cab 13A"
					-- 5:7-158 HFP-11 "C/L7/CC7085/SD158/rcpt"
					-- 5:7-159 HFP-11 "C/L7/CC7085/SD159/Cab 22"
					-- 5:7-160 HFP-11 "C/L7/CC7085/SD160/Cab 16"
					-- 5:7-161 HFP-11 "C/L7/CC7085/SD161/Acc cab"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:7 DLC "DLC @ address 7 L7"

					-- 5:7-162 HFP-11 "C/L7/CC7085/SD162/asst cab"
					-- 5:7-163 HFP-11 "C/L7/CC7085/SD163/Main cab"
					-- 5:7-164 HFP-11 "C/L7/CC7085/SD164/Main cab"
					-- 5:7-165 HFP-11 "C/L7/CC7085/SD165/Main cab"
					-- 5:7-166 HFP-11 "C/L7/CC7085/SD166/Pnty"
					-- 5:7-167 HFP-11 "C/L7/CC7085/SD167/Psg nr Acc cab"
					-- 5:7-168 HMS-S/D/M/SA "C/L7/CC7085/MCP168/Psg nr Ent Dr"
					-- 5:7-169 HTRI-R "C/L7/CC7085/169CM/Psg nr Ent Dr"
					-- Switch ""
					-- Relay
					-- 5:7-170 HFP-11 "C/L7/CC7070/SD170/Pnty"
					-- 5:7-171 HFP-11 "C/L7/CC7070/SD171/Server room"
					-- 5:7-172 HFP-11 "C/L7/CC7070/SD172/Main cab"
					-- 5:7-173 HFP-11 "C/L7/CC7070/SD173/Acc cab"
					-- 5:7-174 HFP-11 "C/L7/CC7070/SD174/Buyer1 Cab"
					-- 5:7-175 HFP-11 "C/L7/CC7070/SD175/Buyer2 cab"
					-- 5:7-176 HTRI-R "C/L7/CC7070/CM176/Psg nr Ent Dr"
					-- Switch ""
					-- Relay
					-- 5:7-177 HMS-S/D/M/SA "C/L7/CC7070/MCP177/Psg nr Ent Dr"
					-- 5:7-178 HFP-11 "C/L7/CC9015B/SD178/ARJO Main cab"
					-- 5:7-179 HFP-11 "C/L7/CC9015B/SD179/ARJO Main cab"
					-- 5:7-180 HFP-11 "C/L7/CC9015B/SD180/ARJO Main cab"
					-- 5:7-181 HFP-11 "C/L7/CC9015B/SD181/ARJO Main cab"
					-- 5:7-182 HFP-11 "C/L7/CC9015B/SD182/ARJO Main cab"
					-- 5:7-183 HFP-11 "C/L7/CC9015B/SD183/ARJO Main cab"
					-- 5:7-184 HFP-11 "C/L7/CC9015B/SD184/Psg nr ARJO M"
					-- 5:7-185 HFP-11 "C/L7/CC9015B/SD185/Psg nr Accoun"
					-- 5:7-186 HFP-11 "C/L7/CC9015B/SD186/ARJO Entry dr"
					-- 5:7-187 HFPT-11 "C/L7/CC9015B/HD187/Pantry"
					-- 5:7-188 HFP-11 "C/L7/CC9015B/SD188/Blue star Ent"
					-- 5:7-189 HFP-11 "C/L7/CC9015B/SD189/Reception Psg"
					-- 5:7-190 HFP-11 "C/L7/CC9015B/SD190/Reception cab"
					-- 5:7-191 HFP-11 "C/L7/CC9015B/SD191/Scanning dept"
					-- 5:7-192 HFP-11 "C/L7/CC9015B/SD192/Operator cab"
					-- 5:7-193 HFP-11 "C/L7/CC9015B/SD193/Account cab"
					-- 5:7-194 HFP-11 "C/L7/CC9015B/SD194/Xerox cab"
					-- 5:7-195 HFP-11 "C/L7/CC9015B/SD195/CA cab"
					-- 5:7-196 HFP-11 "C/L7/CC9015B/SD196/Psg nr CA cab"
					-- 5:7-197 HFP-11 "C/L7/CC9015B/SD197/Ishwarbhai ca"
					-- 5:7-198 HFP-11 "C/L7/CC9015B/SD198/Rakesh bhai c"
					-- 5:7-199 HFP-11 "C/L7/CC9015B/SD199/Kirtibhai cab"
					-- 5:7-200 HFP-11 "C/L7/CC9015B/SD200/Psg nr Assort"
					-- 5:7-201 HFP-11 "C/L7/CC9015B/SD201/Assorter cab"
					-- 5:7-202 HFP-11 "C/L7/CC9015B/SD202/Psg nr Accoun"
					-- 5:7-203 HFP-11 "C/L7/CC9015B/SD203/Dinning Room"
					-- 5:7-204 HFPT-11 "C/L7/CC9015B/HD204/Boss Pantry"
					-- 5:7-205 HFP-11 "C/L7/CC9015B/SD205/Psg nr IT cab"
					-- 5:7-206 HFP-11 "C/L7/CC9015B/SD206/Server Room"
					-- 5:7-207 HFP-11 "C/L7/CC9015B/SD207/IT Dept Cab"

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:7 DLC "DLC @ address 7 L7"

					-- 5:7-208 HFP-11 "C/L7/CC9015B/SD208/Grading cab"
					-- 5:7-209 HFP-11 "C/L7/CC9015B/SD209/Conference rm"
					-- 5:7-210 HFP-11 "C/L7/CC9015B/SD210/Conference rm"
					-- 5:7-211 HFP-11 "C/L7/CC9015B/SD211/Cab 6"
					-- 5:7-212 HFP-11 "C/L7/CC9015B/SD212/Cab 7"
					-- 5:7-213 HFP-11 "C/L7/CC9015B/SD213/Cab 8"
					-- 5:7-214 HFP-11 "C/L7/CC9015B/SD214/Cab 5"
					-- 5:7-215 HFP-11 "C/L7/CC9015B/SD215/Psg nr Cab 6"
					-- 5:7-216 HFP-11 "C/L7/CC9015B/SD216/Warehouse cab"
					-- 5:7-217 HFP-11 "C/L7/CC9015B/SD217/Warehouse cab"
					-- 5:7-218 HFP-11 "C/L7/CC9015B/SD218/Waiting Area "
					-- 5:7-219 HFP-11 "C/L7/CC9015B/SD219/Waiting Area "
					-- 5:7-220 HFP-11 "C/L7/CC9015B/SD220/Boss cab"
					-- 5:7-221 HFP-11 "C/L7/CC9015B/SD221/Boss cab"
					-- 5:7-222 HFP-11 "C/L7/CC9015B/SD222/Sales cab"
					-- 5:7-223 HFP-11 "C/L7/CC9015B/SD223/Stock cab1"
					-- 5:7-224 HFP-11 "C/L7/CC9015B/SD224/Stock cab2"
					-- 5:7-225 HFP-11 "C/L7/CC9015B/SD225/Stock cab3"
					-- 5:7-226 HFP-11 "C/L7/CC9015B/SD226/Mixing Dept"
					-- 5:7-227 HFP-11 "C/L7/CC9015B/SD227/Psg nr Mixing"
					-- 5:7-228 HFP-11 "C/L7/CC9015B/SD228/Cab 4"
					-- 5:7-229 HFP-11 "C/L7/CC9015B/SD229/Cab 3"
					-- 5:7-230 HFP-11 "C/L7/CC9015B/SD230/Cab 2"
					-- 5:7-231 HFP-11 "C/L7/CC9015B/SD231/Piyushbhai ca"
					-- 5:7-232 HFP-11 "C/L7/CC9015B/SD232/Achalbhai cab"
					-- 5:7-233 HFP-11 "C/L7/CC9015B/SD233/Cab 1"
					-- 5:7-234 HFP-11 "C/L7/CC9015B/SD234/Anujbhai cab"
					-- 5:7-235 HFP-11 "C/L7/CC9015B/SD235/Psg nr cab1"
					-- 5:7-236 HMS-S/D/M/SA "C/L7/CC9015B/MCP236/Psg nr sales"
					-- 5:7-237 HMS-S/D/M/SA "C/L7/CC9015B/MCP237/Psg nr Mixin"
					-- 5:7-238 HMS-S/D/M/SA "C/L7/CC9015B/MCP238/Psg nr Recep"
					-- 5:7-239 HMS-S/D/M/SA "C/L7/CC9015B/MCP239/Psg nr ARJIO"
					-- 5:7-240 HTRI-R "C/L7/CC9015B/CM240/Psg nr Mixing"
					-- Switch ""
					-- Relay
					-- 5:7-241 HFP-11 "C/L7/CC7061/SD241/Cab 13B"
					-- 5:7-242 HFP-11 "C/L7/CC7061/SD242/Cab 14"
					-- 5:7-243 HFP-11 "C/L7/CC7061/SD243/Cab 15"
					-- 5:7-244 HFP-11 "C/L7/CC7061/SD244/Cab 16"
					-- 5:7-245 HMS-S/D/M/SA "C/L7/CC7061/MCP245/Cab 16"
					-- 5:7-246 HFP-11 "C/L7/CC7061/SD246/Psg nr cab14"
					-- 5:7-247 HFP-11 "C/L7/CC7061/SD247/Psg nr cab10"
					-- 5:7-248 HFP-11 "C/L7/CC7061/SD248/Psg nr cab3"
					-- 5:7-249 HFP-11 "C/L7/CC7061/SD249/Psg nr cab2"
					-- 5:7-250 HFP-11 "C/L7/CC7061/SD250/Psg nr cab1"
					-- 5:7-251 HFP-11 "C/L7/CC7061/SD251/Reception Entr"
					-- 5:7-252 HTRI-R "C/L7/CC7061/CM252/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 5:8 DLC "DLC @ address 8 L8"

5 Desigo Fire Safety Modular "BDB TOWER C" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
5:8 DLC "DLC @ address 8 L8"

					-- 5:8-27 HFP-11 "C/L8/EC/7F/SD27/ELECT RM SD"
					-- 5:8-28 HFP-11 "C/L8/EC/7F/SD28/AHU RM SD"
					-- 5:8-29 HTRI-R "C/L8/EC/7F/CM29/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 5:8-30 HFP-11 "C/L8/EC/7F/SD30/LIFT LOBBY SD"
					-- 5:8-31 HMS-S/D/M/SA "C/L8/EC/7F/MCP31/FIRE SHAFT L.L."
					-- 5:8-32 HTRI-R "C/L8/EC/7F/CM32/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:8-33 HTRI-S "C/L8/EC/7F/MM33/FIRE SHAFT L.L."
					-- 5:8-44 HFP-11 "C/L8/CC/6F/SD44/ELECT RM SD"
					-- 5:8-45 HFP-11 "C/L8/CC/6F/SD45/AHU RM SD"
					-- 5:8-46 HTRI-R "C/L8/CC/6F/CM46/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 5:8-47 HFP-11 "C/L8/CC/6F/SD47/LIFT LOBBY SD"
					-- 5:8-48 HFP-11 "C/L8/CC/6F/SD48/LIFT LOBBY SD"
					-- 5:8-49 HMS-S/D/M/SA "C/L8/CC/6F/MCP49/FIRE SHAFT L.L."
					-- 5:8-50 HTRI-R "C/L8/CC/6F/CM50/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:8-51 HTRI-S "C/L8/CC/6F/MM51/FIRE SHAFT L.L."
					-- 5:8-54 HFP-11 "C/L8/EC/6F/SD54/CORR NR E.R."
					-- 5:8-55 HFP-11 "C/L8/EC/6F/SD55/CORR NR E.R."
					-- 5:8-56 HFP-11 "C/L8/EC/6F/SD56/ELECT RM"
					-- 5:8-57 HFP-11 "C/L8/EC/6F/SD57/AHU RM"
					-- 5:8-58 HTRI-R "C/L8/EC/6F/CM58/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 5:8-59 HFP-11 "C/L8/EC/6F/SD59/LIFT LOBBY SD"
					-- 5:8-60 HMS-S/D/M/SA "C/L8/EC/6F/MCP60/FIRE SHAFT L.L."
					-- 5:8-61 HTRI-R "C/L8/EC/6F/CM61/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 5:8-62 HTRI-S "C/L8/EC/6F/MM62/FIRE SHAFT L.L."
					-- 5:8-63 HTRI-S "C/L8/6F/MM63/CC6011"
					-- 5:8-67 HTRI-S "C/L8/7F/MM67/CE6057"
					-- 5:9 DLC "DLC @ address 9 L9"
					-- 5:9-27 HFP-11 "C/L9/EC/9F/SD27/LIFT LOBBY SD"
					-- 5:9-28 HTRI-R "C/L9/EC/9F/CM28/DR RELSE CM"
					-- Switch ""
					-- Relay
					-- 5:9-29 HFP-11 "C/L9/EC/9F/SD29/CORR NR CE9/S02"
					-- 5:9-30 HFP-11 "C/L9/EC/9F/SD30/CORR NR CE9/S02"
					-- 5:9-31 HFP-11 "C/L9/EC/9F/SD31/ELECT RM SD"
					-- 5:9-32 HFP-11 "C/L9/EC/9F/SD32/AHU RM"
					-- 5:9-33 HTRI-R "C/L9/EC/9F/CM33/ AHU RM"
					-- Switch ""
					-- Relay

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

5:9 DLC "DLC @ address 9 L9"

```
| | | | | -- 5:9-34 HMS-S/D/M/SA "C/L9/EC/9F/MCP34/FIRE SHAFT L.L."
| | | | | -- 5:9-35 HTRI-R "C/L9/EC/9F/CM35/FIRE SHAFT L.L."
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:9-36 HTRI-S "C/L9/EC/9F/MM36/FIRE SHAFT L.L."
| | | | | -- 5:9-59 HFP-11 "C/L9/EC/8F/SD59ELECT RM SD"
| | | | | -- 5:9-60 HFP-11 "C/L9/EC/8F/SD60/AHU RM SD"
| | | | | -- 5:9-61 HTRI-R "C/L9/EC/8F/CM61/AHU RM CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:9-62 HFP-11 "C/L9/EC/8F/SD62/LIFT LOBBY SD"
| | | | | -- 5:9-63 HMS-S/D/M/SA "C/L9/EC/8F/MCP63/FIRE SHAFT NR L"
| | | | | -- 5:9-64 HTRI-R "C/L9/EC/8F/CM64/FIRE SHAFT NR L."
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:9-65 HTRI-S "C/L9/EC/8F/MM65/FIRE SHAFT NR L."
| | | | | -- 5:9-66 HTRI-S "C/L9/8F/MM66/CE8011"
| | | | | -- 5:9-104 HTRI-S "C/L7/CC/9F/MM104/CC9060A"
| | | | -- 5:10 NIC-C(XNet) "NIC_Xnet @ address 10"
| | | | -- 5:12 NIC-C(HNet) "NIC @ address 12"
| | | -- 5:249 PSC-12 "PSC-12 @ address 249"
| | | | -- 5:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
| | | | -- 5:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
| | | -- Inner Door
| | | | -- 5:253 PMI-D "PMI-D @ address 253"
| | -- CAB-1 "CAB-1 Enclosure #2"
| | | -- CC-5 "Card Cage 5 Slots"
| | | | -- 5:6 DLC "DLC @ address 6 L6"
| | | | | -- 5:6-1 HMS-S/D/M/SA "C/L6/WC/6F/MCP1/FIRE ESC STR "
| | | | | -- 5:6-2 HTRI-R "C/L6/WC/6F/CM2/FIRE ESC STR "
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:6-3 HFP-11 "C/L6/WC/6F/SD3/CORR NR CW 6040"
| | | | | -- 5:6-4 HFP-11 "C/L6/WC/6F/SD4/CORR NR CW 6054"
| | | | | -- 5:6-5 HFP-11 "C/L6/WC/6F/SD5/CORR NR CW 6054"
| | | | | -- 5:6-6 HFP-11 "C/L6/WC/6F/SD6/CORR NR CW 6022"
| | | | | -- 5:6-7 HFP-11 "C/L6/WC/6F/SD7/CORR NR E.R."
| | | | | -- 5:6-8 HFP-11 "C/L6/WC/6F/SD8/CORR NR E.R."
| | | | | -- 5:6-9 HFP-11 "C/L6/WC/6F/SD9/ELECT RM SD"
| | | | | -- 5:6-10 HTRI-R "C/L6/WC/6F/CM10/DR RELSE CW6/S22"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:6-11 HTRI-R "C/L6/WC/6F/CM11/DR RELSE CW6/S22"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 5:6-12 HFP-11 "C/L6/WC/6F/SD12/CORR NR CW6/S22"
| | | | | -- 5:6-13 HFP-11 "C/L6/WC/6F/SD13/CORR NR CW6/S10"
| | | | | -- 5:6-14 HFP-11 "C/L6/WC/6F/SD14/CORR NR CW6/S23"
| | | | | -- 5:6-15 HFP-11 "C/L6/WC/6F/SD15/CORR NR CW6/S23"
| | | | | -- 5:6-16 HFP-11 "C/L6/WC/6F/SD16/CORR NR CW6/S23"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:6 DLC "DLC @ address 6 L6"

				--	5:6-17	HFP-11	"C/L6/WC/6F/SD17/LIFT LOBBY SD"
				--	5:6-18	HFP-11	"C/L6/WC/6F/SD18/LIFT LOBBY SD"
				--	5:6-19	HMS-S/D/M/SA	"C/L6/WC/6F/MCP19/FIRE SHAFT L.L."
				--	5:6-20	HTRI-R	"C/L6/WC/6F/CM20/FIRE SHAFT L.L."
							-- Switch ""
							-- Relay
				--	5:6-21	HTRI-S	"C/L6/WC/6F/MM21/FIRE SHAFT L.L."
				--	5:6-22	HTRI-R	"C/L6/WC/6F/CM22/DR RELSE CM"
							-- Switch ""
							-- Relay
				--	5:6-23	HTRI-R	"C/L6/WC/6F/CM23/AHU RM CM"
							-- Switch ""
							-- Relay
				--	5:6-24	HFP-11	"C/L6/WC/6F/SD24AHU RM SD"
				--	5:6-25	HFP-11	"C/L6/WC/6F/SD25/CORR NR AHU RM"
				--	5:6-26	HFP-11	"C/L6/WC/6F/SD26/CORR NR AHU RM"
				--	5:6-27	HFP-11	"C/L6/WC/6F/SD27/CORR NR CW6162"
				--	5:6-28	HFP-11	"C/L6/WC/6F/SD28/CORR NR CW6061"
				--	5:6-29	HFP-11	"C/L6/WC/6F/SD29/CORR NR CW6163"
				--	5:6-30	HFP-11	"C/L6/WC/6F/SD30/CORR NR CW6/S17"
				--	5:6-31	HMS-S/D/M/SA	"C/L6/WC/6F/MCP31/FIRE ESC STR "
				--	5:6-32	HTRI-R	"C/L6/WC/6F/CM32/FIRE ESC STR "
							-- Switch ""
							-- Relay
				--	5:6-33	HFP-11	"C/L6/WC/6F/SD33/CORR NR CW 6150"
				--	5:6-34	HFP-11	"C/L6/WC/6F/SD34/CORR NR CW 6054"
				--	5:6-35	HMS-S/D/M/SA	"C/L6/WC/6F/MCP35/FIRE ESC STR "
				--	5:6-36	HTRI-R	"C/L6/WC/6F/CM36/FIRE ESC STR "
							-- Switch ""
							-- Relay
				--	5:6-37	HFP-11	"C/L6/WC/5F/SD37/CORR NR BW 5061"
				--	5:6-38	HFP-11	"C/L6/WC/5F/SD38/CORR NR BW 5061"
				--	5:6-39	HFP-11	"C/L6/WC/5F/SD39/CORR NR BW 5071"
				--	5:6-40	HFP-11	"C/L6/WC/5F/SD40/CORR NR BW 5082"
				--	5:6-41	HFP-11	"C/L6/WC/5F/SD41/CORR NR BW 5082"
				--	5:6-42	HFP-11	"C/L6/WC/5F/SD42/ELECT RM SD"
				--	5:6-43	HTRI-R	"C/L6/WC/5F/CM43/DR RELSE CM"
							-- Switch ""
							-- Relay
				--	5:6-44	HFP-11	"C/L6/WC/5F/SD44/LIFT LOBBY "
				--	5:6-45	HFP-11	"C/L6/WC/5F/SD45/LIFT LOBBY "
				--	5:6-46	HMS-S/D/M/SA	"C/L6/WC/5F/MCP46/LIFT LOBBY "
				--	5:6-47	HTRI-R	"C/L6/WC/5F/CM47/FIRE SHAFT L.L."
							-- Switch ""
							-- Relay
				--	5:6-48	HTRI-S	"C/L6/WC/5F/MM48/FIRE SHAFT L.L."
				--	5:6-49	HTRI-R	"C/L6/WC/5F/CM49/DR RELSE NR 3TO4"
							-- Switch ""
							-- Relay
				--	5:6-50	HTRI-R	"C/L6/WC/5F/CM50/AHU RM CM W/C"

5:6-50 HTRI-R "C/L6/WC/5F/CM50/AHU RM CM W/C"

```
| | | | | Switch ""
| | | | | -- Relay
| | | | | -- 5:6-51 HFP-11 "C/L6/WC/5F/SD51/AHU RM "
| | | | | -- 5:6-52 HFP-11 "C/L6/WC/5F/SD52/CORR NR CW 5172"
| | | | | -- 5:6-53 HFP-11 "C/L6/WC/5F/SD53/CORR NR CW 5172"
| | | | | -- 5:6-54 HFP-11 "C/L6/WC/5F/SD54/CORR NR CW 5171"
| | | | | -- 5:6-55 HFP-11 "C/L6/WC/5F/SD55/CORR NR CW 5150"
| | | | | -- 5:6-56 HFP-11 "C/L6/WC/5F/SD56/CORR NR CW 5150"
| | | | | -- 5:6-57 HFP-11 "C/L6/WC/5F/SD57/CORR NR CW 5060"
| | | | | -- 5:6-58 HFP-11 "C/L6/WC/5F/SD58/CORR NR CW5/S18"
| | | | | -- 5:6-59 HTRI-S "C/L6/5F/MM59/CC6013"
| | | | | -- 5:6-60 HMS-S/D/M/SA "C/L6/WC/5F/MCP60/FIRE ESC STR"
| | | | | -- 5:6-61 HTRI-R "C/L6/WC/5F/CM61/FIRE ESC STR MCP"
| | | | | Switch ""
| | | | | -- Relay
| | | | | -- 5:6-77 HTRI-S "C/L6/5F/MM77/CW5060"
| | | | | -- 5:6-79 HTRI-S "C/L6/5F/MM79/CW5140"
| | | | | -- 5:6-80 HTRI-S "C/L6/5F/MM80/CW5150"
| | | | | -- 5:6-83 HTRI-S "C/L6/5F/MM83/CW5020"
| | | | | -- 5:6-84 HTRI-S "C/L6/5F/MM84/CW5160"
| | | | | -- 5:6-85 HTRI-S "C/L6/5F/MM85/CW5010"
| | | | | -- 5:6-87 HTRI-S "C/L6/5F/MM87/CW5172"
| | | | | -- 5:6-90 HTRI-S "C/L6/5F/MM90/BW5081"
| | | | | -- 5:6-91 HTRI-S "C/L6/5F/MM91/BW5072"
| | | | | -- 5:6-92 HTRI-S "C/L6/5F/MM92/BW5071"
| | | | | -- 5:6-93 HTRI-S "C/L6/5F/MM93/BW5062"
| | | | | -- 5:6-94 HTRI-S "C/L6/5F/MM94/BW5091"
| | | | | -- 5:6-96 HTRI-S "C/L6/5F/MM96/BW5052"
| | | | | -- 5:6-97 HTRI-S "C/L6/5F/MM97/BW5051"
| | | | | -- 5:6-98 HTRI-S "C/L6/6F/MM98/CW6062"
| | | | | -- 5:6-99 HTRI-S "C/L6/6F/MM99/CW6063"
| | | | | -- 5:6-100 HTRI-S "C/L6/6F/MM100/CW6052"
| | | | | -- 5:6-101 HTRI-S "C/L6/6F/MM101/CW6056B"
| | | | | -- 5:6-103 HTRI-S "C/L6/6F/MM103/CW6021"
| | | | | -- 5:6-107 HTRI-S "C/L6/6F/MM107/CW6163"
| | | | | -- 5:6-110 HFP-11 "C/L6/BW5061/SD110/Pantry"
| | | | | -- 5:6-111 HFP-11 "C/L6/BW5061/SD111/Passage Area"
| | | | | -- 5:6-112 HFP-11 "C/L6/BW5061/SD112/Accounts Cabin"
| | | | | -- 5:6-113 HFP-11 "C/L6/BW5061/SD113/Buyers Cabin"
| | | | | -- 5:6-114 HFP-11 "C/L6/BW5061/SD114/Main Cabin"
| | | | | -- 5:6-115 HTRI-R "C/L6/BW5061/CM115/Entry Door"
| | | | | -- Switch ""
| | | | | -- Relay
| | | | | -- 5:6-116 HMS-S/D/M/SA "C/L6/BW5061/MCP116/Entry Door"
| | | | | -- 5:6-117 HFP-11 "C/L6/BW6022/SD117/Account Cab"
| | | | | -- 5:6-118 HFP-11 "C/L6/BW6022/SD118/Main Cab"
| | | | | -- 5:6-119 HFP-11 "C/L6/BW6022/SD119/ Assort Cab 2"
| | | | | -- 5:6-120 HFP-11 "C/L6/BW6022/SD120/ Assort Cab 1"
| | | | | -- 5:6-121 HFP-11 "C/L6/BW6022/SD121/ Psg Nr Pantry"
| | | | | -- 5:6-122 HFP-11 "C/L6/BW6022/SD122/Pantry"
```


5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:6 DLC "DLC @ address 6 L6"

```
|      |      |      |-- 5:6-123 HFP-11 "C/L6/BW6022/SD123/Reception"
|      |      |      |-- 5:6-124 HMS-S/D/M/SA "C/L6/BW6022/MCP124/Entry Psg"
|      |      |      |-- 5:6-125 HTRI-R "C/L6/BW6022/CM125/Entry Psg AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:6-129 HTRI-S "C/L6/5F/MM129/CW6061"
|      |      |      |-- 5:6-143 HFP-11 "C/L6/CW5130/SD143/Pnty"
|      |      |      |-- 5:6-144 HFP-11 "C/L6/CW5130/SD144/Main cab 2"
|      |      |      |-- 5:6-145 HFP-11 "C/L6/CW5130/SD145/asst cab"
|      |      |      |-- 5:6-146 HFP-11 "C/L6/CW5130/SD146/Main cab 1"
|      |      |      |-- 5:6-147 HTRI-R "C/L6/CW5130/CM147/Psg nr Ent Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:6-148 HMS-S/D/M/SA "C/L6/CW 5130/MCP148/Psg nr Ent D"
|      |      |      |-- 5:6-149 HFPT-11 "C/L6/CW5030/HD149/Pantry"
|      |      |      |-- 5:6-150 HFP-11 "C/L6/CW5030/SD150/Accounts cab"
|      |      |      |-- 5:6-151 HFPT-11 "C/L6/CW5030/HD151/Cab 1"
|      |      |      |-- 5:6-152 HFP-11 "C/L6/CW5030/SD152/Main cab"
|      |      |      |-- 5:6-153 HFP-11 "C/L6/CW5030/SD153/Main cab"
|      |      |      |-- 5:6-154 HFP-11 "C/L6/CW5030/SD154/Assorter cab"
|      |      |      |-- 5:6-155 HFP-11 "C/L6/CW5030/SD155/Psg nr Assorte"
|      |      |      |-- 5:6-156 HTRI-R "C/L6/CW5030/CM156/Psg nr Entry D"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:6-157 HMS-S/D/M/SA "C/L6/CW5030/MCP157/Psg nr Entry "
|      |      |      |-- 5:6-158 HFP-11 "C/L6/CW5050/SD158/Pnty"
|      |      |      |-- 5:6-159 HFP-11 "C/L6/CW5050/SD159/Accs cab"
|      |      |      |-- 5:6-160 HFP-11 "C/L6/CW5050/SD160/Main cab"
|      |      |      |-- 5:6-161 HTRI-R "C/L6/CW5050/CM161/Psg nr Ent Dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:6-162 HMS-S/D/M/SA "C/L6/CW5050/MCP162/Psg nr Ent Dr"
|      |      |      |-- 5:6-163 HFP-11 "C/L6/CW6161/SD163/Psg Nr Washrm"
|      |      |      |-- 5:6-164 HFP-11 "C/L6/CW6161/SD164/Vishal Cab"
|      |      |      |-- 5:6-165 HFP-11 "C/L6/CW6161/SD165/Psg nr Pantry"
|      |      |      |-- 5:6-166 HFP-11 "C/L6/CW6161/SD166/Pantry"
|      |      |      |-- 5:6-167 HFP-11 "C/L6/CW6161/SD167/Assorter Cab"
|      |      |      |-- 5:6-168 HFP-11 "C/L6/CW6161/SD168/Assorter Cab"
|      |      |      |-- 5:6-169 HFP-11 "C/L6/CW6161/SD169/Assorter Cab"
|      |      |      |-- 5:6-170 HFP-11 "C/L6/CW6161/SD170/Assorting Cab"
|      |      |      |-- 5:6-171 HFP-11 "C/L6/CW6161/SD171/Reception Area"
|      |      |      |-- 5:6-172 HFP-11 "C/L6/CW6161/SD172/Assorting Cab"
|      |      |      |-- 5:6-173 HTRI-R "C/L6/CW6161/CM173/AFC Reception "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:6-174 HMS-S/D/M/SA "C/L6/CW6161/MCP174/Reception Are"
|      |      |      |-- 5:6-183 HFP-11 "C/L6/BW6030A/SD183/Psg near Entr"
|      |      |      |-- 5:6-184 HFP-11 "C/L6/BW6030A/SD184/Cabin 1"
|      |      |      |-- 5:6-185 HFP-11 "C/L6/BW6030A/SD185/Cabin 2"
|      |      |      |-- 5:6-186 HFP-11 "C/L6/BW6030A/SD186/Psg near cabi"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:6 DLC "DLC @ address 6 L6"

```
|      |      |      |-- 5:6-187 HTRI-R "C/L6/BW6030A/CM187/Psg near Entr"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 5:6-188 HMS-S/D/M/SA "C/L6/BW6030A/MCP188/Psg near Ent"
|      |      |      |-- 5:6-191 HFPT-11 "C/L6/CW8021/HD191/Pantry"
|      |      |      |-- 5:6-192 HFP-11 "C/L6/CW8021/SD192/Entry Psg"
|      |      |      |-- 5:6-193 HFP-11 "C/L6/CW8021/SD193/Assorter cab P"
|      |      |      |-- 5:6-194 HFP-11 "C/L6/CW8021/SD194/Assorter cab P"
|      |      |      |-- 5:6-195 HFP-11 "C/L6/CW8021/SD195/Assorter cab P"
|      |      |      |-- 5:6-196 HFP-11 "C/L6/CW8021/SD196/Assorter cab P"
|      |      |      |-- 5:6-197 HFP-11 "C/L6/CW8021/SD197/Assorter cab P"
|      |      |      |-- 5:6-198 HFP-11 "C/L6/CW8021/SD198/Assorter cab P"
|      |      |      |-- 5:6-199 HFP-11 "C/L6/CW8021/SD199/Cab 1"
|      |      |      |-- 5:6-200 HMS-S/D/M/SA "C/L6/CW8021/MCP200/Entry dr Psg"
|      |      |      |-- 5:6-201 HTRI-R "C/L6/CW8021/CM201/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 5:6-202 HFP-11 "C/L6/CW6161/SD202/Accounts Cab"
|      |      |      |-- 5:6-203 HFP-11 "C/L6/CW6161/SD203/Accounts Cab"
|      |      |      |-- 5:6-204 HFP-11 "C/L6/CW6161/SD204/Vishal Cab"
|      |      |      |-- 5:6-205 HFP-11 "C/L6/CW6161/SD205/Conference Cab"
|      |      |      |-- 5:6-206 HFP-11 "C/L6/CW6161/SD206/Manoj Bhai Cab"
|      |      |      |-- 5:6-207 HFP-11 "C/L6/CW6161/SD207/Kiran Bhai Cab"
|      |      |      |-- 5:6-208 HMS-S/D/M/SA "C/L6/CW6161/MCP208/Kiran Bhai Ca"
|      |      |      |-- 5:6-209 HFP-11 "C/L6/CW6055/SD209/Account Cab"
|      |      |      |-- 5:6-210 HFP-11 "C/L6/CW6055/SD210/Back Office"
|      |      |      |-- 5:6-211 HFP-11 "C/L6/CW6055/SD211/Buyer Cab"
|      |      |      |-- 5:6-212 HFP-11 "C/L6/CW6055/SD212/Sales Cab"
|      |      |      |-- 5:6-213 HFP-11 "C/L6/CW6055/SD213/Main Cab"
|      |      |      |-- 5:6-214 HFP-11 "C/L6/CW6055/SD214/PsgNrMain Cab"
|      |      |      |-- 5:6-215 HFP-11 "C/L6/CW6055/SD215/Assortment Cab"
|      |      |      |-- 5:6-216 HFP-11 "C/L6/CW6055/SD216/Purchase Cab"
|      |      |      |-- 5:6-217 HFP-11 "C/L6/CW6055/SD217/PsgNrKitchen"
|      |      |      |-- 5:6-218 HFP-11 "C/L6/CW6055/SD218/PsgNrReception"
|      |      |      |-- 5:6-219 HFPT-11 "C/L6/CW6055/HD219/Pantry"
|      |      |      |-- 5:6-220 HFP-11 "C/L6/CW6055/SD220/Reception"
|      |      |      |-- 5:6-226 HMS-S/D/M/SA "C/L6/CW6055/MCP226/Entry Psg"
|      |      |      |-- 5:6-227 HTRI-R "C/L6/CW6055/CM227/Entry Psg Cupb"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 5:6-231 HFP-11 "C/L6/CC6012/SD231/Entry Psg"
|      |      |      |-- 5:6-232 HFP-11 "C/L6/CC6012/SD232/PsgNrCab1"
|      |      |      |-- 5:6-233 HFP-11 "C/L6/CC6012/SD233/Cab 1"
|      |      |      |-- 5:6-234 HFP-11 "C/L6/CC6012/SD234/Cab 2"
|      |      |      |-- 5:6-235 HFP-11 "C/L6/CC6012/SD235/Cab 3"
|      |      |      |-- 5:6-236 HFP-11 "C/L6/CC6012/SD236/Cab 4"
|      |      |      |-- 5:6-237 HFP-11 "C/L6/CC6012/SD237/Main Cab"
|      |      |      |-- 5:6-238 HFP-11 "C/L6/CC6012/SD238/Main Cab2"
|      |      |      |-- 5:6-239 HFP-11 "C/L6/CC6012/SD239/Account Cab"
|      |      |      |-- 5:6-240 HFP-11 "C/L6/CC6012/SD240/Reception Cab"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:6 DLC "DLC @ address 6 L6"

```
|      |      |      |-- 5:6-241 HFP-11 "C/L6/CC6012/SD241/Psg Nr Account"
|      |      |      |-- 5:6-242 FDOT421 "C/L6/CC6012/SD242/Pantry"
|      |      |      |-- 5:6-243 HMS-S/D/M/SA "C/L6/CC6012/MCP243/Entry Psg"
|      |      |      |-- 5:6-244 HTRI-R "C/L6/CC6012/CM244/Recep AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:11 NIC-C(HNet) "NIC @ address 11"
|      |      |      |-- 5:13 DLC "DLC @ address 13 L10"
|      |      |      |-- 5:13-1 HFP-11 "C/L10/CC1010/SD1/Main cab"
|      |      |      |-- 5:13-2 HFP-11 "C/L10/CC1010/SD2/Entry Psg"
|      |      |      |-- 5:13-3 HTRI-R "C/L10/CC1010/CM3/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:13-4 HMS-S/D/M/SA "C/L10/CC1010/MCP4/Entry Psg"
|      |      |      |-- 5:13-5 HFP-11 "C/L10/CC1020/SD5/Main cab"
|      |      |      |-- 5:13-6 HFP-11 "C/L10/CC1020/SD6/Assorter cab"
|      |      |      |-- 5:13-7 HFP-11 "C/L10/CC1020/SD7/Entry Psg"
|      |      |      |-- 5:13-8 HTRI-R "C/L10/CC1020/CM8/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:13-9 HMS-S/D/M/SA "C/L10/CC1020/MCP9/Entry Psg"
|      |      |      |-- 5:13-10 HFP-11 "C/L10/CC1040/SD10/Main cab 1"
|      |      |      |-- 5:13-11 HFP-11 "C/L10/CC1040/SD11/Main cab 2"
|      |      |      |-- 5:13-12 HFP-11 "C/L10/CC1040/SD12/Accounts cab"
|      |      |      |-- 5:13-13 HFP-11 "C/L10/CC1040/SD13/Psg nr Account"
|      |      |      |-- 5:13-14 HFP-11 "C/L10/CC1040/SD14/Pantry"
|      |      |      |-- 5:13-15 HTRI-R "C/L10/CC1040/SD15/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:13-16 HMS-S/D/M/SA "C/L10/CC1040/MCP16/Entry dr Psg"
|      |      |      |-- 5:13-17 HFP-11 "C/L10/CC1170/SD17/Main cab"
|      |      |      |-- 5:13-18 HFP-11 "C/L10/CC1170/SD18/Main cab"
|      |      |      |-- 5:13-19 HFP-11 "C/L10/CC1170/SD19/Accounts cab"
|      |      |      |-- 5:13-20 HFP-11 "C/L10/CC1170/SD20/Entry Psg"
|      |      |      |-- 5:13-21 HFP-11 "C/L10/CC1170/SD21/Pantry"
|      |      |      |-- 5:13-22 HTRI-R "C/L10/CC1170/CM22/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 5:13-23 HMS-S/D/M/SA "C/L10/CC1170/MCP23/Entry Psg"
|      |      |      |-- 5:13-24 HFP-11 "C/L10/CC1180A/SD24/Main cab"
|      |      |      |-- 5:13-25 HFP-11 "C/L10/CC1180A/SD25/Ankitbhai cab"
|      |      |      |-- 5:13-26 HFP-11 "C/L10/CC1180A/SD26/Arvindbhai ca"
|      |      |      |-- 5:13-27 HFP-11 "C/L10/CC1180A/SD27/B3 cab"
|      |      |      |-- 5:13-28 HFP-11 "C/L10/CC1180A/SD28/B2 cab"
|      |      |      |-- 5:13-29 HFP-11 "C/L10/CC1180A/SD29/B1 cab"
|      |      |      |-- 5:13-30 HFP-11 "C/L10/CC1180A/SD30/B1 cab"
|      |      |      |-- 5:13-31 HFP-11 "C/L10/CC1180A/SD31/Entry Psg"
|      |      |      |-- 5:13-32 HTRI-R "C/L10/CC1180A/CM32/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:13 DLC "DLC @ address 13 L10"

```
|      |      |-- 5:13-33 HMS-S/D/M/SA "C/L10/CC1180A/MCP33/Entry Psg"
|      |      |-- 5:13-34 HFP-11 "C/L10/CC2030/SD34/Cab 3"
|      |      |-- 5:13-35 HFP-11 "C/L10/CC2030/SD35/Cab 2"
|      |      |-- 5:13-36 HFP-11 "C/L10/CC2030/SD36/Main cab"
|      |      |-- 5:13-37 HFP-11 "C/L10/CC2030/SD37/Psg nr Main ca"
|      |      |-- 5:13-38 HTRI-R "C/L10/CC2030/CM38/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 5:13-39 HMS-S/D/M/SA "C/L10/CC2030/MCP39/Entry dr Psg"
|      |      |-- 5:13-40 HFP-11 "C/L10/CC2050/SD40/Entry Psg"
|      |      |-- 5:13-41 HFP-11 "C/L10/CC2050/SD41/Pantry"
|      |      |-- 5:13-42 HFP-11 "C/L10/CC2050/SD42/Reception Psg"
|      |      |-- 5:13-43 HFP-11 "C/L10/CC2050/SD43/Lunch cab"
|      |      |-- 5:13-44 HFP-11 "C/L10/CC2050/SD44/Accounts cab1"
|      |      |-- 5:13-45 HFP-11 "C/L10/CC2050/SD45/Main cab"
|      |      |-- 5:13-46 HFP-11 "C/L10/CC2050/SD46/Accounts cab2"
|      |      |-- 5:13-47 HFP-11 "C/L10/CC2050/SD47/Accounts cab3"
|      |      |-- 5:13-48 HTRI-R "C/L10/CC2050/CM48/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 5:13-49 HMS-S/D/M/SA "C/L10/CC2050/MCP49/Entry dr Psg"
|      |      |-- 5:13-50 HFP-11 "C/L10/CC3160/SD50/Main cab"
|      |      |-- 5:13-51 HFP-11 "C/L10/CC3160/SD51/Cab 1"
|      |      |-- 5:13-52 HFP-11 "C/L10/CC3160/SD52/Psg nr MC"
|      |      |-- 5:13-53 HFP-11 "C/L10/CC3160/SD53/Cab 2"
|      |      |-- 5:13-54 HFP-11 "C/L10/CC3160/SD54/Pantry"
|      |      |-- 5:13-55 HTRI-R "C/L10/CC3160/CM55/AFC Pantry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 5:13-56 HMS-S/D/M/SA "C/L10/CC3160/CM56/Pantry Psg"
|      |      |-- 5:13-57 HFP-11 "C/L10/CC2140/SD57/Main cab"
|      |      |-- 5:13-58 HFP-11 "C/L10/CC2140/SD58/Cab 1"
|      |      |-- 5:13-59 HFP-11 "C/L10/CC2140/SD59/Cab 2"
|      |      |-- 5:13-60 HFP-11 "C/L10/CC2140/SD60/Pantry Psg"
|      |      |-- 5:13-61 HTRI-R "C/L10/CC2140/CM61/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 5:13-62 HMS-S/D/M/SA "C/L10/CC2140/MCP62/Entry dr Psg"
|      |      |-- 5:13-63 HFP-11 "C/L10/CC2220/SD63/Main cab1"
|      |      |-- 5:13-64 HFP-11 "C/L10/CC2220/SD64/Main cab2"
|      |      |-- 5:13-65 HFP-11 "C/L10/CC2220/SD65/Assorter cab"
|      |      |-- 5:13-66 HFP-11 "C/L10/CC2220/SD66/Pantry Psg"
|      |      |-- 5:13-67 HFP-11 "C/L10/CC2220/SD67/Entry dr Psg"
|      |      |-- 5:13-68 HTRI-R "C/L10/CC2220/CM68/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 5:13-69 HMS-S/D/M/SA "C/L10/CC2220/MCP69/Entry dr Psg"
|      |      |-- 5:13-76 HFP-11 "C/L10/CC3040/SD76/Main cab"
|      |      |-- 5:13-77 HFP-11 "C/L10/CC3040/SD77/Pantry"
|      |      |-- 5:13-78 HFP-11 "C/L10/CC3040/SD78/Assorter cab"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:13 DLC "DLC @ address 13 L10"

```
|      |      |-- 5:13-79 HMS-S/D/M/SA "C/L10/CC3040/MCP79/Entry dr Psg"
|      |      |-- 5:13-80 HTRI-R "C/L10/CC3040/CM80/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 5:13-81 HFP-11 "C/L10/SD81/CC3040/ENTRY PSG"
|      |      |-- 5:13-82 HFP-11 "C/L10/CC3250/SD82/Main cab"
|      |      |-- 5:13-83 HFP-11 "C/L10/CC3250/SD83/Assorter cab"
|      |      |-- 5:13-84 HFP-11 "C/L10/CC3250/SD84/Entry Psg"
|      |      |-- 5:13-85 HTRI-R "C/L10/CC3250/CM85/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 5:13-86 HMS-S/D/M/SA "C/L10/CC3250/MCP86/Entry Psg"
|      |      |-- 5:13-87 HFP-11 "C/L10/CC3240/SD87/Main cab 1"
|      |      |-- 5:13-88 HFP-11 "C/L10/CC3240/SD88/Main cab 2"
|      |      |-- 5:13-89 HFP-11 "C/L10/CC3240/SD89/Account cab"
|      |      |-- 5:13-90 HFP-11 "C/L10/CC3240/SD90/Entry Psg"
|      |      |-- 5:13-91 HFP-11 "C/L10/CC3240/SD91/Pantry"
|      |      |-- 5:13-92 HTRI-R "C/L10/CC3240/CM92/AFC Entry dr P"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 5:13-93 HMS-S/D/M/SA "C/L10/CC3240/MCP93/Entry dr Psg"
|      |      |-- 5:13-94 HFP-11 "C/L10/CC1090/SD94/Main cab"
|      |      |-- 5:13-95 HFP-11 "C/L10/CC1090/SD95/Account cab"
|      |      |-- 5:13-96 HFP-11 "C/L10/CC1090/SD96/Entry Psg"
|      |      |-- 5:13-97 HTRI-R "C/L10/CC1090/CM97/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 5:13-98 HMS-S/D/M/SA "C/L10/CC1090/MCP98/Entry Psg"
|      |      |-- 5:13-99 HFP-11 "C/L10/CC1140/SD99/Main cab"
|      |      |-- 5:13-100 HFP-11 "C/L10/CC1140/SD100/Cab 1"
|      |      |-- 5:13-101 HFP-11 "C/L10/CC1140/SD101/Entry dr psg"
|      |      |-- 5:13-102 HTRI-R "C/L10/CC1140/CM102/Entry dr psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 5:13-103 HMS-S/D/M/SA "C/L10/CC1140/MCP103/Entry dr psg"
|      |      |-- 5:13-104 HFP-11 "C/L10/CC2210/SD104/Main cab1"
|      |      |-- 5:13-105 HFP-11 "C/L10/CC2210/SD105/Main cab2"
|      |      |-- 5:13-106 HFP-11 "C/L10/CC2210/SD106/Entry Psg"
|      |      |-- 5:13-107 HFPT-11 "C/L10/CC2210/HD107/Pantry"
|      |      |-- 5:13-108 HTRI-R "C/L10/CC2210/CM108/AFC Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 5:13-109 HMS-S/D/M/SA "C/L10/CC2210/MCP109/Entry Psg"
|      |      |-- 5:13-110 HFP-11 "C/L10/CC3230/SD110/Main cab1"
|      |      |-- 5:13-111 HFP-11 "C/L10/CC3230/SD111/Main cab2"
|      |      |-- 5:13-112 HFP-11 "C/L10/CC3230/SD112/Assorter cab"
|      |      |-- 5:13-113 HFP-11 "C/L10/CC3230/SD113/AFC Assorter "
|      |      |-- 5:13-115 HFP-11 "C/L10/CC3230/SD115/Entry Psg"
|      |      |-- 5:13-116 HTRI-R "C/L10/CC3230/CM116/Entry Psg"
|      |      |  |-- Switch ""
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:13 DLC "DLC @ address 13 L10"

5:13-116 HTRI-R "C/L10/CC3230/CM116/Entry Psg"

```
|      |      |      |  |-- Relay
|      |      |      |  |-- 5:13-117 HMS-S/D/M/SA "C/L10/CC3230/MCP117/Entry Psg"
|      |      |      |  |-- 5:13-118 HFP-11 "C/L10/CC3190/SD118/Main cab"
|      |      |      |  |-- 5:13-119 HFP-11 "C/L10/CC3190/SD119/Assorter cab"
|      |      |      |  |-- 5:13-120 HFP-11 "C/L10/CC3190/SD120/Psg nr MC"
|      |      |      |  |-- 5:13-121 HFP-11 "C/L10/CC3190/SD121/Accounts cab"
|      |      |      |  |-- 5:13-122 HFPT-11 "C/L10/CC3190/HD122/Pantry"
|      |      |      |  |-- 5:13-123 HTRI-R "C/L10/CC3190/CM123/AFC Pantry"
|      |      |      |  |  |-- Switch ""
|      |      |      |  |  |-- Relay
|      |      |      |  |-- 5:13-124 HMS-S/D/M/SA "C/L10/CC3190/MCP124/Psg nr Pantr"
|      |      |      |  |-- 5:13-125 HFP-11 "C/L10/CC3070/SD125/Account cab"
|      |      |      |  |-- 5:13-126 HFP-11 "C/L10/CC3070/SD126/Main cab"
|      |      |      |  |-- 5:13-127 HFP-11 "C/L10/CC3070/SD127/Assorter cab"
|      |      |      |  |-- 5:13-128 HFP-11 "C/L10/CC3070/SD128/Pantry"
|      |      |      |  |-- 5:13-129 HFP-11 "C/L10/CC3070/SD129/Psg Nr Main c"
|      |      |      |  |-- 5:13-130 HMS-S/D/M/SA "C/L10/CC3070/MCP130/Entry dr Psg"
|      |      |      |  |-- 5:13-131 HFP-11 "C/L10/CC3200/SD131/Accounts cab"
|      |      |      |  |-- 5:13-132 HFP-11 "C/L10/CC3200/SD132/Main cab"
|      |      |      |  |-- 5:13-133 HFP-11 "C/L10/CC3200/SD133/Assorter cab "
|      |      |      |  |-- 5:13-134 HFP-11 "C/L10/CC3200/SD134/Assorter cab "
|      |      |      |  |-- 5:13-135 HFP-11 "C/L10/CC3200/SD135/Psg nr Assort"
|      |      |      |  |-- 5:13-136 HFP-11 "C/L10/CC3200/SD136/Pantry"
|      |      |      |  |-- 5:13-137 HTRI-R "C/L10/CC3200/CM137/AFC Accounts "
|      |      |      |  |  |-- Switch ""
|      |      |      |  |  |-- Relay
|      |      |      |  |-- 5:13-138 HMS-S/D/M/SA "C/L10/CC3200/MCP138/Entry dr Psg"
|      |      |      |  |-- 5:13-139 HFP-11 "C/L10/CC3182/SD139/Main cab"
|      |      |      |  |-- 5:13-140 HFP-11 "C/L10/CC3182/SD140/Assorter cab "
|      |      |      |  |-- 5:13-141 HFP-11 "C/L10/CC3182/SD141/Account cab"
|      |      |      |  |-- 5:13-142 HFP-11 "C/L10/CC3182/SD142/Assorter cab "
|      |      |      |  |-- 5:13-143 FDOT421 "C/L10/CC3182/SD143/Entry Psg"
|      |      |      |  |-- 5:13-144 HFP-11 "C/L10/CC3182/SD144/Pantry rm"
|      |      |      |  |-- 5:13-145 HTRI-R "C/L10/CC3182/CM145/Entry Psg"
|      |      |      |  |  |-- Switch ""
|      |      |      |  |  |-- Relay
|      |      |      |  |-- 5:13-146 HMS-S/D/M/SA "C/L10/CC3182/MCP146/Entry Psg"
|      |      |      |  |-- 5:13-147 HFP-11 "C/L10/CC1110/SD147/Main cab"
|      |      |      |  |-- 5:13-148 HFP-11 "C/L10/CC2180/SD148/MAIN cab"
|      |      |      |  |-- 5:13-149 HFP-11 "C/L10/CC2180/SD149/MAIN CAB "
|      |      |      |  |-- 5:13-150 HFP-11 "C/L10/CC2180/SD150/ASSORTER cab"
|      |      |      |  |-- 5:13-151 HFP-11 "C/L10/CC2180/SD151/PANTRY"
|      |      |      |  |-- 5:13-152 HFP-11 "C/L10/CC2180/SD152/ACCOUNTS cab"
|      |      |      |  |-- 5:13-153 HFP-11 "C/L10/CC2180/SD153/PSG NR PANTRY"
|      |      |      |  |-- 5:13-154 HTRI-R "C/L10/CC2180/CM154/AFC Entry dr"
|      |      |      |  |  |-- Switch ""
|      |      |      |  |  |-- Relay
|      |      |      |  |-- 5:13-155 HMS-S/D/M/SA "C/L10/CC2180/MCP155/Entry dr"
|      |      |      |  |-- 5:13-156 HTRI-R "C/L10/CC1110/CM156/Entry dr Psg"
|      |      |      |  |  |-- Switch ""
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:13 DLC "DLC @ address 13 L10"

5:13-156 HTRI-R "C/L10/CC1110/CM156/Entry dr Psg"

```
|      |      |      |  |-- Relay
|      |      |  |-- 5:13-157 HMS-S/D/M/SA "C/L10/CC1110/MCP157/Entry dr Psg"
|      |      |  |-- 5:13-158 HFP-11 "C/L10/CC1100/SD158/Main cab1"
|      |      |  |-- 5:13-159 HFP-11 "C/L10/CC1100/SD159/Main cab2"
|      |      |  |-- 5:13-160 HFP-11 "C/L10/CC1100/SD160/Pantry"
|      |      |  |-- 5:13-161 HTRI-R "C/L10/CC1100/CM161/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 5:13-162 HMS-S/D/M/SA "C/L10/CC1100/MCP162/Entry dr psg"
|      |      |  |-- 5:13-163 HTRI-R "C/L10/CC3070/CM163/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 5:13-164 HFP-11 "C/L10/SD164/CC1070/MAIN CABIN"
|      |      |  |-- 5:13-165 HFP-11 "C/L10/SD165/CC1070/ASSORTOR CABI"
|      |      |  |-- 5:13-166 HFP-11 "C/L10/SD166/CC1070/ASSORTOR CABI"
|      |      |  |-- 5:13-167 HFP-11 "C/L10/SD167/CC1070/ACCOUNT CABIN"
|      |      |  |-- 5:13-168 HFP-11 "C/L10/SD168/CC1070/PSG NR ASSORT"
|      |      |  |-- 5:13-169 HTRI-R "C/L10/CM169/CC1070/ENTRY PSG AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 5:13-170 HMS-S/D/M/SA "C/L10/MCP170/CC1070/ENTRY PSG"
|      |      |  |-- 5:13-171 HFP-11 "C/L10/CC3182/SD171/Cab 6"
|      |      |  |-- 5:13-172 FDOT421 "C/L10/CC3182/SD172/Cab 7"
|      |      |  |-- 5:13-175 HFP-11 "C/L10/CC1160/SD175/Main cab"
|      |      |  |-- 5:13-176 HFP-11 "C/L10/CC1160/SD176/ASSORTER cab"
|      |      |  |-- 5:13-177 HFPT-11 "C/L10/CC1160/HD177/PANTRY"
|      |      |  |-- 5:13-178 HTRI-R "C/L10/CC1160/CM178/ENTRY DR PSG"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 5:13-179 HMS-S/D/M/SA "C/L10/CC1160/MCP179/ENTRY DR PSG"
|      |      |  |-- 5:13-181 HFP-11 "C/L10/CC3100/SD181/Conference RM"
|      |      |  |-- 5:13-182 HFP-11 "C/L10/CC3100/SD182/Conference RM"
|      |      |  |-- 5:13-183 HFP-11 "C/L10/CC3100/SD183/Stock RM"
|      |      |  |-- 5:13-184 HFP-11 "C/L10/CC3100/SD184/Stock RM"
|      |      |  |-- 5:13-185 HFP-11 "C/L10/CC3100/SD185/Strong RM"
|      |      |  |-- 5:13-186 HFP-11 "C/L10/CC3100/SD186/Cab-12"
|      |      |  |-- 5:13-187 HFP-11 "C/L10/CC3100/SD187/Cab-15"
|      |      |  |-- 5:13-188 HFP-11 "C/L10/CC3100/SD188/G.L Cabin"
|      |      |  |-- 5:13-189 HFP-11 "C/L10/CC3100/SD189/H.K Cabin"
|      |      |  |-- 5:13-190 HFP-11 "C/L10/CC3100/SD190/Reception Cab"
|      |      |  |-- 5:13-191 HFP-11 "C/L10/CC3100/SD191/Main Entry Ps"
|      |      |  |-- 5:13-192 HFP-11 "C/L10/CC3100/SD192/Cab-11"
|      |      |  |-- 5:13-193 HFP-11 "C/L10/CC3100/SD193/Lunch RM"
|      |      |  |-- 5:13-194 HFP-11 "C/L10/CC3100/SD194/Cab-10"
|      |      |  |-- 5:13-195 HFPT-11 "C/L10/CC3100/HD195/Front Pantry"
|      |      |  |-- 5:13-196 HFP-11 "C/L10/CC3100/SD196/7-C Cab"
|      |      |  |-- 5:13-197 HFP-11 "C/L10/CC3100/SD197/Admin Cab"
|      |      |  |-- 5:13-198 HFP-11 "C/L10/CC3100/SD198/Admin Cab"
|      |      |  |-- 5:13-199 HFP-11 "C/L10/CC3100/SD199/Lab Cab"
|      |      |  |-- 5:13-200 HFP-11 "C/L10/CC3100/SD200/Cab-6"
```

5 Desigo Fire Safety Modular "BDB TOWER C" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

5:13 DLC "DLC @ address 13 L10"

```
|      |      |-- 5:13-201 HFP-11 "C/L10/CC3100/SD201/Cab-5"
|      |      |-- 5:13-202 FDOT421 "C/L10/CC3100/SD202/Export Cab"
|      |      |-- 5:13-203 FDOT421 "C/L10/CC3100/SD203/Cab-3"
|      |      |-- 5:13-204 FDOT421 "C/L10/CC3100/SD204/Gageing Cab"
|      |      |-- 5:13-205 HFP-11 "C/L10/CC3100/SD205/Cab-4"
|      |      |-- 5:13-206 HFP-11 "C/L10/CC3100/SD206/Cab-14"
|      |      |-- 5:13-207 HFP-11 "C/L10/CC3100/SD207/Cab-9"
|      |      |-- 5:13-208 HFP-11 "C/L10/CC3100/SD208/Cab-8"
|      |      |-- 5:13-209 HFP-11 "C/L10/CC3100/SD209/Cab-2"
|      |      |-- 5:13-210 HFP-11 "C/L10/CC3100/SD210/Server RM"
|      |      |-- 5:13-211 HFP-11 "C/L10/CC3100/SD211/Psg Nr Back P"
|      |      |-- 5:13-212 HFP-11 "C/L10/CC3100/SD212/Psg Nr Cab 15"
|      |      |-- 5:13-213 HFPT-11 "C/L10/CC3100/HD213/Back Side Pan"
|      |      |-- 5:13-214 HFP-11 "C/L10/CC3100/SD214/Psg Nr Server"
|      |      |-- 5:13-215 HFP-11 "C/L10/CC3100/SD215/Cab-1"
|      |      |-- 5:13-216 HFP-11 "C/L10/CC3100/SD216/Cab-1"
|      |      |-- 5:13-217 HFP-11 "C/L10/CC3100/SD217/Cab-1"
|      |      |-- 5:13-218 FDOT421 "C/L10/CC3100/SD218/Cab-7"
|      |      |-- 5:13-219 FDOT421 "C/L10/CC3100/SD219/Psg Nr Cab-A"
|      |      |-- 5:13-220 FDOT421 "C/L10/CC3100/SD220/Psg Nr Cab-4"
|      |      |-- 5:13-221 FDOT421 "C/L10/CC3100/SD221/Psg Nr Cab-9"
|      |      |-- 5:13-222 FDOT421 "C/L10/CC3100/SD222/Psg Nr H.K Ca"
|      |      |-- 5:13-223 HMS-S/D/M/SA "C/L10/CC3100/MCP223/Main Entry "
|      |      |-- 5:13-224 HMS-S/D/M/SA "C/L10/CC3100/MCP224/Back Door Si"
|      |      |-- 5:13-225 HTRI-R "C/L10/CC3100/CM225/Server RM AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 5:13-226 HFP-11 "C/L10/CC3100/SD226/Psg nr Cab-7"
|      |-- 5:16 PSC-12 "PSC-12 @ address 11"
|          |-- 5:16-1 PSC Relay "Relay @ 011:001 - Common Alarm"
|          |-- 5:16-2 PSC Relay "Relay @ 011:002 - Common Trouble"
```

|-- 6 Desigo Fire Safety Modular "BDB TOWER D " Local

```
|      |-- System Flags
|      |-- History Log
|      |-- Behavior
|      |-- Voice
|      |-- Maintenance
|      |-- Field Devices
|      |-- Miscellaneous
|      |-- CAB-2 "CAB-2 Enclosure #1"
|      |      |-- CC-5 "Card Cage 5 Slots"
|      |      |      |-- 6:1 DLC "DLC @ address 1 L1"
|      |      |      |      |-- 6:1-1 HMS-S/D/M/SA "D/L1/EC/GND/MCP1/LIFT LOBBY"
|      |      |      |      |-- 6:1-2 HTRI-R "D/L1/EC/GND/CM2/LIFT LOBBY"
|      |      |      |      |      |-- Switch ""
|      |      |      |      |      |-- Relay
|      |      |      |      |-- 6:1-3 HTRI-S "D/L1/EC/GND/MM3/LIFT LOBBY"
|      |      |      |      |-- 6:1-4 FDOT421 "D/L1/EC/GND/SD4/ERM"
|      |      |      |      |-- 6:1-5 FDOT421 "D/L1/EC/GND/SD5/LIFT LOBBY"
|      |      |      |      |-- 6:1-6 FDOT421 "D/L1/EC/GND/SD6/LIFT LOBBY"
```


6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:1 DLC "DLC @ address 1 L1"

					-- 6:1-7 FDOT421 "D/L1/EC/GND/SD7/LIFT LOBBY"
					-- 6:1-8 HTRI-R "D/L1/EC/GND/CM8/AHU RM"
					-- Switch ""
					-- Relay
					-- 6:1-9 FDOT421 "D/L1/EC/GND/SD9/AHU RM"
					-- 6:1-10 HMS-S/D/M/SA "D/L1/CC/GND/MCP10/LIFT LOBBY"
					-- 6:1-11 HTRI-R "D/L1/CC/GND/CM11/LIFT LOBBY"
					-- Switch ""
					-- Relay
					-- 6:1-12 HTRI-S "D/L1/CC/GND/MM12/LIFT LOBBY"
					-- 6:1-13 FDOT421 "D/L1/CC/GND/SD13/ERM"
					-- 6:1-14 FDOT421 "D/L1/CC/GND/SD14/LIFT LOBBY"
					-- 6:1-15 FDOT421 "D/L1/CC/GND/SD15/LIFT LOBBY"
					-- 6:1-16 HTRI-R "D/L1/CC/GND/CM16/AHU RM"
					-- Switch ""
					-- Relay
					-- 6:1-17 FDOT421 "D/L1/CC/GND/SD17/AHU RM"
					-- 6:1-18 HMS-S/D/M/SA "D/L1/WC/GND/MCP18/LIFT LOBBY"
					-- 6:1-19 HTRI-R "D/L1/WC/GND/CM19/LIFT LOBBY"
					-- Switch ""
					-- Relay
					-- 6:1-20 HTRI-S "D/L1/WC/GND/MM20/LIFT LOBBY"
					-- 6:1-21 FDOT421 "D/L1/WC/GND/SD21/ERM"
					-- 6:1-22 FDOT421 "D/L1/WC/GND/SD22/LIFT LOBBY"
					-- 6:1-23 FDOT421 "D/L1/WC/GND/SD23/LIFT LOBBY"
					-- 6:1-24 FDOT421 "D/L1/WC/GND/SD24/LIFT LOBBY"
					-- 6:1-25 FDOT421 "D/L1/WC/GND/SD25/LIFT LOBBY"
					-- 6:1-26 HTRI-R "D/L1/WC/GND/CM26/AHU RM"
					-- Switch ""
					-- Relay
					-- 6:1-27 FDOT421 "D/L1/WC/GND/SD27/AHU RM"
					-- 6:1-104 HMS-S/D/M/SA "D/L1/CC/UB/MCP104/NEAR LIFT"
					-- 6:1-105 HTRI-R "D/L1/CC/UB/CM105/NEAR LIFT"
					-- Switch ""
					-- Relay
					-- 6:1-106 HTRI-S "D/L1/WC/UB/MM106/ELEC ROOM"
					-- 6:1-107 HTRI-R "D/L1/CC/UB/CM107/FIRE EXIT DOOR"
					-- Switch ""
					-- Relay
					-- 6:1-108 HTRI-R "D/L1/WC/UB/CM108/FIRE EXIT DOOR"
					-- Switch ""
					-- Relay
					-- 6:1-109 HTRI-R "D/L1/WC/UB/CM109/STAIRCASE"
					-- Switch ""
					-- Relay
					-- 6:1-110 HMS-S/D/M/SA "D/L1/WC/UB/MCP110/STAIRCASE"
					-- 6:1-111 HTRI-R "D/L1/WC/UB/CM111/ST COLUMN D425"
					-- Switch ""
					-- Relay
					-- 6:1-112 HMS-S/D/M/SA "D/L1/WC/UB/MCP112/ST COLUMN D425"

6 Desigo Fire Safety Modular "BDB TOWER D " Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
6:1 DLC "DLC @ address 1 L1"

					-- 6:1-113 HMS-S/D/M/SA "D/L1/WC/UB/MCP113/ST COLUMN D353"
					-- 6:1-114 HTRI-R "D/L1/WC/UB/CM114/ST COLUMN D353"
					-- Switch ""
					-- Relay
					-- 6:1-115 HMS-S/D/M/SA "D/L1/WC/UB/MCP115/ST COLUMN D402"
					-- 6:1-116 HTRI-R "D/L1/WC/UB/CM116/ST COLUMN D402"
					-- Switch ""
					-- Relay
					-- 6:1-117 HTRI-R "D/L1/CC/UB/CM117/ST COLUMN D386"
					-- Switch ""
					-- Relay
					-- 6:1-118 HMS-S/D/M/SA "D/L1/CC/UB/MCP118/ST COLUMN D386"
					-- 6:1-119 HTRI-R "D/L1/EC/UB/CM119/ST COLUMN 376"
					-- Switch ""
					-- Relay
					-- 6:1-121 HTRI-S "D/L1/EC/UB/MM121/ELEC ROOM"
					-- 6:1-122 HTRI-S "D/L1/EC/UB/MM122/LIFT MC ROOM"
					-- 6:1-123 HTRI-S "D/L1/CC/UB/MM123/ELEC ROOM"
					-- 6:1-124 FDOT421 "D/L1/CC/UB/SD124/CONTROL RM"
					-- 6:1-125 FDOT421 "D/L1/WC/UB/SD125/FAN ROOM"
					-- 6:1-126 FDOT421 "D/L1/WC/UB/SD126/FAN ROOM"
					-- 6:1-127 FDOT421 "D/L1/CC/UB/SD127/ELEC ROOM"
					-- 6:1-128 FDOT421 "D/L1/EC/UB/SD128/ELEC ROOM"
					-- 6:1-129 FDOT421 "D/L1/EC/UB/SD129/LIFT MC RM"
					-- 6:1-130 FDOT421 "D/L1/EC/UB/SD130/LIFT MC RM"
					-- 6:1-131 FDOT421 "D/L1/CC/UB/SD131/BMS ROOM"
					-- 6:1-132 FDOT421 "D/L1/WC/UB/SD132/ELEC ROOM"
					-- 6:1-133 FDOT421 "D/L1/WC/UB/SD133/DRIVER ROOM"
					-- 6:1-146 HMS-S/D/M/SA "D/L1/WC/LB/MCP146/ST NR FAN RM"
					-- 6:1-147 HTRI-R "D/L1/WC/LB/CM147/ST NR FAN RM"
					-- Switch ""
					-- Relay
					-- 6:1-148 HMS-S/D/M/SA "D/L1/WC/LB/MCP148/RAMP NO. 10"
					-- 6:1-149 HTRI-R "D/L1/WC/LB/CM149/RAMP NO. 10"
					-- Switch ""
					-- Relay
					-- 6:1-150 FDOT421 "D/L1/WC/LB/SD150/ NR LIFT FAN RM"
					-- 6:1-151 HMS-S/D/M/SA "D/L1/WC/LB/MCP151/ST NR PMP RM"
					-- 6:1-152 HTRI-R "D/L1/WC/LB/CM152/ST NR PMP RM"
					-- Switch ""
					-- Relay
					-- 6:1-153 HMS-S/D/M/SA "D/L1/WC/LB/MCP153/ST NR HP RM"
					-- 6:1-154 HTRI-R "D/L1/WC/LB/CM154/ST NR HP RM"
					-- Switch ""
					-- Relay
					-- 6:1-155 HMS-S/D/M/SA "D/L1/WC/LB/MCP155/ST NR TW TK"
					-- 6:1-156 HTRI-R "D/L1/WC/LB/CM156/ST NR TW TK"
					-- Switch ""
					-- Relay
					-- 6:1-161 FDOT421 "D/L1/WC/UB/SD161/PUMP RM"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:1 DLC "DLC @ address 1 L1"

					-- 6:1-162	FDOT421	"D/L1/WC/UB/SD162/PUMP RM"
					-- 6:1-163	FDOT421	"D/L1/WC/UB/SD163/PUMP RM"
					-- 6:1-164	FDOT421	"D/L1/WC/UB/SD164/FIRE DOOR"
					-- 6:1-165	FDOT421	"D/L1/WC/UB/SD165/FIRE DOOR"
					-- 6:1-166	FDOT421	"D/L1/WC/UB/SD166/FAN ROOM"
					-- 6:1-167	FDOT421	"D/L1/WC/UB/SD167/FAN ROOM"
					-- 6:1-168	FDOT421	"D/L1/WC/UB/SD168/SMP PMP RM"
					-- 6:1-169	FDOT421	"D/L1/WC/UB/SD169/SMP PMP RM"
					-- 6:1-170	FDOT421	"D/L1/WC/UB/SD170/HYD PMP RM"
					-- 6:1-171	FDOT421	"D/L1/WC/UB/SD171/HYD PMP RM"
					-- 6:1-172	FDOT421	"D/L1/WC/UB/SD172/HYD PMP RM"
					-- 6:1-173	FDOT421	"D/L1/WC/UB/SD173/FIRE PMP RM"
					-- 6:1-174	FDOT421	"D/L1/WC/UB/SD174/FIRE PMP RM"
					-- 6:1-175	FDOT421	"D/L1/WC/UB/SD175/FIRE PMP RM"
					-- 6:1-176	FDOT421	"D/L1/WC/UB/SD176/FIRE PMP RM"
					-- 6:1-177	FDOT421	"D/L1/WC/UB/SD177/FIRE PMP RM"
					-- 6:1-178	FDOT421	"D/L1/WC/UB/SD178/FIRE PMP RM"
					-- 6:1-179	FDOT421	"D/L1/WC/UB/SD179/FIRE PMP RM"
					-- 6:1-180	FDOT421	"D/L1/WC/UB/SD180/CHANGE RM"
					-- 6:1-181	FDOT421	"D/L1/WC/UB/SD181/CHANGE RM"
					-- 6:1-182	FDOT421	"D/L1/WC/UB/SD182/STP PASSAGE"
					-- 6:1-183	FDOT421	"D/L1/WC/UB/SD183/STP PASSAGE"
					-- 6:1-184	FDOT421	"D/L1/WC/UB/SD184/STP PASSAGE"
					-- 6:1-185	FDOT421	"D/L1/WC/UB/SD185/STP PASSAGE"
					-- 6:1-186	FDOT421	"D/L1/WC/UB/SD186/STP PASSAGE"
					-- 6:1-187	FDOT421	"D/L1/WC/UB/SD187/STP ROOM"
					-- 6:1-188	FDOT421	"D/L1/WC/UB/SD188/STP ROOM"
					-- 6:1-189	FDOT421	"D/L1/WC/UB/SD189/STP ROOM"
					-- 6:1-190	FDOT421	"D/L1/WC/UB/SD190/STP ROOM"
					-- 6:1-191	FDOT421	"D/L1/WC/UB/SD191/STP ROOM"
					-- 6:1-192	FDOT421	"D/L1/WC/UB/SD192/STP ROOM"
					-- 6:1-193	FDOT421	"D/L1/WC/UB/SD193/STP PLANT"
					-- 6:1-194	FDOT421	"D/L1/WC/UB/SD194/STP PLANT"
					-- 6:1-195	FDOT421	"D/L1/WC/UB/SD195/STP PLANT"
					-- 6:1-196	FDOT421	"D/L1/WC/UB/SD196/STP PLANT"
					-- 6:1-197	FDOT421	"D/L1/WC/UB/SD197/STP PLANT"
					-- 6:1-198	FDOT421	"L1/D/WC/LB/SD198/Carpentry Work "
					-- 6:1-199	FDOT421	"D/L1/WC/UB/SD199/FAN ROOM"
					-- 6:1-200	HTRI-R	"D/L1/WC/UB/CM200/FIRE DOOR"
					--	Switch	" "
					--	Relay	
					-- 6:1-201	FDOT421	"D/L1/DE/LB/SD201/Strongrm GD1"
					-- 6:1-202	FDOT421	"D/L1/DE/LB/SD202/Strongrm GD1"
					-- 6:1-203	FDOT421	"D/L1/DE/LB/SD203/Strongrm GD1"
					-- 6:1-204	FDOT421	"D/L1/DE/LB/SD204/Strongrm GD1"
					-- 6:1-205	FDOT421	"D/L1/DE/LB/SD205/Strongrm GD1"
					-- 6:1-206	FDOT421	"D/L1/DE/LB/SD206/Strongrm GD1"
					-- 6:1-207	FDOT421	"D/L1/DE/LB/SD207/Strongrm GD1"
					-- 6:1-208	FDOT421	"D/L1/DE/LB/SD208/Strongrm GD1"
					-- 6:1-209	FDOT421	"D/L1/DE/LB/SD209/Strongrm GD1"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:1 DLC "DLC @ address 1 L1"

```
| | | | |-- 6:1-210 FDOT421 "D/L1/DE/LB/SD210/Strongrm GD1"
| | | | |-- 6:1-211 HMS-S/D/M/SA "D/L1/DE/LB/MCP211/Strongrm GD1"
| | | | |-- 6:1-212 FDOT421 "D/L1/DE/LB/SD212/Strongrm GD2"
| | | | |-- 6:1-213 FDOT421 "D/L1/DE/LB/SD213/Strongrm GD2"
| | | | |-- 6:1-214 FDOT421 "D/L1/DE/LB/SD214/Strongrm GD2"
| | | | |-- 6:1-215 FDOT421 "D/L1/DE/LB/SD215/Strongrm GD2"
| | | | |-- 6:1-216 FDOT421 "D/L1/DE/LB/SD216/Strongrm GD2"
| | | | |-- 6:1-217 FDOT421 "D/L1/DE/LB/SD217/Strongrm GD2"
| | | | |-- 6:1-218 FDOT421 "D/L1/DE/LB/SD218/Strongrm LL"
| | | | |-- 6:1-219 FDOT421 "D/L1/DE/LB/SD219/Strongrm LL"
| | | | |-- 6:1-220 FDOT421 "D/L1/DE/LB/SD220/Strongrm LL"
| | | | |-- 6:1-221 FDOT421 "D/L1/DE/LB/SD221/Strongrm LL"
| | | | |-- 6:1-222 FDOT421 "D/L1/DE/LB/SD222/Strongrm LL"
| | | | |-- 6:1-223 FDOT421 "D/L1/DE/LB/SD223/Strongrm LL"
| | | | |-- 6:1-224 HMS-S/D/M/SA "D/L1/DE/LB/MCP224/Psg nr Strong "
| | | | |-- 6:1-225 HTRI-R "D/L1/DE/LB/CM225/Psg nr Strong r"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:2 DLC "DLC @ address 2 L2"
| | | | |-- 6:2-1 HFP-11 "D/L2/1F/SD1/CORR DC 1110"
| | | | |-- 6:2-2 HFP-11 "D/L2/1F/SD2/CORR DC 1110"
| | | | |-- 6:2-3 HFP-11 "D/L2/1F/SD3/CORR DC 1090"
| | | | |-- 6:2-4 FDOT421 "D/L2/1F/SD4/CORR NR DC1140"
| | | | |-- 6:2-5 HFP-11 "D/L2/1F/SD5/CORR FIRE ESC DC"
| | | | |-- 6:2-6 HFP-11 "D/L2/1F/SD6/CORR DC1060"
| | | | |-- 6:2-7 HFP-11 "D/L2/1F/SD7/CORR DC1040"
| | | | |-- 6:2-8 HFP-11 "D/L2/1F/SD8/CORR DC1040"
| | | | |-- 6:2-9 HFP-11 "D/L2/1F/SD9/CORR DC1180"
| | | | |-- 6:2-10 HFP-11 "D/L2/1F/SD10/CORR DC EleRm"
| | | | |-- 6:2-11 HFP-11 "D/L2/1F/SD11/CORR DC ElcRm"
| | | | |-- 6:2-12 HMS-S/D/M/SA "D/L2/1F/MCP12/FIRE ESC STR"
| | | | |-- 6:2-13 HTRI-R "D/L2/1F/CM13/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:2-14 HTRI-R "D/L2/1F/CM14/DR RELESE CM NR L"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:2-15 HMS-S/D/M/SA "D/L2/1F/MCP15/FIRE SHAFT L.L."
| | | | |-- 6:2-16 HTRI-R "D/L2/C/1F/CM16/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:2-17 HTRI-S "D/L2/C/1F/MM17/FIRE SHAFT L.L."
| | | | |-- 6:2-18 HFP-11 "D/L2/C/1F/SD18/LIFT LOBBY SD"
| | | | |-- 6:2-19 HFP-11 "D/L2/C/1F/SD19/LIBT LOBBY SD"
| | | | |-- 6:2-20 HFP-11 "D/L2/C/1F/SD20/ELECTRIC RM"
| | | | |-- 6:2-21 HTRI-R "D/L2/C/1F/CM21/DR RELESE NR L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:2-22 HFP-11 "D/L2/C/1F/SD22/AHU RM SD L.L."
| | | | |-- 6:2-23 HTRI-R "D/L2/C/1F/CM23/AHU RM CM L.L."
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:2 DLC "DLC @ address 2 L2"

6:2-23 HTRI-R "D/L2/C/1F/CM23/AHU RM CM L.L."

```
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 6:2-24 HFP-11 "D/L2/C/1F/SD24/CORR DC/304"
| | | | | |-- 6:2-25 HFP-11 "D/L2/C/1F/SD25/CORR "
| | | | | |-- 6:2-26 HFP-11 "D/L2/E/1F/SD26/ELECT RM SD"
| | | | | |-- 6:2-28 HFP-11 "D/L2/E/1F/SD28/LIFT LOBBY SD "
| | | | | |-- 6:2-29 HMS-S/D/M/SA "D/L2/E/1F/MCP29/FIRE SHAFT L.L."
| | | | | |-- 6:2-30 HTRI-R "D/L2/E/1F/CM30/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 6:2-31 HTRI-S "D/L2/E/1F/MM31/FIRE SHAFT L.L."
| | | | | |-- 6:2-32 HTRI-R "D/L2/C/2F/CM32/DR RELESE NR L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 6:2-33 HFP-11 "D/L2/C/2F/SD33/CORR DC2071"
| | | | | |-- 6:2-34 HFP-11 "D/L2/C/2F/SD34/CORR DC2071"
| | | | | |-- 6:2-35 HFP-11 "D/L2/C/2F/SD35/CORR DC2072"
| | | | | |-- 6:2-36 HFP-11 "D/L2/C/2F/SD36/CORR DC2090"
| | | | | |-- 6:2-37 FDOT421 "D/L2/C/2F/SD37/CORR DC2062 AFC"
| | | | | |-- 6:2-39 HTRI-R "D/L2/C/2F/CM39/STR NR DC2062"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 6:2-40 HMS-S/D/M/SA "D/L2/C/2F/MCP40/STR NR DC2062"
| | | | | |-- 6:2-41 FDOT421 "D/L2/2F/SD41/CORR NR DC2130"
| | | | | |-- 6:2-42 HFP-11 "D/L2/2F/SD42/CORR DC2040"
| | | | | |-- 6:2-43 HFP-11 "D/L2/2F/SD43/CORR DC2030"
| | | | | |-- 6:2-44 HFP-11 "D/L2/2F/SD44/CORR DC2180"
| | | | | |-- 6:2-45 FDOT421 "D/L2/2F/SD45/CORR NR DC2190 AFC"
| | | | | |-- 6:2-46 HFP-11 "D/L2/C/2F/SD46/CORR Nr EleRm"
| | | | | |-- 6:2-47 HFP-11 "D/L2/C/2F/SD47/ELECT RM SD"
| | | | | |-- 6:2-48 HTRI-R "D/L2/C/2F/CM48/DR RELESE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 6:2-49 HTRI-R "D/L2/C/2F/CM49/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 6:2-50 HMS-S/D/M/SA "D/L2/C/2F/MCP50/FIRE SHAFT L.L."
| | | | | |-- 6:2-51 HTRI-S "D/L2/C/2F/MM51/FIRE SHAFT L.L."
| | | | | |-- 6:2-52 HFP-11 "D/L2/C/2F/SD52/LIFT LOBBY SD"
| | | | | |-- 6:2-53 HFP-11 "D/L2/C/2F/SD53/LIFT LOBBY SD"
| | | | | |-- 6:2-54 HTRI-R "D/L2/C/2F/CM54/DR RELESE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 6:2-55 HFP-11 "D/L2/C/2F/SD55/AHU RM SD"
| | | | | |-- 6:2-56 HTRI-R "D/L2/C/2F/CM56/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 6:2-57 HFP-11 "D/L2/C/2F/SD57/CORR AHU"
| | | | | |-- 6:2-58 HFP-11 "D/L2/C/2F/SD58/CORR AHU"
| | | | | |-- 6:2-59 FDOT421 "D/L2/C/2F/SD59/COR DC2230 AFC"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:2 DLC "DLC @ address 2 L2"

					-- 6:2-61 HFP-11 "D/L2/E/2F/SD61/ELECT RM SD"
					-- 6:2-62 HFP-11 "D/L2/E/2F/SD62/AHU RM SD"
					-- 6:2-63 HTRI-R "D/L2/E/2F/CM63/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 6:2-64 HFP-11 "D/L2/E/2F/SD64/LIFT LOBBY SD"
					-- 6:2-65 HTRI-R "D/L2/E/2F/CM65/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:2-66 HMS-S/D/M/SA "D/L2/E/2F/MCP66/FIRE SHAFT L.L."
					-- 6:2-67 HTRI-S "D/L2/E/2F/MM67/FIRE SHAFT L.L."
					-- 6:2-68 HTRI-R "D/L2/C/3F/CM68/DR RELELSE CM"
					-- Switch ""
					-- Relay
					-- 6:2-69 HFP-11 "D/L2/3F/SD69/CORR DW3/S30"
					-- 6:2-70 HFP-11 "D/L2/3F/SD70/CORR DW3/S30"
					-- 6:2-71 HFP-11 "D/L2/3F/SD71/CORR DC 3100"
					-- 6:2-72 HFP-11 "D/L2/3F/SD72/CORR DC 3111"
					-- 6:2-73 HFP-11 "D/L2/3F/SD73/CORR DC 3111"
					-- 6:2-74 HTRI-R "D/L2/C/3F/CM74/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 6:2-75 HMS-S/D/M/SA "D/L2/C/3F/MCP75/FIRE ESC STR"
					-- 6:2-76 HFP-11 "D/L2/3F/SD76/CORR DC 3070"
					-- 6:2-77 HFP-11 "D/L2/3F/SD77/CORR DC 3070"
					-- 6:2-78 HFP-11 "D/L2/3F/SD78/CORR DC 3140"
					-- 6:2-79 HFP-11 "D/L2/3F/SD79/CORR DC 3140"
					-- 6:2-80 HFP-11 "D/L2/3F/SD80/CORR DC 3160"
					-- 6:2-81 HFP-11 "D/L2/3F/SD81/CORR DC 3160"
					-- 6:2-82 HFP-11 "D/L2/3F/SD82/CORR DC 3010"
					-- 6:2-83 HFP-11 "D/L2/C/3F/SD83/CORR E.R."
					-- 6:2-84 FDOT421 "D/L2/DC/3F/SD84/CORR NR ELECT RM"
					-- 6:2-85 HFP-11 "D/L2/C/3F/SD85/ELECT RM SD"
					-- 6:2-86 HTRI-R "D/L2/C/3F/CM86/ELECT RM CM"
					-- Switch ""
					-- Relay
					-- 6:2-87 HTRI-R "D/L2/C/3F/CM87/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:2-88 HTRI-S "D/L2/C/3F/MM88/FIRE SHAFT L.L."
					-- 6:2-89 HMS-S/D/M/SA "D/L2/C/3F/MCP89/FIRE SHAFT L.L."
					-- 6:2-90 HFP-11 "D/L2/C/3F/SD90/LIFT LOBBY SD"
					-- 6:2-91 HFP-11 "D/L2/C/3F/SD91/LIFT LOBBY SD"
					-- 6:2-92 HTRI-R "D/L2/C/3F/CM92/DR RELESE CM NR A"
					-- Switch ""
					-- Relay
					-- 6:2-93 HTRI-R "D/L2/C/3F/CM93/AHU RM CM "
					-- Switch ""
					-- Relay
					-- 6:2-94 HFP-11 "D/L2/C/3F/SD94/AHU RM SD "

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:2 DLC "DLC @ address 2 L2"

					-- 6:2-95 HFP-11 "D/L2/3F/SD95/CORR DE 3150"
					-- 6:2-96 HFP-11 "D/L2/3F/SD96/CORR DE 3150"
					-- 6:2-97 FDOT421 "D/L2/3F/SD97/CORR NR DE3140 AFC"
					-- 6:2-98 HFP-11 "D/L2/3F/SD98/CORR DE 3210"
					-- 6:2-99 HFP-11 "D/L2/3F/SD99/CORR DE 3210"
					-- 6:2-100 HFP-11 "D/L2/3F/SD100/CORR DE 3100"
					-- 6:2-101 HFP-11 "D/L2/3F/SD101/CORR DE 3210"
					-- 6:2-102 HFP-11 "D/L2/E/3F/SD102/CORR FIRE ESC"
					-- 6:2-103 HFP-11 "D/L2/E/3F/SD103/CORR FIRE ESC"
					-- 6:2-104 HFP-11 "D/L2/E/3F/SD104/CORR FIRE ESC"
					-- 6:2-105 HMS-S/D/M/SA "D/L2/MCP105/DC3140/DC1230/Entry "
					-- 6:2-106 HFP-11 "D/L2/3F/SD106/CORR DE 3020"
					-- 6:2-107 HFP-11 "D/L2/3F/SD107/CORR DE 3020"
					-- 6:2-108 FDOT421 "D/L2/DE/3F/SD108/CORR NR ELECT R"
					-- 6:2-109 HTRI-R "D/L2/E/3F/CM109/DR RELESE CM NR "
					-- Switch ""
					-- Relay
					-- 6:2-110 HFP-11 "D/L2/E/3F/SD110/AHU RM SD "
					-- 6:2-111 HTRI-R "D/L2/E/3F/CM111/AHU RM CM "
					-- Switch ""
					-- Relay
					-- 6:2-112 HFP-11 "D/L2/E/3F/SD112/ELECT RM SD"
					-- 6:2-113 HMS-S/D/M/SA "D/L2/E/3F/MCP113/FIRE SHAFT L.L."
					-- 6:2-114 HTRI-R "D/L2/E/3F/CM114/FIRE SHAFT L.L. "
					-- Switch ""
					-- Relay
					-- 6:2-115 HTRI-S "D/L2/E/3F/MM115/FIRE SHAFT L.L. "
					-- 6:2-116 HMS-S/D/M/SA "D/L2/E/3F/MCP116/FIRE ESC STR"
					-- 6:2-117 HTRI-R "D/L2/E/3F/CM117/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 6:2-118 HFP-11 "D/L2/E/3F/SD118/LIFT LOBBY SD "
					-- 6:2-119 HFP-11 "D/L2/DC3100/SD119/Byer Cab 4"
					-- 6:2-120 HMS-S/D/M/SA "D/L2/DC3100/MCP120/Main Entry"
					-- 6:2-121 HFP-11 "D/L2/DC3100/SD121/Pantry"
					-- 6:2-122 HFP-11 "D/L2/DC3100/SD122/Byer Cab 3"
					-- 6:2-123 HFP-11 "D/L2/DC1190/SD123/Psg nr Entry"
					-- 6:2-124 HFP-11 "D/L2/DC1190/SD124/Pantry"
					-- 6:2-125 HFP-11 "D/L2/DC1190/SD125/Accounts cab"
					-- 6:2-126 HFP-11 "D/L2/DC1190/SD126/Assorter cab"
					-- 6:2-127 HFP-11 "D/L2/DC1190/SD127/Main cab"
					-- 6:2-128 HFP-11 "D/L2/DC1190/SD128/Main cab"
					-- 6:2-129 HTRI-R "D/L2/DC1190/CM129/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:2-130 HMS-S/D/M/SA "D/L2/DC1190/MCP130/Psg nr Entry"
					-- 6:2-131 HFP-11 "D/L2/DC3080/SD131/Main cab"
					-- 6:2-132 HFP-11 "D/L2/DC3080/SD132/Assorter cab"
					-- 6:2-133 HFP-11 "D/L2/DC3080/SD133/Psg nr Pantry"
					-- 6:2-134 HFP-11 "D/L2/DC3080/SD134/Account cab"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:2 DLC "DLC @ address 2 L2"

```
| | | | | -- 6:2-135 HFPT-11 "D/L2/DC3080/HD135/Pantry"
| | | | | -- 6:2-136 HTRI-R "D/L2/DC3080/CM136/Entry dr Psg"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:2-137 HMS-S/D/M/SA "D/L2/DC3080/MCP137/Entry dr Psg"
| | | | | -- 6:2-138 HTRI-R "D/L2/DC3100/CM138/Psg nr Entry"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:2-139 HFP-11 "D/L2/DC3100/SD139/Server rm"
| | | | | -- 6:2-140 HFP-11 "D/L2/SD140/DC3140/MAIN CABIN"
| | | | | -- 6:2-141 HFP-11 "D/L2/SD141/DC3140/ASSORTOR CAB 1"
| | | | | -- 6:2-142 HFP-11 "D/L2/SD142/DC3140/ASSORTOR CAB 2"
| | | | | -- 6:2-143 HFP-11 "D/L2/SD143/DC3140/PSG NR MAIN CA"
| | | | | -- 6:2-144 HFP-11 "D/L2/SD144/DC3140/PANTRY"
| | | | | -- 6:2-145 HTRI-R "D/L2/CM145/DC3140/ENTRY PSG AFC"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:2-146 HTRI-S "D/D/L2/3F/MM146/DC3070"
| | | | | -- 6:2-147 HTRI-S "D/L2/3F/MM147/DC3130"
| | | | | -- 6:2-148 HMS-S/D/M/SA "D/L2/MCP148/DC3140/ENTRY PSG AFC"
| | | | | -- 6:2-149 HFP-11 "D/L2/SD149/DC1230/Main Cabin"
| | | | | -- 6:2-150 HFP-11 "D/L2/SD150/DC1230/Main Cabin 2"
| | | | | -- 6:2-151 HTRI-S "D/L2/3F/MM151/DC3150"
| | | | | -- 6:2-152 HFP-11 "D/L2/SD152/DC1230/Entry Psg"
| | | | | -- 6:2-153 HTRI-S "D/L2/3F/MM153/DC3060"
| | | | | -- 6:2-154 HTRI-S "D/L2/3F/MM154/DC3160"
| | | | | -- 6:2-155 HTRI-S "D/L2/3F/MM155/DC3090B"
| | | | | -- 6:2-156 HTRI-S "D/L2/3F/MM156/DC3020"
| | | | | -- 6:2-157 HFP-11 "D/L2/SD157/DC1230/Pantry"
| | | | | -- 6:2-158 HTRI-R "D/L2/CM158/DC1230/ENTRY PSG AFC"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:2-159 HTRI-S "D/L2/3F/MM159/DC3010A"
| | | | | -- 6:2-160 HTRI-S "D/L2/3F/MM160/DC3190"
| | | | | -- 6:2-161 HTRI-S "D/L2/3F/MM161/DC3200"
| | | | | -- 6:2-162 HTRI-S "D/L2/3F/MM162/DE3160"
| | | | | -- 6:2-163 HTRI-S "D/L2/3F/MM163/DE3060"
| | | | | -- 6:2-164 HTRI-S "D/L2/3F/MM164/DE3140"
| | | | | -- 6:2-165 HTRI-S "D/L2/3F/MM165/DE3180"
| | | | | -- 6:2-166 HTRI-S "D/L2/3F/MM166/DE3100"
| | | | | -- 6:2-167 HTRI-S "D/L2/3F/MM167/DE3130"
| | | | | -- 6:2-168 HTRI-S "D/L2/3F/MM168/DE3120"
| | | | | -- 6:2-169 HFP-11 "D/L2/DC3100/SD169/Director Cab"
| | | | | -- 6:2-170 HFP-11 "D/L2/DC3100/SD170/Account dept"
| | | | | -- 6:2-171 HFP-11 "D/L2/DC3100/SD171/Account dept"
| | | | | -- 6:2-172 HTRI-R "D/L2/DC3100/CM172/AFC Account de"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:2-173 HMS-S/D/M/SA "D/L2/DC3100/MCP173/Psg nr Grding"
| | | | | -- 6:2-174 HTRI-S "D/L2/3F/MM174/DE3210"
```


6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:2 DLC "DLC @ address 2 L2"

					-- 6:2-175 HTRI-S "D/L2/3F/MM175/DE3080"
					-- 6:2-176 HFP-11 "D/L2/DC3050/SD176/Main cab"
					-- 6:2-177 HFP-11 "D/L2/DC3050/SD177/Assorter cab"
					-- 6:2-178 HTRI-R "D/L2/DC3050/CM178/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:2-179 HMS-S/D/M/SA "D/L2/DC3050/MCP179/Psg nr Entry"
					-- 6:2-180 HTRI-S "D/L2/3F/MM180/DE3240"
					-- 6:2-181 HTRI-S "D/L2/3F/MM181/DE3050"
					-- 6:2-182 HTRI-S "D/L2/3F/MM182/DE3250"
					-- 6:2-183 HTRI-S "D/L2/3F/MM183/DE3230"
					-- 6:2-188 HTRI-S "D/L2/2F/MM188/DC2220"
					-- 6:2-190 HTRI-S "D/L2/2F/MM190/DC2240"
					-- 6:2-192 HTRI-S "D/L2/2F/MM192/DC2250"
					-- 6:2-193 HTRI-S "D/L2/2F/MM193/DC2260"
					-- 6:2-194 HTRI-S "D/L2/2F/MM194/DC2200"
					-- 6:2-195 HTRI-S "D/L2/2F/MM195/DC2190"
					-- 6:2-196 HFP-11 "D/L2/SD196/DC2040/Cabin 1"
					-- 6:2-197 HFP-11 "D/L2/SD197/DC2040/Cabin 2"
					-- 6:2-198 HFP-11 "D/L2/SD198/DC2040/Cabin 3"
					-- 6:2-199 HTRI-S "D/L2/2F/MM199/DC2020"
					-- 6:2-200 HTRI-S "D/L2/2F/MM200/DC2160"
					-- 6:2-201 HFP-11 "D/L2/SD201/DC2040/Cabin 4"
					-- 6:2-202 HTRI-S "D/L2/2F/MM202/DC2030"
					-- 6:2-203 HFP-11 "D/L2/SD203/DC2040/Cabin 5"
					-- 6:2-204 HTRI-S "D/L2/2F/MM204/DC2140"
					-- 6:2-205 HFP-11 "D/L2/SD205/DC2040/Psg Nr Cabin 3"
					-- 6:2-206 HTRI-S "D/L2/2F/MM206/DC2130"
					-- 6:2-207 HTRI-S "D/L2/2F/MM207/DC2120"
					-- 6:2-208 HTRI-S "D/L2/2F/MM208/DC2061"
					-- 6:2-209 HTRI-S "D/L2/2F/MM209/DC2062"
					-- 6:2-210 HFP-11 "D/L2/SD210/DC2040/Entry Door Psg"
					-- 6:2-211 HTRI-S "D/L2/2F/MM211/DC2100"
					-- 6:2-212 HTRI-S "D/L2/2F/MM212/DC2071"
					-- 6:2-213 HTRI-S "D/L2/2F/MM213/DC2072"
					-- 6:2-214 HTRI-S "D/L2/2F/MM214/DC2090"
					-- 6:2-215 HTRI-R "D/L2/CM215/DC2040/Entry Door "
					-- Switch ""
					-- Relay
					-- 6:2-216 HTRI-S "D/L2/1F/MM216/DC1110"
					-- 6:2-217 HMS-S/D/M/SA "D/L2/MCP217/DC2040/Psg Nr Cabin "
					-- 6:2-218 HTRI-S "D/L2/1F/MM218/DC1130"
					-- 6:2-219 HTRI-S "D/L2/1F/MM219/DC1090"
					-- 6:2-221 HTRI-S "D/L2/1F/MM221/DC1140"
					-- 6:2-222 HTRI-S "D/L2/1F/MM222/DC1150"
					-- 6:2-224 HTRI-S "D/L2/1F/MM224/DC1070"
					-- 6:2-226 HTRI-S "D/L2/1F/MM226/DC1160A"
					-- 6:2-228 HTRI-S "D/L2/1F/MM228/DC1160"
					-- 6:2-230 HTRI-S "D/L2/1F/MM230/DC1030"
					-- 6:2-231 HTRI-S "D/L2/1F/MM231/DC1170"

6 Desigo Fire Safety Modular "BDB TOWER D " Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
6:2 DLC "DLC @ address 2 L2"

					-- 6:2-232 HTRI-S "D/L2/1F/MM232/DC1020"
					-- 6:2-233 HTRI-S "D/L2/1F/MM233/DC1180"
					-- 6:2-236 HTRI-S "D/L2/1F/MM236/DC1190A"
					-- 6:2-237 HTRI-S "D/L2/1F/MM237/DC1240"
					-- 6:2-241 HTRI-S "D/L2/1F/MM241/DC1210"
					-- 6:2-242 HFP-11 "D/L2/DC3100/SD242/Conferance"
					-- 6:2-243 HFP-11 "D/L2/DC3100/SD243/ Stock Cab"
					-- 6:2-244 HFP-11 "D/L2/DC3100/SD244/Certified Cab "
					-- 6:2-245 HFP-11 "D/L2/DC3100/SD245/Byer Cab1 "
					-- 6:2-246 HFP-11 "D/L2/DC3100/SD246/director cab"
					-- 6:2-247 HFP-11 "D/L2/DC3100/SD247/Non Cerfie cab"
					-- 6:2-248 HFP-11 "D/L2/DC3100/SD248/Non Cerfie Cab"
					-- 6:2-249 HFP-11 "D/L2/DC3100/SD249/Byer cab2"
					-- 6:2-250 HFP-11 "D/L2/DC3100/SD250/Pantry"
					-- 6:2-251 HFP-11 "D/L2/DC3100/SD251/Gradding Cab"
					-- 6:2-252 HFP-11 "D/L2/DC3100/SD252/Reception"
					-- 6:3 XDLC "XDLC @ address 3 L3"
					-- 6:3-1 HFP-11 "D/L3/WC/2F/SD1/CORR CW 2180"
					-- 6:3-2 HFP-11 "D/L3/WC/2F/SD2/CORR CW2170"
					-- 6:3-3 HFP-11 "D/L3/WC/2F/SD3/CORR CW 2110"
					-- 6:3-4 FDOT421 "D/L3/WC/2F/SD4/CORR CW2120"
					-- 6:3-5 HFP-11 "D/L3/WC/2F/SD5/CORR CW2130"
					-- 6:3-6 HFP-11 "D/L3/WC/2F/SD6/ELECT RM SD"
					-- 6:3-7 HTRI-R "D/L3/WC/2F/CM7/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 6:3-8 HFP-11 "D/L3/WC/2F/SD8/LIFT LOBBY SD"
					-- 6:3-9 HFP-11 "D/L3/WC/2F/SD9/LIFT LOBBY SD"
					-- 6:3-10 HTRI-R "D/L3/WC/2F/CM10/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:3-11 HMS-S/D/M/SA "D/L3/WC/2F/MCP11/FIRE SHAFT L.L."
					-- 6:3-12 HTRI-S "D/L3/WC/2F/MM12/FIRE SHAFT L.L."
					-- 6:3-13 HTRI-R "D/L3/WC/2F/CM13/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 6:3-14 HFP-11 "D/L3/WC/2F/SD14/SMALL CORR "
					-- 6:3-15 HFP-11 "D/L3/WC/2F/SD15/CORR AHU"
					-- 6:3-16 HFP-11 "D/L3/WC/2F/SD16/CORR AHU "
					-- 6:3-17 HTRI-R "D/L3/WC/2F/CM17/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 6:3-18 HFP-11 "D/L3/WC/2F/SD18/AHU RM SD"
					-- 6:3-19 FDOT421 "D/L3/WC/2F/SD19/CORR NR DW2/S27"
					-- 6:3-20 HFP-11 "D/L3/WC/2F/SD20/CORR 2022"
					-- 6:3-21 HFP-11 "D/L3/WC/2F/SD21/CORR CURVE"
					-- 6:3-22 HFP-11 "D/L3/WC/2F/SD22/CORR CURVE"
					-- 6:3-23 HFP-11 "D/L3/WC/2F/SD23/CORR CURVE"
					-- 6:3-25 HTRI-R "D/L3/WC/2F/CM25/FIRE ESC STR"
					-- Switch ""

```
6 Desigo Fire Safety Modular "BDB TOWER D " Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      6:3 XDLC "XDLC @ address 3 L3"
        6:3-25 HTRI-R "D/L3/WC/2F/CM25/FIRE ESC STR"
```

```
| | | | | |-- Relay
| | | | |-- 6:3-26 HMS-S/D/M/SA "D/L3/WC/2F/MCP26/FIRE ESC STR"
| | | | |-- 6:3-27 HFP-11 "D/L3/WC/2F/SD27/CORR DW2060"
| | | | |-- 6:3-28 HFP-11 "D/L3/WC/2F/SD28/CORR DW2080"
| | | | |-- 6:3-29 HFP-11 "D/L3/WC/2F/SD29/CORR DW2090 AFC"
| | | | |-- 6:3-30 HFP-11 "D/L3/WC/2F/SD30/CORR DW2100"
| | | | |-- 6:3-31 HFP-11 "D/L3/WC/2F/SD31/CORR DW2130"
| | | | |-- 6:3-32 HFP-11 "D/L3/WC/2F/SD32/CORR DW2130"
| | | | |-- 6:3-33 HFP-11 "D/L3/WC/2F/SD33/CORR DW2140"
| | | | |-- 6:3-34 HFP-11 "D/L3/WC/1F/SD34/CORR CW1030"
| | | | |-- 6:3-35 HFP-11 "D/L3/WC/1F/SD35/CORR CW1030"
| | | | |-- 6:3-36 HFP-11 "D/L3/WC/1F/SD36/CORR CW1070"
| | | | |-- 6:3-37 HFP-11 "D/L3/WC/1F/SD37/CORR 1100"
| | | | |-- 6:3-38 HFP-11 "D/L3/WC/1F/SD38/ELECT RM SD"
| | | | |-- 6:3-39 HTRI-R "D/L3/WC/1F/CM39/DR RELESE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:3-40 HFP-11 "D/L3/WC/1F/SD40/LIFT LOBBY SD"
| | | | |-- 6:3-41 HFP-11 "D/L3/WC/1F/SD41/LIFT LOBBY SD"
| | | | |-- 6:3-42 HTRI-R "D/L3/WC/1F/CM42/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:3-43 HMS-S/D/M/SA "D/L3/WC/1F/MCP43/FIRE SHAFT L.L."
| | | | |-- 6:3-44 HTRI-S "D/L3/WC/1F/MM44/FIRE SHAFT L.L."
| | | | |-- 6:3-45 HTRI-R "D/L3/WC/1F/CM45/DR RELESE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:3-46 HFP-11 "D/L3/WC/1F/SD46/CORR 1380"
| | | | |-- 6:3-47 HFP-11 "D/L3/WC/1F/SD47/SMALL CORR "
| | | | |-- 6:3-48 HFP-11 "D/L3/WC/1F/SD48/CORR DW1420"
| | | | |-- 6:3-49 HFP-11 "D/L3/WC/1F/SD49/CORR DW1370"
| | | | |-- 6:3-50 FDOT421 "D/L3/WC/1F/SD50/CORR DW1370"
| | | | |-- 6:3-51 HFP-11 "D/L3/WC/1F/SD51/AHU RM SD"
| | | | |-- 6:3-52 HTRI-R "D/L3/WC/1F/CM52/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:3-53 HFP-11 "D/L3/WC/1F/SD53/CORR DW1360"
| | | | |-- 6:3-54 FDOT421 "D/L3/WC/1F/SD54/CORR NR DW1150"
| | | | |-- 6:3-55 HFP-11 "D/L3/WC/1F/SD55/CORR NR DW1180"
| | | | |-- 6:3-57 HFP-11 "D/L3/WC/1F/SD57/CORR CURVE"
| | | | |-- 6:3-59 HTRI-R "D/L3/WC/1F/CM59/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:3-60 HMS-S/D/M/SA "D/L3/WC/1F/MCP60/FIRE ESC STR"
| | | | |-- 6:3-61 HFP-11 "D/L3/WC/1F/SD61/CORR DW1220"
| | | | |-- 6:3-62 HFP-11 "D/L3/WC/1F/SD62/CORR DW1220"
| | | | |-- 6:3-63 HFP-11 "D/L3/WC/1F/SD63/CORR DW1230"
| | | | |-- 6:3-64 HFP-11 "D/L3/WC/1F/SD64/CORR DW1260"
| | | | |-- 6:3-65 FDOT421 "D/L3/WC/1F/SD65/COR DW1270 AFC"
| | | | |-- 6:3-66 HFP-11 "D/L3/WC/1F/SD66/CORR DW1330"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:3 XDLC "XDLC @ address 3 L3"

					-- 6:3-67 HFP-11 "D/L3/WC/1F/SD67/CORR DW1310"
					-- 6:3-82 XTRI-S "D/L3/2F/MM82/CW2090"
					-- 6:3-83 HFP-11 "D/L3/DW2100/SD83/Pantry"
					-- 6:3-84 HTRI-S "D/L3/2F/MM84/CW2100"
					-- 6:3-85 HTRI-S "D/L3/MM85/CW2160"
					-- 6:3-86 HTRI-S "D/L3/2F/MM86/CW2110"
					-- 6:3-87 HTRI-S "D/L3/2F/MM87/CW2155"
					-- 6:3-90 HTRI-S "D/L3/2F/MM90/CW2140"
					-- 6:3-91 HTRI-S "D/L3/2F/MM91/CW2150"
					-- 6:3-92 HTRI-S "D/L3/2F/MM92/DC2080"
					-- 6:3-93 HTRI-S "D/L3/2F/MM93/DW2332"
					-- 6:3-96 HTRI-S "D/L3/2F/MM96/DW2330"
					-- 6:3-99 HTRI-S "D/L3/2F/MM99/DW2031"
					-- 6:3-100 HTRI-S "D/L3/2F/MM100/Dwstar rays4"
					-- 6:3-101 HTRI-S "D/L3/2F/MM101/Dwstar rays5"
					-- 6:3-102 HTRI-S "D/L3/2F/MM102/DW2331"
					-- 6:3-104 HFP-11 "D/L3/DW2100/SD104/Psg nr Accts c"
					-- 6:3-105 HTRI-S "D/L3/2F/MM105/DW2070"
					-- 6:3-106 HTRI-R "D/L3/DW1220/CM106/AFC Entry Psg"
					-- Switch ""
					-- Relay
					-- 6:3-107 HMS-S/D/M/SA "D/L3/DW1220/MCP107/Entry Psg."
					-- 6:3-108 HTRI-S "D/L3/2F/MM108/DW2090"
					-- 6:3-109 HTRI-S "D/L3/2F/MM109/DW2310"
					-- 6:3-110 HFP-11 "D/L3/DW1220/SD110/MAIN CABIN"
					-- 6:3-111 HTRI-S "D/L3/2F/MM111/DW2110"
					-- 6:3-112 HTRI-S "D/L3/2F/MM112/DW2120"
					-- 6:3-113 HFP-11 "D/L3/DW1220/SD113/ACCOUNT CABIN "
					-- 6:3-114 HFP-11 "D/L3/DW1220/SD114/ACCOUNT CABIN "
					-- 6:3-115 HFP-11 "D/L3/DW1220/SD115/Psg Nr ACCOUNT"
					-- 6:3-116 HFP-11 "D/L3/DW1220/SD116/Pantry "
					-- 6:3-117 HTRI-S "D/L3/2F/MM117/DW2140"
					-- 6:3-120 XTRI-S "D/L3/2F/MM120/DW1300"
					-- 6:3-121 XTRI-S "D/L3/1F/MM121/DW1290"
					-- 6:3-122 XTRI-S "D/L3/1F/MM122/DW1320"
					-- 6:3-123 XTRI-S "D/L3/1F/MM123/DW1280""
					-- 6:3-124 XTRI-S "D/L3/1F/MM124/DW1330"
					-- 6:3-125 XTRI-S "D/L3/1F/MM125/DW1270"
					-- 6:3-126 XTRI-S "D/L3/1F/MM126/DW1340"
					-- 6:3-127 HTRI-S "D/L3/1F/MM127/DW1260"
					-- 6:3-128 XTRI-S "D/L3/1F/MM128/DW1250"
					-- 6:3-129 XTRI-S "D/L3/1F/MM129/DW1240"
					-- 6:3-130 XTRI-S "D/L3/1F/MM130/DW1230"
					-- 6:3-132 XTRI-S "D/L3/1F/MM132/DW1210"
					-- 6:3-134 XTRI-S "D/L3/1F/MM134/DW1350"
					-- 6:3-135 XTRI-S "D/L3/1F/MM135/DW1190"
					-- 6:3-136 HTRI-S "D/L3/1F/MM136/DW1180"
					-- 6:3-137 HTRI-S "D/L3/1F/MM137/DW1170"
					-- 6:3-140 HTRI-S "D/L3/1F/MM140/DW1150"
					-- 6:3-141 HTRI-S "D/L3/1F/MM141/DW1355"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:3 XDLC "XDLC @ address 3 L3"

					-- 6:3-142	HTRI-S	"D/L3/1F/MM142/DW1140"
					-- 6:3-144	HTRI-S	"D/L3/1F/MM144/DW1360"
					-- 6:3-147	HTRI-S	"D/L3/1F/MM147/DW1380"
					-- 6:3-148	HTRI-S	"D/L3/1F/MM148/DW1390"
					-- 6:3-149	HTRI-S	"D/L3/1F/MM149/DW1400"
					-- 6:3-151	HTRI-S	"D/L3/1F/MM151/DW1420"
					-- 6:3-152	HTRI-S	"D/L3/1F/MM152/DW1120"
					-- 6:3-153	HTRI-S	"D/L3/1F/MM153/DW1110"
					-- 6:3-154	HTRI-S	"D/L3/1F/MM154/DW1100"
					-- 6:3-155	XTRI-S	"D/L3/1F/MM155/DW1090"
					-- 6:3-156	XTRI-S	"D/L3/1F/MM156/DW1080"
					-- 6:3-158	XTRI-S	"D/L3/1F/MM158/DW1010"
					-- 6:3-159	XTRI-S	"D/L3/1F/MM159/DW1020"
					-- 6:3-162	XTRI-S	"D/L3/1F/MM162/DW1030"
					-- 6:3-163	HTRI-S	"D/L3/1F/MM163/DW1040"
					-- 6:3-164	HFP-11	"D/L3/CW2120/SD164/Pantry"
					-- 6:3-165	HFP-11	"D/L3/CW2120/SD165/Cab 1"
					-- 6:3-166	HFP-11	"D/L3/CW2120/SD166/Main cab"
					-- 6:3-167	HFP-11	"D/L3/CW2120/SD167/Main cab"
					-- 6:3-168	HFP-11	"D/L3/CW2120/SD168/Assorter cab"
					-- 6:3-169	HFP-11	"D/L3/CW2120/SD169/Cab 2"
					-- 6:3-170	HFP-11	"D/L3/CW2120/SD170/Psg nr Entranc"
					-- 6:3-171	HTRI-R	"D/L3/CW2120/CM171/Psg nr Entranc"
					--	Switch	" "
					--	Relay	
					-- 6:3-172	HMS-S/D/M/SA	"D/L3/CW2120/MCP172/Psg nr Entranc"
					-- 6:3-173	HFP-11	"D/L3/CW2180/SD173/Main cab"
					-- 6:3-174	HFP-11	"D/L3/CW2180/SD174/Assorter cab"
					-- 6:3-175	HFP-11	"D/L3/CW2180/SD175/Psg nr Entry"
					-- 6:3-176	HTRI-R	"D/L3/CW2180/CM176/Psg nr Entry"
					--	Switch	" "
					--	Relay	
					-- 6:3-177	HMS-S/D/M/SA	"D/L3/CW2180/MCP177/Psg nr Entry"
					-- 6:3-181	HFPT-11	"D/L3/DC1120/HD181/Pantry"
					-- 6:3-182	HFP-11	"D/L3/DC1120/SD182/Psg nr wash rm"
					-- 6:3-183	HFP-11	"D/L3/DC1120/SD183/Accounts cab"
					-- 6:3-184	HFP-11	"D/L3/DC1120/SD184/Weighing cab"
					-- 6:3-185	HFP-11	"D/L3/DC1120/SD185/Main cab1"
					-- 6:3-186	HFP-11	"D/L3/DC1120/SD186/Main cab2"
					-- 6:3-187	HFP-11	"D/L3/DC1120/SD187/Reception"
					-- 6:3-188	HFP-11	"D/L3/DC1120/SD188/AFC Reception"
					-- 6:3-189	HFP-11	"D/L3/DC1120/SD189/AFC Entry dr P"
					-- 6:3-190	HFP-11	"D/L3/DC1120/SD190/Entry dr Psg"
					-- 6:3-191	HTRI-R	"D/L3/DC1120/CM191/Entry dr Psg"
					--	Switch	" "
					--	Relay	
					-- 6:3-192	HMS-S/D/M/SA	"D/L3/DC1120/MCP192/Entry dr Psg"
					-- 6:3-195	HFP-11	"D/L3/DW1200/SD195/Pantry"
					-- 6:3-196	HFP-11	"D/L3/DW1200/SD196/Assorter cab"
					-- 6:3-197	HFP-11	"D/L3/DW1200/SD197/Main cab"

6 Desigo Fire Safety Modular "BDB TOWER D " Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
6:3 XDLC "XDLC @ address 3 L3"

					-- 6:3-198 HTRI-R "D/L3/DW1200/CM198/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:3-199 HMS-S/D/M/SA "D/L3/DW1200/MCP199/Psg nr Entry"
					-- 6:3-201 HFPT-11 "D/L3/DW1161/HD201/Pantry"
					-- 6:3-202 HFP-11 "D/L3/DW1161/SD202/Cab 7"
					-- 6:3-203 HFP-11 "D/L3/DW1161/SD203/Reception Psg"
					-- 6:3-204 HFP-11 "D/L3/DW1161/SD204/Account Cab"
					-- 6:3-205 HFP-11 "D/L3/DW1161/SD205/Psg nr Acc.cab"
					-- 6:3-206 HFP-11 "D/L3/DW1161/SD206/Cab 6"
					-- 6:3-207 HFP-11 "D/L3/DW1161/SD207/Cab 1 "
					-- 6:3-208 HFP-11 "D/L3/DW1161/SD208/Cab 2"
					-- 6:3-209 HFP-11 "D/L3/DW1161/SD209/Cab 3"
					-- 6:3-210 HFP-11 "D/L3/DW1161/SD210/Assorter cab"
					-- 6:3-211 HTRI-R "D/L3/DW1161/CM211/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:3-212 HMS-S/D/M/SA "D/L3/DW1161/MCP212/Psg nr Entry"
					-- 6:3-213 HFP-11 "D/L3/DW2050/SD213/Waiting Area"
					-- 6:3-214 HFP-11 "D/L3/DW2050/SD214/Account cab"
					-- 6:3-215 HFP-11 "D/L3/DW2050/SD215/Assorter cab"
					-- 6:3-216 HFP-11 "D/L3/DW2050/SD216/Buyers cab"
					-- 6:3-217 HFP-11 "D/L3/DW2050/SD217/Executive cab"
					-- 6:3-218 HTRI-R "D/L3/DW2050/CM218/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:3-219 HMS-S/D/M/SA "D/L3/DW2050/MCP219/Psg nr Entry"
					-- 6:3-220 HFPT-11 "D/L3/DW2060/HD220/Pantry"
					-- 6:3-221 HFP-11 "D/L3/DW2060/SD221/Assorter cab"
					-- 6:3-222 HFP-11 "D/L3/DW2060/SD222/Main cab"
					-- 6:3-223 HFP-11 "D/L3/DW2060/SD223/Psg nr Entry"
					-- 6:3-224 HTRI-R "D/L3/DW2060/CM224/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:3-225 HMS-S/D/M/SA "D/L3/DW2060/MCP225/Psg nr Entry"
					-- 6:3-226 HFP-11 "D/L3/DW2100/SD226/Accounts cab"
					-- 6:3-227 HFP-11 "D/L3/DW2100/SD227/Cab 1"
					-- 6:3-228 HFP-11 "D/L3/DW2100/SD228/Main cab"
					-- 6:3-229 HFP-11 "D/L3/DW2100/SD229/Assorter cab"
					-- 6:3-230 HTRI-R "D/L3/DW2100/CM230/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:3-231 HMS-S/D/M/SA "D/L3/DW2100/MCP231/Psg nr Entry"
					-- 6:3-232 HFP-11 "D/L3/DW2300/SD232/Pantry"
					-- 6:3-233 HFP-11 "D/L3/DW2300/SD233/Accounts cab"
					-- 6:3-234 HFP-11 "D/L3/DW2300/SD234/Main cab"
					-- 6:3-235 HTRI-R "D/L3/DW2300/CM235/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:3-236 HMS-S/D/M/SA "D/L3/DW2300/MCP236/Psg nr Entry"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:3 XDLC "XDLC @ address 3 L3"

```
| | | | | -- 6:3-237 HFPT-11 "D/L3/DW2290/HD237/Pantry"
| | | | | -- 6:3-238 HFP-11 "D/L3/DW2290/SD238/Cab 1"
| | | | | -- 6:3-239 HFP-11 "D/L3/DW2290/SD239/Main cab"
| | | | | -- 6:3-240 HTRI-R "D/L3/DW2290/CM240/Psg nr Entry"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:3-241 HMS-S/D/M/SA "D/L3/DW2290/MCP241/Psg nr Entry"
| | | | | -- 6:3-242 HFP-11 "D/L3/DW2130/SD242/Pantry"
| | | | | -- 6:3-243 HFP-11 "D/L3/DW2130/SD243/Cab 1"
| | | | | -- 6:3-244 HFP-11 "D/L3/DW2130/SD244/Cab 2"
| | | | | -- 6:3-245 HFP-11 "D/L3/DW2130/SD245/Cab 3"
| | | | | -- 6:3-246 HFP-11 "D/L3/DW2130/SD246/Psg nr cab 1"
| | | | | -- 6:3-247 HTRI-R "D/L3/DW2130/CM247/Psg nr Entry"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:3-248 HMS-S/D/M/SA "D/L3/DW2130/MCP248/Psg nr Entry"
| | | | | -- 6:3-249 HFP-11 "D/L3/DW2280/SD249/Pantry"
| | | | | -- 6:3-250 HFP-11 "D/L3/DW2280/SD250/Executive cab"
| | | | | -- 6:3-251 HTRI-R "D/L3/DW2280/CM251/Psg nr Entry"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:3-252 HMS-S/D/M/SA "D/L3/DW2280/MCP252/Psg nr Entry"
| | | | | -- 6:4 DLC "DLC @ address 4 L4"
| | | | | -- 6:4-1 HTRI-R "D/L4/C/4F/CM1/DR RELESE CM NR L."
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:4-2 HFP-11 "D/L4/4F/SD2/ CORR DC 4072"
| | | | | -- 6:4-3 HFP-11 "D/L4/4F/SD3/ CORR DC 4072"
| | | | | -- 6:4-4 HFP-11 "D/L4/4F/SD4/ CORR DC 4071"
| | | | | -- 6:4-5 HFP-11 "D/L4/C/4F/SD5/CorrS/31FireStr"
| | | | | -- 6:4-6 FDOT421 "D/L4/C/4F/SD6/Corr Nr DC4060"
| | | | | -- 6:4-7 HFP-11 "D/L4/C4F/SD7/ CORR DC4111"
| | | | | -- 6:4-8 HFP-11 "D/L4/4F/SD8/ CORR DC4040"
| | | | | -- 6:4-9 HFP-11 "D/L4/4F/SD9/ CORR DC4040"
| | | | | -- 6:4-10 HFP-11 "D/L4/4F/SD10/ CORR DC4020"
| | | | | -- 6:4-11 HFP-11 "D/L4/4F/SD11/ CORR DC4010"
| | | | | -- 6:4-12 HFP-11 "D/L4/4F/SD12/ CORR DC4010"
| | | | | -- 6:4-13 HFP-11 "D/L4/4F/SD13/ELECT RM SD"
| | | | | -- 6:4-14 HTRI-R "D/L4/4F/CM14/DR RELESE CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:4-15 HMS-S/D/M/SA "D/L4/4F/MCP15/FIRE SHAFT L.L."
| | | | | -- 6:4-16 HTRI-R "D/L4/4F/CM16/FIRE SHAFT L.L."
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:4-17 HTRI-S "D/L4/4F/MM17/FIRE SHAFT L.L."
| | | | | -- 6:4-18 HFP-11 "D/L4/4F/SD18/LIFT LOBBY SD"
| | | | | -- 6:4-19 HFP-11 "D/L4/4F/SD19/LIFT LOBBY SD"
| | | | | -- 6:4-20 HTRI-R "D/L4/4F/CM20/DR RELESE CM"
| | | | | | -- Switch ""
```

```
6 Desigo Fire Safety Modular "BDB TOWER D " Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      6:4 DLC "DLC @ address 4 L4"
        6:4-20 HTRI-R "D/L4/4F/CM20/DR RELESE CM"
```

```
| | | | | |-- Relay
| | | | |-- 6:4-21 HFP-11 "D/L4/4F/SD21/AHU RM SD"
| | | | |-- 6:4-22 HTRI-R "D/L4/4F/CM22/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:4-23 HFP-11 "D/L4/4F/SD23/ CORR 4150"
| | | | |-- 6:4-24 HFP-11 "D/L4/4F/SD24/ CORR 4150"
| | | | |-- 6:4-25 FDOT421 "D/L4/4F/SD25/CORR NR DC4150""
| | | | |-- 6:4-26 HFP-11 "D/L4/4F/SD26/CORR NR 4181"
| | | | |-- 6:4-27 HFP-11 "D/L4/4F/SD27/CORR NR 4200"
| | | | |-- 6:4-28 HFP-11 "D/L4/4F/SD28/CORR NR 4181"
| | | | |-- 6:4-29 HFP-11 "D/L4/4F/SD29/CORR NR ELECT RM AF"
| | | | |-- 6:4-30 HFP-11 "D/L4/4F/SD30/ELECT RM SD"
| | | | |-- 6:4-31 HFP-11 "D/L4/4F/SD31/AHU RM SD"
| | | | |-- 6:4-32 HTRI-R "D/L4/4F/CM32/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:4-33 FDOT421 "D/L4/DE/4F/SD33/LIFT LOBBY SD"
| | | | |-- 6:4-34 HMS-S/D/M/SA "D/L4/4F/MCP34/FIRE SHAFT L.L."
| | | | |-- 6:4-35 HTRI-R "D/L4/4F/CM35/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:4-36 HTRI-S "D/L4/4F/MM36/FIRE SHAFT L.L."
| | | | |-- 6:4-37 HMS-S/D/M/SA "D/L4/4F/MCP37/FIRE ESC STR"
| | | | |-- 6:4-38 HTRI-R "D/L4/4F/CM38/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:4-39 HMS-S/D/M/SA "D/L4/4F/MCP39/FIRE ESC STR"
| | | | |-- 6:4-40 HTRI-R "D/L4/4F/CM40/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:4-41 HTRI-R "D/L4/5F/CM41/DR RELESE CM NR L.L"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:4-42 HFP-11 "D/L4/5F/SD42/CORR NR 530"
| | | | |-- 6:4-43 HFP-11 "D/L4/5F/SD43/CORR NR 530"
| | | | |-- 6:4-44 HFP-11 "D/L4/5F/SD44/CORR NR DW5/S09"
| | | | |-- 6:4-45 FDOT421 "D/L4/5F/SD45/CORR NR DC5/S31"
| | | | |-- 6:4-46 HFP-11 "D/L4/5F/SD46/CORR NR 531"
| | | | |-- 6:4-47 HMS-S/D/M/SA "D/L4/5F/MCP47/FIRE ESC STR"
| | | | |-- 6:4-48 HTRI-R "D/L4/5F/CM48/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:4-49 HFP-11 "D/L4/5F/SD49/CORR NR 5120"
| | | | |-- 6:4-50 HFP-11 "D/L4/5F/SD50/CORR NR 5140"
| | | | |-- 6:4-51 HFP-11 "D/L4/5F/SD51/CORR NR 5140"
| | | | |-- 6:4-52 HFP-11 "D/L4/5F/SD52/CORR NR 5020"
| | | | |-- 6:4-53 HFP-11 "D/L4/5F/SD53/CORR NR E.R."
| | | | |-- 6:4-54 HFP-11 "D/L4/5F/SD54/CORR NR E.R."
| | | | |-- 6:4-55 HFP-11 "D/L4/5F/SD55/ELECT RM SD"
```


6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:4 DLC "DLC @ address 4 L4"

					-- 6:4-56 HTRI-R "D/L4/5F/CM56/DR RELESE CM "
					-- Switch ""
					-- Relay
					-- 6:4-57 HMS-S/D/M/SA "D/L4/5F/MCP57/FIRE SHAFT L.L."
					-- 6:4-58 HTRI-R "D/L4/5F/CM58/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:4-59 HTRI-S "D/L4/5F/MM59/FIRE SHAFT L.L."
					-- 6:4-60 HFP-11 "D/L4/5F/SD60/LIFT LOBBY SD"
					-- 6:4-61 HFP-11 "D/L4/5F/SD61/LIFT LOBBY SD"
					-- 6:4-62 HTRI-R "D/L4/5F/CM62/DR RELESE NR AHU "
					-- Switch ""
					-- Relay
					-- 6:4-63 HFP-11 "D/L4/5F/SD63/AHU RM SD"
					-- 6:4-64 HTRI-R "D/L4/5F/CM64/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 6:4-65 HFP-11 "D/L4/5F/SD65/CORR NR AHU"
					-- 6:4-66 HFP-11 "D/L4/5F/SD66/CORR NR AHU "
					-- 6:4-67 HFP-11 "D/L4/5F/SD67/CORR NR 5090"
					-- 6:4-68 HFP-11 "D/L4/5F/SD68/CORR NR 5100"
					-- 6:4-69 HFP-11 "D/L4/5F/SD69/CORR NR 5100"
					-- 6:4-70 HFP-11 "D/L4/5F/SD70/CORR NR 5060"
					-- 6:4-71 HFP-11 "D/L4/5F/SD71/CORR NR 5041"
					-- 6:4-72 HFP-11 "D/L4/5F/SD72/CORR NR 5041"
					-- 6:4-73 HFP-11 "D/L4/5F/SD73/CORR NR 5041"
					-- 6:4-74 HFP-11 "D/L4/5F/SD74/CORR NR 5150"
					-- 6:4-75 FDOT421 "D/L4/5F/SD75/CORR NR DE5150"
					-- 6:4-76 HMS-S/D/M/SA "D/L4/5F/MCP76/FIRE STR 5060"
					-- 6:4-77 HTRI-R "D/L4/5F/CM77/FIRE STR 5060"
					-- Switch ""
					-- Relay
					-- 6:4-78 HFP-11 "D/L4/5F/SD78/ELECT RM SD"
					-- 6:4-79 HTRI-R "D/L4/5F/CM79/DR RELESE CM NR L.L"
					-- Switch ""
					-- Relay
					-- 6:4-80 HFP-11 "D/L4/5F/SD80/AHU RM SD"
					-- 6:4-81 HTRI-R "D/L4/5F/CM81/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 6:4-82 HFP-11 "D/L4/5F/SD82/LIFT LOBBY SD"
					-- 6:4-83 HMS-S/D/M/SA "D/L4/5F/MCP83/FIRE SHAFT L.L."
					-- 6:4-84 HTRI-R "D/L4/5F/CM84/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:4-85 HTRI-S "D/L4/5F/MM85/FIRE SHAFT L.L."
					-- 6:4-86 HFP-11 "D/L4/DC4160/SD86/Pantry"
					-- 6:4-87 HFP-11 "D/L4/DC4160/SD87/Assorter cab"
					-- 6:4-88 HTRI-R "D/L4/DC4160/CM88/Psg nr Entry"
					-- Switch ""

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:4 DLC "DLC @ address 4 L4"

6:4-88 HTRI-R "D/L4/DC4160/CM88/Psg nr Entry"

| | | | | | |-- Relay

| | | | | |-- **6:4-89 HMS-S/D/M/SA "D/L4/DC4160/MCP89/Psg nr Entry"**

| | | | | |-- 6:4-90 HFP-11 "D/L4/DC4020/SD90/Main cab"

| | | | | |-- 6:4-91 HFP-11 "D/L4/DC4020/SD91/Main cab"

| | | | | |-- 6:4-92 HFP-11 "D/L4/DC4020/SD92/Assorter cab"

| | | | | |-- 6:4-93 HFP-11 "D/L4/DC4020/SD93/Assorter cab"

| | | | | |-- 6:4-94 HFP-11 "D/L4/DC4020/SD94/Psg nr Main cab"

| | | | | |-- 6:4-95 HFP-11 "D/L4/DC4020/SD95/Pantry"

| | | | | |-- 6:4-96 HFP-11 "D/L4/DC4020/SD96/Buyer cab"

| | | | | |-- 6:4-97 HFP-11 "D/L4/DC4020/SD97/Psg nr Entry"

| | | | | |-- 6:4-98 HTRI-R "D/L4/DC4020/CM98/Psg nr Entry"

| | | | | | |-- Switch ""

| | | | | | |-- Relay

| | | | | |-- **6:4-99 HMS-S/D/M/SA "D/L4/DC4020/MCP99/Psg nr Entry"**

| | | | | |-- 6:4-100 HFP-11 "D/L4/DE4011/SD100/Conference rm"

| | | | | |-- 6:4-101 HFP-11 "D/L4/DE4011/SD101/Vishalbhai cab"

| | | | | |-- 6:4-102 HTRI-S "D/L4/5F/MM102/DC5101"

| | | | | |-- 6:4-103 HTRI-S "D/L4/5F/MM103/DC5102"

| | | | | |-- 6:4-104 HFP-11 "D/L4/DE4011/SD104/GoodsReceiptC"

| | | | | |-- 6:4-105 HMS-S/D/M/SA "D/L4/DE4011/MCP105/PsgnNrWashRM"

| | | | | |-- 6:4-106 HTRI-S "D/L4/5F/MM106/DC5060"

| | | | | |-- 6:4-107 HTRI-S "D/L4/5F/MM107/DC5120"

| | | | | |-- 6:4-108 HFP-11 "D/L4/DC4160/SD108/MAIN CABIN"

| | | | | |-- 6:4-109 HFP-11 "D/L4/DC4160/SD109/ACCOUNT CABIN"

| | | | | |-- 6:4-110 HFP-11 "D/L4/DE4011/SD110/Dineshbhai cab"

| | | | | |-- 6:4-111 HTRI-S "D/L4/5F/MM111/DC5090"

| | | | | |-- 6:4-112 HTRI-S "D/L4/5F/MM112/DC5150B"

| | | | | |-- 6:4-113 HFP-11 "D/L4/DC4230/SD113/AccountDeptCab"

| | | | | |-- 6:4-114 HFP-11 "D/L4/DC4230/SD114/Account Dept"

| | | | | |-- 6:4-115 HTRI-S "D/L4/5F/MM115/DC5020"

| | | | | |-- 6:4-116 HTRI-S "D/L4/5F/MM116/DC5170"

| | | | | |-- 6:4-117 HTRI-S "D/L4/5F/MM117/DC5010"

| | | | | |-- 6:4-118 HTRI-S "D/L4/5F/MM118/DC5180"

| | | | | |-- 6:4-119 HFP-11 "D/L4/DC4230/SD119/Entry Psg"

| | | | | |-- 6:4-121 HTRI-S "D/L4/4F/MM121/DC4082B"

| | | | | |-- 6:4-122 HTRI-S "D/L4/5F/MM122/DE5080"

| | | | | |-- 6:4-123 HMS-S/D/M/SA "D/L4/DC54230/MCP123/EntryPsgAFC"

| | | | | |-- 6:4-124 HTRI-S "D/L4/5F/MM124/DE5070"

| | | | | |-- 6:4-125 HTRI-R "D/L4/DC54230/CM125/Entry Psg"

| | | | | | |-- Switch ""

| | | | | | |-- Relay

| | | | | |-- **6:4-126 HTRI-S "D/L4/5F/MM126/DE5110"**

| | | | | |-- 6:4-127 HTRI-S "D/L4/5F/MM127/DE5060"

| | | | | |-- 6:4-128 HTRI-S "D/L4/5F/MM128/DC5191"

| | | | | |-- 6:4-129 HTRI-S "D/L4/5F/MM129/DE5132"

| | | | | |-- 6:4-130 HTRI-S "D/L4/5F/MM130/DE5131"

| | | | | |-- 6:4-131 HTRI-S "D/L4/5F/MM131/DC4082A"

| | | | | |-- 6:4-132 HTRI-S "D/L4/5F/MM132/DE5030"

| | | | | |-- 6:4-133 HTRI-S "D/L4/5F/MM133/DE5020"

| | | | | |-- 6:4-134 HTRI-S "D/L4/5F/MM134/DE5090A"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:4 DLC "DLC @ address 4 L4"

					-- 6:4-135 HFP-11 "D/L4/DC4150/SD135/Main Cab"
					-- 6:4-136 HTRI-S "D/L4/5F/MM136/DE5010"
					-- 6:4-137 HFP-11 "D/L4/DC4150/SD137/Assortor Cab"
					-- 6:4-138 HMS-S/D/M/SA "D/L4/DE4011/MCP138/Psg nr DC Ent"
					-- 6:4-139 HTRI-S "D/L4/4F/MM139/DC4200"
					-- 6:4-140 HTRI-S "D/L4/4F/MM140/DC4190"
					-- 6:4-141 HTRI-S "D/L4/4F/MM141/DC4180"
					-- 6:4-142 HTRI-S "D/L4/4F/MM142/DC4170"
					-- 6:4-143 HTRI-S "D/L4/4F/MM143/DC4210"
					-- 6:4-144 HFP-11 "D/L4/DE4011/SD144/PankajBhaiCab"
					-- 6:4-145 HMS-S/D/M/SA "D/L4/DC4150/MCP145/EntryPsg"
					-- 6:4-148 HTRI-S "D/L4/4F/MM148/DC4142B"
					-- 6:4-149 HTRI-S "D/L4/4F/MM149/DC4010"
					-- 6:4-151 HTRI-S "D/L4/4F/MM151/DC4130"
					-- 6:4-153 HTRI-S "D/L4/4F/MM153/DC4120"
					-- 6:4-154 HTRI-S "D/L4/4F/MM154/DC4030"
					-- 6:4-155 HTRI-S "D/L4/4F/MM155/DC4040"
					-- 6:4-156 HTRI-S "D/L4/4F/MM156/DC4112"
					-- 6:4-157 HTRI-S "D/L4/4F/MM157/DC4111"
					-- 6:4-160 HTRI-S "D/L4/4F/MM160/DC4101"
					-- 6:4-161 HMS-S/D/M/SA "D/L4/DE4011/MCP161/Psg nr DE Ent"
					-- 6:4-162 HTRI-R "D/L4/DE4011/CM162/Psg nr DE Entr"
					-- Switch ""
					-- Relay
					-- 6:4-163 HFP-11 "D/L4/DE4011/SD163/Sandipbhai cab"
					-- 6:4-164 HFP-11 "D/L4/DE4011/SD164/PsgNrDineshCab"
					-- 6:4-165 HFP-11 "D/L4/DC4150/SD165/Entry Psg"
					-- 6:4-166 HFPT-11 "D/L4/DC5110/HD166/Pantry"
					-- 6:4-167 HFP-11 "D/L4/DC5110/SD167/Accounts cab"
					-- 6:4-168 HFP-11 "D/L4/DC5110/SD168/Boss cab"
					-- 6:4-169 HFP-11 "D/L4/DC5110/SD169/Buyers cab"
					-- 6:4-170 HFP-11 "D/L4/DC5110/SD170/Assorter cab"
					-- 6:4-171 HTRI-R "D/L4/DC5110/CM171/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:4-172 HMS-S/D/M/SA "D/L4/DC5110/MCP172/Psg nr Entry"
					-- 6:4-173 HFP-11 "D/L4/DC5081/SD173/Psg nr meeting"
					-- 6:4-174 HFP-11 "D/L4/DC4150/SD174/Pantry"
					-- 6:4-175 HFPT-11 "D/L4/DC5081/HD175/Pantry"
					-- 6:4-176 HFP-11 "D/L4/DC5081/SD176/Wash rm "
					-- 6:4-177 HTRI-R "D/L4/DC5081/CM177/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:4-178 HMS-S/D/M/SA "D/L4/DC5081/MCP178/Psg nr Entry"
					-- 6:4-179 HFP-11 "D/L4/DC5140/SD179/Assorter cab"
					-- 6:4-180 HFP-11 "D/L4/DC5140/SD180/Main cab"
					-- 6:4-181 HFP-11 "D/L4/DC5140/SD181/Account cab"
					-- 6:4-182 HFP-11 "D/L4/DC5140/SD182/Psg nr Entranc"
					-- 6:4-183 HFP-11 "D/L4/DC5140/SD183/Pantry"
					-- 6:4-184 HTRI-R "D/L4/DC5140/CM184/Psg nr Entry"

					-- Switch ""
					-- Relay
					-- 6:4-185 HMS-S/D/M/SA "D/L4/DC5140/MCP185/Psg nr Entry"
					-- 6:4-186 HFP-11 "D/L4/DC5160/SD186/Pantry"
					-- 6:4-187 HFP-11 "D/L4/DC5160/SD187/Psg nr Entry"
					-- 6:4-188 HFP-11 "D/L4/DC5160/SD188/Assorter cab"
					-- 6:4-189 HFPT-11 "D/L4/DC5160/HD189/MD cab"
					-- 6:4-190 HTRI-R "D/L4/DC5160/CM190/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:4-191 HMS-S/D/M/SA "D/L4/DC5160/MCP191/Psg nr Entry"
					-- 6:4-192 HFP-11 "D/L4/DC5081/SD192/Vijaybhai cab"
					-- 6:4-193 HFP-11 "D/L4/DC5081/SD193/Conference rm"
					-- 6:4-194 HFP-11 "D/L4/DC5081/SD194/Manjeet cab"
					-- 6:4-195 HFP-11 "D/L4/DC5081/SD195/Dhara cab"
					-- 6:4-196 HFP-11 "D/L4/DC5081/SD196/Vandana cab"
					-- 6:4-197 HFP-11 "D/L4/DC5081/SD197/Hub rm cab"
					-- 6:4-198 HFP-11 "D/L4/DC5081/SD198/Hub rm cab"
					-- 6:4-199 HFP-11 "D/L4/DC5081/SD199/NRK cab Toilet"
					-- 6:4-200 HFP-11 "D/L4/DC5081/SD200/NRK cab "
					-- 6:4-201 HFP-11 "D/L4/DC5081/SD201/Psg nr NRK cab"
					-- 6:4-202 HFP-11 "D/L4/DC5081/SD202/Deepak shah ca"
					-- 6:4-203 HFP-11 "D/L4/DC5081/SD203/Secreatory cab"
					-- 6:4-204 HFP-11 "D/L4/DC5081/SD204/Rahulbhai cab"
					-- 6:4-205 HTRI-R "D/L4/DC4150/CM205/Entry Psg AFC"
					-- Switch ""
					-- Relay
					-- 6:4-206 HFP-11 "D/L4/DC5081/SD206/Dilipbhai cab"
					-- 6:4-207 HFP-11 "D/L4/DC5081/SD207/Niyazbhai cab"
					-- 6:4-208 HFP-11 "D/L4/DC5081/SD208/Meeting rm"
					-- 6:4-209 HFP-11 "D/L4/DC5030/SD209/Main cab"
					-- 6:4-210 HFP-11 "D/L4/DC5030/SD210/Account cab"
					-- 6:4-211 HFP-11 "D/L4/DC5030/SD211/Psg nr Account"
					-- 6:4-212 HFP-11 "D/L4/DC5030/SD212/Assorter cab"
					-- 6:4-213 HFP-11 "D/L4/DC5030/SD213/Psg nr Entry"
					-- 6:4-214 HTRI-R "D/L4/DC5030/CM214/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:4-215 HMS-S/D/M/SA "D/L4/DC5030/MCP215/Psg nr Entry"
					-- 6:4-216 HFP-11 "D/L4/DC5040/SD216/Pantry"
					-- 6:4-217 HFP-11 "D/L4/DC5040/SD217/Main cab"
					-- 6:4-218 HFP-11 "D/L4/DC5040/SD218/Cab 2"
					-- 6:4-219 HFP-11 "D/L4/DC5040/SD219/Cab 1"
					-- 6:4-220 HTRI-R "D/L4/DC5040/CM220/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:4-221 HMS-S/D/M/SA "D/L4/DC5040/MCP221/Psg nr Entry"
					-- 6:4-222 HFP-11 "D/L4/DE4011/SD222/Pantry"
					-- 6:4-223 HFP-11 "D/L4/DE4011/SD223/Pantry"
					-- 6:4-224 HFP-11 "D/L4/DE4011/SD224/Rajkumarbhai c"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:4 DLC "DLC @ address 4 L4"

					-- 6:4-225 HFP-11 "D/L4/DE4011/SD225/KGK Gems"
					-- 6:4-226 HFP-11 "D/L4/DE4011/SD226/Gauravbhai cab"
					-- 6:4-227 HFP-11 "D/L4/DE4011/SD227/Piyushbhai cab"
					-- 6:4-228 HFP-11 "D/L4/DE4011/SD228/Harshal bhaiCa"
					-- 6:4-229 HFP-11 "D/L4/DC5070/SD229/Main cab"
					-- 6:4-230 HFP-11 "D/L4/DC5070/SD230/Account cab"
					-- 6:4-231 HFP-11 "D/L4/DC5070/SD231/Pantry"
					-- 6:4-232 HFP-11 "D/L4/DC5070/SD232/Entry Psg"
					-- 6:4-233 HFP-11 "D/L4/DC5070/SD233/Assorter cab"
					-- 6:4-234 HTRI-R "D/L4/DC5070/CM234/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:4-235 HMS-S/D/M/SA "D/L4/DC5070/MCP235/Psg nr Entry"
					-- 6:4-236 HFP-11 "D/L4/DE4011/SD236/Rudrabhai cab"
					-- 6:4-237 HFP-11 "D/L4/DE4011/SD237/Client rm 4 ca"
					-- 6:4-238 HFP-11 "D/L4/DE4011/SD238/Client rm 3 ca"
					-- 6:4-239 HFP-11 "D/L4/DE4011/SD239/Client rm 2 ca"
					-- 6:4-240 HFP-11 "D/L4/DE4011/SD240/Client rm 1 ca"
					-- 6:4-241 HFP-11 "D/L4/DE4011/SD241/Assorter cab 1"
					-- 6:4-242 HFP-11 "D/L4/DE4011/SD242/Assorter cab 2"
					-- 6:4-243 HFP-11 "D/L4/DE4011/SD243/Server rm"
					-- 6:4-244 HFP-11 "D/L4/DE4011/SD244/AssoterCab2"
					-- 6:4-245 HFP-11 "D/L4/DE4011/SD245/PsgNrClient1 "
					-- 6:4-246 HFP-11 "D/L4/DE4011/SD246/Stock RM"
					-- 6:4-249 HFP-11 "D/L4/DE4011/SD249/Psg nr counter"
					-- 6:4-150 FDOT421 "D/L4/DE4011/SD150/PsgNrClientRM6"
					-- 6:4-120 FDOT421 "D/L4/DE4011/SD120/PsgNrWashRM"
					-- 6:4-146 FDOT421 "D/L4/DE4011/SD146/ClientRM5RM"
					-- 6:4-147 FDOT421 "D/L4/DE4011/SD147/Clientrm6Cab"
					-- 6:4-152 FDOT421 "D/L4/DE4011/SD152/PsgNrHarshalBh"
					-- 6:4-158 FDOT421 "D/L4/DE4011/SD158/WarehouseCab"
					-- 6:4-159 FDOT421 "D/L4/DE4011/SD159/Atulbhai cab"
					-- 6:4-247 FDOT421 "D/L4/DE4011/SD247/Nilesh RM"
					-- 6:4-248 FDOT421 "D/L4/DE4011/SD248/PsgNrNilesh"
					-- 6:4-250 FDOT421 "D/L4/DE4011/SD250/Reception Area"
					-- 6:4-251 FDOT421 "D/L4/DE4011/SD251/AbhishekbhaiC1"
					-- 6:4-252 FDOT421 "D/L4/DE4011/SD251/AbhishekbhaiC2"
					-- 6:5 DLC "DLC @ address 5 L5"
					-- 6:5-1 HFP-11 "D/L5/WC/4F/SD1/CORR NR CW 4092"
					-- 6:5-2 HFP-11 "D/L5/WC/4F/SD2/CORR NR CW 4090"
					-- 6:5-3 HFP-11 "D/L5/WC/4F/SD3/CORR NR CW 4110"
					-- 6:5-4 HFP-11 "D/L5/WC/4F/SD4/CORR NR CW 4120"
					-- 6:5-5 HFP-11 "D/L5/WC/4F/SD5/CORR NR CW 4120"
					-- 6:5-6 HFP-11 "D/L5/WC/4F/SD6/ELECT RM SD"
					-- 6:5-9 FDOT421 "D/L5/WC/4F/SD9/CORR NR ELECT RM"
					-- 6:5-10 HFP-11 "D/L5/WC/4F/SD10/CORR NR E.R."
					-- 6:5-11 HTRI-R "D/L5/WC/4F/CM11/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 6:5-12 HFP-11 "D/L5/WC/4F/SD12/LIFT LOBBY SD"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:5 DLC "DLC @ address 5 L5"

				-- 6:5-13 HFP-11 "D/L5/WC/4F/SD13/LIFT LOBBY SD"
				-- 6:5-14 HTRI-R "D/L5/WC/4F/CM14/FIRE SHAFT L.L."
				-- Switch ""
				-- Relay
				-- 6:5-15 HMS-S/D/M/SA "D/L5/WC/4F/MCP15/FIRE SHAFT L.L."
				-- 6:5-16 HTRI-S "D/L5/WC/4F/MM16/FIRE SHAFT L.L."
				-- 6:5-17 HTRI-R "D/L5/WC/4F/CM17/DR RELEASE CM"
				-- Switch ""
				-- Relay
				-- 6:5-18 FDOT421 "D/L5/WC/4F/SD18/CORR NR DC 4081"
				-- 6:5-19 HFP-11 "D/L5/WC/4F/SD19/CORR NR DW 4011"
				-- 6:5-20 HFP-11 "D/L5/WC/4F/SD20/CORR NR DW 4021"
				-- 6:5-21 HFP-11 "D/L5/WC/4F/SD21/CORR NR DW 4021"
				-- 6:5-22 HFP-11 "D/L5/WC/4F/SD22/AHU RM SD"
				-- 6:5-23 HTRI-R "D/L5/WC/4F/CM23/AHU RM CM"
				-- Switch ""
				-- Relay
				-- 6:5-24 HFP-11 "D/L5/WC/4F/SD24/CORR NR AHU "
				-- 6:5-25 HTRI-R "D/L5/WC/4F/CM25/FIRE ESC STR "
				-- Switch ""
				-- Relay
				-- 6:5-26 HMS-S/D/M/SA "D/L5/WC/4F/MCP26/FIRE ESC STR "
				-- 6:5-27 HFP-11 "D/L5/WC/4F/SD27/CORR NR DW 4060"
				-- 6:5-28 HFP-11 "D/L5/WC/4F/SD28/CORR NR DW 4310"
				-- 6:5-29 HFP-11 "D/L5/WC/4F/SD29/CORR NR DW 4080"
				-- 6:5-30 HFP-11 "D/L5/WC/4F/SD30/CORR NR DW 4101"
				-- 6:5-31 HFP-11 "D/L5/WC/4F/SD31/CORR NR DW 4260"
				-- 6:5-32 HFP-11 "D/L5/WC/4F/SD32/CORR NR DW 4260"
				-- 6:5-33 HFP-11 "D/L5/WC/3F/SD33/CORR NR CW 3100"
				-- 6:5-34 HFP-11 "D/L5/WC/3F/SD34/CORR NR 3110"
				-- 6:5-35 HFP-11 "D/L5/WC/3F/SD35/CORR NR 3110"
				-- 6:5-36 HFP-11 "D/L5/WC/3F/SD36/CORR NR 3130"
				-- 6:5-37 HFP-11 "D/L5/WC/3F/SD37/CORR NR 3150"
				-- 6:5-38 HFP-11 "D/L5/WC/3F/SD38/ELECT RM SD"
				-- 6:5-39 HTRI-R "D/L5/WC/3F/CM39/DR RELEASE CM"
				-- Switch ""
				-- Relay
				-- 6:5-40 HFP-11 "D/L5/WC/3F/SD40/LIFT LOBBY SD"
				-- 6:5-41 HFP-11 "D/L5/WC/3F/SD41/LIFT LOBBY SD"
				-- 6:5-42 HTRI-R "D/L5/WC/3F/CM42/FIRE SHAFT L.L."
				-- Switch ""
				-- Relay
				-- 6:5-43 HMS-S/D/M/SA "D/L5/WC/3F/MCP43/FIRE SHAFT L.L."
				-- 6:5-44 HTRI-S "D/L5/WC/3F/MM44/FIRE SHAFT L.L."
				-- 6:5-45 HFP-11 "D/L5/WC/3F/SD45/SMALL CORR "
				-- 6:5-46 HFP-11 "D/L5/WC/3F/SD46/CORR NR AHU "
				-- 6:5-47 HFP-11 "D/L5/WC/3F/SD47/CORR NR AHU"
				-- 6:5-48 HFP-11 "D/L5/WC/3F/SD48/AHU RM SD"
				-- 6:5-49 HTRI-R "D/L5/WC/3F/CM49/AHU RM CM"
				-- Switch ""

```

6 Desigo Fire Safety Modular "BDB TOWER D " Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      6:5 DLC "DLC @ address 5 L5"
        6:5-49 HTRI-R "D/L5/WC/3F/CM49/AHU RM CM"

```

				-- Relay
				--- 6:5-50 HFP-11 "D/L5/WC/3F/SD50/CORR NR DW 3030"
				--- 6:5-51 HFP-11 "D/L5/WC/3F/SD51/CORR NR DW 3050"
				--- 6:5-52 HFP-11 "D/L5/WC/3F/SD52/CORR NR 3060"
				--- 6:5-53 HFP-11 "D/L5/WC/3F/SD53/CORR NR CURVE"
				--- 6:5-54 HFP-11 "D/L5/WC/3F/SD54/CORR NR CURVE"
				--- 6:5-55 HFP-11 "D/L5/WC/3F/SD55/CORR NR CURVE"
				--- 6:5-58 HTRI-R "D/L5/WC/3F/CM58/FIRE ESC STR"
				-- Switch "
				-- Relay
				--- 6:5-59 HMS-S/D/M/SA "D/L5/WC/3F/MCP59/FIRE ESC STR"
				--- 6:5-60 HFP-11 "D/L5/WC/3F/SD60/CORR NR DW 3130"
				--- 6:5-61 HFP-11 "D/L5/WC/3F/SD61/CORR NR "
				--- 6:5-62 HFP-11 "D/L5/WC/3F/SD62/CORR NR 3150"
				--- 6:5-63 HFP-11 "D/L5/WC/3F/SD63/CORR NR 3370"
				--- 6:5-64 HFP-11 "D/L5/WC/3F/SD64/CORR NR 3340"
				--- 6:5-65 HFP-11 "D/L5/WC/3F/SD65/CORR NR 3350"
				--- 6:5-66 HTRI-R "D/L5/WC/3F/CM66/DR RELESE CM"
				-- Switch "
				-- Relay
				--- 6:5-67 HFP-11 "D/L5/DW3050/SD67/MAIN CAB"
				--- 6:5-68 HFP-11 "D/L5/DW3050/SD68/ASSORTER CAB 1"
				--- 6:5-69 HFP-11 "D/L5/DW3050/SD69/ASSORTER CAB 2"
				--- 6:5-70 HFP-11 "D/L5/DW3050/SD70/PSG NR ASSORTER"
				--- 6:5-71 HFP-11 "D/L5/DW3050/SD71/PANTRY"
				--- 6:5-72 HMS-S/D/M/SA "D/L5/DW3050/MCP72/ENTRY PSG"
				--- 6:5-73 HTRI-R "D/L5/DW3050/CM73/ENTRY PSG AFC"
				-- Switch "
				-- Relay
				--- 6:5-74 HFP-11 "D/L5/DW3400/SD74/MAIN CAB"
				--- 6:5-75 HFP-11 "D/L5/DW3400/SD75/Entry Psg"
				--- 6:5-76 HFP-11 "D/L5/DW3400/SD76/Entry Psg"
				--- 6:5-77 HMS-S/D/M/SA "D/L5/DW3400/MCP77/Entry Psg"
				--- 6:5-78 HTRI-R "D/L5/DW3400/CM78/Entry Psg"
				-- Switch "
				-- Relay
				--- 6:5-82 HTRI-S "D/L5/4F/MM82/CW4091"
				--- 6:5-83 HTRI-S "D/L5/4F/MM83/CW4092"
				--- 6:5-85 HTRI-S "D/L5/4F/MM85/CW4100"
				--- 6:5-87 HTRI-S "D/L5/4F/MM87/CW4160"
				--- 6:5-89 HTRI-S "D/L5/4F/MM89/CW4130"
				--- 6:5-90 HTRI-S "D/L5/4F/MM90/CW4140"
				--- 6:5-91 HTRI-S "D/L5/4F/MM91/CW4150"
				--- 6:5-92 HTRI-S "D/L5/4F/MM92/DW4082"
				--- 6:5-95 HTRI-S "D/L5/4F/MM95/DW4021"
				--- 6:5-96 HTRI-S "D/L5/4F/MM96/DC4081"
				--- 6:5-97 HTRI-S "D/L5/4F/MM97/DW4022"
				--- 6:5-98 HTRI-S "D/L5/4F/MM98/DW4030"
				--- 6:5-101 HTRI-S "D/L5/4F/MM101/DW4083"
				--- 6:5-104 HTRI-S "D/L5/4F/MM104/DW4310"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:5 DLC "DLC @ address 5 L5"

				-- 6:5-108	HTRI-S	"D/L5/4F/MM108/DW4290"
				-- 6:5-109	HTRI-S	"D/L5/4F/MM109/DW4091"
				-- 6:5-111	HTRI-S	"D/L5/4F/MM111/DW4280"
				-- 6:5-112	HTRI-S	"D/L5/4F/MM112/DW4270"
				-- 6:5-114	HTRI-S	"D/L5/4F/MM114/DW4111"
				-- 6:5-119	HTRI-S	"D/L5/3F/MM119/DW3350"
				-- 6:5-120	HTRI-S	"D/L5/3F/MM120/DW3190"
				-- 6:5-121	HTRI-S	"D/L5/3F/MM121/DW3180"
				-- 6:5-123	HTRI-S	"D/L5/3F/MM123/DW3370"
				-- 6:5-128	HTRI-S	"D/L5/3F/MM128/DW3150"
				-- 6:5-131	HTRI-S	"D/L5/3F/MM131/DW3130"
				-- 6:5-132	HTRI-S	"D/L5/3F/MM132/DW3120"
				-- 6:5-136	HTRI-S	"D/L5/3F/MM136/DW3080"
				-- 6:5-137	HTRI-S	"D/L5/3F/MM137/DW3070"
				-- 6:5-138	HTRI-S	"D/L5/3F/MM138/DW3170"
				-- 6:5-139	HTRI-S	"D/L5/3F/MM139/DW3060"
				-- 6:5-141	HTRI-S	"D/L5/3F/MM141/DW3410B"
				-- 6:5-142	HTRI-S	"D/L5/3F/MM142/DW3040"
				-- 6:5-145	HTRI-S	"D/L5/3F/MM145/DW3010"
				-- 6:5-147	HTRI-S	"D/L5/3F/MM147/CW3150"
				-- 6:5-150	HTRI-S	"D/L5/3F/MM150/CW3090"
				-- 6:5-151	HTRI-S	"D/L5/3F/MM151/CW3120"
				-- 6:5-152	HTRI-S	"D/L5/3F/MM152/CW3110"
				-- 6:5-154	HTRI-S	"D/L5/3F/MM154/CW3090C"
				-- 6:5-155	HFPT-11	"D/L5/CW4120/HD155/Pantry"
				-- 6:5-156	HFP-11	"D/L5/CW4120/SD156/Cab 1"
				-- 6:5-157	HFP-11	"D/L5/CW4120/SD157/Cab 2"
				-- 6:5-158	HFP-11	"D/L5/CW4120/SD158/Main cabin"
				-- 6:5-159	HFP-11	"D/L5/CW4120/SD159/Psg nr Main ca"
				-- 6:5-160	HTRI-R	"D/L5/CW4120/CM160/Psg nr Entry D"
					-- Switch	" "
					-- Relay	
				-- 6:5-161	HMS-S/D/M/SA	"D/L5/CW4120/MCP161/Psg nr Entry "
				-- 6:5-162	HFP-11	"D/L5/CW4110/SD162/Pantry"
				-- 6:5-163	HFP-11	"D/L5/CW4110/SD163/Psg nr cab"
				-- 6:5-164	HFP-11	"D/L5/CW4110/SD164/Main cab"
				-- 6:5-165	HFP-11	"D/L5/CW4110/SD165/Cab 1"
				-- 6:5-166	HFP-11	"D/L5/CW4110/SD166/Cab 2"
				-- 6:5-167	HTRI-R	"D/L5/CW4110/CM167/Psg nr Entry D"
					-- Switch	" "
					-- Relay	
				-- 6:5-168	HMS-S/D/M/SA	"D/L5/CW4110/MCP168/Psg nr Entry "
				-- 6:5-169	HFP-11	"D/L5/CW3130/SD169/Main cab"
				-- 6:5-170	HFP-11	"D/L5/CW3130/SD170/Accounts cab"
				-- 6:5-171	HFP-11	"D/L5/CW3130/SD171/Psg nr main ca"
				-- 6:5-172	HFP-11	"D/L5/CW3130/SD172/Psg nr ent"
				-- 6:5-173	HTRI-R	"D/L5/CW3130/CM173/Psg nr ent"
					-- Switch	" "
					-- Relay	
				-- 6:5-174	HMS-S/D/M/SA	"D/L5/CW3130/MCP174/Psg nr ent"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:5 DLC "DLC @ address 5 L5"

				-- 6:5-175 HFP-11 "D/L5/CW3140/SD175/Pantry"
				-- 6:5-176 HFP-11 "D/L5/CW3140/SD176/Psg nr Account"
				-- 6:5-177 HFP-11 "D/L5/CW3140/SD177/Accounts cab"
				-- 6:5-178 HFP-11 "D/L5/CW3140/SD178/Assorter cab"
				-- 6:5-179 HFP-11 "D/L5/CW3140/SD179/Psg nr Assorte"
				-- 6:5-180 HFP-11 "D/L5/CW3140/SD180/Main cab"
				-- 6:5-181 HTRI-R "D/L5/CW3140/CM181/Psg nr Entry D"
				-- Switch ""
				-- Relay
				-- 6:5-182 HMS-S/D/M/SA "D/L5/CW3140/MCP182/Psg nr Entry "
				-- 6:5-183 HFP-11 "D/L5/CW4180/SD183/Pantry"
				-- 6:5-184 HFP-11 "D/L5/CW4180/SD184/Cab 1"
				-- 6:5-185 HFP-11 "D/L5/CW4180/SD185/Cab 2"
				-- 6:5-186 HTRI-R "D/L5/CW4180/CM186/Psg nr Entry D"
				-- Switch ""
				-- Relay
				-- 6:5-187 HMS-S/D/M/SA "D/L5/CW4180/MCP187/Psg nr Entry "
				-- 6:5-195 HFP-11 "D/L5/CW4170/SD195/Pantry"
				-- 6:5-196 HFP-11 "D/L5/CW4170/SD196/Assorter cab"
				-- 6:5-197 HFP-11 "D/L5/CW4170/SD197/Main cab"
				-- 6:5-198 HTRI-R "D/L5/CW4170/CM198/Psg nr Entry D"
				-- Switch ""
				-- Relay
				-- 6:5-199 HMS-S/D/M/SA "D/L5/CW4170/MCP199/Psg nr Entry "
				-- 6:5-200 HFP-11 "D/L5/DW4011/SD200/Sales cab 1"
				-- 6:5-201 HFP-11 "D/L5/DW4011/SD201/Purchase cab"
				-- 6:5-202 HFP-11 "D/L5/DW4011/SD202/Psg nr Purchas"
				-- 6:5-203 HFP-11 "D/L5/DW4011/SD203/Main Cabin"
				-- 6:5-204 HFP-11 "D/L5/DW4011/SD204/Main cab"
				-- 6:5-205 HFP-11 "D/L5/DW4011/SD205/Main cab"
				-- 6:5-206 HFP-11 "D/L5/DW4011/SD206/Assorter cab"
				-- 6:5-209 HFP-11 "D/L5/DW4011/SD209/Account cab"
				-- 6:5-210 HFP-11 "D/L5/DW4011/SD210/Pantry"
				-- 6:5-211 HTRI-R "D/L5/DW4011/CM211/Psg nr Entry"
				-- Switch ""
				-- Relay
				-- 6:5-212 HMS-S/D/M/SA "D/L5/DW4011/MCP212/Psg nr Entry"
				-- 6:5-213 HFP-11 "D/L5/DW4040/SD213/Psg nr Entry"
				-- 6:5-214 HFP-11 "D/L5/DW4040/SD214/Accounts Dept"
				-- 6:5-215 HFP-11 "D/L5/DW4040/SD215/Buyers cab"
				-- 6:5-216 HFP-11 "D/L5/DW4040/SD216/Executive cab"
				-- 6:5-217 HFP-11 "D/L5/DW4040/SD217/Pantry"
				-- 6:5-218 HTRI-R "D/L5/DW4040/CM218/Psg nr Entry"
				-- Switch ""
				-- Relay
				-- 6:5-219 HMS-S/D/M/SA "D/L5/DW4040/MCP219/Psg nr Entry"
				-- 6:5-220 HFP-11 "D/L5/DW4051/SD220/Psg nr Entry"
				-- 6:5-221 HFP-11 "D/L5/DW4051/SD221/Reception"
				-- 6:5-222 HFP-11 "D/L5/DW4051/SD222/Accounts cab"
				-- 6:5-223 HFP-11 "D/L5/DW4051/SD223/Psg nr Account"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:5 DLC "DLC @ address 5 L5"

```
| | | |-- 6:5-224 HFP-11 "D/L5/DW4051/SD224/E marketing ca"
| | | |-- 6:5-225 HFP-11 "D/L5/DW4051/SD225/Buyers cab"
| | | |-- 6:5-226 HFP-11 "D/L5/DW4051/SD226/Main cab"
| | | |-- 6:5-227 HFP-11 "D/L5/DW4051/SD227/Stock cab"
| | | |-- 6:5-228 HFP-11 "D/L5/DW4051/SD228/Psg nr Main ca"
| | | |-- 6:5-229 HTRI-R "D/L5/DW4051/CM229/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 6:5-230 HMS-S/D/M/SA "D/L5/DW4051/MCP230/Psg nr Entry"
| | | |-- 6:5-231 HFP-11 "D/L5/DW4052/SD231/Pantry"
| | | |-- 6:5-232 HFP-11 "D/L5/DW4052/SD232/Accounts cab"
| | | |-- 6:5-233 HFP-11 "D/L5/DW4052/SD233/Assorter cab"
| | | |-- 6:5-234 HFP-11 "D/L5/DW4052/SD234/Main cab"
| | | |-- 6:5-235 HFP-11 "D/L5/DW4052/SD235/Psg nr Entry"
| | | |-- 6:5-236 HTRI-R "D/L5/DW4052/CM236/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 6:5-237 HMS-S/D/M/SA "D/L5/DW4052/MCP237/Psg nr Entry"
| | | |-- 6:5-238 HTRI-S "D/L5/3F/MM238/DW3170"
| | | |-- 6:5-241 HFP-11 "D/L5/DW4300/SD241/Entry Psg"
| | | |-- 6:5-242 HFP-11 "D/L5/DW4300/SD242/Main Cabin"
| | | |-- 6:5-243 HFP-11 "D/L5/DW4300/SD243/Cabin 1"
| | | |-- 6:5-244 HMS-S/D/M/SA "D/L5/DW4300/MCP244/Entry Psg"
| | | |-- 6:5-245 HTRI-R "D/L5/DW4300/CM245/Entry Psg AFC"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- CC-5 "Card Cage 5 Slots"
| | | |-- 6:7 DLC "DLC @ address 7 L7"
| | | | |-- 6:7-1 HFP-11 "D/L7/WC/6F/SD1/CORR NR CW 6142"
| | | | |-- 6:7-2 HFP-11 "D/L7/WC/6F/SD2/CORR NR CW 6142"
| | | | |-- 6:7-3 HFP-11 "D/L7/WC/6F/SD3/CORR NR CW 6090"
| | | | |-- 6:7-4 HFP-11 "D/L7/WC/6F/SD4/CORR NR CW 6100"
| | | | |-- 6:7-5 HFP-11 "D/L7/WC/6F/SD5/CORR NR CW 6110"
| | | | |-- 6:7-6 HFP-11 "D/L7/WC/6F/SD6/ELECT RM SD"
| | | | |-- 6:7-7 HTRI-R "D/L7/WC/6F/CM7/DR RELESE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:7-8 HFP-11 "D/L7/WC/6F/SD8/LIFT LOBBY SD"
| | | | |-- 6:7-9 HFP-11 "D/L7/WC/6F/SD9/LIFT LOBBY SD"
| | | | |-- 6:7-10 HTRI-R "D/L7/WC/6F/CM10/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:7-11 HMS-S/D/M/SA "D/L7/WC/6F/MCP11/FIRE SHAFT L.L."
| | | | |-- 6:7-12 HTRI-S "D/L7/WC/6F/MM12/FIRE SHAFT L.L."
| | | | |-- 6:7-13 HTRI-R "D/L7/WC/6F/CM13/DR RELESE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:7-14 HFP-11 "D/L7/WC/6F/SD14/CORR NR DW 6369"
| | | | |-- 6:7-15 HFP-11 "DL7/WC/6F/SD15/CORR NR DW 6100"
| | | | |-- 6:7-16 HFP-11 "D/L7/WC/6F/SD16/CORR NR DR"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:7 DLC "DLC @ address 7 L7"

					-- 6:7-17 HFP-11 "D/L7/WC/6F/SD17/AHU RM SD"
					-- 6:7-18 HTRI-R "D/L7/WC/6F/CM18/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 6:7-19 HFP-11 "D/L7/WC/6F/SD19/CORR NR DW 6010"
					-- 6:7-20 HFP-11 "D/L7/WC/6F/SD20/CORR NR DW 6031"
					-- 6:7-21 HFP-11 "D/L7/WC/6F/SD21/CORR NR DW 6031"
					-- 6:7-22 HFP-11 "D/L7/WC/6F/SD22/CORR NR 6031"
					-- 6:7-23 HFP-11 "D/L7/WC/6F/SD23/CORR CURVE SIDE"
					-- 6:7-24 HFP-11 "D/L7/WC/6F/SD24/CORR CURVE SIDE"
					-- 6:7-28 HTRI-S "D/L7/6F/MM28/DW6010"
					-- 6:7-29 HTRI-R "D/L7/WC/6F/CM29/STR NR DW 6070"
					-- Switch ""
					-- Relay
					-- 6:7-30 HMS-S/D/M/SA "D/L7/WC/6F/MCP30/STR NR DW 6070"
					-- 6:7-32 HFP-11 "D/L7/WC/6F/SD32/CORR NR DW 6090"
					-- 6:7-33 HFP-11 "D/L7/WC/6F/SD33/CORR NR DW 6340"
					-- 6:7-34 HFP-11 "D/L7/WC/6F/SD34/CORR NR DW 6120"
					-- 6:7-35 HFP-11 "D/L7/WC/6F/SD35/CORR NR DW 6120"
					-- 6:7-36 HFP-11 "D/L7/WC/6F/SD36/CORR NR DW 6140"
					-- 6:7-37 HFP-11 "D/L7/WC/5F/SD37/CORR NR 5092"
					-- 6:7-38 HFP-11 "D/L7/WC/5F/SD38/CORR NR 5092"
					-- 6:7-39 HFP-11 "D/L7/WC/5F/SD39/CORR NR 5100"
					-- 6:7-40 HFP-11 "D/L7/WC/5F/SD40/CORR NR S/13"
					-- 6:7-41 HFP-11 "D/L7/WC/5F/SD41/CORR NR S/20"
					-- 6:7-42 HFP-11 "D/L7/WC/5F/SD42/ELECT RM SD"
					-- 6:7-43 HTRI-R "D/L7/WC/5F/CM43/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 6:7-44 HFP-11 "D/L7/WC/5F/SD44/LIFT LOBBY SD"
					-- 6:7-45 HFP-11 "D/L7/WC/5F/SD45/LIFT LOBBY SD"
					-- 6:7-46 HTRI-R "D/L7/WC/5F/CM46/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:7-47 HMS-S/D/M/SA "D/L7/WC/5F/MCP47/FIRE SHAFT L.L."
					-- 6:7-48 HTRI-S "D/L7/WC/5F/MM48/FIRE SHAFT L.L."
					-- 6:7-49 HTRI-R "D/L7/WC/5F/CM49/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 6:7-50 HFP-11 "D/L7/WC/5F/SD50/CORR NR DWS/28"
					-- 6:7-51 HFP-11 "D/L7/WC/5F/SD51/AHU RM SD"
					-- 6:7-52 HTRI-R "D/L7/WC/5F/CM52/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 6:7-53 HFP-11 "D/L7/WC/5F/SD53/CORR NR DR"
					-- 6:7-54 HFP-11 "D/L7/WC/5F/SD54/CORR NR AHU"
					-- 6:7-55 HFP-11 "D/L7/WC/5F/SD55/CORR NR 5012"
					-- 6:7-56 HFP-11 "D/L7/WC/5F/SD56/CORR NR CURVE"
					-- 6:7-57 HFP-11 "D/L7/WC/5F/SD57/CORR NR CURVE"
					-- 6:7-58 HFP-11 "D/L7/WC/5F/SD58/CORR "

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:7 DLC "DLC @ address 7 L7"

					-- 6:7-59 HFPT-11 "D/L7/HD59/CW6130/PANTRY"
					-- 6:7-62 HTRI-R "D/L7/WC/5F/CM62/FIRE STAIR CASE "
					-- Switch ""
					-- Relay
					-- 6:7-63 HMS-S/D/M/SA "D/L7/WC/5F/MCP63/FIRE STAIR CASE"
					-- 6:7-64 HFP-11 "D/L7/WC/5F/SD64/CORR NR DW 5080"
					-- 6:7-65 HFP-11 "D/L7/WC/5F/SD65/CORR NR 5340"
					-- 6:7-66 HFP-11 "D/L7/WC/5F/SD66/CORR NR 5340"
					-- 6:7-67 HFP-11 "D/L7/WC/5F/SD67/CORR NR 5140"
					-- 6:7-68 HFP-11 "D/L7/WC/5F/SD68/CORR NR 5140"
					-- 6:7-69 HFP-11 "D/L7/WC/5F/SD69/CORR NR 5140"
					-- 6:7-70 HFP-11 "D/L7/WC/5F/SD70/CORR NR 5290"
					-- 6:7-71 HFP-11 "D/L7/DW6340/SD71/Cab 1"
					-- 6:7-72 HFP-11 "D/L7/DW6340/SD72/Cab 2"
					-- 6:7-73 HFP-11 "D/L7/DW6340/SD73/Psg nr Entry"
					-- 6:7-74 HTRI-R "D/L7/DW6340/CM74/Psg nr Entry dr"
					-- Switch ""
					-- Relay
					-- 6:7-75 HMS-S/D/M/SA "D/L7/DW6340/MCP75/Psg nr Entry d"
					-- 6:7-77 HFP-11 "D/L7/DW6330/SD77/Pantry"
					-- 6:7-78 HFP-11 "D/L7/DW6330/SD78/Main cab"
					-- 6:7-79 HFP-11 "D/L7/DW6330/SD79/Accounts cab"
					-- 6:7-80 HTRI-R "D/L7/DW6330/CM80/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:7-81 HMS-S/D/M/SA "D/L7/DW6330/MCP81/Psg nr Entry"
					-- 6:7-85 HTRI-S "D/L7/D/6F/MM85/CW6071"
					-- 6:7-86 HTRI-S "D/L7/6F/MM86/CW6142"
					-- 6:7-87 HTRI-S "D/L7/6F/MM87/CW6072"
					-- 6:7-88 HTRI-S "D/L7/6F/MM88/CW6080"
					-- 6:7-89 HTRI-S "D/L7/6F/MM89/CW6141"
					-- 6:7-90 HTRI-S "D/L7/6F/MM90/CW6090"
					-- 6:7-91 HTRI-S "D/L7/WC/6F/MM91/CW6092A"
					-- 6:7-93 HTRI-S "D/L7/6F/MM93/CW6110"
					-- 6:7-94 HTRI-S "D/L7/WC/6F/MM94/CW6120"
					-- 6:7-97 HTRI-S "D/L7/6F/MM97/DW6362"
					-- 6:7-100 HTRI-S "D/L7/6F/MM100/DW6020"
					-- 6:7-101 HTRI-S "D/L7/6F/MM101/DW6031"
					-- 6:7-106 HTRI-S "D/L7/6F/MM106/DW6060"
					-- 6:7-107 HTRI-S "D/L7/6F/MM107/DW6110"
					-- 6:7-108 HFP-11 "D/L7/SD108/CW6130/MAIN CABIN"
					-- 6:7-109 HFP-11 "D/L7/SD109/CW6130/CABIN 1"
					-- 6:7-110 HFP-11 "D/L7/SD110/CW6130/CABIN 2"
					-- 6:7-111 HFP-11 "D/L7/SD111/CW6130/CABIN 3"
					-- 6:7-112 HTRI-S "D/L7/6F/MM112/DW6100"
					-- 6:7-113 HFP-11 "D/L7/DW6080/SD113/Pantry"
					-- 6:7-114 HFP-11 "D/L7/SD114/CW6130/PSG NR PANTRY"
					-- 6:7-115 HMS-S/D/M/SA "D/L7/MCP115/CW6130/ENTRY PSG"
					-- 6:7-116 HTRI-S "D/L7/6F/MM116/DW6130"
					-- 6:7-117 HTRI-S "D/L7/6F/MM117/DW6320"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:7 DLC "DLC @ address 7 L7"

```
| | | | | -- 6:7-118 HTRI-R "D/L7/CM118/CW6130/ENTRY PSG AFC"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:7-119 HTRI-S "D/L7/6F/MM119/DW6140"
| | | | | -- 6:7-120 HTRI-S "D/L7/6F/MM120/DW6300"
| | | | | -- 6:7-121 HTRI-S "D/L7/6F/MM121/DW6150"
| | | | | -- 6:7-122 HTRI-S "D/L7/6F/MM122/DW6160"
| | | | | -- 6:7-123 HTRI-S "D/L7/6F/MM123/DW6290"
| | | | | -- 6:7-124 HTRI-S "D/L7/5F/MM124/DW5160"
| | | | | -- 6:7-126 HTRI-S "D/L7/5F/MM126/DW5300"
| | | | | -- 6:7-129 HTRI-S "D/L7/5F/MM129/DW5310"
| | | | | -- 6:7-130 HTRI-S "D/L7/5F/MM130/DW5320"
| | | | | -- 6:7-131 HTRI-S "D/L7/5F/MM131/DW5130"
| | | | | -- 6:7-132 HTRI-S "D/L7/5F/MM132/DW5120"
| | | | | -- 6:7-134 HTRI-S "D/L7/5F/MM134/DW5110"
| | | | | -- 6:7-135 HTRI-S "D/L7/5F/MM135/DW5100"
| | | | | -- 6:7-136 HTRI-S "D/L7/5F/MM136/DW5340"
| | | | | -- 6:7-138 HTRI-S "D/L7/5F/MM138/DW5080"
| | | | | -- 6:7-139 HTRI-S "D/L7/5F/MM139/DW5070"
| | | | | -- 6:7-140 HTRI-S "D/L7/5F/MM140/DW5351"
| | | | | -- 6:7-143 HTRI-S "D/L7/5F/MM143/DW5040"
| | | | | -- 6:7-144 HTRI-S "D/L7/5F/MM144/DW5030"
| | | | | -- 6:7-146 HTRI-S "D/L7/5F/MM146/DW5021"
| | | | | -- 6:7-147 HTRI-S "D/L7/5F/MM147/DW5012"
| | | | | -- 6:7-148 HTRI-S "D/L7/5F/MM148/DW5352"
| | | | | -- 6:7-149 HTRI-S "D/L7/5F/MM149/DW5011"
| | | | | -- 6:7-150 HTRI-S "D/L7/5F/MM150/DW5360"
| | | | | -- 6:7-152 HTRI-S "D/L7/5F/MM152/DW5353"
| | | | | -- 6:7-153 HFPT-11 "D/L7/DW6032/HD153/Pantry"
| | | | | -- 6:7-154 HTRI-S "D/L7/5F/MM154/CW5100"
| | | | | -- 6:7-155 HFP-11 "D/L7/DW6032/SD155/Cabin 1"
| | | | | -- 6:7-157 HFP-11 "D/L7/DW6032/SD157/Account Cab"
| | | | | -- 6:7-158 HFP-11 "D/L7/DW6032/SD158/Staff Lunch ca"
| | | | | -- 6:7-159 HFP-11 "D/L7/DW6032/SD159/Cabin 3"
| | | | | -- 6:7-160 HFP-11 "D/L7/DW6032/SD160/Psg Nr Pantry"
| | | | | -- 6:7-161 HFP-11 "D/L7/DW6032/SD161/Cabin 2"
| | | | | -- 6:7-162 HFP-11 "D/L7/DW6032/SD162/Cabin 2"
| | | | | -- 6:7-163 HFP-11 "D/L7/CW5090/SD163/Reception"
| | | | | -- 6:7-164 HFP-11 "D/L7/CW5090/SD164/cab 1"
| | | | | -- 6:7-165 HFP-11 "D/L7/CW5090/SD165/cab 2"
| | | | | -- 6:7-166 HFP-11 "D/L7/CW5090/SD166/Accounts cab"
| | | | | -- 6:7-167 HFP-11 "D/L7/CW5090/SD167/cab 3"
| | | | | -- 6:7-168 HFP-11 "D/L7/CW5090/SD168/cab 4"
| | | | | -- 6:7-169 HFP-11 "D/L7/CW5090/SD169/Psg nr cab 4"
| | | | | -- 6:7-170 HFP-11 "D/L7/CW5090/SD170/Pantry"
| | | | | -- 6:7-171 HFP-11 "D/L7/CW5090/SD171/Psg nr Recepti"
| | | | | -- 6:7-172 HTRI-R "D/L7/CW5090/CM172/Psg nr Recepti"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:7-173 HMS-S/D/M/SA "D/L7/CW5090/MCP173/Psg nr Recept"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:7 DLC "DLC @ address 7 L7"

					-- 6:7-174 HFPT-11 "D/L7/DW5050/HD174/Pantry"
					-- 6:7-175 HFP-11 "D/L7/DW5050/SD175/Psg nr Assorte"
					-- 6:7-176 HTRI-R "D/L7/DW5050/CM176/AFC Pantry"
					-- Switch ""
					-- Relay
					-- 6:7-177 HFP-11 "D/L7/DW5050/SD177/Cab 1"
					-- 6:7-178 HFP-11 "D/L7/DW5050/SD178/Main cab"
					-- 6:7-179 HFP-11 "D/L7/DW5050/SD179/Main cab"
					-- 6:7-180 HMS-S/D/M/SA "D/L7/DW5050/MCP180/Psg nr Entry"
					-- 6:7-181 HFP-11 "D/L7/CW5110/SD181/Reception"
					-- 6:7-182 HFPT-11 "D/L7/CW5110/HD182/Pantry"
					-- 6:7-183 HFP-11 "D/L7/CW5110/SD183/Account cab"
					-- 6:7-184 HFP-11 "D/L7/CW5110/SD184/Main cab"
					-- 6:7-185 HFP-11 "D/L7/CW5110/SD185/Main cab"
					-- 6:7-186 HFP-11 "D/L7/CW5110/SD186/Assorter cab"
					-- 6:7-187 HFP-11 "D/L7/CW5110/SD187/Assorter cab"
					-- 6:7-188 HTRI-R "D/L7/CW5110/CM188/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 6:7-189 HMS-S/D/M/SA "D/L7/CW5110/MCP189/Psg nr Entry "
					-- 6:7-190 HFP-11 "D/L7/CW6100/SD190/Pantry"
					-- 6:7-191 HFP-11 "D/L7/CW6100/SD191/Pantry"
					-- 6:7-192 HFP-11 "D/L7/CW6100/SD192/Main cab"
					-- 6:7-194 HTRI-R "D/L7/CW6100/CM194/Pantry"
					-- Switch ""
					-- Relay
					-- 6:7-195 HMS-S/D/M/SA "D/L7/CW6100/MCP195/Pantry"
					-- 6:7-196 HFPT-11 "D/L7/CW5120/HD196/Pantry"
					-- 6:7-197 HFP-11 "D/L7/CW5120/SD197/sales cab 1"
					-- 6:7-198 HFP-11 "D/L7/CW5120/SD198/Buyers cab 1"
					-- 6:7-199 HFP-11 "D/L7/CW5120/SD199/Buyers cab 2"
					-- 6:7-200 HFP-11 "D/L7/CW5120/SD200/MD cab"
					-- 6:7-201 HFP-11 "D/L7/CW5120/SD201/sales cab 2"
					-- 6:7-202 HFP-11 "D/L7/CW5120/SD202/Psg nr sales c"
					-- 6:7-203 HFP-11 "D/L7/CW5120/SD203/Reception Area"
					-- 6:7-204 HTRI-R "D/L7/CW5120/CM204/Psg nr Entry D"
					-- Switch ""
					-- Relay
					-- 6:7-205 HMS-S/D/M/SA "D/L7/CW5120/MCP205/Psg nr Entry "
					-- 6:7-208 HFP-11 "D/L7/DW5330/SD208/Main cab"
					-- 6:7-209 HFP-11 "D/L7/DW5330/SD209/Cab 1"
					-- 6:7-210 HFP-11 "D/L7/DW5330/SD210/Psg nr cab 1"
					-- 6:7-211 HMS-S/D/M/SA "D/L7/DW5330/MCP211/Psg nr Entry"
					-- 6:7-212 HTRI-R "D/L7/DW5330/CM212/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:7-214 HFP-11 "D/L7/DC6100/SD214/Psg nr Entranc"
					-- 6:7-215 HFP-11 "D/L7/DC6100/SD215/Pantry Area"
					-- 6:7-216 HFP-11 "D/L7/DC6100/SD216/Lunch Area"
					-- 6:7-217 HFP-11 "D/L7/DC6100/SD217/Accounts cab"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:7 DLC "DLC @ address 7 L7"

					-- 6:7-218 HFP-11 "D/L7/DC6100/SD218/Trading Cab"
					-- 6:7-219 HFP-11 "D/L7/DC6100/SD219/Assorter Cab"
					-- 6:7-220 HFP-11 "D/L7/DC6100/SD220/Bagging cab"
					-- 6:7-221 HFP-11 "D/L7/DC6100/SD221/Psg nr Trading"
					-- 6:7-222 HFP-11 "D/L7/DC6100/SD222/Director cab"
					-- 6:7-223 HMS-S/D/M/SA "D/L7/DC6100/MCP223/Psg nr Entry"
					-- 6:7-224 HTRI-R "D/L7/DC6100/CM224/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:7-226 HFP-11 "D/L7/DW6310/SD226/Pantry"
					-- 6:7-227 HFP-11 "D/L7/DW6310/SD227/Main cab"
					-- 6:7-228 HFP-11 "D/L7/DW6310/SD228/Assorter cab"
					-- 6:7-229 HFP-11 "D/L7/DW6310/SD229/Account cab"
					-- 6:7-230 HTRI-R "D/L7/DW6310/CM230/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:7-231 HMS-S/D/M/SA "D/L7/DW6310/MCP231/Psg nr Entry"
					-- 6:7-232 HFP-11 "D/L7/DW6120/SD232/Psg nr Entry"
					-- 6:7-233 HFP-11 "D/L7/DW6120/D233/Pantry "
					-- 6:7-234 HFP-11 "D/L7/DW6120/SD234/Accounts Cab"
					-- 6:7-235 HFP-11 "D/L7/DW6120/SD235/MD cab"
					-- 6:7-236 HFP-11 "D/L7/DW6120/SD236/Buyers cab"
					-- 6:7-237 HFP-11 "D/L7/DW6120/SD237/Assorter cab"
					-- 6:7-238 HTRI-R "D/L7/DW6120/CM238/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:7-239 HMS-S/D/M/SA "D/L7/DW6120/MCP239/Psg nr Entry"
					-- 6:7-240 HFP-11 "D/L7/DW6032/SD240/Cabin 1"
					-- 6:7-241 HTRI-R "D/L7/CM241/DW6032/AFC Reception"
					-- Switch ""
					-- Relay
					-- 6:7-242 HMS-S/D/M/SA "D/L7/MCP242/DW6032/Reception Are"
					-- 6:7-243 HFP-11 "D/L7/DW6090/SD243/Psg nr Main ca"
					-- 6:7-244 HFP-11 "D/L7/DW6090/SD244/Pantry"
					-- 6:7-245 HMS-S/D/M/SA "D/L7/DW6090/MCP245/Psg nr Entry"
					-- 6:7-246 HTRI-R "D/L7/DW6090/CM246/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:7-247 HFP-11 "D/L7/DW6080/SD247/Main cab"
					-- 6:7-248 HFP-11 "D/L7/DW6080/SD248/Assorter cab"
					-- 6:7-249 HFP-11 "D/L7/DW6080/SD249/Waiting cab"
					-- 6:7-250 HFP-11 "D/L7/DW6080/SD250/Psg nr Assort."
					-- 6:7-251 HTRI-R "D/L7/DW6080/CM251/AFC Pantry"
					-- Switch ""
					-- Relay
					-- 6:7-252 HMS-S/D/M/SA "D/L7/DW6080/MCP252/Pantry"
					-- 6:8 DLC "DLC @ address 8 L8"
					-- 6:8-1 HTRI-R "D/L8/8F/CM1/DR RELEASE CM NR E.R."
					-- Switch ""
					-- Relay

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:8 DLC "DLC @ address 8 L8"

					-- 6:8-2 HFP-11 "D/L8/8F/SD2/ELECT RM SD"
					-- 6:8-3 HFP-11 "D/L8/8F/SD3/CORR NR 8130"
					-- 6:8-4 HFP-11 "D/L8/8F/SD4/CORR NR 8130"
					-- 6:8-5 HFP-11 "D/L8/8F/SD5/CORR NR 8090"
					-- 6:8-6 HFP-11 "D/L8/8F/SD6/CORR NR FIRE ESC"
					-- 6:8-7 HFP-11 "D/L8/8F/SD7/CORR NR FIRE ESC"
					-- 6:8-8 HFP-11 "D/L8/8F/SD8/CORR NR 8070"
					-- 6:8-9 HFP-11 "D/L8/8F/SD9/CORR NR 8050"
					-- 6:8-10 HFP-11 "D/L8/8F/SD10/CORR NR 8170"
					-- 6:8-11 HFP-11 "D/L8/8F/SD11/CORR NR 8180"
					-- 6:8-12 HFP-11 "D/L8/8F/SD12/CORR NR E.R."
					-- 6:8-13 HFP-11 "D/L8/8F/SD13/CORR NR E.R."
					-- 6:8-14 HFP-11 "D/L8/8F/SD14/ELECT RM SD"
					-- 6:8-15 HMS-S/D/M/SA "D/L8/8F/MCP15/FIRE ESC NR 8090"
					-- 6:8-16 HTRI-R "D/L8/8F/CM16/FIRE ESC NR 8090"
					-- Switch ""
					-- Relay
					-- 6:8-17 HTRI-R "D/L8/8F/CM17/DR RELESE CM NR E.R"
					-- Switch ""
					-- Relay
					-- 6:8-18 HMS-S/D/M/SA "D/L8/8F/MCP18/FIRE SHAFT L.L."
					-- 6:8-19 HTRI-R "D/L8/8F/CM19/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:8-20 HTRI-S "D/L8/8F/MM20/FIRE SHAFT L.L."
					-- 6:8-21 HFP-11 "D/L8/8F/SD21/LIFT LOBBY SD"
					-- 6:8-22 HFP-11 "D/L8/8F/SD22/LIFT LOBBY SD"
					-- 6:8-23 HTRI-R "D/L8/8F/CM23/DR RELESE CM NR8062"
					-- Switch ""
					-- Relay
					-- 6:8-24 HFP-11 "D/L8/8F/SD24/AHU RM SD"
					-- 6:8-25 HTRI-R "D/L8/8F/CM25/AHU RM CM NR 8061"
					-- Switch ""
					-- Relay
					-- 6:8-26 HFP-11 "D/L8/8F/SD26/CORR NR 8061"
					-- 6:8-27 HFP-11 "D/L8/8F/SD27/CORR NR 8061"
					-- 6:8-28 HFP-11 "D/L8/8F/SD28/CORR NR 8070"
					-- 6:8-29 HFP-11 "D/L8/8F/SD29/CORR NR 8081"
					-- 6:8-30 HFP-11 "D/L8/8F/SD30/CORR NR 8081"
					-- 6:8-31 HFP-11 "D/L8/8F/SD31/CORR NR 8031"
					-- 6:8-32 HMS-S/D/M/SA "D/L8/8F/MCP32/FIRE ESC STR NR 80"
					-- 6:8-33 HTRI-R "D/L8/8F/CM33/FIRE ESC STR NR 803"
					-- Switch ""
					-- Relay
					-- 6:8-34 HFP-11 "D/L8/8F/SD34/CORR NR DE8/S03"
					-- 6:8-35 HFP-11 "D/L8/8F/SD35/CORR NR E.R."
					-- 6:8-36 HFP-11 "D/L8/8F/SD36/CORR NR E.R."
					-- 6:8-37 HFP-11 "D/L8/8F/SD37/CORR NR E.R."
					-- 6:8-38 HFP-11 "D/L8/8F/SD38/CORR NR E.R."
					-- 6:8-39 HFP-11 "D/L8/8F/SD39/ELECT RM SD EAST"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:8 DLC "DLC @ address 8 L8"

					-- 6:8-40 HFP-11 "D/L8/8F/SD40/AHU RM SD EAST"
					-- 6:8-41 HTRI-R "D/L8/8F/CM41/AHU RM CM EAST"
					-- Switch ""
					-- Relay
					-- 6:8-42 HFP-11 "D/L8/8F/SD42/LIFT LOBBY SD EAST"
					-- 6:8-43 HMS-S/D/M/SA "D/L8/8F/MCP43/FIRE SHAFT L.L. EA"
					-- 6:8-44 HTRI-R "D/L8/8F/CM44/FIRE SHAFT L.L. EAS"
					-- Switch ""
					-- Relay
					-- 6:8-45 HTRI-S "D/L8/8F/MM45/FIRE SHAFT L.L. EAS"
					-- 6:8-46 HTRI-R "D/L8/9F/CM46/DR RELESE CM WEST"
					-- Switch ""
					-- Relay
					-- 6:8-47 HFP-11 "D/L8/9F/SD47/CORR NR DC 9030"
					-- 6:8-48 HFP-11 "D/L8/9F/SD48/CORR NR 9030"
					-- 6:8-49 HFP-11 "D/L8/9F/SD49/CORR NR 9040"
					-- 6:8-50 HFP-11 "D/L8/9F/SD50/CORR NR 9021"
					-- 6:8-51 HFP-11 "D/L8/9F/SD51/CORR NR FIRE ESC"
					-- 6:8-52 HTRI-R "D/L8/9F/CM52/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 6:8-53 HMS-S/D/M/SA "D/L8/9F/MCP53/FIRE ESC STR"
					-- 6:8-54 HFP-11 "D/L8/9F/SD54/CORR NR 9080"
					-- 6:8-55 HFP-11 "D/L8/9F/SD55/CORR NR 9110"
					-- 6:8-56 HFP-11 "D/L8/9F/SD56/CORR NR 9110"
					-- 6:8-57 HFP-11 "D/L8/9F/SD57/CORR NR 9131"
					-- 6:8-58 HFP-11 "D/L8/9F/SD58/CORR NR 9133"
					-- 6:8-59 HFP-11 "D/L8/9F/SD59/CORR NR 9133"
					-- 6:8-60 HFP-11 "D/L8/9F/SD60/ELECT RM SD"
					-- 6:8-61 HTRI-R "D/L8/9F/CM61/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 6:8-62 HTRI-R "D/L8/9F/CM62/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:8-63 HMS-S/D/M/SA "D/L8/9F/MCP63/FIRE SHAFT L.L."
					-- 6:8-64 HTRI-S "D/L8/9F/MM64/FIRE SHAFT L.L."
					-- 6:8-65 HFP-11 "D/L8/9F/SD65/LIFT LOBBY SD"
					-- 6:8-66 HFP-11 "D/L8/9F/SD66/LIFT LOBBY SD"
					-- 6:8-67 HTRI-R "D/L8/9F/CM67/AHU RM SD"
					-- Switch ""
					-- Relay
					-- 6:8-68 HFP-11 "D/L8/9F/SD68/AHU RM CM"
					-- 6:8-69 HTRI-S "D/L8/9F/MM69/DC9040"
					-- 6:8-70 HFP-11 "D/L8/DE8081A/SD70/Main cab1"
					-- 6:8-71 HFP-11 "D/L8/9F/SD71/CORR NR MIDDLE PASG"
					-- 6:8-73 HTRI-R "D/L8/9F/CM73/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 6:8-74 HFP-11 "D/L8/9F/SD74/AHU RM SD"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:8 DLC "DLC @ address 8 L8"

					-- 6:8-75 HFP-11 "D/L8/9F/SD75/ELECT RM SD"
					-- 6:8-76 HFP-11 "D/L8/9F/SD76/LIFT LOBBY SD"
					-- 6:8-77 HTRI-R "D/L8/9F/CM77/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 6:8-78 HMS-S/D/M/SA "D/L8/9F/MCP78/FIRE SHAFT L.L."
					-- 6:8-79 HTRI-S "D/L8/9F/MM79/FIRE SHAFT L.L."
					-- 6:8-80 HFP-11 "D/L8/9F/SD80/CORR DC9012A"
					-- 6:8-81 HFP-11 "D/L8/DC9131/SD81/Waitng Area"
					-- 6:8-82 HFP-11 "D/L8/DC9131/SD82/Accounts dept"
					-- 6:8-83 HFP-11 "D/L8/DC9131/SD83/Main cab"
					-- 6:8-84 HFP-11 "D/L8/DC9131/SD84/Assorter cab"
					-- 6:8-85 HFP-11 "D/L8/DC9131/SD85/Cab 3"
					-- 6:8-86 HFPT-11 "D/L8/DC9131/HD86/Cab 3"
					-- 6:8-87 HFP-11 "D/L8/DC9131/SD87/Psg nr Cab 5"
					-- 6:8-88 HFP-11 "D/L8/DC9131/SD88/Cab 8"
					-- 6:8-89 HFP-11 "D/L8/DC9131/SD89/Cab 4"
					-- 6:8-90 HFPT-11 "D/L8/DC9131/HD90/Cab 4"
					-- 6:8-91 HFPT-11 "D/L8/DC9131/HD91/Pantry"
					-- 6:8-92 HTRI-R "D/L8/DC9131/CM92/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:8-93 HMS-S/D/M/SA "D/L8/DC9131/MCP93/Psg nr Entry"
					-- 6:8-94 HMS-S/D/M/SA "D/L8/MCP94/DE8050A/ENTRY PSG"
					-- 6:8-95 HTRI-S "D/L8/9F/MM95/DW9020"
					-- 6:8-96 HTRI-S "D/L8/9F/MM96/DC9022"
					-- 6:8-97 HTRI-S "D/L8/9F/MM97/DC9030A"
					-- 6:8-98 HTRI-S "D/L8/9F/MM98/DC9030"
					-- 6:8-99 HFP-11 "D/L8/SD99/DE8050A/MAIN CABIN"
					-- 6:8-100 HFP-11 "D/L8/SD100/DE8050A/ASSORTOR CABI"
					-- 6:8-101 HFP-11 "D/L8/SD101/DE8050A/BUYER CABIN"
					-- 6:8-102 HFP-11 "D/L8/SD102/DE8050A/ENTRY PSG"
					-- 6:8-103 HFP-11 "D/L8/SD103/DE8050A/ACCOUNT CABIN"
					-- 6:8-104 HFP-11 "D/L8/SD104/DE8050A/ASSORTOR CABI"
					-- 6:8-105 HFP-11 "D/L8/SD105/DE8050A/PANTRY"
					-- 6:8-106 HTRI-R "D/L8/CM106/DE8050A/ENTRY PSG AFC"
					-- Switch ""
					-- Relay
					-- 6:8-107 HFP-11 "D/L8/DE8081A/SD107/Assorter cab"
					-- 6:8-108 HTRI-S "D/L8/9F/MM108/DC9110"
					-- 6:8-109 HTRI-S "D/L8/9F/MM109/DC9012"
					-- 6:8-110 HTRI-S "D/L8/9F/MM110/DC9120"
					-- 6:8-112 HTRI-S "D/L8/9F/MM112/DC9090"
					-- 6:8-113 HFP-11 "D/L8/DE8081A/SD113/Main cab2"
					-- 6:8-114 HTRI-S "D/L8/9F/MM114/DC9132"
					-- 6:8-116 HTRI-S "D/L8/9F/MM116/DE9011"
					-- 6:8-117 HTRI-S "D/L8/9F/MM117/DE8011"
					-- 6:8-118 HFPT-11 "D/L8/DE8081A/HD118/Pantry"
					-- 6:8-119 HTRI-S "D/L8/9F/MM119/DE8010A"
					-- 6:8-120 HTRI-S "D/L8/9F/MM120/DC9010A"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:8 DLC "DLC @ address 8 L8"

```
| | | | | -- 6:8-122 HTRI-S "D/L8/9F/MM122/DE8020"
| | | | | -- 6:8-123 HTRI-R "D/L8/DE8081A/CM123/Entry dr psg"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:8-124 HTRI-S "D/L8/9F/MM124/DE9012A"
| | | | | -- 6:8-125 HTRI-S "D/L8/9F/MM125/DE8031"
| | | | | -- 6:8-126 HTRI-S "D/L8/9F/MM126/DE8040"
| | | | | -- 6:8-127 HTRI-S "D/L8/9F/MM127/DE8082"
| | | | | -- 6:8-128 HTRI-S "D/L8/9F/MM128/DE8081-B"
| | | | | -- 6:8-129 HMS-S/D/M/SA "D/L8/DE8081A/MCP129/Entry dr psg"
| | | | | -- 6:8-130 HMS-S/D/M/SA "D/L8/DE8090A/MCP130/Entry psg"
| | | | | -- 6:8-132 HTRI-S "D/L8/8F/MM132/DE8061"
| | | | | -- 6:8-133 HFP-11 "D/L8/DC8020/SD133/Main cab 1"
| | | | | -- 6:8-134 HFP-11 "D/L8/DC8020/SD134/Main cab 2"
| | | | | -- 6:8-135 HTRI-S "D/L8/9F/MM135/DE8063"
| | | | | -- 6:8-136 HTRI-S "D/L8/9F/MM136/DC8210"
| | | | | -- 6:8-137 HTRI-S "D/L8/9F/MM137/DC8200"
| | | | | -- 6:8-138 HTRI-S "D/L8/9F/MM138/DC8010"
| | | | | -- 6:8-139 HFP-11 "D/L8/DC8020/SD139/Entry Psg"
| | | | | -- 6:8-140 HTRI-S "D/L8/9F/MM140/DC8190A"
| | | | | -- 6:8-141 HTRI-S "D/L8/9F/MM141/DC8190B"
| | | | | -- 6:8-142 HTRI-S "D/L8/9F/MM142/DC8180"
| | | | | -- 6:8-143 HFP-11 "D/L8/DC8020/SD143/Account cab"
| | | | | -- 6:8-144 HTRI-S "D/L8/9F/MM144/DC8040"
| | | | | -- 6:8-145 HFP-11 "D/L8/DC8020/SD145/Pantry"
| | | | | -- 6:8-146 HTRI-S "D/L8/9F/MM146/DC8160"
| | | | | -- 6:8-147 HTRI-S "D/L8/9F/MM147/DC8050"
| | | | | -- 6:8-148 HTRI-S "D/L8/9F/MM148/DC8060"
| | | | | -- 6:8-149 HTRI-S "D/L8/9F/MM149/DC8150"
| | | | | -- 6:8-150 HTRI-S "D/L8/9F/MM150/DC8070"
| | | | | -- 6:8-151 HTRI-R "D/L8/DC8020/CM151/AFC Entry Psg"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:8-152 HMS-S/D/M/SA "D/L8/DC8020/MCP152/Entry Psg"
| | | | | -- 6:8-153 HTRI-S "D/L8/9F/MM153/DC8090"
| | | | | -- 6:8-154 HTRI-S "D/L8/9F/MM154/DC8132"
| | | | | -- 6:8-155 HTRI-S "D/L8/9F/MM155/DC9120A"
| | | | | -- 6:8-156 HTRI-S "D/L8/9F/MM156/DC8101"
| | | | | -- 6:8-157 HTRI-S "D/L8/9F/MM157/DC8102"
| | | | | -- 6:8-158 HTRI-S "D/L8/9F/MM158/DC8120"
| | | | | -- 6:8-159 HTRI-S "D/L8/9F/MM159/DC8110"
| | | | | -- 6:8-160 HFP-11 "D/L8/DC8140/SD160/Entry Psg"
| | | | | -- 6:8-161 HFP-11 "D/L8/DC8140/SD161/Assorter cab"
| | | | | -- 6:8-162 HFP-11 "D/L8/DC8140/SD162/Account cab"
| | | | | -- 6:8-163 HFP-11 "D/L8/DC8140/SD163/Main cab"
| | | | | -- 6:8-164 HFP-11 "D/L8/DC8140/SD164/Pantry"
| | | | | -- 6:8-165 HTRI-R "D/L8/DC8140/CM165/Entry Psg"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:8-166 HMS-S/D/M/SA "D/L8/DC8140/MCP166/Entry Psg"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:8 DLC "DLC @ address 8 L8"

```
| | | | |-- 6:8-167 HFP-11 "D/L8/DC/SD167/DC TERACE LIFT RM"
| | | | |-- 6:8-168 HFP-11 "D/L8/DC/SD168/DC TERACE LIFT RM"
| | | | |-- 6:8-169 HFP-11 "D/L8/DC/SD169/DC TERACE LIFT RM"
| | | | |-- 6:8-170 HTRI-S "D/L8/8F/MM170/DC8131"
| | | | |-- 6:8-174 HFP-11 "D/L8/DC8030/SD174/Main cab"
| | | | |-- 6:8-175 HFP-11 "D/L8/DC8030/SD175/Account cab"
| | | | |-- 6:8-176 FDOT421 "D/L8/DE8050/SD176/Accounts cab"
| | | | |-- 6:8-177 HFP-11 "D/L8/DE8050/SD177/Pantry"
| | | | |-- 6:8-178 HFP-11 "D/L8/DE8050/SD178/Assorter cab"
| | | | |-- 6:8-179 HFP-11 "D/L8/DE8050/SD179/Main cab"
| | | | |-- 6:8-180 HFP-11 "D/L8/DE8050/SD180/Main cab"
| | | | |-- 6:8-181 FDOT421 "D/L8/DE8050/SD181/Psg nr Main ca"
| | | | |-- 6:8-182 HFP-11 "D/L8/DE8050/SD182/Accounts cab 2"
| | | | |-- 6:8-183 HFP-11 "D/L8/DE8050/SD183/Psg nr Entranc"
| | | | |-- 6:8-184 HTRI-R "D/L8/DE8050/CM184/Psg nr Entranc"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:8-185 HMS-S/D/M/SA "D/L8/DE8050/MCP185/Psg nr Entran"
| | | | |-- 6:8-186 HFP-11 "D/L8/DC8030/SD186/Lunch cab"
| | | | |-- 6:8-187 HFP-11 "D/L8/DC8030/SD187/Computer cab"
| | | | |-- 6:8-188 HFP-11 "D/L8/DC8030/SD188/Pantry"
| | | | |-- 6:8-189 HFP-11 "D/L8/DC8030/SD189/Psg nr Account"
| | | | |-- 6:8-190 HTRI-R "D/L8/DC8030/CM190/AFC Pantry"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:8-191 HMS-S/D/M/SA "D/L8/DC8030/MCP191/Pantry side"
| | | | |-- 6:8-192 HTRI-S "D/L8/9F/MM192/DC9070/80"
| | | | |-- 6:8-193 HFP-11 "D/L8/SD193/DE8070A/MANAGER CABIN"
| | | | |-- 6:8-194 HFP-11 "D/L8/SD194/DE8070A/MAIN CABIN"
| | | | |-- 6:8-195 HFP-11 "D/L8/SD195/DE8070A/BHAGAT CABIN"
| | | | |-- 6:8-196 HFP-11 "D/L8/SD196/DE8070A/ASSORTOR CABI"
| | | | |-- 6:8-197 HFP-11 "D/L8/SD197/DE8070A/ACCCOUNT CABI"
| | | | |-- 6:8-198 HFP-11 "D/L8/SD198/DE8070A/ENTRY PSG."
| | | | |-- 6:8-199 HFP-11 "D/L8/SD199/DE8070A/PANTRY"
| | | | |-- 6:8-200 HTRI-R "D/L8/CM200/DE8070A/PANTRY AFC"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:8-201 HMS-S/D/M/SA "D/L8/MCP201/DE8070A/ENTRY PSG."
| | | | |-- 6:8-202 HFP-11 "D/L8/DC8170/SD202/Main cab3"
| | | | |-- 6:8-203 HFP-11 "D/L8/DC8170/SD203/Main cab2"
| | | | |-- 6:8-204 HFP-11 "D/L8/DC8170/SD204/Main cab1"
| | | | |-- 6:8-205 HFP-11 "D/L8/DC8170/SD205/Entry Psg"
| | | | |-- 6:8-206 HFP-11 "D/L8/DC8170/SD206/Pantry"
| | | | |-- 6:8-207 HTRI-R "D/L8/DC8170/CM207/AFC Entry Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 6:8-208 HMS-S/D/M/SA "D/L8/DC8170/MCP208/Entry Psg"
| | | | |-- 6:8-209 HFP-11 "D/L8/SD209/DC9060/Rec Psg"
| | | | |-- 6:8-210 HFP-11 "D/L8/SD210/DC9060/PANTRY"
| | | | |-- 6:8-211 HFP-11 "D/L8/SD211/DC8080/ASSOTER CABIN"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:8 DLC "DLC @ address 8 L8"

					-- 6:8-212 HFP-11 "D/L8/SD212/DC8080/ACCOUNT CABIN"
					-- 6:8-213 HFP-11 "D/L8/SD213/DC8080/PSG NR ACCOUNT"
					-- 6:8-214 HFP-11 "D/L8/SD214/DC8080/MAIN CABIN"
					-- 6:8-215 HTRI-R "D/L8/CM215/DC8080/ENTERY PSG AFC"
					-- Switch ""
					-- Relay
					-- 6:8-216 HMS-S/D/M/SA "D/L8/MCP216/DC8080/ENTERY PSG"
					-- 6:8-220 HFP-11 "D/L8/DC9100/SD220/Main cab"
					-- 6:8-221 HFP-11 "D/L8/DC9100/SD221/Main cab"
					-- 6:8-222 HFP-11 "D/L8/DC9100/SD222/Assorter cab"
					-- 6:8-223 HFP-11 "D/L8/DC9100/SD223/Entry Psg"
					-- 6:8-224 HFP-11 "D/L8/DC9100/SD224/Pantry"
					-- 6:8-225 HTRI-R "D/L8/DC9100/CM225/Entry Psg"
					-- Switch ""
					-- Relay
					-- 6:8-226 HMS-S/D/M/SA "D/L8/DC9100/MCP226/Entry Psg"
					-- 6:8-227 HFP-11 "D/L8/DE8090A/SD227/Main cab 2"
					-- 6:8-228 HFP-11 "D/L8/DE8090A/SD228/Main cab 1"
					-- 6:8-229 HFP-11 "D/L8/DE8090A/SD229/Visitor cab"
					-- 6:8-230 HFP-11 "D/L8/DE8090A/SD230/Dinning rm ps"
					-- 6:8-231 HFP-11 "D/L8/DE8090A/SD231/Dinning rm ps"
					-- 6:8-232 HFP-11 "D/L8/DE8090A/SD232/Assorter cab"
					-- 6:8-233 HFP-11 "D/L8/DE8090A/SD233/Account cab"
					-- 6:8-234 HFP-11 "D/L8/DE8090A/SD234/Psg nr Main c"
					-- 6:8-235 HFP-11 "D/L8/DE8090A/SD235/Entry psg"
					-- 6:8-236 HFPT-11 "D/L8/DE8090A/HD236/Pantry"
					-- 6:8-237 HTRI-R "D/L8/DE8090A/CM237/Entry psg"
					-- Switch ""
					-- Relay
					-- 6:8-238 HFP-11 "D/L8/DC9050/SD238/Pantry"
					-- 6:8-239 HFP-11 "D/L8/DC9050/SD239/Account cab"
					-- 6:8-240 HFP-11 "D/L8/DC9050/SD240/Cab 2"
					-- 6:8-241 HFP-11 "D/L8/DC9050/SD241/Cab 1"
					-- 6:8-242 HFP-11 "D/L8/DC9050/SD242/Psg nr cab 2"
					-- 6:8-243 HTRI-R "D/L8/DC9050/CM243/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:8-244 HMS-S/D/M/SA "D/L8/DC9050/MCP244/Psg nr Entry"
					-- 6:8-245 HFP-11 "D/L8/DC9060/SD245/Pantry"
					-- 6:8-246 HFP-11 "D/L8/DC9060/SD246/Main cab"
					-- 6:8-247 HFP-11 "D/L8/DC9060/SD247/Safe cab"
					-- 6:8-248 HFP-11 "D/L8/DC9060/SD248/Executive cab"
					-- 6:8-249 HFP-11 "D/L8/DC9060/SD249/Assorter cab"
					-- 6:8-250 HFP-11 "D/L8/DC9060/SD250/Account cab"
					-- 6:8-251 HTRI-R "D/L8/DC9060/CM251/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 6:8-252 HMS-S/D/M/SA "D/L8/DC9060/MCP252/Psg nr Entry"
					-- 6:9 DLC "DLC @ address 9 L9"
					-- 6:9-1 HTRI-R "D/L9/WC/9F/CM1/FIRE SHAFT L.L."

```

6 Desigo Fire Safety Modular "BDB TOWER D " Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      6:9 DLC "DLC @ address 9 L9"
        6:9-1 HTRI-R "D/L9/WC/9F/CM1/FIRE SHAFT L.L."

```

				-- Switch ""
				-- Relay
				-- 6:9-2 HMS-S/D/M/SA "D/L9/WC/9F/MCP2/FIRE SHAFT L.L."
				-- 6:9-3 HTRI-S "D/L9/WC/9F/MM3/FIRE SHAFT L.L."
				-- 6:9-4 HFP-11 "D/L9/WC/9F/SD4/LIFT LOBBY SD"
				-- 6:9-5 HFP-11 "D/L9/WC/9F/SD5/LIFT LOBBY SD"
				-- 6:9-6 HFP-11 "D/L9/WC/9F/SD6/ELECT RM SD"
				-- 6:9-7 HFP-11 "D/L9/WC/9F/SD7/AHU RM SD"
				-- 6:9-8 HTRI-R "D/L9/WC/9F/CM8/AHU RM CM"
				-- Switch ""
				-- Relay
				-- 6:9-9 HTRI-R "D/L9/WC/8F/CM9/FIRE SHAFT L.L."
				-- Switch ""
				-- Relay
				-- 6:9-10 HMS-S/D/M/SA "D/L9/WC/8F/MCP10/FIRE SHAFT L.L."
				-- 6:9-11 HTRI-S "D/L9/WC/8F/MM11/FIRE SHAFT L.L."
				-- 6:9-12 HFP-11 "D/L9/WC/8F/SD12/LIFT LOBBY SD"
				-- 6:9-13 HFP-11 "D/L9/WC/8F/SD13/LIFT LOBBY SD"
				-- 6:9-14 HFP-11 "D/L9/WC/8F/SD14/ELECT RM SD"
				-- 6:9-15 HTRI-R "D/L9/WC/8F/CM15/AHU RM CM"
				-- Switch ""
				-- Relay
				-- 6:9-16 HFP-11 "D/L9/WC/8F/SD16/AHU RM SD"
				-- 6:9-17 HTRI-R "D/L9/WC/7F/CM17/FIRE SHAFT L.L."
				-- Switch ""
				-- Relay
				-- 6:9-18 HMS-S/D/M/SA "D/L9/WC/7F/MCP18/FIRE SHAFT L.L."
				-- 6:9-19 HTRI-S "D/L9/WC/7F/MM19/FIRE SHAFT L.L."
				-- 6:9-20 HFP-11 "D/L9/WC/7F/SD20/LIFT LOBBY SD"
				-- 6:9-21 HFP-11 "D/L9/WC/7F/SD21/LIFT LOBBY SD"
				-- 6:9-22 HFP-11 "D/L9/WC/7F/SD22/AHU RM SD"
				-- 6:9-23 HTRI-R "D/L9/WC/7F/CM23/AHU RM CM"
				-- Switch ""
				-- Relay
				-- 6:9-24 HFP-11 "D/L9/WC/7F/SD24/CORR NR DW7/S10"
				-- 6:9-25 HFP-11 "D/L9/WC/7F/SD25/CORR NR DW 7020"
				-- 6:9-26 HFP-11 "D/L9/WC/7F/SD26/ELECT RM SD"
				-- 6:9-27 HFP-11 "D/L9/WC/SD27/DW TERENCE LIFT RM"
				-- 6:9-28 HFP-11 "D/L9/WC/SD28/DW TERENCE LIFT RM"
				-- 6:9-29 HFP-11 "D/L9/WC/SD29/DW TERENCE LIFT RM"
				-- 6:9-30 HFP-11 "D/L9/WC/SD30/DW TERENCE LIFT RM"
				-- 6:9-31 HFP-11 "D/L9/WC/SD31/DW TERENCE LIFT RM"
				-- 6:9-41 HTRI-S "D/L9/9F/MM41/DW9010"
				-- 6:9-45 HTRI-S "D/L9/7F/MM45/DW7020"
				-- 6:9-46 HTRI-S "D/L9/7F/MM46/DW7040"
				-- 6:9-48 HFP-11 "D/L9/DW7050/SD48/Pantry"
				-- 6:9-49 HFP-11 "D/L9/DW7050/SD49/Sales cab"
				-- 6:9-50 HFP-11 "D/L9/DW7050/SD50/Cab nr sales ca"
				-- 6:9-51 HFP-11 "D/L9/DW7050/SD51/Manufacturing c"
				-- 6:9-52 HFP-11 "D/L9/DW7050/SD52/Account cab1"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

6:9 DLC "DLC @ address 9 L9"

| | | | | -- 6:9-53 HFP-11 "D/L9/DW7050/SD53/Account cab2"
| | | | | -- 6:9-54 HFP-11 "D/L9/DW7050/SD54/Psg nr MFG cab"
| | | | | -- 6:9-55 HFP-11 "D/L9/DW7050/SD55/Psg nr Entry"
| | | | | -- 6:9-56 HTRI-R "D/L9/DW7050/CM56/Psg nr Entry "
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:9-57 HMS-S/D/M/SA "D/L9/DW7050/MCP57/Psg nr Entry"
| | | | | -- 6:9-58 HFP-11 "D/L9/DW7010/SD58/Main Cabin"
| | | | | -- 6:9-59 HFP-11 "D/L9/DW7010/SD59/Entry Psg"
| | | | | -- 6:9-60 HTRI-R "D/L9/DW7010/CM60/Entry Psg AFC"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:9-61 HMS-S/D/M/SA "D/L9/DW7050/MCP61/Entry Psg"
| | | | | -- 6:9-62 FDOT421 "D/L9/DW8020/SD62/Assorter Cabin"
| | | | | -- 6:9-63 HFP-11 "D/L9/DW8020/SD63/Pantry Psg"
| | | | | -- 6:9-64 HFP-11 "D/L9/DW8020/SD64/Main Cabin"
| | | | | -- 6:9-65 HFP-11 "D/L9/DW8020/SD65/Entry Dr Psg"
| | | | | -- 6:9-66 HTRI-R "D/L9/DW8020/CM66/Afc Psg nr Entr"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:9-67 HMS-S/D/M/SA "D/L9/DW8020/MCP67/Psg nr Entry"
| | | | | -- 6:9-68 HFP-11 "D/L9/DW8010/SD68/Main Cabin"
| | | | | -- 6:9-69 HFP-11 "D/L9/DW8010/SD69/Assorter Cabin"
| | | | | -- 6:9-70 HFP-11 "D/L9/DW8010/SD70/Assorter Cabin"
| | | | | -- 6:9-71 HFP-11 "D/L9/DW8010/SD71/Psg Nr Asst Cab"
| | | | | -- 6:9-72 HFP-11 "D/L9/DW8010/SD72/Account Cab"
| | | | | -- 6:9-73 HFP-11 "D/L9/DW8010/SD73/Assorter Cab 2"
| | | | | -- 6:9-74 HFPT-11 "D/L7/DW8010/HD74/Pantry"
| | | | | -- 6:9-75 HFP-11 "D/L9/DW8010/SD75/Entry Dr psg"
| | | | | -- 6:9-76 HTRI-R "D/L9/DW8010/CM76/Afc Psg nr Entr"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:9-77 HMS-S/D/M/SA "D/L9/DW8010/MCP77/Psg nr Entry"
| | | | -- 6:10 NIC-C(XNet) "NIC_Xnet @ address 10"
| | | | -- 6:11 NIC-C(HNet) "NIC @ address 11"
| | | -- 6:249 PSC-12 "PSC-12 @ address 249"
| | | | -- 6:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
| | | | -- 6:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
| | | -- Inner Door
| | | | -- 6:253 PMI-D "PMI-D Tower D-6"
| | -- CAB-1 "CAB-1 Enclosure #2"
| | | | -- CC-5 "Card Cage 5 Slots"
| | | | -- 6:6 DLC "DLC @ address 6 L6"
| | | | | -- 6:6-1 HTRI-R "D/L6/6F/CM1/DR RELESE CM"
| | | | | | -- Switch ""
| | | | | | -- Relay
| | | | | -- 6:6-2 HFP-11 "D/L6/6F/SD2/CORR NR DR "
| | | | | -- 6:6-3 HFP-11 "D/L6/6F/SD3/CORR NR DR"
| | | | | -- 6:6-4 HFP-11 "D/L6/6F/SD4/CORR NR DR"
| | | | | -- 6:6-5 HFP-11 "D/L6/6F/SD5/CORR NR FIRE ESC "

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:6 DLC "DLC @ address 6 L6"

```
|      |      |      |-- 6:6-6 HFP-11 "D/L6/6F/SD6/CORR NR FIRE ESC "
|      |      |      |-- 6:6-7 HMS-S/D/M/SA "D/L6/6F/MCP7/FIRE ESC STR"
|      |      |      |-- 6:6-8 HTRI-R "D/L6/6F/CM8/FIRE ESC STR"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-9 HFP-11 "D/L6/6F/SD9/CORR NR 6070"
|      |      |      |-- 6:6-10 HFP-11 "D/L6/6F/SD10/CORR NR 6070"
|      |      |      |-- 6:6-11 HFP-11 "D/L6/6F/SD11/CORR NR 6070"
|      |      |      |-- 6:6-12 HFP-11 "D/L6/6F/SD12/CORR NR 6030"
|      |      |      |-- 6:6-13 HFP-11 "D/L6/6F/SD13/CORR NR 6030"
|      |      |      |-- 6:6-14 HFP-11 "D/L6/6F/SD14/CORR NR 6190"
|      |      |      |-- 6:6-15 HFP-11 "D/L6/6F/SD15/CORR NR 6190"
|      |      |      |-- 6:6-16 HFP-11 "D/L6/6F/SD16/ELECT RM SD"
|      |      |      |-- 6:6-17 HTRI-R "D/L6/6F/CM17/DR RELESE CM "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-18 HMS-S/D/M/SA "D/L6/6F/MCP18/FIRE SHAFT LL "
|      |      |      |-- 6:6-19 HTRI-R "D/L6/6F/CM19/FIRE SHAFT L.L."
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-20 HTRI-S "D/L6/6F/MM20/FIRE SHAFT L.L."
|      |      |      |-- 6:6-21 HFP-11 "D/L6/6F/SD21/LIFT LOBBY SD"
|      |      |      |-- 6:6-22 HFP-11 "D/L6/6F/SD22/LIFT LOBBY SD"
|      |      |      |-- 6:6-23 HFP-11 "D/L6/6F/SD23/CORR NR AHU "
|      |      |      |-- 6:6-24 HFP-11 "D/L6/6F/SD24/AHU RM SD"
|      |      |      |-- 6:6-25 HTRI-R "D/L6/6F/CM25/AHU RM CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-26 HFP-11 "D/L6/6F/SD26/CORR NR AHU"
|      |      |      |-- 6:6-27 HFP-11 "D/L6/6F/SD27/CORR NR AHU "
|      |      |      |-- 6:6-29 HTRI-R "D/L6/6F/CM29/FIRE ESC STR"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-30 HFP-11 "D/L6/DE/6F/SD30/AHU RM"
|      |      |      |-- 6:6-31 HTRI-R "D/L6/DE/6F/CM31/AHU ROOM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-32 HFP-11 "D/L6/DE/6F/SD32/ELECTRICAL ROOM"
|      |      |      |-- 6:6-33 HFP-11 "D/L6/DE/6F/SD33/LIFT LOBBY"
|      |      |      |-- 6:6-34 HTRI-R "D/L6/DE/6F/CM34/FIRE SHAFT"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-35 HTRI-S "D/L6/DE/6F/MM35/FIRE SHAFT"
|      |      |      |-- 6:6-36 HMS-S/D/M/SA "D/L6/DE/6F/MCP36/FIRE SHAFT LL"
|      |      |      |-- 6:6-37 HTRI-R "D/L6/7F/CM37/DR RELESE NR DWS/30"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-38 HFP-11 "D/L6/7F/SD38/CORR NR DW S/30"
|      |      |      |-- 6:6-39 HFP-11 "D/L6/7F/SD39/CORR NR DW S/30"
|      |      |      |-- 6:6-40 HFP-11 "D/L6/7F/SD40/CORR NR 7080"
```


6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:6 DLC "DLC @ address 6 L6"

```
|      |      |      |-- 6:6-41 HFP-11 "D/L6/7F/SD41/CORR NR FIRE ESC"
|      |      |      |-- 6:6-42 HFP-11 "D/L6/7F/SD42/CORR NR FIRE ESC"
|      |      |      |-- 6:6-43 HMS-S/D/M/SA "D/L6/7F/MCP43/FIRE ESC STR"
|      |      |      |-- 6:6-44 HTRI-R "D/L6/7F/CM44/FIRE ESC STR"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-45 HFP-11 "D/L6/7F/SD45/CORR NR 7100"
|      |      |      |-- 6:6-46 HFP-11 "D/L6/7F/SD46/CORR NR 7132"
|      |      |      |-- 6:6-47 HFP-11 "D/L6/7F/SD47/CORR NR 7132"
|      |      |      |-- 6:6-48 HFP-11 "D/L6/7F/SD48/CORR NR 7140"
|      |      |      |-- 6:6-49 HFP-11 "D/L6/7F/SD49/CORR NR 7170"
|      |      |      |-- 6:6-50 HFP-11 "D/L6/7F/SD50/CORR NR 7170"
|      |      |      |-- 6:6-51 HFP-11 "D/L6/7F/SD51/ELECT RM SD"
|      |      |      |-- 6:6-52 HTRI-R "D/L6/7F/CM52/DR RELESE CM NR E.R"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-53 HMS-S/D/M/SA "D/L6/7F/MCP53/FIRE SHAFT LL"
|      |      |      |-- 6:6-54 HTRI-R "D/L6/7F/CM54/FIRE SHAFT L.L. "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-55 HTRI-S "D/L6/7F/MM55/FIRE SHAFT L.L. "
|      |      |      |-- 6:6-56 HFP-11 "D/L6/7F/SD56/LIFT LOBBY SD  "
|      |      |      |-- 6:6-57 HFP-11 "D/L6/7F/SD57/LIFT LOBBY SD  "
|      |      |      |-- 6:6-58 HTRI-R "D/L6/7F/CM58/DR RELELSE CM "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-59 HFP-11 "D/L6/7F/SD59/AHU RM SD  "
|      |      |      |-- 6:6-60 HTRI-R "D/L6/7F/CM60/AHU RM CM  "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-61 HFP-11 "D/L6/7F/SD61/CORR NR E.R."
|      |      |      |-- 6:6-62 HFP-11 "D/L6/7F/SD62/CORR NR E.R."
|      |      |      |-- 6:6-63 HFP-11 "D/L6/7F/SD63/CORR NR 7200"
|      |      |      |-- 6:6-64 HFP-11 "D/L6/7F/SD64/CORR NR 7420"
|      |      |      |-- 6:6-65 HFP-11 "D/L6/7F/SD65/CORR NR 7420"
|      |      |      |-- 6:6-66 HFP-11 "D/L6/7F/SD66/CORR NR 7222"
|      |      |      |-- 6:6-67 HFP-11 "D/L6/7F/SD67/CORR NR 7222"
|      |      |      |-- 6:6-68 HMS-S/D/M/SA "D/L6/7F/MCP68/FIRE ESC STR"
|      |      |      |-- 6:6-69 HTRI-R "D/L6/7F/CM69/FIRE ESC STR"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-70 HFP-11 "D/L6/7F/SD70/LIFT LOBBY SD  "
|      |      |      |-- 6:6-71 HFP-11 "D/L6/7F/SD71/AHU RM SD  "
|      |      |      |-- 6:6-72 HTRI-R "D/L6/7F/CM72/AHU RM CM  "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:6-73 HFP-11 "D/L6/7F/SD73/LIFT LOBBY SD"
|      |      |      |-- 6:6-74 HTRI-S "D/L6/7F/MM74/FIRE SHAFT L.L.  "
|      |      |      |-- 6:6-75 HTRI-R "D/L6/7F/CM75/FIRE SHAFT L.L.  "
|      |      |      |  |-- Switch ""
```

			-- Relay	
				-- 6:6-76 HMS-S/D/M/SA "D/L6/7F/MCP76/FIRE SHAFT L.L."
				-- 6:6-77 HFP-11 "D/L6/DC6112/SD77/Reception"
				-- 6:6-78 HFPT-11 "D/L6/DC6112/HD78/Pantry"
				-- 6:6-79 HFP-11 "D/L6/DC6112/SD79/Account staff"
				-- 6:6-80 HFPT-11 "D/L6/DC6112/HD80/Psg nr Assorter"
				-- 6:6-81 HFP-11 "D/L6/DC6112/SD81/Assorter cab"
				-- 6:6-82 HFP-11 "D/L6/DC6112/SD82/Store room"
				-- 6:6-83 HFP-11 "D/L6/DC6112/SD83/Main cab"
				-- 6:6-84 HFP-11 "D/L6/DC6112/SD84/Main cab"
				-- 6:6-85 HFP-11 "D/L6/DC6112/SD85/Manager cab"
				-- 6:6-86 HTRI-R "D/L6/DC6112/CM86/Psg nr Entry"
				-- Switch ""
				-- Relay
				-- 6:6-87 HMS-S/D/M/SA "D/L6/DC6112/MCP87/Psg nr Entry"
				-- 6:6-88 HFP-11 "D/L6/DC6111AA/SD88/Reception "
				-- 6:6-89 HFP-11 "D/L6/DC6111A/SD89/Accounts cab"
				-- 6:6-90 HFP-11 "D/L6/DC6111A/SD90/Pantry "
				-- 6:6-91 HTRI-S "D/L6/7F/MM91/DC7070"
				-- 6:6-92 HTRI-S "D/L6/7F/MM92/DC7062"
				-- 6:6-94 HTRI-S "D/L6/7F/MM94/DC7090"
				-- 6:6-95 HTRI-S "D/L6/7F/MM95/DC7101"
				-- 6:6-96 HFP-11 "D/L6/SD96/DC6210/CABIN 1"
				-- 6:6-97 HTRI-S "D/L6/7F/MM97/DC7040"
				-- 6:6-98 HTRI-S "D/L6/7F/MM98/DC7110"
				-- 6:6-99 HTRI-S "D/L6/7F/MM99/DC7120"
				-- 6:6-100 HTRI-S "D/L6/7F/MM100/DC7030"
				-- 6:6-101 HFP-11 "D/L6/SD101/DC6210/CABIN 2/MAIN C"
				-- 6:6-102 HTRI-S "D/L6/7F/MM102/DC7140"
				-- 6:6-103 HTRI-S "D/L6/7F/MM103/DC7020"
				-- 6:6-104 HTRI-S "D/L6/7F/MM104/DC7150"
				-- 6:6-105 HTRI-S "D/L6/7F/MM105/DC7160"
				-- 6:6-106 HTRI-S "D/L6/7F/MM106/DC7010"
				-- 6:6-107 HTRI-S "D/L6/7F/MM107/DC7-extra"
				-- 6:6-108 HTRI-S "D/L6/7F/MM108/DC7170"
				-- 6:6-110 HFP-11 "D/L6/SD110/DC6210/CABIN 3"
				-- 6:6-111 HTRI-S "D/L6/7F/MM111/DC7190"
				-- 6:6-112 HFP-11 "D/L6/SD112/DC6210/CABIN 4"
				-- 6:6-113 HFP-11 "D/L6/SD113/DC6210/RECEPTION"
				-- 6:6-114 HTRI-S "D/L6/7F/MM114/DC7211"
				-- 6:6-115 HTRI-S "D/L6/7F/MM115/DC7250"
				-- 6:6-116 HFP-11 "D/L6/SD116/DC6210/PANTRY"
				-- 6:6-117 HTRI-S "D/L6/6F/MM117/DC6200"
				-- 6:6-118 HTRI-S "D/L6/7F/MM118/DC7213"
				-- 6:6-120 HFP-11 "D/L6/SD120/DC7050/Psg Nr. MAIN C"
				-- 6:6-121 HMS-S/D/M/SA "D/L6/MCP121/DC7050/ENTRY PSG"
				-- 6:6-122 HFP-11 "D/L6/SD122/DC7050/MAIN CABIN 1"
				-- 6:6-123 HFP-11 "D/L6/SD123/DC7050/MAIN CABIN2"
				-- 6:6-124 HFP-11 "D/L6/SD124/DC7050/ASSORTOR CABIN"
				-- 6:6-125 HFPT-11 "D/L6/HD125/DC7050/Pantrv"

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:6 DLC "DLC @ address 6 L6"

```
|      |      |      |  -- 6:6-126 HTRI-S "D/L6/6F/MM126/DC6220"
|      |      |      |  -- 6:6-127 HTRI-R "D/L6/CM127/DC7050/ENTRY PSG. AFC"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |      |  -- 6:6-128 HTRI-S "D/L6/6F/MM128/DC6190"
|      |      |      |  -- 6:6-129 HTRI-S "D/L6/6F/MM129/DE6010"
|      |      |      |  -- 6:6-130 HTRI-S "D/L6/6F/MM130/DC6020"
|      |      |      |  -- 6:6-131 HTRI-S "D/L6/6F/MM131/DC6180"
|      |      |      |  -- 6:6-132 HTRI-S "D/L6/6F/MM132/DC6170"
|      |      |      |  -- 6:6-133 HTRI-R "D/L6/CM133/DC6210/AFC ENTRY PSG"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |      |  -- 6:6-134 HMS-S/D/M/SA "D/L6/MCP134/DC6210/ENTRY DR"
|      |      |      |  -- 6:6-135 HTRI-S "D/L6/6F/MM135/DC6160"
|      |      |      |  -- 6:6-136 HTRI-S "D/L6/6F/MM136/DC6050"
|      |      |      |  -- 6:6-140 HTRI-S "D/L6/6F/MM140/DC6130"
|      |      |      |  -- 6:6-142 HTRI-S "D/L6/6F/MM142/DC6080"
|      |      |      |  -- 6:6-143 HTRI-S "D/L6/6F/MM143/DC6120"
|      |      |      |  -- 6:6-144 HMS-S/D/M/SA "D/L6/DC6111A/MCP144/Psg nr Entry"
|      |      |      |  -- 6:6-145 HMS-S/D/M/SA "D/L6/DC6111B/MCP145/Psg nr Entry"
|      |      |      |  -- 6:6-146 HTRI-S "D/L6/6F/MM146/DC6091"
|      |      |      |  -- 6:6-147 HTRI-R "D/L6/DC6111B/CM147/Psg nr Entry"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |      |  -- 6:6-148 HTRI-S "D/L6/6F/MM148/DC6092"
|      |      |      |  -- 6:6-149 HTRI-S "D/L6/7F/MM149/DE7010"
|      |      |      |  -- 6:6-150 HFP-11 "D/L6/SD150/DC7131/32/AccountCabin"
|      |      |      |  -- 6:6-151 HFP-11 "D/L6/SD151/DC7131/32/Asort Cabin"
|      |      |      |  -- 6:6-152 HFP-11 "D/L6/SD152/DC7131/32/Main Cabin "
|      |      |      |  -- 6:6-153 HFP-11 "D/L6/SD153/DC7131/32/Main Cabin"
|      |      |      |  -- 6:6-154 HFP-11 "D/L6/SD154/DC7131/32/WaitingRoom"
|      |      |      |  -- 6:6-155 HFP-11 "D/L6/SD155/DC7131/32/Entry Psg "
|      |      |      |  -- 6:6-156 HFPT-11 "D/L6/HD156/DC7131/32/Pantry"
|      |      |      |  -- 6:6-157 HTRI-R "D/L6/CM157/DC7131/32/EtyDoor Psg"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |      |  -- 6:6-158 HMS-S/D/M/SA "D/L6/MCP158/DC7131/32/EntDoorNrP"
|      |      |      |  -- 6:6-175 HFP-11 "D/L6/DC7080/SD175/Psg nr Entry"
|      |      |      |  -- 6:6-176 HFP-11 "D/L6/DC7080/SD176/Main cab"
|      |      |      |  -- 6:6-177 HFP-11 "D/L6/DC7080/SD177/Accounts cab"
|      |      |      |  -- 6:6-178 HTRI-R "D/L6/DC7080/CM178/Psg nr Entry"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |      |  -- 6:6-179 HMS-S/D/M/SA "D/L6/DC7080/MCP179/Psg nr Entry"
|      |      |      |  -- 6:6-186 HFP-11 "D/L6/DC6111A/SD186/Lunch rm"
|      |      |      |  -- 6:6-187 HFP-11 "D/L6/DC6111A/SD187/Psg nr Acc ca"
|      |      |      |  -- 6:6-188 HFP-11 "D/L6/DC6111A/SD188/Psg nr Assort"
|      |      |      |  -- 6:6-189 HFP-11 "D/L6/DC6111A/SD189/Assorter cab "
|      |      |      |  -- 6:6-190 HFP-11 "D/L6/DC6111A/SD190/Assorter cab "
|      |      |      |  -- 6:6-191 HFP-11 "D/L6/DC6111A/SD191/Buyers cabl"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:6 DLC "DLC @ address 6 L6"

				--	6:6-192	HFP-11	"D/L6/DC6111A/SD192/Rajubhai"
				--	6:6-193	HFP-11	"D/L6/DC6111A/SD193/Pappubhai"
				--	6:6-194	HFP-11	"D/L6/DC6111A/SD194/Buyer cab2"
				--	6:6-195	HFP-11	"D/L6/DC7180/SD195/Pantry"
				--	6:6-196	HFP-11	"D/L6/DC7180/SD196/Reception"
				--	6:6-197	HFP-11	"D/L6/DC7180/SD197/Cab 4"
				--	6:6-198	HFP-11	"D/L6/DC7180/SD198/Cab 1"
				--	6:6-199	HFP-11	"D/L6/DC7180/SD199/Cab 2"
				--	6:6-200	HFP-11	"D/L6/DC7180/SD200/Cab 3"
				--	6:6-201	HFP-11	"D/L6/DC7180/SD201/Psg nr cab 4"
				--	6:6-202	HFP-11	"D/L6/DC7180/SD202/Assorter cab"
				--	6:6-203	HFP-11	"D/L6/DC7180/SD203/Accounts cab"
				--	6:6-204	HTRI-R	"D/L6/DC7180/CM204/Psg nr Entry"
				--	Switch	"	"
				--	Relay		
				--	6:6-205	HMS-S/D/M/SA	"D/L6/DC7180/MCP205/Psg nr Entry"
				--	6:6-206	HFP-11	"D/L6/DC6111A/SD206/Bharat bahi"
				--	6:6-207	HFP-11	"D/L6/DC6111A/SD207/Chetali cab"
				--	6:6-208	HFP-11	"D/L6/DC6111A/SD208/Meeting rm"
				--	6:6-214	HFP-11	"D/L6/DC7190A/SD214/Main Cab"
				--	6:6-215	HFP-11	"D/L6/DC7190A/SD215/Entr Psg"
				--	6:6-216	HTRI-R	"D/L6/DC7190A/CM216/Entry Psg AFC"
				--	Switch	"	"
				--	Relay		
				--	6:6-217	HMS-S/D/M/SA	"D/L6/DC7190A/MCP217/Psg Nr Entry"
				--	6:6-226	HFP-11	"D/L6/DC7200/SD226/Assorter cab"
				--	6:6-227	HFP-11	"D/L6/DC7200/SD227/Assorter cab"
				--	6:6-228	HFPT-11	"D/L6/DC7200/HD228/Pantry"
				--	6:6-229	HTRI-R	"D/L6/DC7200/CM229/Psg nr Entry"
				--	Switch	"	"
				--	Relay		
				--	6:6-230	HMS-S/D/M/SA	"D/L6/DC7200/MCP230/Psg nr Entry"
				--	6:6-240	HFP-11	"D/L6/DC6070/SD240/Assorter cab"
				--	6:6-241	HFP-11	"D/L6/DC6070/SD241/Main cab"
				--	6:6-242	HFP-11	"D/L6/DC6070/SD242/Main cab"
				--	6:6-243	HFP-11	"D/L6/DC6070/SD243/Pantry"
				--	6:6-244	HTRI-R	"D/L6/DC6070/CM244/Psg nr Entry"
				--	Switch	"	"
				--	Relay		
				--	6:6-245	HMS-S/D/M/SA	"D/L6/DC6070/MCP245/Psg nr Entry"
				--	6:6-246	HFP-11	"D/L6/DC6140/SD246/Accounts cab"
				--	6:6-247	HFP-11	"D/L6/DC6140/SD247/Main cab"
				--	6:6-248	HFP-11	"D/L6/DC6140/SD248/cab 1"
				--	6:6-249	HFP-11	"D/L6/DC6140/SD249/Psg nr Main ca"
				--	6:6-250	HFP-11	"D/L6/DC6140/SD250/Psg nr Entry"
				--	6:6-251	HTRI-R	"D/L6/DC6140/CM251/Psg nr Entry"
				--	Switch	"	"
				--	Relay		
				--	6:6-252	HMS-S/D/M/SA	"D/L6/DC6140/MCP252/Psg nr Entry"
				--	6:12	NIC-C(HNet)	"NIC @ address 12"

6 Desigo Fire Safety Modular "BDB TOWER D " Local
CAB-1 "CAB-1 Enclosure #2"
CC-5 "Card Cage 5 Slots"

```
|      |  |-- 6:13 DLC "DLC DE LOOP10"
|      |  |  |-- 6:13-1 HFP-11 "D/L10/DE3200/SD1/Entry dr Psg"
|      |  |  |-- 6:13-2 HFP-11 "D/L10/DE3200/SD2/Pantry"
|      |  |  |-- 6:13-3 HFP-11 "D/L10/DE3200/SD3/Accounts cab"
|      |  |  |-- 6:13-4 HFP-11 "D/L10/DE3200/SD4/Main cab"
|      |  |  |-- 6:13-5 HFP-11 "D/L10/DE3200/SD5/Main cab"
|      |  |  |-- 6:13-6 HFP-11 "D/L10/DE3200/SD6/Assorter cab"
|      |  |  |-- 6:13-7 HTRI-R "D/L10/DE3200/CM7/Entry dr Psg"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 6:13-8 HMS-S/D/M/SA "D/L10/DE3200/MCP8/Entry dr Psg"
|      |  |  |-- 6:13-9 HFP-11 "D/L10/DE5041/SD9/Accounts cab"
|      |  |  |-- 6:13-10 HFP-11 "D/L10/DE5041/SD10/Main cab 1"
|      |  |  |-- 6:13-11 HFP-11 "D/L10/DE5041/SD11/Main cab 2"
|      |  |  |-- 6:13-12 HFP-11 "D/L10/DE5041/SD12/Main cab 3"
|      |  |  |-- 6:13-13 HFP-11 "D/L10/DE5041/SD13/Main cab 3"
|      |  |  |-- 6:13-14 HFP-11 "D/L10/DE5041/SD14/Assorter cab"
|      |  |  |-- 6:13-15 HFP-11 "D/L10/DE5041/SD15/Pantry"
|      |  |  |-- 6:13-16 HFP-11 "D/L10/DE5041/SD16/Entry dr Psg"
|      |  |  |-- 6:13-17 HTRI-R "D/L10/DE5041/CM17/AFC Entry dr P"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 6:13-18 HMS-S/D/M/SA "D/L10/DE5041/MCP18/Entry dr Psg"
|      |  |  |-- 6:13-19 HFP-11 "D/L10/DE5120/SD19/Assorter cab 1"
|      |  |  |-- 6:13-20 HFP-11 "D/L10/DE5120/SD20/Assorter cab 2"
|      |  |  |-- 6:13-21 HFP-11 "D/L10/DE5120/SD21/Main cab"
|      |  |  |-- 6:13-22 HFP-11 "D/L10/DE5120/SD22/Entry Psg"
|      |  |  |-- 6:13-23 HFP-11 "D/L10/DE5120/SD23/Pantry"
|      |  |  |-- 6:13-24 HTRI-R "D/L10/DE5120/CM24/Entry Psg"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 6:13-25 HMS-S/D/M/SA "D/L10/DE5120/MCP25/Entry Psg"
|      |  |  |-- 6:13-26 HFP-11 "D/L10/DE3010/SD26/Accounts cab"
|      |  |  |-- 6:13-27 HFP-11 "D/L10/DE3010/SD27/Buyer cab"
|      |  |  |-- 6:13-28 HFP-11 "D/L10/DE3010/SD28/Main cab"
|      |  |  |-- 6:13-29 HFP-11 "D/L10/DE3010/SD29/Entry dr psg"
|      |  |  |-- 6:13-30 HTRI-R "D/L10/DE3010/CM30/Entry dr psg"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 6:13-31 HMS-S/D/M/SA "D/L10/DE3010/MCP31/Entry dr psg"
|      |  |  |-- 6:13-32 HFP-11 "D/L10/DE5090/SD32/Cab nr Washrm"
|      |  |  |-- 6:13-33 HFP-11 "D/L10/DE5090/SD33/Main cab"
|      |  |  |-- 6:13-34 HFP-11 "D/L10/DE5090/SD34/Buyer cab"
|      |  |  |-- 6:13-35 HFP-11 "D/L10/DE5090/SD35/Psg nr MC"
|      |  |  |-- 6:13-36 HFP-11 "D/L10/DE5090/SD36/Accounts cab"
|      |  |  |-- 6:13-37 HFP-11 "D/L10/DE5090/SD37/Psg nr Acc. Ca"
|      |  |  |-- 6:13-38 HFP-11 "D/L10/DE5090/SD38/Entry dr psg"
|      |  |  |-- 6:13-39 HFP-11 "D/L10/DE5090/SD39/Pantry"
|      |  |  |-- 6:13-40 HTRI-R "D/L10/DE5090/CM40/Entry dr psg"
|      |  |  |  |-- Switch ""
```

```
| | | | | Relay
```

```
| | | | |
```

```
| | | | | |-- 6:13-41 HMS-S/D/M/SA "D/L10/DE5090/MCP41/Entry dr psg"
```

```
| | | | | |-- 6:13-45 HFP-11 "D/L10/DE5150/SD45/Main cab"
```

```
| | | | | |-- 6:13-46 HFP-11 "D/L10/DE5150/SD46/Assorter cab"
```

```
| | | | | |-- 6:13-47 HFP-11 "D/L10/DE5150/SD47/Entry dr psg"
```

```
| | | | | |-- 6:13-48 HTRI-R "D/L10/DE5150/CM48/AFC Entry dr p"
```

```
| | | | | | |-- Switch ""
```

```
| | | | | | |-- Relay
```

```
| | | | | |-- 6:13-49 HMS-S/D/M/SA "D/L10/DE5150/MCP49/Entry dr psg"
```

```
| | | | | |-- 6:13-50 HFP-11 "D/L10/DE3190/SD50/Main cab"
```

```
| | | | | |-- 6:13-51 HFP-11 "D/L10/DE3190/SD51/Assorter cab"
```

```
| | | | | |-- 6:13-52 HFP-11 "D/L10/DE3190/SD52/DM Cab"
```

```
| | | | | |-- 6:13-53 HFP-11 "D/L10/DE3190/SD53/Account cab"
```

```
| | | | | |-- 6:13-54 HFP-11 "D/L10/DE3190/SD54/Reception psg"
```

```
| | | | | |-- 6:13-55 HFP-11 "D/L10/DE3190/SD55/Psg nr MC"
```

```
| | | | | |-- 6:13-56 HFP-11 "D/L10/DE3190/SD56/Pantry"
```

```
| | | | | |-- 6:13-57 HTRI-R "D/L10/DE3190/CM57/AFC Entry Psg"
```

```
| | | | | | |-- Switch ""
```

```
| | | | | | |-- Relay
```

```
| | | | | |-- 6:13-58 HMS-S/D/M/SA "D/L10/DE3190/MCP58/Entry Psg"
```

```
| | | | | |-- 6:13-59 HFP-11 "D/L10/DE3150/SD59/Main cab"
```

```
| | | | | |-- 6:13-60 HFP-11 "D/L10/DE3150/SD60/Accounts cab"
```

```
| | | | | |-- 6:13-61 HFP-11 "D/L10/DE3150/SD61/Entry Psg"
```

```
| | | | | |-- 6:13-62 HFP-11 "D/L10/DE3150/SD62/Pantry"
```

```
| | | | | |-- 6:13-63 HTRI-R "D/L10/DE3150/CM63/AFC Pantry"
```

```
| | | | | | |-- Switch ""
```

```
| | | | | | |-- Relay
```

```
| | | | | |-- 6:13-64 HMS-S/D/M/SA "D/L10/DE3150/MCP64/Entry Psg"
```

```
| | | | | |-- 6:13-65 HFP-11 "D/L10/DE3070/SD65/Main cab"
```

```
| | | | | |-- 6:13-66 HFP-11 "D/L10/DE3070/SD66/Account cab"
```

```
| | | | | |-- 6:13-67 HFP-11 "D/L10/DE3070/SD67/Entry dr Psg"
```

```
| | | | | |-- 6:13-68 HTRI-R "D/L10/DE3070/CM68/AFC Entry Psg"
```

```
| | | | | | |-- Switch ""
```

```
| | | | | | |-- Relay
```

```
| | | | | |-- 6:13-69 HMS-S/D/M/SA "D/L10/DE3070/MCP69/Nr Accounts c"
```

```
| | | | | |-- 6:13-70 HFP-11 "D/L10/DE3220/SD70/Main cab"
```

```
| | | | | |-- 6:13-71 HFP-11 "D/L10/DE3220/SD71/Assorter cab"
```

```
| | | | | |-- 6:13-72 HFP-11 "D/L10/DE3220/SD72/Psg nr Assorte"
```

```
| | | | | |-- 6:13-73 HFPT-11 "D/L10/DE3220/HD73/Pantry"
```

```
| | | | | |-- 6:13-74 HTRI-R "D/L10/DE3220/CM74/Entry dr Psg"
```

```
| | | | | | |-- Switch ""
```

```
| | | | | | |-- Relay
```

```
| | | | | |-- 6:13-75 HMS-S/D/M/SA "D/L10/DE3220/MCP75/Entry dr Psg"
```

```
| | | | | |-- 6:13-76 HFP-11 "D/L10/DE3260/SD76/Account cab"
```

```
| | | | | |-- 6:13-77 HFP-11 "D/L10/DE3260/SD77/Main cab"
```

```
| | | | | |-- 6:13-78 HFP-11 "D/L10/DE3260/SD78/Assorter cab"
```

```
| | | | | |-- 6:13-79 HFP-11 "D/L10/DE3260/SD79/Psg nr MC"
```

```
| | | | | |-- 6:13-80 HFP-11 "D/L10/DE3260/SD80/Pantry"
```

```
| | | | | |-- 6:13-81 HTRI-R "D/L10/DE3260/CM81/Entry dr psg"
```

```
| | | | | | |-- Switch ""
```

```
6 Desigo Fire Safety Modular "BDB TOWER D " Local
  CAB-1 "CAB-1 Enclosure #2"
    CC-5 "Card Cage 5 Slots"
      6:13 DLC "DLC DE LOOP10"
        6:13-81 HTRI-R "D/L10/DE3260/CM81/Entry dr psg"
```

```
| | Relay  
| | |-- 6:13-82 HMS-S/D/M/SA "D/L10/DE3260/MCP82/Entry dr psg"  
| | |-- 6:13-83 HFP-11 "D/L10/DE3090/SD83/Main cab"  
| | |-- 6:13-84 HFP-11 "D/L10/DE3090/SD84/Assorter cab"  
| | |-- 6:13-85 HFP-11 "D/L10/DE3090/SD85/Pantry"  
| | |-- 6:13-86 HTRI-R "D/L10/DE3090/CM86/AFC pantry"  
| | | |-- Switch ""  
| | | |-- Relay  
| | |-- 6:13-87 HMS-S/D/M/SA "D/L10/DE3090/MCP87/Entry dr psg"  
| | |-- 6:13-88 HFP-11 "D/L10/DE3170/SD88/Main cab"  
| | |-- 6:13-89 HFP-11 "D/L10/DE3170/SD89/Assorter cab"  
| | |-- 6:13-90 HFP-11 "D/L10/DE3170/SD90/Psg nr Entry"  
| | |-- 6:13-91 HTRI-R "D/L10/DE3170/CM91/Psg nr Entry"  
| | | |-- Switch ""  
| | | |-- Relay  
| | |-- 6:13-92 HMS-S/D/M/SA "D/L10/DE3170/MCP92/Psg nr Entry"  
| | |-- 6:13-93 HFP-11 "D/L10/DE3110/SD93/Main cab"  
| | |-- 6:13-94 HFP-11 "D/L10/DE3110/SD94/Account cab"  
| | |-- 6:13-95 HFP-11 "D/L10/DE3110/SD95/Psg nr Acc. ca"  
| | |-- 6:13-96 HFPT-11 "D/L10/DE3110/HD96/Pantry"  
| | |-- 6:13-97 HTRI-R "D/L10/DE3110/CM97/AFC Pantry"  
| | | |-- Switch ""  
| | | |-- Relay  
| | |-- 6:13-98 HMS-S/D/M/SA "D/L10/DE3110/MCP98/Psg nr Pantry"  
| | |-- 6:13-99 HFP-11 "D/ L10/SD99/DE3040/MAIN CABIN"  
| | |-- 6:13-100 HFP-11 "D/L10/SD100/DE3040/CABIN 1"  
| | |-- 6:13-101 HFP-11 "D/L10/SD101/DE3040/CABIN 2"  
| | |-- 6:13-102 HFP-11 "D/L10/SD102/DE3040/PSG NR MAIN C"  
| | |-- 6:13-103 HFP-11 "D/L10/SD103/DE3040/PANTRY"  
| | |-- 6:13-104 HTRI-R "D/L10/CM104/DE3040/AFC ENTRY PSG"  
| | | |-- Switch ""  
| | | |-- Relay  
| | |-- 6:13-105 HMS-S/D/M/SA "D/L10/MCP105/DE3040/ ENTRY PSG"  
| | |-- 6:13-173 HFP-11 "D/ L10/SD173/DE3020/MAIN CABIN 1"  
| | |-- 6:13-174 HFP-11 "D/ L10/SD174/DE3020/MAIN CABIN 2"  
| | |-- 6:13-175 HFP-11 "D/ L10/SD175/DE3020/ACCOUNT CABI"  
| | |-- 6:13-176 HFP-11 "D/ L10/SD176/DE3020/PANTRY"  
| | |-- 6:13-177 HTRI-R "D/ L10/CM177/DE3020/AFC ENTRY PS"  
| | | |-- Switch ""  
| | | |-- Relay  
| | |-- 6:13-178 HMS-S/D/M/SA "D/ L10/MCP178/DE3020/ ENTRY PSG"  
| | |-- 6:13-181 HFP-11 "D/ L10/DE5140/SD181/Pantry"  
| | |-- 6:13-182 HFP-11 "D/ L10/DE5140/SD182/Account Cab"  
| | |-- 6:13-183 HFP-11 "D/L10/DE5140/SD183/Assortor Cab"  
| | |-- 6:13-184 HFP-11 "D/L10/DE5140/SD184/Main Cabin"  
| | |-- 6:13-185 HFP-11 "D/L10/DE5140/SD185/Psg Nr Pantry"  
| | |-- 6:13-186 HTRI-R "D/L10/DE5140/CM186/EntryPsgAFC"  
| | | |-- Switch ""  
| | | |-- Relay  
| | |-- 6:13-187 HMS-S/D/M/SA "D/L10/DE5140/MCP187/Entry Psg"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:13 DLC "DLC DE LOOP10"

```
|      |      |      |  -- 6:13-189 HFP-11 "D/ L10/DE5080A/SD189/Cab 103"
|      |      |      |  -- 6:13-190 HFP-11 "D/ L10/DE5080A/SD190/Cab 104"
|      |      |      |  -- 6:13-191 HFP-11 "D/L10/DE5080A/SD191/CabDryPantry"
|      |      |      |  -- 6:13-192 HFP-11 "D/ L10/DE5080A/SD192/Cab 102"
|      |      |      |  -- 6:13-193 HFP-11 "D/ L10/DE5080A/SD193/Cab 101"
|      |      |      |  -- 6:13-194 HFP-11 "D/ L10/DE5080A/SD194/Reception P"
|      |      |      |  -- 6:13-195 HTRI-R "D/L10/DE5080A/CM195/EntryPsgAFC"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:13-196 HMS-S/D/M/SA "D/L10/DE5080A/MCP196/Entry Psg"
|      |      |  -- 6:14 DLC "DLC LOOP11"
|      |      |      |  -- 6:14-12 HFP-11 "D/L11/DC1150A/SD12/Assorter cab"
|      |      |      |  -- 6:14-13 HFP-11 "D/L11/DC1150A/SD13/Account cab"
|      |      |      |  -- 6:14-15 HFP-11 "D/L11/DC1150A/SD15/Main cab"
|      |      |      |  -- 6:14-17 HFP-11 "D/L11/DC1150A/SD17/Main cab"
|      |      |      |  -- 6:14-19 HFP-11 "D/L11/DC2073/SD19/Cab 1"
|      |      |      |  -- 6:14-20 HFP-11 "D/L11/DC2073/SD20/Cab 1"
|      |      |      |  -- 6:14-21 HFP-11 "D/L11/DC2073/SD21/Cab 2"
|      |      |      |  -- 6:14-22 HFP-11 "D/L11/DC2073/SD22/Cab 2"
|      |      |      |  -- 6:14-23 HFP-11 "D/L11/DC2073/SD23/Cab 3"
|      |      |      |  -- 6:14-24 HFP-11 "D/L11/DC2073/SD24/Cab 4"
|      |      |      |  -- 6:14-25 HFP-11 "D/L11/DC2073/SD25/Psg nr Cab 2"
|      |      |      |  -- 6:14-26 HFP-11 "D/L11/DC2073/SD26/Assorter cab"
|      |      |      |  -- 6:14-27 HFP-11 "D/L11/DC2073/SD27/Pantry"
|      |      |      |  -- 6:14-28 HFP-11 "D/L11/DC2073/SD28/Reception"
|      |      |      |  -- 6:14-29 HFP-11 "D/L11/DC2073/SD29/Psg nr Main En"
|      |      |      |  -- 6:14-30 HTRI-R "D/L11/DC2073/CM30/Main Entry"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:14-31 HMS-S/D/M/SA "D/L11/DC2073/MCP31/Main Entry"
|      |      |      |  -- 6:14-32 HFP-11 "D/L11/DC4141/SD32/Main Cab 1"
|      |      |      |  -- 6:14-33 HFP-11 "D/L11/DC4141/SD33/Main Cab 2"
|      |      |      |  -- 6:14-34 HFP-11 "D/L11/DC4141/SD34/Entry Psg"
|      |      |      |  -- 6:14-35 HFP-11 "D/L11/DC4141/SD35/Pantry"
|      |      |      |  -- 6:14-36 HTRI-R "D/L11/DC4141/CM36/AFC New Pantry"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:14-37 HMS-S/D/M/SA "D/L11/DC4141/MCP37/New Pantry"
|      |      |      |  -- 6:14-38 HFP-11 "D/L11/DC4060/SD38/Main Cab 1"
|      |      |      |  -- 6:14-39 HFP-11 "D/L11/DC4060/SD39/Main Cab 2"
|      |      |      |  -- 6:14-40 HFP-11 "D/L11/DC4060/SD40/Entry Psg"
|      |      |      |  -- 6:14-41 HFP-11 "D/L11/DC4060/SD41/Lunch room"
|      |      |      |  -- 6:14-42 HFP-11 "D/L11/DC4060/SD42/Pantry dr side"
|      |      |      |  -- 6:14-43 HTRI-R "D/L11/DC4060/CM43/AFC Entry Psg"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:14-44 HMS-S/D/M/SA "D/L11/DC4060/MCP44/Entry Psg"
|      |      |      |  -- 6:14-45 HFP-11 "D/L11/DC4050/SD45/Main Cab"
|      |      |      |  -- 6:14-46 HFP-11 "D/L11/DC4050/SD46/Assorter cab"
|      |      |      |  -- 6:14-47 HFP-11 "D/L11/DC4050/SD47/Psg nr Assorte"
```


6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:14 DLC "DLC LOOP11"

```
|      |      |      |-- 6:14-48 HFPT-11 "D/L11/DC4050/HD48/Pantry"
|      |      |      |-- 6:14-49 HTRI-R "D/L11/DC4050/CM49/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 6:14-50 HMS-S/D/M/SA "D/L11/DC4050/MCP50/Entry dr Psg"
|      |      |      |-- 6:14-51 HFP-11 "D/L11/DC4071/SD51/Account Cab"
|      |      |      |-- 6:14-52 HFP-11 "D/L11/DC4071/SD52/Main cab"
|      |      |      |-- 6:14-53 HFP-11 "D/L11/DC4071/SD53/Assorter cab"
|      |      |      |-- 6:14-54 HFP-11 "D/L11/DC4071/SD54/Assorter cab"
|      |      |      |-- 6:14-55 HFP-11 "D/L11/DC4071/SD55/Psg nr Pantry"
|      |      |      |-- 6:14-56 HFPT-11 "D/L11/DC4071/HD56/Pantry"
|      |      |      |-- 6:14-57 HTRI-R "D/L11/DC4071/CM57/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 6:14-58 HMS-S/D/M/SA "D/L11/DC4071/MCP58/Entry dr psg"
|      |      |      |-- 6:14-59 HFP-11 "D/L11/DC4072/SD59/Sales cab"
|      |      |      |-- 6:14-60 HFP-11 "D/L11/DC4072/SD60/Accounts cab"
|      |      |      |-- 6:14-61 HFP-11 "D/L11/DC4072/SD61/Main cab"
|      |      |      |-- 6:14-62 HFP-11 "D/L11/DC4072/SD62/Pantry"
|      |      |      |-- 6:14-63 HFP-11 "D/L11/DC4072/SD63/Assorter cab"
|      |      |      |-- 6:14-64 HFP-11 "D/L11/DC4072/SD64/Psg nr MC"
|      |      |      |-- 6:14-65 HFP-11 "D/L11/DC4072/SD65/GAI Cab"
|      |      |      |-- 6:14-66 HFP-11 "D/L11/DC4072/SD66/GAI Cab"
|      |      |      |-- 6:14-67 HFP-11 "D/L11/DC4072/SD67/Entry Psg"
|      |      |      |-- 6:14-68 HFP-11 "D/L11/DC4072/SD68/Entry Psg"
|      |      |      |-- 6:14-69 HTRI-R "D/L11/DC4072/CM69/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 6:14-70 HMS-S/D/M/SA "D/L11/DC4072/MCP70/Entry Psg"
|      |      |      |-- 6:14-71 HFP-11 "D/L11/DC3030/SD71/Main cab"
|      |      |      |-- 6:14-72 HFP-11 "D/L11/DC3030/SD72/Pantry"
|      |      |      |-- 6:14-73 HFP-11 "D/L11/DC3030/SD73/Assorter cab"
|      |      |      |-- 6:14-74 HFP-11 "D/L11/DC3030/SD74/Entry dr Psg"
|      |      |      |-- 6:14-75 HTRI-R "D/L11/DC3030/CM75/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 6:14-76 HMS-S/D/M/SA "D/L11/DC3030/MCP76/Entry dr Psg"
|      |      |      |-- 6:14-77 HFP-11 "D/L11/DC3040/SD77/Main cab"
|      |      |      |-- 6:14-78 HFP-11 "D/L11/DC3040/SD78/Assorter cab"
|      |      |      |-- 6:14-79 HFP-11 "D/L11/DC3040/SD79/Entry dr Psg"
|      |      |      |-- 6:14-80 HTRI-R "D/L11/DC3040/CM80/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 6:14-81 HMS-S/D/M/SA "D/L11/DC3040/MCP81/Entry dr Psg"
|      |      |      |-- 6:14-82 HFP-11 "D/L11/DC2010/SD82/Main cab"
|      |      |      |-- 6:14-83 HFP-11 "D/L11/DC2010/SD83/Main cab"
|      |      |      |-- 6:14-84 HFP-11 "D/L11/DC2010/SD84/Assorter cab"
|      |      |      |-- 6:14-85 HFP-11 "D/L11/DC2010/SD85/Psg nr MC"
|      |      |      |-- 6:14-86 HTRI-R "D/L11/DC2010/CM86/Psg nr MC"
|      |      |      |-- Switch ""
```

```
| | Relay
| | | -- 6:14-87 HMS-S/D/M/SA "D/L11/DC2010/MCP87/Psg nr MC"
| | | -- 6:14-88 HFP-11 "D/L11/DC2170/SD88/Main cab"
| | | -- 6:14-89 HFP-11 "D/L11/DC2170/SD89/Main cab"
| | | -- 6:14-90 HFP-11 "D/L11/DC2170/SD90/Main cab"
| | | -- 6:14-91 HFP-11 "D/L11/DC2170/SD91/Main cab"
| | | -- 6:14-92 HTRI-R "D/L11/DC2170/CM92/Main cab"
| | | | -- Switch ""
| | | | -- Relay
| | | -- 6:14-93 HMS-S/D/M/SA "D/L11/DC2170/MCP93/Main cab"
| | | -- 6:14-94 HFP-11 "D/L11/DC5050/SD94/Assorter cab"
| | | -- 6:14-95 HFP-11 "D/L11/DC5050/SD95/Assorter cab"
| | | -- 6:14-96 HFP-11 "D/L11/DC5050/SD96/Assorter cab"
| | | -- 6:14-97 HFP-11 "D/L11/DC5050/SD97/Entry Psg"
| | | -- 6:14-98 HFP-11 "D/L11/DC5050/SD98/Entry Psg"
| | | -- 6:14-99 HTRI-R "D/L11/DC5050/CM99/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | -- 6:14-100 HMS-S/D/M/SA "D/L11/DC5050/MCP100/Entry Psg"
| | | -- 6:14-101 HFP-11 "D/L11/DC3170/SD101/Pantry"
| | | -- 6:14-102 HFP-11 "D/L11/DC3170/SD102/Assorter cab"
| | | -- 6:14-103 HFP-11 "D/L11/DC3170/SD103/Assorter cab"
| | | -- 6:14-104 HFP-11 "D/L11/DC3170/SD104/Main cab"
| | | -- 6:14-105 HFP-11 "D/L11/DC3170/SD105/Entry Psg"
| | | -- 6:14-106 HTRI-R "D/L11/DC3170/CM106/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | -- 6:14-107 HMS-S/D/M/SA "D/L11/DC3170/MCP107/Entry Psg"
| | | -- 6:14-108 HFP-11 "D/L11/DC1050/SD108/Assorter cab"
| | | -- 6:14-109 HFP-11 "D/L11/DC1050/SD109/Main cab"
| | | -- 6:14-110 HFP-11 "D/L11/DC1050/SD110/Account cab"
| | | -- 6:14-111 HFP-11 "D/L11/DC1050/SD111/Pantry"
| | | -- 6:14-112 HTRI-R "D/L11/DC1050/CM112/Entry dr Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | -- 6:14-113 HMS-S/D/M/SA "D/L11/DC1050/MCP113/Entry dr Psg"
| | | -- 6:14-114 HFP-11 "D/L11/DC1060/SD114/Main cab"
| | | -- 6:14-115 HFP-11 "D/L11/DC1060/SD115/Assorter cab"
| | | -- 6:14-116 HFP-11 "D/L11/DC1060/SD116/Lunch cab"
| | | -- 6:14-117 HTRI-R "D/L11/DC1060/CM117/AFC Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | -- 6:14-118 HMS-S/D/M/SA "D/L11/DC1060/MCP118/Entry Psg"
| | | -- 6:14-119 HFP-11 "D/L11/DC1010/SD119/Assorter cab"
| | | -- 6:14-120 HFP-11 "D/L11/DC1010/SD120/Main cab"
| | | -- 6:14-121 HFP-11 "D/L11/DC1010/SD121/Entry Psg"
| | | -- 6:14-122 HTRI-R "D/L11/DC1010/CM122/Entry Psg"
| | | | -- Switch ""
| | | | -- Relay
| | | -- 6:14-123 HMS-S/D/M/SA "D/L11/DC1010/MCP123/Entry Psg"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:14 DLC "DLC LOOP11"

```
|      |      |      |-- 6:14-124 HFP-11 "D/L11/DC5130/SD124/Main cab"
|      |      |      |-- 6:14-125 HFP-11 "D/L11/DC5130/SD125/Main cab"
|      |      |      |-- 6:14-126 HFP-11 "D/L11/DC5130/SD126/Assorter cab"
|      |      |      |-- 6:14-127 HFP-11 "D/L11/DC5130/SD127/Entry Psg"
|      |      |      |-- 6:14-128 HTRI-R "D/L11/DC5130/CM128/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 6:14-129 HMS-S/D/M/SA "D/L11/DC5130/MCP129/Entry Psg"
|      |      |      |-- 6:14-130 HFP-11 "D/L11/DC3010/SD130/Main cab"
|      |      |      |-- 6:14-131 HFP-11 "D/L11/DC3010/SD131/Accounts cab"
|      |      |      |-- 6:14-132 HFP-11 "D/L11/DC3010/SD132/Entry Psg"
|      |      |      |-- 6:14-133 HFPT-11 "D/L11/DC3010/HD133/Pantry"
|      |      |      |-- 6:14-134 HTRI-R "D/L11/DC3010/CM134/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 6:14-135 HMS-S/D/M/SA "D/L11/DC3010/MCP135/Entry Psg"
|      |      |      |-- 6:14-136 HFP-11 "D/L11/DC2180/SD136/Accounts cab "
|      |      |      |-- 6:14-137 HFP-11 "D/L11/DC2180/SD137/Accounts cab "
|      |      |      |-- 6:14-138 HFP-11 "D/L11/DC2180/SD138/Main cab"
|      |      |      |-- 6:14-139 HFP-11 "D/L11/DC2180/SD139/Assorter cab"
|      |      |      |-- 6:14-140 HFP-11 "D/L11/DC2180/SD140/Entry dr psg"
|      |      |      |-- 6:14-141 HFP-11 "D/L11/DC2180/SD141/Pantry"
|      |      |      |-- 6:14-142 HTRI-R "D/L11/DC2180/CM142/AFC Pantry"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 6:14-143 HMS-S/D/M/SA "D/L11/DC2180/MCP143/Pantry side"
|      |      |      |-- 6:14-144 HFP-11 "D/L11/DC3090A/SD144/Assoror Cab"
|      |      |      |-- 6:14-145 HFP-11 "D/L11/DC3090A/SD145/Cabin 2"
|      |      |      |-- 6:14-146 HFP-11 "D/L11/DC3090A/SD146/Cabin 3"
|      |      |      |-- 6:14-147 HFP-11 "D/L11/DC3090A/SD147/Psg.Nr. Cab2"
|      |      |      |-- 6:14-148 HFP-11 "D/L11/DC3090A/SD148/Pantry "
|      |      |      |-- 6:14-149 HTRI-R "D/L11/DC3090A/CM149/AFC Entry Ps"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 6:14-150 HFP-11 "D/L11/DC2150/SD150/Assorter cab"
|      |      |      |-- 6:14-151 HFP-11 "D/L11/DC2150/SD151/Main cab 1"
|      |      |      |-- 6:14-152 HFP-11 "D/L11/DC2150/SD152/Main cab 2"
|      |      |      |-- 6:14-153 HFP-11 "D/L11/DC2150/SD153/Main cab 3"
|      |      |      |-- 6:14-154 HFP-11 "D/L11/DC2150/SD154/Main cab 4"
|      |      |      |-- 6:14-155 HFP-11 "D/L11/DC2150/SD155/Entry Psg"
|      |      |      |-- 6:14-156 HFP-11 "D/L11/DC2150/SD156/Pantry"
|      |      |      |-- 6:14-157 HTRI-R "D/L11/DC2150/CM157/AFC Pantry"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 6:14-158 HMS-S/D/M/SA "D/L11/DC2150/MCP158/Entry Psg"
|      |      |      |-- 6:14-159 HFP-11 "D/L11/DC2050/SD159/Assorter cab"
|      |      |      |-- 6:14-160 HFP-11 "D/L11/DC2050/SD160/Main cab"
|      |      |      |-- 6:14-161 HFP-11 "D/L11/DC2050/SD161/Main cab"
|      |      |      |-- 6:14-162 HFP-11 "D/L11/DC2050/SD162/Assorter cab"
|      |      |      |-- 6:14-163 HFP-11 "D/L11/DC2050/SD163/Pantry"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:14 DLC "DLC LOOP11"

```
|      |      |      |-- 6:14-164 HTRI-R "D/L11/DC2050/CM164/AFC Pantry"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:14-165 HMS-S/D/M/SA "D/L11/DC2050/MCP165/Entry dr Psg"
|      |      |      |-- 6:14-166 HFP-11 "D/L11/DC2230/SD166/Cab 1"
|      |      |      |-- 6:14-167 HFP-11 "D/L11/DC2230/SD167/Main cab"
|      |      |      |-- 6:14-168 HFP-11 "D/L11/DC2230/SD168/Assorter cab"
|      |      |      |-- 6:14-169 HFP-11 "D/L11/DC2230/SD169/Psg nr cab 1"
|      |      |      |-- 6:14-170 HFPT-11 "D/L11/DC2230/HD170/Pantry psg"
|      |      |      |-- 6:14-171 HTRI-R "D/L11/DC2230/CM171/Entry dr psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:14-172 HMS-S/D/M/SA "D/L11/DC2230/MCP172/Entry dr psg"
|      |      |      |-- 6:14-173 HFP-11 "D/L11/DC4220/SD173/Cabin 6"
|      |      |      |-- 6:14-174 HFP-11 "D/L11/DC4220/SD174/Cabin 5"
|      |      |      |-- 6:14-175 HFP-11 "D/L11/DC4220/SD175/Cabin 4"
|      |      |      |-- 6:14-176 HFP-11 "D/L11/DC4220/SD176/Cabin 3"
|      |      |      |-- 6:14-177 HFP-11 "D/L11/DC4220/SD177/Main Cabin"
|      |      |      |-- 6:14-178 HFP-11 "D/L11/DC4220/SD178/Main Cabin"
|      |      |      |-- 6:14-203 HFP-11 "D/L11/DC1040/SD203/Main psg"
|      |      |      |-- 6:14-204 HTRI-R "D/L11/DC1040/CM204/Entry dr psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:14-205 HMS-S/D/M/SA "D/L11/DC1040/MCP205/Entry dr psg"
|      |      |      |-- 6:14-206 HFP-11 "D/L11/DC6150/SD206/Accounts cab"
|      |      |      |-- 6:14-207 HFP-11 "D/L11/DC6150/SD207/Main cab 1"
|      |      |      |-- 6:14-208 HFP-11 "D/L11/DC6150/SD208/Main cab 2"
|      |      |      |-- 6:14-209 HFP-11 "D/L11/DC6150/SD209/Conference ro"
|      |      |      |-- 6:14-210 HFP-11 "D/L11/DC6150/SD210/Pantry"
|      |      |      |-- 6:14-211 HFP-11 "D/L11/DC6150/SD211/Reception"
|      |      |      |-- 6:14-212 HTRI-R "D/L11/DC6150/CM212/AFC pantry"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:14-213 HMS-S/D/M/SA "D/L11/DC6150/MCP213/Entry dr psg"
|      |      |      |-- 6:14-214 HFP-11 "D/L11/DC2110/SD214/Main cab"
|      |      |      |-- 6:14-215 HFP-11 "D/L11/DC2110/SD215/Entry dr psg"
|      |      |      |-- 6:14-216 HTRI-R "D/L11/DC2110/CM216/Entry dr psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:14-217 HMS-S/D/M/SA "D/L11/DC2110/MCP217/Entry dr psg"
|      |      |      |-- 6:14-218 HFP-11 "D/L11/DC8080/SD218/Main cab"
|      |      |      |-- 6:14-219 HFP-11 "D/L11/DC8080/SD219/Assorter cab"
|      |      |      |-- 6:14-220 HFP-11 "D/L11/DC8080/SD220/Psg nr Main c"
|      |      |      |-- 6:14-221 HFP-11 "D/L11/DC8080/SD221/Accounts cab"
|      |      |      |-- 6:14-222 HTRI-R "D/L11/DC8080/CM222/AFC Entry psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 6:14-223 HMS-S/D/M/SA "D/L11/DC8080/MCP223/Entry psg"
|      |      |      |-- 6:14-224 HFP-11 "D/L11/DC4220/SD224/Pantry"
|      |      |      |-- 6:14-225 HFP-11 "D/L11/DC4220/SD225/Reception Psg"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local
CAB-1 "CAB-1 Enclosure #2"
CC-5 "Card Cage 5 Slots"
6:14 DLC "DLC LOOP11"

```
|      |      |      |  -- 6:14-226 HMS-S/D/M/SA "D/L11/DC4220/MCP226/Entry Psg"
|      |      |      |  -- 6:14-227 HTRI-R "D/L11/DC4220/CM227/Entry Psg"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:14-229 HFP-11 "D/L11/DC1100/SD229/Main cab"
|      |      |      |  -- 6:14-230 HFP-11 "D/L11/DC1100/SD230/Account cab"
|      |      |      |  -- 6:14-231 HTRI-R "D/L11/DC1100/CM231/Entry dr psg"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:14-232 HMS-S/D/M/SA "D/L11/DC1100/MCP232/Entry dr psg"
|      |      |      |  -- 6:14-233 HFP-11 "D/L11/DC1080/SD233/Main cab"
|      |      |      |  -- 6:14-234 HFP-11 "D/L11/DC1080/SD234/Assorter cab"
|      |      |      |  -- 6:14-235 HFP-11 "D/L11/DC1080/SD235/Entry dr Psg"
|      |      |      |  -- 6:14-236 HTRI-R "D/L11/DC1080/CM236/AFC Entry Psg"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:14-237 HMS-S/D/M/SA "D/L11/DC1080/MCP237/Entry dr Psg"
|      |      |      |  -- 6:14-238 HFP-11 "D/L11/DC3180/SD238/Main cab"
|      |      |      |  -- 6:14-239 HFP-11 "D/L11/DC3180/SD239/Assorter cab"
|      |      |      |  -- 6:14-240 HFP-11 "D/L11/DC3180/SD240/Entry dr psg"
|      |      |      |  -- 6:14-241 HFP-11 "D/L11/DC3180/SD241/Pantry"
|      |      |      |  -- 6:14-242 HTRI-R "D/L11/DC3180/CM242/AFC Entry psg"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:14-243 HMS-S/D/M/SA "D/L11/DC3180/MCP243/Entry psg"
|      |      |      |  -- 6:14-244 HMS-S/D/M/SA "D/L11/DC3090A/MCP244/Entry Psg"
|      |      |      |  -- 6:14-245 HFP-11 "D/L11/DC3090A/SD245/Main Cabin"
|      |      |      |  -- 6:14-246 HFP-11 "D/L11/DC3090A/SD246/Main Cabin"
|      |      |      |  -- 6:14-247 HFP-11 "D/L11/DC3090A/SD247/Main Cabin"
|      |      |      |  -- 6:14-249 HFP-11 "D/L11/DC1150A/SD249/Entry Pass"
|      |      |      |  -- 6:14-250 HFP-11 "D/L11/DC1150A/SD250/Pantry"
|      |      |      |  -- 6:14-251 HTRI-R "D/L11/DC1150A/CM251/AFC NR Entry"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 6:14-252 HMS-S/D/M/SA "D/L11/DC1150A/MCP252/Entry DR"
|      |      |  -- 6:15 DLC "DLC LOOP 12"
|      |      |  -- 6:15-1 HFP-11 "D/L12/DW3030/SD1/Main cab 1"
|      |      |  -- 6:15-2 HFP-11 "D/L12/DW3030/SD2/Main cab 2"
|      |      |  -- 6:15-3 HFP-11 "D/L12/DW3030/SD3/Main cab 3"
|      |      |  -- 6:15-4 HFP-11 "D/L12/DW3030/SD4/Account cab"
|      |      |  -- 6:15-5 HFP-11 "D/L12/DW3030/SD5/Psg nr Account "
|      |      |  -- 6:15-6 HFP-11 "D/L12/DW3030/SD6/Pantry"
|      |      |  -- 6:15-7 HTRI-R "D/L12/DW3030/CM7/Entry dr Psg"
|      |      |      |  -- Switch ""
|      |      |      |  -- Relay
|      |      |  -- 6:15-8 HMS-S/D/M/SA "D/L12/DW3030/MCP8/Entry dr Psg"
|      |      |  -- 6:15-9 HFP-11 "D/L12/DW3100/SD9/Main cab 1"
|      |      |  -- 6:15-10 HFP-11 "D/L12/DW3100/SD10/Main cab 2"
|      |      |  -- 6:15-11 HFP-11 "D/L12/DW3100/SD11/Entry dr Psg"
|      |      |  -- 6:15-12 HFP-11 "D/L12/DW3100/SD12/Main cab"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:15 DLC "DLC LOOP 12"

```
|      |      |-- 6:15-13 HTRI-R "D/L12/DW3100/CM13/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-14 HMS-S/D/M/SA "D/L12/DW3100/MCP14/Entry dr Psg"
|      |      |-- 6:15-15 HFP-11 "D/L12/DW3110/SD15/Main cab 3"
|      |      |-- 6:15-16 HFP-11 "D/L12/DW3110/SD16/Main cab 2"
|      |      |-- 6:15-17 HFP-11 "D/L12/DW3110/SD17/Entry dr Psg"
|      |      |-- 6:15-18 HFP-11 "D/L12/DW3110/SD18/Main cab 1"
|      |      |-- 6:15-19 HFP-11 "D/L12/DW3110/SD19/Pantry"
|      |      |-- 6:15-20 HTRI-R "D/L12/DW3110/CM20/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-21 HMS-S/D/M/SA "D/L12/DW3110/MCP21/Entry dr Psg"
|      |      |-- 6:15-22 HFP-11 "D/L12/DW1410/SD22/Main cab 1"
|      |      |-- 6:15-23 HFP-11 "D/L12/DW1410/SD23/Main cab 2"
|      |      |-- 6:15-24 HFP-11 "D/L12/DW1410/SD24/Assorter cab"
|      |      |-- 6:15-25 HFP-11 "D/L12/DW1410/SD25/Entry dr Psg"
|      |      |-- 6:15-26 HTRI-R "D/L12/DW1410/CM26/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-27 HMS-S/D/M/SA "D/L12/DW1410/MCP27/Nr Assorter c"
|      |      |-- 6:15-28 HFP-11 "D/L12/DW1310/SD28/Main cab"
|      |      |-- 6:15-29 HFP-11 "D/L12/DW1310/SD29/Entry Psg"
|      |      |-- 6:15-30 HFP-11 "D/L12/DW1310/SD30/Assorter cab"
|      |      |-- 6:15-31 HFPT-11 "D/L12/DW1310/HD31/Pantry"
|      |      |-- 6:15-32 HTRI-R "D/L12/DW1310/CM32/AFC Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-33 HMS-S/D/M/SA "D/L12/DW1310/MCP33/Entry dr Psg"
|      |      |-- 6:15-34 HFP-11 "D/L12/DW1060/SD34/Main cab"
|      |      |-- 6:15-35 HFP-11 "D/L12/DW1060/SD35/Assorter cab 1"
|      |      |-- 6:15-36 HFP-11 "D/L12/DW1060/SD36/Assorter cab 2"
|      |      |-- 6:15-37 HFP-11 "D/L12/DW1060/SD37/Entry dr Psg"
|      |      |-- 6:15-38 HFP-11 "D/L12/DW1060/SD38/Assorter cab 3"
|      |      |-- 6:15-39 HTRI-R "D/L12/DW1060/CM39/AFC Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-40 HMS-S/D/M/SA "D/L12/DW1060/MCP40/Entry dr Psg"
|      |      |-- 6:15-41 HFP-11 "D/L12/DW1050/SD41/Account cab"
|      |      |-- 6:15-42 HFP-11 "D/L12/DW1050/SD42/Lunch cab"
|      |      |-- 6:15-43 HFP-11 "D/L12/DW1050/SD43/Main cab"
|      |      |-- 6:15-44 HFP-11 "D/L12/DW1050/SD44/Entry Psg"
|      |      |-- 6:15-45 HTRI-R "D/L12/DW1050/CM45/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-46 HMS-S/D/M/SA "D/L12/DW1050/MCP46/Entry Psg"
|      |      |-- 6:15-47 HFP-11 "D/L12/DW1260/SD47/Assorter cab"
|      |      |-- 6:15-48 HFPT-11 "D/L12/DW1260/HD48/Pantry"
|      |      |-- 6:15-49 HTRI-R "D/L12/DW1260/CM49/Entry Psg"
|      |      |  |-- Switch ""
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:15 DLC "DLC LOOP 12"

6:15-49 HTRI-R "D/L12/DW1260/CM49/Entry Psg"

```
|      |      |      |  |-- Relay
|      |      |  |-- 6:15-50 HMS-S/D/M/SA "D/L12/DW1260/MCP50/Entry Psg"
|      |      |  |-- 6:15-51 HFP-11 "D/L12/DW3410A/SD51/Cab 6"
|      |      |  |-- 6:15-52 HFP-11 "D/L12/DW3410A/SD52/Cab 4"
|      |      |  |-- 6:15-53 HFP-11 "D/L12/DW3410A/SD53/Cab 5"
|      |      |  |-- 6:15-54 HFP-11 "D/L12/DW3410A/SD54/Psg nr cab 5"
|      |      |  |-- 6:15-55 HFP-11 "D/L12/DW3410A/SD55/Cab 2"
|      |      |  |-- 6:15-56 HFP-11 "D/L12/DW3410A/SD56/Cab 7"
|      |      |  |-- 6:15-57 HFP-11 "D/L12/DW3410A/SD57/Cab 8"
|      |      |  |-- 6:15-58 HFP-11 "D/L12/DW3410A/SD58/Cab 1"
|      |      |  |-- 6:15-59 HFP-11 "D/L12/DW3410A/SD59/Cab 3"
|      |      |  |-- 6:15-60 HFP-11 "D/L12/DW3410A/SD60/Reception"
|      |      |  |-- 6:15-61 HTRI-R "D/L12/DW3410A/CM61/AFC Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |  |-- 6:15-62 HMS-S/D/M/SA "D/L12/DW3410A/MCP62/Entry Psg"
|      |      |  |-- 6:15-63 HFP-11 "D/L12/DW3140/SD63/Assorter cab"
|      |      |  |-- 6:15-64 HFP-11 "D/L12/DW3140/SD64/Pantry"
|      |      |  |-- 6:15-65 HFP-11 "D/L12/DW3140/SD65/Accounts cab"
|      |      |  |-- 6:15-66 HFP-11 "D/L12/DW3140/SD66/Main cab"
|      |      |  |-- 6:15-67 HTRI-R "D/L12/DW3140/CM67/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |  |-- 6:15-68 HMS-S/D/M/SA "D/L12/DW3140/MCP68/Entry Psg"
|      |      |  |-- 6:15-69 HFP-11 "D/L12/DW3390/SD69/Account cab"
|      |      |  |-- 6:15-70 HFP-11 "D/L12/DW3390/SD70/Assorter cab"
|      |      |  |-- 6:15-71 HTRI-R "D/L12/DW3390/CM71/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |  |-- 6:15-72 HMS-S/D/M/SA "D/L12/DW3390/MCP72/Entry Psg"
|      |      |  |-- 6:15-73 HFP-11 "D/L12/DW3340/SD73/Assorter cab"
|      |      |  |-- 6:15-74 HFPT-11 "D/L12/DW3340/HD74/Entry Psg "
|      |      |  |-- 6:15-75 HFP-11 "D/L12/DW3340/SD75/Main cab"
|      |      |  |-- 6:15-76 HFP-11 "D/L12/DW3340/SD76/AFC Entry Psg"
|      |      |  |-- 6:15-77 HTRI-R "D/L12/DW3340/CM77/AFC Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |  |-- 6:15-78 HMS-S/D/M/SA "D/L12/DW3340/MCP78/Entry Psg"
|      |      |  |-- 6:15-79 HFP-11 "D/L12/DW3200/SD79/Accounts cab"
|      |      |  |-- 6:15-80 HFPT-11 "D/L12/DW3200/HD80/Pantry"
|      |      |  |-- 6:15-81 HFP-11 "D/L12/DW3200/SD81/Main cab"
|      |      |  |-- 6:15-82 HFP-11 "D/L12/DW3200/SD82/Assorter cab"
|      |      |  |-- 6:15-83 HFP-11 "D/L12/DW3200/SD83/Assorter cab"
|      |      |  |-- 6:15-84 HFP-11 "D/L12/DW3200/SD84/Reception"
|      |      |  |-- 6:15-85 HTRI-R "D/L12/DW3200/CM85/AFC Reception"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |  |-- 6:15-86 HMS-S/D/M/SA "D/L12/DW3200/MCP86/Entry Psg"
|      |      |  |-- 6:15-87 HFP-11 "D/L12/DW3160/SD87/Main cab"
|      |      |  |-- 6:15-88 HFP-11 "D/L12/DW3160/SD88/Assorter cab"
```

6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:15 DLC "DLC LOOP 12"

```
|      |      |-- 6:15-89 HFP-11 "D/L12/DW3160/SD89/Assorter cab"
|      |      |-- 6:15-90 HFP-11 "D/L12/DW3160/SD90/Entry Psg"
|      |      |-- 6:15-91 HFP-11 "D/L12/DW3160/SD91/Pantry"
|      |      |-- 6:15-92 HTRI-R "D/L12/DW3160/CM92/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-93 HMS-S/D/M/SA "D/L12/DW3160/MCP93/Entry Psg"
|      |      |-- 6:15-94 HFP-11 "D/L12/DW3090/SD94/Main cab"
|      |      |-- 6:15-95 HFP-11 "D/L12/DW3090/SD95/Account cab"
|      |      |-- 6:15-96 HFP-11 "D/L12/DW3090/SD96/Psg nr Pantry"
|      |      |-- 6:15-97 HFP-11 "D/L12/DW3090/SD97/Main cab1"
|      |      |-- 6:15-98 HFPT-11 "D/L12/DW3090/HD98/Pantry"
|      |      |-- 6:15-99 HFP-11 "D/L12/DW3090/SD99/Main cab2"
|      |      |-- 6:15-100 HFP-11 "D/L12/DW3090/SD100/Sales cab"
|      |      |-- 6:15-101 HFP-11 "D/L12/DW3090/SD101/Export cab"
|      |      |-- 6:15-102 HFP-11 "D/L12/DW3090/SD102/Entry Psg"
|      |      |-- 6:15-103 HTRI-R "D/L12/DW3090/CM103/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-104 HMS-S/D/M/SA "D/L12/DW3090/MCP104/Entry Psg"
|      |      |-- 6:15-105 HFP-11 "D/L12/DW4060/SD105/Main cab"
|      |      |-- 6:15-106 HFP-11 "D/L12/DW4060/SD106/Assorter cab"
|      |      |-- 6:15-107 HFP-11 "D/L12/DW4060/SD107/Pantry psg"
|      |      |-- 6:15-108 HTRI-R "D/L12/DW4060/CM108/Entry psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-109 HMS-S/D/M/SA "D/L12/DW4060/MCP109/Entry psg"
|      |      |-- 6:15-110 HFP-11 "D/L12/DW6050/SD110/Main cab"
|      |      |-- 6:15-111 HFP-11 "D/L12/DW6050/SD111/Accounts cab"
|      |      |-- 6:15-112 HFP-11 "D/L12/DW6050/SD112/Entry Psg"
|      |      |-- 6:15-113 HFPT-11 "D/L12/DW6050/HD113/Pantry"
|      |      |-- 6:15-114 HTRI-R "D/L12/DW6050/CM114/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-115 HMS-S/D/M/SA "D/L12/DW6050/MCP115/Entry Psg"
|      |      |-- 6:15-116 HFP-11 "D/L12/DW5290/SD116/Main cab"
|      |      |-- 6:15-117 HFP-11 "D/L12/DW5290/SD117/Account cab"
|      |      |-- 6:15-118 HFP-11 "D/L12/DW5290/SD118/Pantry"
|      |      |-- 6:15-119 HTRI-R "D/L12/DW5290/CM119/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 6:15-120 HMS-S/D/M/SA "D/L12/DW5290/MCP120/Entry Psg"
|      |      |-- 6:15-121 HFP-11 "D/L12/DW5060/SD121/Main cab"
|      |      |-- 6:15-122 HFP-11 "D/L12/DW5060/SD122/Account cab"
|      |      |-- 6:15-123 HFP-11 "D/L12/DW5060/SD123/Assorter cab"
|      |      |-- 6:15-124 HFP-11 "D/L12/DW5060/SD124/Psg nr acct c"
|      |      |-- 6:15-125 HFP-11 "D/L12/DW5060/SD125/Pantry"
|      |      |-- 6:15-126 HMS-S/D/M/SA "D/L12/DW5060/MCP126/Entry dr Psg"
|      |      |-- 6:15-127 HTRI-R "D/L12/DW5060/CM127/Entry dr Psg"
|      |      |  |-- Switch ""
```


6 Desigo Fire Safety Modular "BDB TOWER D " Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

6:15 DLC "DLC LOOP 12"

6:15-127 HTRI-R "D/L12/DW5060/CM127/Entry dr Psg"

```
|      |      |      |  |-- Relay
|      |      |  |-- 6:15-128 HFP-11 "D/L12/DW4070/SD128/Main cab"
|      |      |  |-- 6:15-129 HFP-11 "D/L12/DW4070/SD129/Assorter cab"
|      |      |  |-- 6:15-130 HFP-11 "D/L12/DW4070/SD130/Psg nr Assort"
|      |      |  |-- 6:15-131 HFP-11 "D/L12/DW4070/SD131/Pantry"
|      |      |  |-- 6:15-132 HMS-S/D/M/SA "D/L12/DW4070/MCP132/Entry dr psg"
|      |      |  |-- 6:15-133 HTRI-R "D/L12/DW4070/CM133/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 6:15-145 HFP-11 "D/L12/DW2320/SD145/Main cab"
|      |      |  |-- 6:15-146 HFP-11 "D/L12/DW2320/SD146/Account cab"
|      |      |  |-- 6:15-147 HFP-11 "D/L12/DW2320/SD147/Pantry psg"
|      |      |  |-- 6:15-148 HFP-11 "D/L12/DW2320/SD148/Assorter cab"
|      |      |  |-- 6:15-149 HTRI-R "D/L12/DW2320/CM149/AFC Assorter "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 6:15-150 HMS-S/D/M/SA "D/L12/DW2320/MCP150/Entry dr Psg"
|      |      |  |-- 6:15-151 HFP-11 "D/L12/DW1070/SD151/Cab 1"
|      |      |  |-- 6:15-152 HFP-11 "D/L12/DW1070/SD152/Reception are"
|      |      |  |-- 6:15-153 HFP-11 "D/L12/DW1070/SD153/Pantry"
|      |      |  |-- 6:15-154 HTRI-R "D/L12/DW1070/CM154/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 6:15-155 HMS-S/D/M/SA "D/L12/DW1070/MCP155/Entry dr psg"
|      |      |  |-- 6:15-156 HFP-11 "D/L12/DW4101/SD156/Main cab"
|      |      |  |-- 6:15-157 HFP-11 "D/L12/DW4101/SD157/Main cab"
|      |      |  |-- 6:15-158 HFP-11 "D/L12/DW4101/SD158/Assorter cab "
|      |      |  |-- 6:15-159 HFP-11 "D/L12/DW4101/SD159/Assorter cab "
|      |      |  |-- 6:15-160 HFP-11 "D/L12/DW4101/SD160/Assorter cab "
|      |      |  |-- 6:15-161 HFP-11 "D/L12/DW4101/SD161/Accounts cab"
|      |      |  |-- 6:15-162 HFP-11 "D/L12/DW4101/SD162/Psg nr Acc ca"
|      |      |  |-- 6:15-163 HFPT-11 "D/L12/DW4101/HD163/Pantry psg"
|      |      |  |-- 6:15-164 HTRI-R "D/L12/DW4101/CM164/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 6:15-165 HMS-S/D/M/SA "D/L12/DW4101/MCP165/Entry dr psg"
|      |      |  |-- 6:15-167 HFP-11 "D/L12/DW4112/SD167/Main cab"
|      |      |  |-- 6:15-168 HFP-11 "D/L12/DW4112/SD168/Assorter cab"
|      |      |  |-- 6:15-169 HFP-11 "D/L12/DW4112/SD169/Assorter cab"
|      |      |  |-- 6:15-170 HFPT-11 "D/L12/DW4112/HD170/Pantry"
|      |      |  |-- 6:15-171 HTRI-R "D/L12/DW4112/CM171/AFC Pantry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |  |-- 6:15-172 HMS-S/D/M/SA "D/L12/DW4112/MCP172/Psg nr pantr"
|      |      |  |-- 6:15-173 HFP-11 "D/L12/DW4260/SD173/Main cab"
|      |      |  |-- 6:15-174 HFP-11 "D/L12/DW4260/SD174/Assorter cab"
|      |      |  |-- 6:15-175 HFPT-11 "D/L12/DW4260/SD175/Psg nr Assort"
|      |      |  |-- 6:15-176 HTRI-R "D/L12/DW4260/CM176/AFC Entry dr"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
```

```
| -- System Flags
|
| -- History Log
|
| -- Behavior
|
| -- Voice
|
| -- Maintenance
|
| -- Field Devices
|
| -- Miscellaneous
|
| -- CAB-2 "CAB-2 Enclosure #1"
|
| | -- CC-5 "Card Cage 5 Slots"
|
| | | -- 7:1 XDLC "DLC @ address 1 L1"
|
| | | | -- 7:1-1 HFP-11 "E/L1/E-DTC/SD-1/Cab 1"
|
| | | | -- 7:1-2 HFP-11 "E/L1/E-DTC/SD-2/Cab 2"
|
| | | | -- 7:1-3 HFP-11 "E/L1/E-DTC/SD-3/Cab 3"
|
| | | | -- 7:1-4 HFP-11 "E/L1/E-DTC/SD-4/Cab 4"
|
| | | | -- 7:1-5 HFP-11 "E/L1/E-DTC/SD-5/Cab 5"
|
| | | | -- 7:1-6 HFP-11 "E/L1/E-DTC/SD-6/Cab 6"
|
| | | | -- 7:1-7 HFP-11 "E/L1/E-DTC/SD-7/Cab 7"
|
| | | | -- 7:1-8 HFP-11 "E/L1/E-DTC/SD-8/Cab 8"
|
| | | | -- 7:1-9 HFP-11 "E/L1/E-DTC/SD-9/Cab 9"
|
| | | | -- 7:1-10 HFP-11 "E/L1/E-DTC/SD-10/Cab 10"
|
| | | | -- 7:1-11 HFP-11 "E/L1/E-DTC/SD-11/Cab 11"
|
| | | | -- 7:1-12 HFP-11 "E/L1/E-DTC/SD-12/Cab 12"
|
| | | | -- 7:1-13 HFP-11 "E/L1/E-DTC/SD-13/Cab 13"
|
| | | | -- 7:1-14 HFP-11 "E/L1/E-DTC/SD-14/Cab 14"
|
| | | | -- 7:1-15 HFP-11 "E/L1/E-DTC/SD-15/Cab 15"
|
| | | | -- 7:1-16 HFP-11 "E/L1/E-DTC/SD-16/Cab 16"
|
| | | | -- 7:1-17 HFP-11 "E/L1/E-DTC/SD-17/Cab 17"
|
| | | | -- 7:1-18 HFP-11 "E/L1/E-DTC/SD-18/Cab 18"
|
| | | | -- 7:1-19 HFP-11 "E/L1/E-DTC/SD-19/Cab 19"
|
| | | | -- 7:1-20 HFP-11 "E/L1/E-DTC/SD-20/Cab 20"
|
| | | | -- 7:1-21 HFP-11 "E/L1/E-DTC/SD-21/Cab 21"
|
| | | | -- 7:1-22 HFP-11 "E/L1/E-DTC/SD-22/Cab 22"
|
| | | | -- 7:1-23 HFP-11 "E/L1/E-DTC/SD-23/Cab 23"
|
| | | | -- 7:1-24 HFP-11 "E/L1/E-DTC/SD-24/Cab 24"
|
| | | | -- 7:1-25 HFP-11 "E/L1/E-DTC/SD-25/Cab 25"
|
| | | | -- 7:1-26 HFP-11 "E/L1/E-DTC/SD-26/Cab 26"
|
| | | | -- 7:1-27 HFP-11 "E/L1/E-DTC/SD-27/Cab 27"
|
| | | | -- 7:1-28 HFP-11 "E/L1/E-DTC/SD-28/Cab 28"
|
| | | | -- 7:1-29 HFP-11 "E/L1/E-DTC/SD-29/Cab 29"
|
| | | | -- 7:1-30 HFP-11 "E/L1/E-DTC/SD-30/Cab 30"
|
| | | | -- 7:1-31 HFP-11 "E/L1/E-DTC/SD-31/Cab 31"
|
| | | | -- 7:1-32 HFP-11 "E/L1/E-DTC/SD-32/Cab 32"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:1 XDLC "DLC @ address 1 L1"

					--	7:1-33	HFP-11	"E/L1/E-DTC/SD-33/Cab 33"
					--	7:1-34	HFP-11	"E/L1/E-DTC/SD-34/Cab 34"
					--	7:1-35	HFP-11	"E/L1/E-DTC/SD-35/Cab 35"
					--	7:1-36	HFP-11	"E/L1/E-DTC/SD-36/Cab 36"
					--	7:1-37	HFP-11	"E/L1/E-DTC/SD-37/Cab 37"
					--	7:1-38	HFP-11	"E/L1/E-DTC/SD-38/Cab 38"
					--	7:1-39	HFP-11	"E/L1/E-DTC/SD-39/Cab 39"
					--	7:1-40	HFP-11	"E/L1/E-DTC/SD-40/Cab 40"
					--	7:1-41	HFP-11	"E/L1/E-DTC/SD-41/Cab 41"
					--	7:1-42	HFP-11	"E/L1/E-DTC/SD-42/Cab 42"
					--	7:1-43	HFP-11	"E/L1/E-DTC/SD-43/Cab 43"
					--	7:1-44	HFP-11	"E/L1/E-DTC/SD-44/Cab 44"
					--	7:1-45	HFP-11	"E/L1/E-DTC/SD-45/Cab 45"
					--	7:1-46	HFP-11	"E/L1/E-DTC/SD-46/Cab 46"
					--	7:1-47	HFP-11	"E/L1/E-DTC/SD-47/Cab 47"
					--	7:1-48	HFP-11	"E/L1/E-DTC/SD-48/Cab 48"
					--	7:1-49	HFP-11	"E/L1/E-DTC/SD-49/Cab 49"
					--	7:1-50	HFP-11	"E/L1/E-DTC/SD-50/Cab 50"
					--	7:1-51	HFP-11	"E/L1/E-DTC/SD-51/Cab 51"
					--	7:1-52	HFP-11	"E/L1/E-DTC/SD-52/Cab 52"
					--	7:1-53	HFP-11	"E/L1/E-DTC/SD-53/Cab 53"
					--	7:1-54	HFP-11	"E/L1/E-DTC/SD-54/Cab 54"
					--	7:1-55	HFP-11	"E/L1/E-DTC/SD-55/Cab 55"
					--	7:1-56	HFP-11	"E/L1/E-DTC/SD-56/Cab 56"
					--	7:1-57	HFP-11	"E/L1/E-DTC/SD-57/Cab 57"
					--	7:1-58	HFP-11	"E/L1/E-DTC/SD-58/Cab 58"
					--	7:1-59	HFP-11	"E/L1/E-DTC/SD-59/Cab 59"
					--	7:1-60	HFP-11	"E/L1/E-DTC/SD-60/Cab 60"
					--	7:1-61	HFP-11	"E/L1/E-DTC/SD-61/Cab 61"
					--	7:1-62	HFP-11	"E/L1/E-DTC/SD-62/Cab 62"
					--	7:1-63	HFP-11	"E/L1/E-DTC/SD-63/Cab 63"
					--	7:1-64	HFP-11	"E/L1/E-DTC/SD-64/Cab 64"
					--	7:1-65	HFP-11	"E/L1/E-DTC/SD-65/Cab 65"
					--	7:1-66	HFP-11	"E/L1/E-DTC/SD-66/Cab 66"
					--	7:1-67	HFP-11	"E/L1/E-DTC/SD-67/Cab 67"
					--	7:1-68	HFP-11	"E/L1/E-DTC/SD-68/Cab 68"
					--	7:1-69	HFP-11	"E/L1/E-DTC/SD-69/Cab 69"
					--	7:1-70	HFP-11	"E/L1/E-DTC/SD-70/Cab 70"
					--	7:1-71	HFP-11	"E/L1/E-DTC/SD-71/Cab 71"
					--	7:1-72	HFP-11	"E/L1/E-DTC/SD-72/Cab 72"
					--	7:1-73	HFP-11	"E/L1/E-DTC/SD-73/Cab 73"
					--	7:1-74	HFP-11	"E/L1/E-DTC/SD-74/Cab 74"
					--	7:1-75	HFP-11	"E/L1/E-DTC/SD-75/Cab 75"
					--	7:1-76	HFP-11	"E/L1/E-DTC/SD-76/Cab 76"
					--	7:1-77	HFP-11	"E/L1/E-DTC/SD-77/Cab 77"
					--	7:1-78	HFP-11	"E/L1/E-DTC/SD-78/Cab 78"
					--	7:1-79	HFP-11	"E/L1/E-DTC/SD-79/Cab 79"
					--	7:1-80	HFP-11	"E/L1/E-DTC/SD-80/Cab 80"
					--	7:1-81	HFP-11	"E/L1/E-DTC/SD-81/Cab 81"
					--	7:1-82	HFP-11	"E/L1/E-DTC/SD-82/Cab 82"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:1 XDLC "DLC @ address 1 L1"

					-- 7:1-83 HFP-11 "E/L1/E-DTC/SD-83/Reception Area"
					-- 7:1-84 FDOT421 "E/L1/E-DTC/SD-84/Psg Nr Cab 54"
					-- 7:1-85 FDOT421 "E/L1/E-DTC/SD-85/Psg Nr Cab 58 "
					-- 7:1-86 FDOT421 "E/L1/E-DTC/SD-86/Psg Nr Cab 79"
					-- 7:1-87 FDOT421 "E/L1/E-DTC/SD-87/Psg Nr Cab 81"
					-- 7:1-88 FDOT421 "E/L1/E-DTC/SD-88/Psg Nr Cab 68"
					-- 7:1-89 FDOT421 "E/L1/E-DTC/SD-89/Psg Nr Cab 62"
					-- 7:1-90 FDOT421 "E/L1/E-DTC/SD-90/Psg Nr Cab 44"
					-- 7:1-91 FDOT421 "E/L1/E-DTC/SD-91/Psg Nr Cab 42"
					-- 7:1-92 FDOT421 "E/L1/E-DTC/SD-92/Psg Nr Cab 40"
					-- 7:1-93 FDOT421 "E/L1/E-DTC/SD-93/Psg Nr Cab 36"
					-- 7:1-94 FDOT421 "E/L1/E-DTC/SD-94/Psg Nr Cab 22"
					-- 7:1-95 FDOT421 "E/L1/E-DTC/SD-95/Psg Nr Cab 11"
					-- 7:1-96 FDOT421 "E/L1/E-DTC/SD-96/Psg Nr Cab 05"
					-- 7:1-97 FDOT421 "E/L1/E-DTC/SD-97/Psg Nr Cab 16"
					-- 7:1-98 FDOT421 "E/L1/E-DTC/SD-98/Psg Nr Cab 14"
					-- 7:1-99 FDOT421 "E/L1/E-DTC/SD-99/Psg Nr Cab 28"
					-- 7:1-100 FDOT421 "E/L1/E-DTC/SD-100/Psg Nr Cab 26"
					-- 7:1-101 FDOT421 "E/L1/E-DTC/SD-101/Psg Nr Cab 25"
					-- 7:1-103 HTRI-S "E/L1/CC/UB/MM103/ELEC ROOM"
					-- 7:1-104 HMS-S/D/M/SA "E/L1/EC/UB/MCP104/ELEC ROOM"
					-- 7:1-105 HTRI-R "E/L1/EC/UB/CM105/ELEC ROOM"
					-- Switch ""
					-- Relay
					-- 7:1-106 HTRI-S "E/L1/EC/GND/MM106/Lift Lobby "
					-- 7:1-107 FDOT421 "E/L1/EE/GND/SD-107/LL Security C"
					-- 7:1-108 HMS-S/D/M/SA "E/L1/WC/UB/MCP108/ST COLUMN E555"
					-- 7:1-109 HTRI-R "E/L1/WC/UB/CM109/ST COLUMN E555"
					-- Switch ""
					-- Relay
					-- 7:1-110 HMS-S/D/M/SA "E/L1/EE/GND/MCP-110/Lift Lobby"
					-- 7:1-111 HTRI-R "E/L1/WC/UB/CM111/NR RAMP NO. 4"
					-- Switch ""
					-- Relay
					-- 7:1-112 HTRI-R "E/L1/WC/UB/CM112/ NR RAMP 4 STP"
					-- Switch ""
					-- Relay
					-- 7:1-113 HMS-S/D/M/SA "E/L1/WC/UB/MCP113/NR RAMP 4 STP"
					-- 7:1-114 HTRI-R "E/L1/CC/UB/CM114/ST COLUMN E581"
					-- Switch ""
					-- Relay
					-- 7:1-115 FDOT421 "E/L1/EE/GND/SD115/Lift Lobby En"
					-- 7:1-116 HTRI-R "E/L1/EC/UB/CM116/ST COLUMN E523"
					-- Switch ""
					-- Relay
					-- 7:1-117 HMS-S/D/M/SA "E/L1/EC/UB/MCP117/ST COLUMN E523"
					-- 7:1-118 HTRI-S "E/L1/EC/UB/MM118/ELEC ROOM"
					-- 7:1-119 HTRI-S "E/L1/EC/UB/MM119/LIFT MC RM"
					-- 7:1-120 HFP-11 "E/L1/CC/UB/SD120/ELEC ROOM"
					-- 7:1-121 HFP-11 "E/L1/WC/UB/SD121/ELEC ROOM"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:1 XDLC "DLC @ address 1 L1"

					-- 7:1-122 HFP-11 "E/L1/WC/UB/SD122/NR ELEC ROOM"
					-- 7:1-123 HTRI-R "E/L1/EE/GND/CM-123/Lift Lobby AF"
					-- Switch ""
					-- Relay
					-- 7:1-124 HFP-11 "E/L1/EE/GND/SD-124/Electric Room"
					-- 7:1-125 HFP-11 "E/L1/EC/UB/SD125/DRIVER ROOM"
					-- 7:1-126 HTRI-S "E/L1/EE/GND/MM-126/Lift Lobby AF"
					-- 7:1-127 HFP-11 "E/L1/CC/UB/SD127/BMS ROOM"
					-- 7:1-128 HTRI-R "E/L1/EE/GND/CM-128/LL AHU Room"
					-- Switch ""
					-- Relay
					-- 7:1-129 HFP-11 "E/L1/EC/UB/SD129/LIFT ROOM"
					-- 7:1-130 HFP-11 "E/L1EC/UB/SD130/ELEC ROOM"
					-- 7:1-131 HMS-S/D/M/SA "E/L1/E-DTC/MCP-131/Psg Nr Cab 59"
					-- 7:1-132 HMS-S/D/M/SA "E/L1/E-DTC/MCP-132/Psg Nr Cab 27"
					-- 7:1-133 HMS-S/D/M/SA "E/L1/E-DTC/MCP-133/Psg Nr Cab 03"
					-- 7:1-134 HMS-S/D/M/SA "E/L1/E-DTC/MCP-134/Psg Nr Cab 22"
					-- 7:1-135 HMS-S/D/M/SA "E/L1/E-DTC/MCP-135/Psg Nr Cab 77"
					-- 7:1-136 HMS-S/D/M/SA "E/L1/E-DTC/MCP-136/Reception"
					-- 7:1-137 HMS-S/D/M/SA "E/L1/E-DTC/MCP-137/Psg Nr Cab 70"
					-- 7:1-138 HMS-S/D/M/SA "E/L1/E-DTC/MCP-138/Psg Nr Cab 49"
					-- 7:1-139 HMS-S/D/M/SA "E/L1/E-DTC/MCP-139/Psg Nr Cab 31"
					-- 7:1-140 HMS-S/D/M/SA "E/L1/E-DTC/MCP-140/Psg Nr Cab 67"
					-- 7:1-141 HMS-S/D/M/SA "E/L1/E-DTC/MCP-141/Psg Nr Cab 06"
					-- 7:1-142 HTRI-R "E/L1/C/GND/CM-142/Electric Room"
					-- Switch ""
					-- Relay
					-- 7:1-143 HFP-11 "E/L1/E-DTC/SD-143/Psg Nr Cab 47"
					-- 7:1-144 HFP-11 "E/L1/E-DTC/SD-144/Psg Nr Cab 61"
					-- 7:1-145 HFP-11 "E/L1/E-DTC/SD-145/Electric Room"
					-- 7:1-146 HFP-11 "E/L1/E-DTC/SD-146/Server Room"
					-- 7:1-147 HFP-11 "E/L1/E-DTC/SD-147/Psg AFC Cab 1"
					-- 7:1-148 HFP-11 "E/L1/E-DTC/SD-148/Psg AFC Cab 2"
					-- 7:1-149 HFP-11 "E/L1/E-DTC/SD-149/Psg AFC Cab 3"
					-- 7:1-150 HFP-11 "E/L1/E-DTC/SD-150/Psg AFC Cab 4"
					-- 7:1-151 HFP-11 "E/L1/E-DTC/SD-151/Psg AFC Cab 5"
					-- 7:1-152 HFP-11 "E/L1/E-DTC/SD-152/Psg AFC Cab 6"
					-- 7:1-153 HFP-11 "E/L1/E-DTC/SD-153/Psg AFC Cab 7"
					-- 7:1-154 HFP-11 "E/L1/E-DTC/SD-154/Psg AFC Cab 8"
					-- 7:1-155 HFP-11 "E/L1/E-DTC/SD-155/Psg AFC Cab 9"
					-- 7:1-156 HFP-11 "E/L1/E-DTC/SD-156/Psg AFC Cab 10"
					-- 7:1-157 HFP-11 "E/L1/E-DTC/SD-157/Psg AFC Cab 11"
					-- 7:1-158 HFP-11 "E/L1/E-DTC/SD-158/Psg AFC Cab 12"
					-- 7:1-159 HFP-11 "E/L1/E-DTC/SD-159/Psg AFC Cab 13"
					-- 7:1-160 HFP-11 "E/L1/E-DTC/SD-160/Psg AFC Cab 14"
					-- 7:1-161 HFP-11 "E/L1/E-DTC/SD-161/Psg AFC Cab 15"
					-- 7:1-162 HFP-11 "E/L1/E-DTC/SD-162/Psg AFC Cab 16"
					-- 7:1-163 HFP-11 "E/L1/E-DTC/SD-163/Psg AFC Cab 17"
					-- 7:1-164 HFP-11 "E/L1/E-DTC/SD-164/Psg AFC Cab 18"
					-- 7:1-165 HFP-11 "E/L1/E-DTC/SD-165/Psg AFC Cab 19"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:1 XDLC "DLC @ address 1 L1"

					--	7:1-166	HFP-11	"E/L1/E-DTC/SD-166/Psg	AFC	Cab	20"
					--	7:1-167	HFP-11	"E/L1/E-DTC/SD-167/Psg	AFC	Cab	21"
					--	7:1-168	HFP-11	"E/L1/E-DTC/SD-168/Psg	AFC	Cab	22"
					--	7:1-169	HFP-11	"E/L1/E-DTC/SD-169/Psg	AFC	Cab	23"
					--	7:1-170	HFP-11	"E/L1/E-DTC/SD-170/Psg	AFC	Cab	24"
					--	7:1-171	HFP-11	"E/L1/E-DTC/SD-171/Psg	AFC	Cab	25"
					--	7:1-172	HFP-11	"E/L1/E-DTC/SD-172/Psg	AFC	Cab	26"
					--	7:1-173	HFP-11	"E/L1/E-DTC/SD-173/Psg	AFC	Cab	27"
					--	7:1-174	HFP-11	"E/L1/E-DTC/SD-174/Psg	AFC	Cab	28"
					--	7:1-175	HFP-11	"E/L1/E-DTC/SD-175/Psg	AFC	Cab	29"
					--	7:1-176	HFP-11	"E/L1/E-DTC/SD-176/Psg	AFC	Cab	30"
					--	7:1-177	HFP-11	"E/L1/E-DTC/SD-177/Psg	AFC	Cab	31"
					--	7:1-178	HFP-11	"E/L1/E-DTC/SD-178/Psg	AFC	Cab	32"
					--	7:1-179	HFP-11	"E/L1/E-DTC/SD-179/Psg	AFC	Cab	33"
					--	7:1-180	HFP-11	"E/L1/E-DTC/SD-180/Psg	AFC	Cab	34"
					--	7:1-181	HFP-11	"E/L1/E-DTC/SD-181/Psg	AFC	Cab	35"
					--	7:1-182	HFP-11	"E/L1/E-DTC/SD-182/Psg	AFC	Cab	36"
					--	7:1-183	HFP-11	"E/L1/E-DTC/SD-183/Psg	AFC	Cab	37"
					--	7:1-184	HFP-11	"E/L1/E-DTC/SD-184/Psg	AFC	Cab	38"
					--	7:1-185	HFP-11	"E/L1/E-DTC/SD-185/Psg	AFC	Cab	39"
					--	7:1-186	HFP-11	"E/L1/E-DTC/SD-186/Psg	AFC	Cab	40"
					--	7:1-187	HFP-11	"E/L1/E-DTC/SD-187/Psg	AFC	Cab	41"
					--	7:1-188	HFP-11	"E/L1/E-DTC/SD-188/Psg	AFC	Cab	42"
					--	7:1-189	HFP-11	"E/L1/E-DTC/SD-189/Psg	AFC	Cab	43"
					--	7:1-190	HFP-11	"E/L1/E-DTC/SD-190/Psg	AFC	Cab	44"
					--	7:1-191	HFP-11	"E/L1/E-DTC/SD-191/Psg	AFC	Cab	45"
					--	7:1-192	HFP-11	"E/L1/E-DTC/SD-192/Psg	AFC	Cab	46"
					--	7:1-193	HFP-11	"E/L1/E-DTC/SD-193/Psg	AFC	Cab	47"
					--	7:1-194	HFP-11	"E/L1/E-DTC/SD-194/Psg	AFC	Cab	48"
					--	7:1-195	HFP-11	"E/L1/E-DTC/SD-195/Psg	AFC	Cab	49"
					--	7:1-196	HFP-11	"E/L1/E-DTC/SD-196/Psg	AFC	Cab	50"
					--	7:1-197	HFP-11	"E/L1/E-DTC/SD-197/Psg	AFC	Cab	51"
					--	7:1-198	HFP-11	"E/L1/E-DTC/SD-198/Psg	AFC	Cab	52"
					--	7:1-199	HFP-11	"E/L1/E-DTC/SD-199/Psg	AFC	Cab	53"
					--	7:1-200	HFP-11	"E/L1/E-DTC/SD-200/Psg	AFC	Cab	54"
					--	7:1-201	HFP-11	"E/L1/E-DTC/SD-201/Psg	AFC	Cab	55"
					--	7:1-202	HFP-11	"E/L1/E-DTC/SD-202/Psg	AFC	Cab	56"
					--	7:1-203	HFP-11	"E/L1/E-DTC/SD-203/Psg	AFC	Cab	57"
					--	7:1-204	HFP-11	"E/L1/E-DTC/SD-204/Psg	AFC	Cab	58"
					--	7:1-205	HFP-11	"E/L1/E-DTC/SD-205/Psg	AFC	Cab	59"
					--	7:1-206	HFP-11	"E/L1/E-DTC/SD-206/Psg	AFC	Cab	60"
					--	7:1-207	HFP-11	"E/L1/E-DTC/SD-207/Psg	AFC	Cab	61"
					--	7:1-208	HFP-11	"E/L1/E-DTC/SD-208/Psg	AFC	Cab	62"
					--	7:1-209	HFP-11	"E/L1/E-DTC/SD-209/Psg	AFC	Cab	63"
					--	7:1-210	HFP-11	"E/L1/E-DTC/SD-210/Psg	AFC	Cab	64"
					--	7:1-211	HFP-11	"E/L1/E-DTC/SD-211/Psg	AFC	Cab	65"
					--	7:1-212	HFP-11	"E/L1/E-DTC/SD-212/Psg	AFC	Cab	66"
					--	7:1-213	HFP-11	"E/L1/E-DTC/SD-213/Psg	AFC	Cab	67"
					--	7:1-214	HFP-11	"E/L1/E-DTC/SD-214/Psg	AFC	Cab	68"
					--	7:1-215	HFP-11	"E/L1/E-DTC/SD-215/Psg	AFC	Cab	69"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:1 XDLC "DLC @ address 1 L1"

					-- 7:1-216 HFP-11 "E/L1/E-DTC/SD-216/Psg AFC Cab 70"
					-- 7:1-217 HFP-11 "E/L1/E-DTC/SD-217/Psg AFC Cab 71"
					-- 7:1-218 HFP-11 "E/L1/E-DTC/SD-218/Psg AFC Cab 72"
					-- 7:1-219 HFP-11 "E/L1/E-DTC/SD-219/Psg AFC Cab 73"
					-- 7:1-220 HFP-11 "E/L1/E-DTC/SD-220/Psg AFC Cab 74"
					-- 7:1-221 HFP-11 "E/L1/E-DTC/SD-221/Psg AFC Cab 75"
					-- 7:1-222 HFP-11 "E/L1/E-DTC/SD-222/Psg AFC Cab 76"
					-- 7:1-223 HFP-11 "E/L1/E-DTC/SD-223/Psg AFC Cab 77"
					-- 7:1-224 HFP-11 "E/L1/E-DTC/SD-224/Psg AFC Cab 78"
					-- 7:1-225 HFP-11 "E/L1/E-DTC/SD-225/Psg AFC Cab 79"
					-- 7:1-226 HFP-11 "E/L1/E-DTC/SD-226/Psg AFC Cab 80"
					-- 7:1-227 HFP-11 "E/L1/E-DTC/SD-227/Psg AFC Cab 81"
					-- 7:1-228 HFP-11 "E/L1/E-DTC/SD-228/Psg AFC Cab 82"
					-- 7:1-229 HFP-11 "E/L1/E-DTC/SD-229/Reception Area"
					-- 7:1-230 FDOT421 "E/L1/EE/GND/SD-230/LL AHU Room"
					-- 7:1-231 HFP-11 "E/L1/E-DTC/SD-231/Psg AFC 58 Cab"
					-- 7:1-232 HFP-11 "E/L1/E-DTC/SD-232/Psg AFC 79 Cab"
					-- 7:1-233 HFP-11 "E/L1/E-DTC/SD-233/Psg AFC 81 Cab"
					-- 7:1-236 HFP-11 "E/L1/E-DTC/SD-236/Psg AFC 44 Cab"
					-- 7:1-237 HFP-11 "E/L1/E-DTC/SD-237/Psg AFC 42 Cab"
					-- 7:1-238 HFP-11 "E/L1/E-DTC/SD-238/Psg AFC 40 Cab"
					-- 7:1-239 HFP-11 "E/L1/E-DTC/SD-239/Psg AFC 36 Cab"
					-- 7:1-240 HFP-11 "E/L1/E-DTC/SD-240/Psg AFC 22 Cab"
					-- 7:1-241 HFP-11 "E/L1/E-DTC/SD-241/Psg AFC 11 Cab"
					-- 7:1-242 HFP-11 "E/L1/E-DTC/SD-242/Psg AFC 05 Cab"
					-- 7:1-243 HFP-11 "E/L1/E-DTC/SD-243/Psg AFC 16 Cab"
					-- 7:1-244 HFP-11 "E/L1/E-DTC/SD-244/Psg AFC 14 Cab"
					-- 7:1-245 HFP-11 "E/L1/E-DTC/SD-245/Psg AFC 28 Cab"
					-- 7:1-246 HFP-11 "E/L1/E-DTC/SD-246/Psg AFC 26 Cab"
					-- 7:1-247 HFP-11 "E/L1/E-DTC/SD-247/Psg AFC 25 Cab"
					-- 7:1-248 HMS-S/D/M/SA "E/L1/EC/GND/MCP-248/Lift Lobby"
					-- 7:1-249 HTRI-R "E/L1/EC/GND/CM-249/Lift Lobby AF"
					-- Switch ""
					-- Relay
					-- 7:1-250 HTRI-S "E/L1/EC/GND/MM-250/Lift Lobby AF"
					-- 7:1-251 FDOT421 "E/L1/EC/GND/SD-251/Electric Room"
					-- 7:1-252 FDOT421 "E/L1/EC/GND/SD-252/Lift Lobby"
					-- 7:2 XDLC "DLC @ address 2 L2"
					-- 7:2-1 HTRI-R "E/L2/C/3F/CM1/DR REL NR EC3050"
					-- Switch ""
					-- Relay
					-- 7:2-2 HFP-11 "E/L2/C/3F/SD2/CORR NR EC3050"
					-- 7:2-3 HFP-11 "E/L2/E/3F/SD3/CORR NR EC3050"
					-- 7:2-4 HFP-11 "E/L2/C/3F/SD4/CORR NR EW3/S19"
					-- 7:2-5 HFP-11 "E/L2/C/3F/SD5/CORR NR EW3/219"
					-- 7:2-6 HFP-11 "E/L2/C/3F/SD6/CORR NR S07"
					-- 7:2-7 HFP-11 "E/L2/C/3F/SD7/CORR NR EC3"
					-- 7:2-8 HMS-S/D/M/SA "E/L2/C/3F/MCP8/FIRE ESC STR"
					-- 7:2-9 HTRI-R "E/L2/C/3F/CM9/FIRE ESC STR"
					-- Switch ""

```
7 Desigo Fire Safety Modular "BDB TOWER E" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      7:2 XDLC "DLC @ address 2 L2"
        7:2-9 HTRI-R "E/L2/C/3F/CM9/FIRE ESC STR"
```

```
| | | | | |-- Relay
| | | | |-- 7:2-10 HFP-11 "E/L2/C/3F/SD10/CORR NR S20"
| | | | |-- 7:2-11 HFP-11 "E/L2/C/3F/SD11/CORR NR EC3090"
| | | | |-- 7:2-12 HFP-11 "E/L2/C/3F/SD12/CORR NR EC3090"
| | | | |-- 7:2-13 HFP-11 "E/L2/C/3F/SD13/CORR NR E.R."
| | | | |-- 7:2-14 HFP-11 "E/L2/C/3F/SD14/CORR NR E.R."
| | | | |-- 7:2-15 HTRI-R "E/L2/C/3F/CM15/DR REL NR LL"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-16 HFP-11 "E/L2/C/3F/SD16/LIFT LOBBY "
| | | | |-- 7:2-17 HFP-11 "E/L2/C/3F/SD17/LIFT LOBBY "
| | | | |-- 7:2-18 HMS-S/D/M/SA "E/L2/C/3F/MCP18/FIRE SHAFT L.L."
| | | | |-- 7:2-19 HTRI-R "E/L2/C/3F/CM19/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-20 HTRI-S "E/L2/C/3F/MM20/FIRE SHAFT L.L."
| | | | |-- 7:2-21 HFP-11 "E/L2/C/3F/SD21/ELECT RM "
| | | | |-- 7:2-22 HFP-11 "E/L2/C/3F/SD22/AHU RM "
| | | | |-- 7:2-23 HTRI-R "E/L2/C/3F/CM23/AHU RM "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-24 HFP-11 "E/L2/C/3F/SD24/CORR NR EC3070"
| | | | |-- 7:2-25 HFP-11 "E/L2/C/3F/SD25/CORR NR EC3070"
| | | | |-- 7:2-26 HFP-11 "E/L2/C/3F/SD26/CORR NR EC3/S22"
| | | | |-- 7:2-27 HFP-11 "E/L2/C/3F/SD27/CORR NR EC3/S22"
| | | | |-- 7:2-28 HFP-11 "E/L2/3F/SD28/CORR NR EE3030"
| | | | |-- 7:2-29 HFP-11 "E/L2/3F/SD29/CORR NR EE3100"
| | | | |-- 7:2-30 HFP-11 "E/L2/3F/SD30/CORR NR EE3100"
| | | | |-- 7:2-31 HFP-11 "E/L2/3F/SD31/CORR NR EE3120"
| | | | |-- 7:2-32 HFP-11 "E/L2/3F/SD32/CORR NR EE3/S24"
| | | | |-- 7:2-33 HFP-11 "E/L2/3F/SD33/CORR NR EE3/S24"
| | | | |-- 7:2-34 HTRI-R "E/L2/3F/CM34DR RELESE CM NR L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-35 HFP-11 "E/L2/3F/SD35/ELECT RM "
| | | | |-- 7:2-36 HFP-11 "E/L2/3F/SD36/AHU RM "
| | | | |-- 7:2-37 HTRI-R "E/L2/3F/CM37/AHU RM "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-38 HFP-11 "E/L2/3F/SD38/LIFT LOBBY "
| | | | |-- 7:2-39 HMS-S/D/M/SA "E/L2/3F/MCP39/FIRE SHAFT L.L."
| | | | |-- 7:2-40 XTRI-R "E/L2/3F/CM40/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-41 HTRI-S "E/L2/3F/MM41/FIRE SHAFT L.L."
| | | | |-- 7:2-42 HMS-S/D/M/SA "E/L2/2F/MCP42/FIRE ESC STR"
| | | | |-- 7:2-43 HTRI-R "E/L2/2F/CM43/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-44 HFP-11 "E/L2/C/2F/SD44/CORR NR ECS07"
```


7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:2 XDLC "DLC @ address 2 L2"

					-- 7:2-45 HFP-11 "E/L2/C/2F/SD45/CORR NR ECS07"
					-- 7:2-46 HFP-11 "E/L2/C/2F/SD46/CORR NR EC2020"
					-- 7:2-47 HFP-11 "E/L2/C/2F/SD47/CORR NR EC2020"
					-- 7:2-48 HFP-11 "E/L2/C/2F/SD48/CORR NR EC2082"
					-- 7:2-49 HFP-11 "E/L2/C/2F/SD49/CORR NR E.R."
					-- 7:2-50 HFP-11 "E/L2/C/2F/SD50/CORR NR E.R."
					-- 7:2-51 HTRI-R "E/L2/C/2F/CM51/DR RELESE CM NR L"
					-- Switch ""
					-- Relay
					-- 7:2-52 HFP-11 "E/L2/C/2F/SD52/LIFT LOBBY "
					-- 7:2-53 HFP-11 "E/L2/C/2F/SD53/LIFT LOBBY "
					-- 7:2-54 HFP-11 "E/L2/C/2F/SD54/ELECT RM "
					-- 7:2-55 XTRI-R "E/L2/C/2F/CM55/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:2-56 HMS-S/D/M/SA "E/L2/C/2F/MCP56/FIRE SHAFT L.L."
					-- 7:2-57 HTRI-S "E/L2/C/2F/MM57/FIRE SHAFT L.L."
					-- 7:2-58 HTRI-R "E/L2/C/2F/CM58/DR RELESE NR LL"
					-- Switch ""
					-- Relay
					-- 7:2-59 HFP-11 "E/L2/C/2F/SD59/AHU RM "
					-- 7:2-60 HTRI-R "E/L2/2F/CM60/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:2-61 HFP-11 "E/L2/C/2F/SD61/CORR NR AHU "
					-- 7:2-62 HFP-11 "E/L2/C/2F/SD62/CORR NR EC2133"
					-- 7:2-63 HFP-11 "E/L2/C/2F/SD63/CORR NR EC2132"
					-- 7:2-64 HFP-11 "E/L2/C/2F/SD64/CORR NR EC2132"
					-- 7:2-65 HMS-S/D/M/SA "E/L2/2F/MCP65/IRE ESC STR"
					-- 7:2-66 HTRI-R "E/L2/2F/CM66/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:2-67 HFP-11 "E/L2/2F/SD67/ELECT RM SD"
					-- 7:2-68 HFP-11 "E/L2/2F/SD68/AHU RM SD"
					-- 7:2-69 HTRI-R "E/L2/2F/CM69/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:2-70 HFP-11 "E/L2/2F/SD70/LIFT LOBBY SD"
					-- 7:2-71 HMS-S/D/M/SA "E/L2/2F/MCP71/FIRE SHAFT L.L."
					-- 7:2-72 HTRI-R "E/L2/2F/CM72/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:2-73 HTRI-S "E/L2/2F/MM73/FIRE SHAFT L.L."
					-- 7:2-74 HFP-11 "E/L2/EE1011/SD74/Main cabin"
					-- 7:2-75 HFP-11 "E/L2/EE1011/SD75/Assortor Cab 1"
					-- 7:2-76 HTRI-R "E/L2/1F/CM76/DR RELESE NR EC1080"
					-- Switch ""
					-- Relay
					-- 7:2-77 HFP-11 "E/L2/1F/SD77/CORR NR EC 1080"
					-- 7:2-78 HFP-11 "E/L2/1F/SD78/CORR NR EC 1080"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:2 XDLC "DLC @ address 2 L2"

					-- 7:2-79 HFP-11 "E/L2/1F/SD79/CORR NR EC 1050"
					-- 7:2-80 HFP-11 "E/L2/1F/SD80/CORR NR EC1/S07"
					-- 7:2-81 HFP-11 "E/L2/1F/SD81/CORR NR EC1/S07"
					-- 7:2-82 HTRI-R "E/L2/1F/CM82/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:2-83 HMS-S/D/M/SA "E/L2/1F/MCP83/FIRE ESC STR"
					-- 7:2-84 HFP-11 "E/L2/1F/SD84/CORR NR EC 1040"
					-- 7:2-85 HFP-11 "E/L2/1F/SD85/CORR NR EC1/S06"
					-- 7:2-86 HFP-11 "E/L2/1F/SD86/CORR NR EC 1010"
					-- 7:2-87 HFP-11 "E/L2/1F/SD87/CORR NR E.R."
					-- 7:2-88 HFP-11 "E/L2/1F/SD88/ELECT RM SD"
					-- 7:2-89 HTRI-R "E/L2/1F/CM89/DR RELESE CM NR E.R"
					-- Switch ""
					-- Relay
					-- 7:2-90 HFP-11 "E/L2/1F/SD90/CORR NR EC1/S21"
					-- 7:2-91 XTRI-R "E/L2/1F/CM91/FIRE SHAFT L.L.C/C"
					-- Switch ""
					-- Relay
					-- 7:2-92 HMS-S/D/M/SA "E/L2/1F/MCP92/FIRE SHAF L.L.C/C"
					-- 7:2-93 HTRI-S "E/L2/1F/MM93/FIRE SHAFT L.L.C/C"
					-- 7:2-94 HFP-11 "E/L2/1F/SD94/LIFT LOBBY SD C/C"
					-- 7:2-95 HFP-11 "E/L2/1F/SD95/LIFT LOBBY SD C/C"
					-- 7:2-97 HTRI-R "E/L2/1F/CM97/AHU RM CM C/C"
					-- Switch ""
					-- Relay
					-- 7:2-98 HFP-11 "E/L2/1F/SD98/AHU RM SD C/C"
					-- 7:2-99 HFP-11 "E/L2/EE1011/SD99/Assortor Cab 2"
					-- 7:2-100 HFP-11 "E/L2/EE1011/SD100/Assortor Cab 2"
					-- 7:2-101 HFP-11 "E/L2/1F/SD101/ELECT RM SD E/C"
					-- 7:2-102 HFP-11 "E/L2/1F/SD102/AHU RM SD E/C"
					-- 7:2-103 HTRI-R "E/L2/1F/CM103/AHU RM CM E/C"
					-- Switch ""
					-- Relay
					-- 7:2-104 HFP-11 "E/L2/1F/SD104/LIFT LOBBY SD E/C"
					-- 7:2-105 HTRI-R "E/L2/1F/CM105/FIRE SHAFT L.L.E/C"
					-- Switch ""
					-- Relay
					-- 7:2-106 HMS-S/D/M/SA "E/L2/1F/MCP106/FIRE SHAFT L.L.E/"
					-- 7:2-107 HTRI-S "E/L2/1F/MM107/FIRE SHAFT L.L.E/C"
					-- 7:2-108 HFP-11 "E/L2/1F/SD108/SMALL CORR "
					-- 7:2-110 HTRI-S "E/L2/3F/MM110/EC3080"
					-- 7:2-111 XTRI-S "E/L2/3F/MM111/EC3100"
					-- 7:2-112 HFP-11 "E/L2/EE1011/SD112/Assortor Cab 2"
					-- 7:2-113 HFP-11 "E/L2/EE1011/SD113/Lunch Cabin"
					-- 7:2-114 HFP-11 "E/L2/EE1011/SD114/Assortor Cab 3"
					-- 7:2-116 XTRI-S "E/L2/2F/MM116/EC2060"
					-- 7:2-117 HFP-11 "E/L2/EE1011/SD117/Assortor Cab 3"
					-- 7:2-118 HFP-11 "E/L2/EE1011/SD118/Assortor Cab 3"
					-- 7:2-119 XTRI-S "E/L2/2F/MM119/EC2040"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:2 XDLC "DLC @ address 2 L2"

					-- 7:2-120 HFP-11 "E/L2/EE1011/SD120/Account Cabin"
					-- 7:2-122 HFP-11 "E/L2/EE1011/SD122/Director Cabin"
					-- 7:2-123 XTRI-S "E/L2/2F/MM123/EC2020"
					-- 7:2-124 XTRI-S "E/L2/2F/MM124/EC2010"
					-- 7:2-125 HFP-11 "E/L2/EE1011/SD125/Psg Nr. Pantry"
					-- 7:2-127 XTRI-S "E/L2/2F/MM127/EC2150"
					-- 7:2-128 XTRI-S "E/L2/2F/MM128/EC2140"
					-- 7:2-129 HFP-11 "E/L2/EE1011/SD129/Waiting Area P"
					-- 7:2-130 XTRI-S "E/L2/C//2F/MM130/EC2100"
					-- 7:2-131 HTRI-S "E/L2/2F/MM131/"
					-- 7:2-132 HFP-11 "E/L2/EE1011/SD132/Reception Psg"
					-- 7:2-133 XTRI-S "E/L2/2F/MM133/EC2120"
					-- 7:2-135 HFPT-11 "E/L2/EC3060/HD135/Pantry"
					-- 7:2-136 HFPT-11 "E/L2/EE1011/HD136/Pantry"
					-- 7:2-137 HMS-S/D/M/SA "E/L2/EE1011/MCP137/Waiting Area "
					-- 7:2-138 HMS-S/D/M/SA "E/L2/EE1011/MCP138/Psg Nr.Main C"
					-- 7:2-139 HTRI-S "E/L2/1F/MM139/EC1160"
					-- 7:2-141 HTRI-S "E/L2/1F/MM141/EC1150"
					-- 7:2-142 HTRI-S "E/L2/1F/MM142/EC1030"
					-- 7:2-143 HTRI-S "E/L2/C/2F/MM143/EC1120"
					-- 7:2-145 HTRI-S "E/L2/1F/MM145/EC1130"
					-- 7:2-146 HTRI-S "E/L2/1F/MM146/EC1050-A"
					-- 7:2-148 HTRI-S "E/L2/1F/MM148/EC1050"
					-- 7:2-149 HTRI-S "E/L2/1F/MM149/EC1110"
					-- 7:2-150 HTRI-S "E/L2/1F/MM150/EC1060"
					-- 7:2-152 HTRI-S "E/L2/1F/MM152/EC1100"
					-- 7:2-153 HTRI-S "E/L2/1F/MM153/EC1080"
					-- 7:2-154 HTRI-S "E/L2/1F/MM154/EC1090"
					-- 7:2-155 HTRI-S "E/L2/1F/MM155/EC1080-(A) "
					-- 7:2-158 HTRI-S "E/L2/2F/MM158/EE2010"
					-- 7:2-161 HTRI-R "E/L2/EE1011/CM161/Waitting Psg A"
					-- Switch ""
					-- Relay
					-- 7:2-163 HTRI-S "E/L2/1F/MM163/EE3110"
					-- 7:2-164 HTRI-S "E/L2/3F/MM164/EE3120"
					-- 7:2-166 HTRI-S "E/L2/3F/MM166/EC3050"
					-- 7:2-171 HTRI-S "E/L2/3F/MM171/EE3070"
					-- 7:2-176 HMS-S/D/M/SA "E/L2/EW/GND/MCP-176/Lift Lobby"
					-- 7:2-177 HTRI-R "E/L2/EW/GND/CM-177/Lift Lobby AF"
					-- Switch ""
					-- Relay
					-- 7:2-178 HTRI-S "E/L2/EW/GND/MM-178/Lift Lobby AF"
					-- 7:2-179 FDOT421 "E/L2/EW/GND/SD-179/Electric Room"
					-- 7:2-180 FDOT421 "E/L2/EW/GND/SD-180/Lift Lobby En"
					-- 7:2-181 FDOT421 "E/L2/EW/GND/SD-181/LL security c"
					-- 7:2-182 FDOT421 "E/L2/EW/GND/SD-182/Lift Lobby "
					-- 7:2-183 FDOT421 "E/L2/EW/GND/SD-183/Lift Lobby "
					-- 7:2-184 FDOT421 "E/L2/EW/GND/SD-184/Lift Lobby En"
					-- 7:2-185 FDOT421 "E/L2/EW/GND/SD-185/Lift Lobby AH"
					-- 7:2-186 HTRI-R "E/L2/EW/GND/CM-186/Lift Lobby AH"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:2 XDLC "DLC @ address 2 L2"

7:2-186 HTRI-R "E/L2/EW/GND/CM-186/Lift Lobby AH"

```
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:2-187 HFP-11 "E/L2/EC3010/SD187/Accounts cab"
| | | | | |-- 7:2-188 HFP-11 "E/L2/EC3010/SD188/Assorter cab"
| | | | | |-- 7:2-189 HFP-11 "E/L2/EC3010/SD189/Main cab"
| | | | | |-- 7:2-190 HFP-11 "E/L2/EC3010/SD190/Pantry"
| | | | | |-- 7:2-191 HFP-11 "E/L2/EC3010/SD191/Washroom area"
| | | | | |-- 7:2-192 HFP-11 "E/L2/EC3010/SD192/Reception"
| | | | | |-- 7:2-193 HTRI-R "E/L2/EC3010/CM193/Entry dr Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:2-194 HMS-S/D/M/SA "E/L2/EC3010/MCP194/Entry dr Psg"
| | | | | |-- 7:2-195 HFP-11 "E/L2/EC3070/SD195/Reception"
| | | | | |-- 7:2-196 HFPT-11 "E/L2/EC3070/HD196/Pantry"
| | | | | |-- 7:2-197 HFP-11 "E/L2/EC3070/SD197/Meeting rm"
| | | | | |-- 7:2-198 HFP-11 "E/L2/EC3070/SD198/Psg nr account"
| | | | | |-- 7:2-199 HFP-11 "E/L2/EC3070/SD199/Account cab"
| | | | | |-- 7:2-200 HFP-11 "E/L2/EC3070/SD200/Boss cab"
| | | | | |-- 7:2-201 HFP-11 "E/L2/EC3070/SD201/Main cab"
| | | | | |-- 7:2-202 HTRI-R "E/L2/EC3070/CM202/Entry dr Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:2-203 HMS-S/D/M/SA "E/L2/EC3070/MCP203/Entry dr Psg"
| | | | | |-- 7:2-204 HFP-11 "E/L2/EC3060/SD204/Main cab1"
| | | | | |-- 7:2-205 HFP-11 "E/L2/EC3060/SD205/Main cab2"
| | | | | |-- 7:2-206 HFP-11 "E/L2/EC3060/SD206/Account cab"
| | | | | |-- 7:2-207 HFP-11 "E/L2/EC3060/SD207/Account cab"
| | | | | |-- 7:2-208 HFP-11 "E/L2/EC3060/SD208/Reception"
| | | | | |-- 7:2-209 HFP-11 "E/L2/EC3060/SD209/Pantry"
| | | | | |-- 7:2-210 HFP-11 "E/L2/EC3060/SD210/store rm"
| | | | | |-- 7:2-211 XTRI-R "E/L2/EC3060/CM211/Entry dr Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:2-212 HMS-S/D/M/SA "E/L2/EC3060/MCP212/Entry dr Psg"
| | | | | |-- 7:2-226 HFP-11 "E/L2/EE3060/SD226/Main cab"
| | | | | |-- 7:2-227 HFP-11 "E/L2/EE3060/SD227/Assorter cab"
| | | | | |-- 7:2-228 HFP-11 "E/L2/EE3060/SD228/Psg nr Assorte"
| | | | | |-- 7:2-229 HFP-11 "E/L2/EE3060/SD229/Accounts cab"
| | | | | |-- 7:2-230 HFPT-11 "E/L2/EE3060/HD230/Pantry"
| | | | | |-- 7:2-231 HTRI-R "E/L2/EE3060/CM231/Entry dr Psg"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 7:2-232 HMS-S/D/M/SA "E/L2/EE3060/MCP232/Entry dr Psg"
| | | | | |-- 7:2-233 HFP-11 "E/L2/EC1170/SD233/Assorter cab1"
| | | | | |-- 7:2-234 HFP-11 "E/L2/EC1170/SD234/AFC Assorter c"
| | | | | |-- 7:2-235 HFP-11 "E/L2/EC1170/SD235/Main cab"
| | | | | |-- 7:2-236 HFP-11 "E/L2/EC1170/SD236/AFC Main cab"
| | | | | |-- 7:2-237 HFP-11 "E/L2/EC1170/SD237/Entry Psg"
| | | | | |-- 7:2-238 HFP-11 "E/L2/EC1170/SD238/Account cab"
| | | | | |-- 7:2-239 HFP-11 "E/L2/EC1170/SD239/Assorter cab2"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:2 XDLC "DLC @ address 2 L2"

```
| | | | |-- 7:2-240 HFP-11 "E/L2/EC1170/SD240/AFC Assorter c"
| | | | |-- 7:2-241 HTRI-R "E/L2/EC1170/CM241/Electric cupbo"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-242 HMS-S/D/M/SA "E/L2/EC1170/MCP242/Entry Psg"
| | | | |-- 7:2-243 HFP-11 "E/L2/EC2160/SD243/main cab"
| | | | |-- 7:2-244 HFP-11 "E/L2/EC2160/SD244/Assoter cab"
| | | | |-- 7:2-245 HFP-11 "E/L2/EC2160/SD245/psg nr assoter"
| | | | |-- 7:2-246 HFP-11 "E/L2/EC2160/SD246/pantry"
| | | | |-- 7:2-247 HTRI-R "E/L2/EC2160/CM247/Entry psg afc"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:2-248 HMS-S/D/M/SA "E/L2/EC2160/MCP248/Entry Psg"
| | | | |-- 7:2-250 XTRI-S "E/L2/1F/MM250/EC3110"
| | | |-- 7:3 XDLC "DLC @ address 3 L3"
| | | | |-- 7:3-1 HFP-11 "E/L3/WC/2F/SD1/CORR NR 2260"
| | | | |-- 7:3-2 HFP-11 "E/L3/WC/2F/SD2/CORR NR 2260"
| | | | |-- 7:3-3 HTRI-R "E/L3/WC/2F/CM3/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:3-4 HMS-S/D/M/SA "E/L3/WC/2F/MCP4/FIRE ESC STR"
| | | | |-- 7:3-5 HFP-11 "E/L3/WC/2F/SD5/CORR NR 2170"
| | | | |-- 7:3-6 HFP-11 "E/L3/WC/2F/SD6/CORR NR 2200"
| | | | |-- 7:3-7 HFP-11 "E/L3/WC/2F/SD7/CORR NR 2230"
| | | | |-- 7:3-8 HFP-11 "E/L3/WC/2F/SD8/CORR NR AHU"
| | | | |-- 7:3-9 HFP-11 "E/L3/WC/2F/SD9/CORR NR AHU"
| | | | |-- 7:3-10 HTRI-R "E/L3/WC/2F/CM10/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:3-11 HFP-11 "E/L3/WC/2F/SD11/AHU RM SD"
| | | | |-- 7:3-12 HTRI-R "E/L3/WC/2F/CM12/DR RELESE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:3-13 HFP-11 "E/L3/WC/2F/SD13/LIFT LOBBY SD"
| | | | |-- 7:3-14 HFP-11 "E/L3/WC/2F/SD14/LIFT LOBBY SD"
| | | | |-- 7:3-15 HTRI-R "E/L3/WC/2F/CM15/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:3-16 HMS-S/D/M/SA "E/L3/WC/2F/MCP16/FIRE SHAFT L.L."
| | | | |-- 7:3-17 HTRI-S "E/L3/WC/2F/MM17/FIRE SHAFT L.L."
| | | | |-- 7:3-18 HFP-11 "E/L3/WC/2F/SD18/ELECT RM SD"
| | | | |-- 7:3-19 HTRI-R "E/L3/WC/2F/CM19/DR RELESE NR E.R"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:3-20 HFP-11 "E/L3/WC/2F/SD20/CORR NR 2020"
| | | | |-- 7:3-21 HFP-11 "E/L3/WC/2F/SD21/CORR NR 2200"
| | | | |-- 7:3-22 HFP-11 "E/L3/WC/2F/SD22/CORR NR 2050"
| | | | |-- 7:3-23 HFP-11 "E/L3/WC/2F/SD23/CORR NR 2180"
| | | | |-- 7:3-24 HFP-11 "E/L3/WC/2F/SD24/CORR NR 2070"
| | | | |-- 7:3-25 HFP-11 "E/L3/WC/1F/SD25/CORR NR 1200"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-26 HFP-11 "E/L3/WC/1F/SD26/CORR NR 1230"
					-- 7:3-27 HFP-11 "E/L3/WC/1F/SD27/CORR NR 1230"
					-- 7:3-28 HFP-11 "E/L3/WC/1F/SD28/CORR NR 1170"
					-- 7:3-29 HFP-11 "E/L3/WC/1F/SD29/SMALL CORR "
					-- 7:3-30 HFP-11 "E/L3/WC/1F/SD30/SMALL CORR "
					-- 7:3-31 HTRI-R "E/L3/WC/1F/CM31/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:3-32 HFP-11 "E/L3/WC/1F/SD32/AHU RM SD"
					-- 7:3-33 HTRI-R "E/L3/WC/1F/CM33/DR RELESE CM AHU"
					-- Switch ""
					-- Relay
					-- 7:3-34 HFP-11 "E/L3/WC/1F/SD34/LIFT LOBBY SD"
					-- 7:3-35 HFP-11 "E/L3/WC/1F/SD35/LIFT LOBBY SD"
					-- 7:3-36 HTRI-R "E/L3/WC/1F/CM36/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:3-37 HMS-S/D/M/SA "E/L3/WC/1F/MCP37/FIRE SHAFT L.L."
					-- 7:3-38 HTRI-S "E/L3/WC/1F/MM38/FIRE SHAFT L.L."
					-- 7:3-39 HTRI-R "E/L3/WC/1F/CM39/DR RELESE CM "
					-- Switch ""
					-- Relay
					-- 7:3-40 HFP-11 "E/L3/WC/1F/SD40/ELECT RM SD"
					-- 7:3-41 HFP-11 "E/L3/WC/1F/SD41/CORR NR 1020"
					-- 7:3-42 HFP-11 "E/L3/WC/1F/SD42/CORR NR 1020"
					-- 7:3-43 HFP-11 "E/L3/WC/1F/SD43/CORR NR 1100"
					-- 7:3-44 HFP-11 "E/L3/WC/1F/SD44/CORR NR 1070"
					-- 7:3-45 HFP-11 "E/L3/WC/1F/SD45/CORR NR EW1070"
					-- 7:3-46 HTRI-S "E/L3/2F/MM46/DW2180"
					-- 7:3-47 HTRI-S "E/L3/2F/MM47/DW2170"
					-- 7:3-49 HTRI-S "E/L3/2F/MM49/DW2260"
					-- 7:3-55 HTRI-S "E/L3/2F/MM55/EW2170"
					-- 7:3-56 HTRI-S "E/L3/2F/MM56/EW2200"
					-- 7:3-60 HTRI-S "E/L3/2F/MM60/EW2040"
					-- 7:3-61 HTRI-S "E/L3/2F/MM61/EW2200 (B) "
					-- 7:3-62 HTRI-S "E/L3/2F/MM62/EW2030"
					-- 7:3-63 HTRI-S "E/L3/2F/MM63/EW2020"
					-- 7:3-64 HTRI-S "E/L3/2F/MM64/EW2010"
					-- 7:3-65 HTRI-S "E/L3/2F/MM65/DW2220"
					-- 7:3-67 HTRI-S "E/L3/2F/MM67/DW2200"
					-- 7:3-80 HTRI-S "E/L3/1F/MM80/EW1050"
					-- 7:3-81 HTRI-S "E/L3/1F/MM81/EW1090"
					-- 7:3-82 HTRI-S "E/L3/1F/MM82/EW1100"
					-- 7:3-85 HTRI-S "E/L3/1F/MM85/EW1110"
					-- 7:3-86 HTRI-S "E/L3/1F/MM86/EW1120"
					-- 7:3-88 HTRI-S "E/L3/1F/MM88/EW1130"
					-- 7:3-89 HTRI-S "E/L3/1F/MM89/EW1012"
					-- 7:3-90 HTRI-S "E/L3/1F/MM90/EW1011"
					-- 7:3-91 HTRI-S "E/L3/1F/MM91/EW1140"
					-- 7:3-92 HTRI-S "E/L3/1F/MM92/EW1150"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-96 HTRI-S "E/L3/1F/MM96/EW1220"
					-- 7:3-98 HTRI-S "E/L3/1F/MM98/EW1180"
					-- 7:3-100 HTRI-S "E/L3/1F/MM100/EW1200"
					-- 7:3-102 HFP-11 "E/L3/DW2250/SD102/Account cab"
					-- 7:3-103 HFP-11 "E/L3/DW2250/SD103/Main cab"
					-- 7:3-104 HFP-11 "E/L3/DW2250/SD104/Psg nr Main ca"
					-- 7:3-105 HFP-11 "E/L3/DW2250/SD105/Assorter cab"
					-- 7:3-106 HTRI-R "E/L3/DW2250/CM106/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 7:3-107 HMS-S/D/M/SA "E/L3/DW2250/MCP107/Psg nr Entry"
					-- 7:3-108 HFP-11 "E/L3/DW2190/SD108/Pantry"
					-- 7:3-109 HFP-11 "E/L3/DW2190/SD109/Managers cab 2"
					-- 7:3-110 HFP-11 "E/L3/DW2190/SD110/Managers cab 1"
					-- 7:3-111 HFP-11 "E/L3/DW2190/SD111/Directors cab"
					-- 7:3-112 HTRI-R "E/L3/DW2190/CM112/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 7:3-113 HMS-S/D/M/SA "E/L3/DW2190/MCP113/Psg nr Entry"
					-- 7:3-114 HFP-11 "E/L3/DW2240/SD114/Pantry"
					-- 7:3-115 HFP-11 "E/L3/DW2240/SD115/Main cab"
					-- 7:3-116 HTRI-R "E/L3/DW2240/CM116/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 7:3-117 HMS-S/D/M/SA "E/L3/DW2240/MCP117/Psg nr Entry"
					-- 7:3-118 HFP-11 "E/L3/DW2230/SD118/Pantry"
					-- 7:3-119 HFP-11 "E/L3/DW2230/SD119/Main cab"
					-- 7:3-120 HTRI-R "E/L3/DW2230/CM120/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 7:3-121 HMS-S/D/M/SA "E/L3/DW2230/MCP121/Psg nr Entry"
					-- 7:3-122 HFP-11 "E/L3/DW2210/SD122/Cab 1"
					-- 7:3-123 HFP-11 "E/L3/DW2210/SD123/Cab 2"
					-- 7:3-125 HFP-11 "E/L3/DW2210/SD125/Main cab"
					-- 7:3-126 HFP-11 "E/L3/DW2210/SD126/Psg nr Cab 2"
					-- 7:3-127 HTRI-R "E/L3/DW2210/CM127/Psg nr Entry"
					-- Switch ""
					-- Relay
					-- 7:3-128 HMS-S/D/M/SA "E/L3/DW2210/MCP128/Psg nr Entry"
					-- 7:3-129 HFP-11 "E/L3/EW2050/SD129/Main cab"
					-- 7:3-130 HFP-11 "E/L3/EW2050/SD130/Assorter cab"
					-- 7:3-131 HFP-11 "E/L3/EW2050/SD131/Psg nr Assorte"
					-- 7:3-132 HFP-11 "E/L3/EW2050/SD132/Accounts cab"
					-- 7:3-133 HFPT-11 "E/L3/EW2050/HD133/Pantry"
					-- 7:3-134 HTRI-R "E/L3/EW2050/CM134/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-135 HMS-S/D/M/SA "E/L3/EW2050/MCP135/Entry dr Psg"
					-- 7:3-136 HFP-11 "E/L3/EW2190/SD136/Main cab"
					-- 7:3-137 HFP-11 "E/L3/EW2190/SD137/Account cab"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-138 HFP-11 "E/L3/EW2190/SD138/Account cab Ps"
					-- 7:3-139 HTRI-R "E/L3/EW2190/CM139/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-140 HMS-S/D/M/SA "E/L3/EW2190/MCP140/Entry dr Psg"
					-- 7:3-146 HFP-11 "E/L3/EW1020/SD146/Main cab"
					-- 7:3-147 HFP-11 "E/L3/EW1020/SD147/Assorter cab"
					-- 7:3-148 HFP-11 "E/L3/EW1020/SD148/Account cab"
					-- 7:3-149 HFP-11 "E/L3/EW1020/SD149/Account cab ps"
					-- 7:3-150 HFP-11 "E/L3/EW1020/SD150/Pantry"
					-- 7:3-151 HTRI-R "E/L3/EW1020/CM151/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-152 HMS-S/D/M/SA "E/L3/EW1020/MCP152/Entry dr Psg"
					-- 7:3-153 HFP-11 "E/L3/EW1160/SD153/Entry Psg"
					-- 7:3-154 HFP-11 "E/L3/EW1160/SD154/Entry Psg"
					-- 7:3-155 HFP-11 "E/L3/EW1160/SD155/Pantry"
					-- 7:3-156 HFP-11 "E/L3/EW1160/SD156/Main cab1"
					-- 7:3-157 HFP-11 "E/L3/EW1160/SD157/Main cab2"
					-- 7:3-158 HFP-11 "E/L3/EW1160/SD158/Assorter cab1"
					-- 7:3-159 HFP-11 "E/L3/EW1160/SD159/Assorter cab2"
					-- 7:3-160 HFP-11 "E/L3/EW1160/SD160/Accounts cab"
					-- 7:3-161 HTRI-R "E/L3/EW1160/CM161/Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:3-162 HMS-S/D/M/SA "E/L3/EW1160/MCP162/Entry Psg"
					-- 7:3-163 HFP-11 "E/L3/EW2060/SD163/Main cab"
					-- 7:3-164 HFP-11 "E/L3/EW2060/SD164/Assorter cab"
					-- 7:3-165 HFP-11 "E/L3/EW2060/SD165/Psg nr Assorte"
					-- 7:3-166 HFP-11 "E/L3/EW2060/SD166/Pantry"
					-- 7:3-167 HTRI-R "E/L3/EW2060/CM167/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-168 HMS-S/D/M/SA "E/L3/EW2060/MCP168/Entry dr Psg"
					-- 7:3-169 HFP-11 "E/L3/EW1190/SD169/Assorter cab"
					-- 7:3-170 HFP-11 "E/L3/EW1190/SD170/Main cab"
					-- 7:3-171 HFP-11 "E/L3/EW1190/SD171/Psg nr Main ca"
					-- 7:3-172 HTRI-R "E/L3/EW1190/CM172/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-173 HMS-S/D/M/SA "E/L3/EW1190/MCP173/Entry dr Psg"
					-- 7:3-174 HFP-11 "E/L3/EW2180/SD174/Main cab"
					-- 7:3-175 HFP-11 "E/L3/EW2180/SD175/Assorter cab"
					-- 7:3-176 HFP-11 "E/L3/EW2180/SD176/Entry Psg"
					-- 7:3-177 HTRI-R "E/L3/EW2180/CM177/Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:3-178 HMS-S/D/M/SA "E/L3/EW2180/MCP178/Entry Psg"
					-- 7:3-179 HFP-11 "E/L3/EW1030/SD179/Main cab"
					-- 7:3-180 HFP-11 "E/L3/EW1030/SD180/Assorter cab"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-181 HFP-11 "E/L3/EW1030/SD181/Psg nr Assorte"
					-- 7:3-182 HFPT-11 "E/L3/EW1030/HD182/Pantry"
					-- 7:3-183 HTRI-R "E/L3/EW1030/CM183/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-184 HMS-S/D/M/SA "E/L3/EW1030/MCP184/Entry dr Psg"
					-- 7:3-185 HFP-11 "E/L3/EW1070/SD185/Main cab"
					-- 7:3-186 HFP-11 "E/L3/EW1070/SD186/Assorter cab"
					-- 7:3-187 FDOT421 "E/L3/EW1070/SD187/AFC Assorter c"
					-- 7:3-188 FDOT421 "E/L3/EW1070/SD188/Entry dr Psg"
					-- 7:3-189 HTRI-R "E/L3/EW1070/CM189/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:3-190 HMS-S/D/M/SA "E/L3/EW1070/MCP190/Entry dr Psg"
					-- 7:3-191 HFP-11 "E/L3/EW1170/SD191/Sales dept"
					-- 7:3-192 HFP-11 "E/L3/EW1170/SD192/Sales dept"
					-- 7:3-193 HFP-11 "E/L3/EW1170/SD193/Purchase dept"
					-- 7:3-194 HFPT-11 "E/L3/EW1170/HD194/Pantry"
					-- 7:3-195 HFP-11 "E/L3/EW1170/SD195/Psg nr Pantry"
					-- 7:3-196 HFP-11 "E/L3/EW1170/SD196/Account dept"
					-- 7:3-197 HFP-11 "E/L3/EW1170/SD197/Cab nr Entry"
					-- 7:3-198 HFP-11 "E/L3/EW1170/SD198/Reception Psg"
					-- 7:3-199 HTRI-R "E/L3/EW1170/CM199/Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:3-200 HMS-S/D/M/SA "E/L3/EW1170/MCP200/Entry Psg"
					-- 7:3-201 HFP-11 "E/L3/EW2060/SD201/Cab 1"
					-- 7:3-202 HFP-11 "E/L3/EW2060/SD202/Cab 2"
					-- 7:3-203 HFP-11 "E/L3/EW2060/SD203/Cab 3"
					-- 7:3-204 HFP-11 "E/L3/EW2060/SD204/Cab 4"
					-- 7:3-205 HFP-11 "E/L3/EW2060/SD205/Pantry Psg"
					-- 7:3-206 HFP-11 "E/L3/EW2060/SD206/Pantry"
					-- 7:3-207 HFP-11 "E/L3/EW2060/SD207/Entry Psg"
					-- 7:3-210 HFP-11 "E/L3/EW1080/SD210/Main cab"
					-- 7:3-211 HFP-11 "E/L3/EW1080/SD211/Entry psg"
					-- 7:3-212 HTRI-R "E/L3/EW1080/CM212/Entry psg"
					-- Switch ""
					-- Relay
					-- 7:3-213 HMS-S/D/M/SA "E/L3/EW1080/MCP213/Entry psg"
					-- 7:3-214 HFP-11 "E/L3/EW1170/SD214/psg Nr Assoter"
					-- 7:3-215 HFP-11 "E/L3/EW1060/SD215/Main Cabin"
					-- 7:3-216 HFP-11 "E/L3/EW1060/SD216/Account Cab"
					-- 7:3-217 HFP-11 "E/L3/EW1060/SD217/Assoter Cab"
					-- 7:3-218 HFPT-11 "L3/EW1060/HD218/Pantry"
					-- 7:3-219 HTRI-R "E/L3/EW1060/CM219/Afc Entry psg"
					-- Switch ""
					-- Relay
					-- 7:3-220 HMS-S/D/M/SA "E/L3/EW1060/MCP220/Entry Dr psg"
					-- 7:3-243 HFP-11 "E/L3/EW1230/SD243/Main cab"
					-- 7:3-244 HFP-11 "E/L3/EW1230/SD244/Assorter cab"

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:3 XDLC "DLC @ address 3 L3"

					-- 7:3-245 HFP-11 "E/L3/EW1230/SD245/Assorter cab"
					-- 7:3-246 HFP-11 "E/L3/EW1230/SD246/Pantry"
					-- 7:3-247 HMS-S/D/M/SA "E/L3/EW1230/MCP247/Entry psg"
					-- 7:3-248 HTRI-R "E/L3/EW1230/CM248/AFC Pantry"
					-- Switch ""
					-- Relay
					-- 7:4 XDLC "DLC @ address 4 L4"
					-- 7:4-4 HFP-11 "E/L4/5F/SD4/CORR NR 5/S19"
					-- 7:4-5 HFP-11 "E/L4/5F/SD5/CORR NR 5183"
					-- 7:4-6 HFP-11 "E/L4/5F/SD6/CORR NR 5183"
					-- 7:4-9 HFP-11 "E/L4/5F/SD9/ELECT RM SD"
					-- 7:4-10 HMS-S/D/M/SA "E/L4/5F/MCP10/FIRE SHAFT L.L."
					-- 7:4-11 HTRI-R "E/L4/5F/CM11/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:4-12 HTRI-S "E/L4/5F/MM12/FIRE SHAFT L.L."
					-- 7:4-13 HFP-11 "E/L4/5F/SD13/AHU RM SD"
					-- 7:4-14 HTRI-R "E/L4/5F/CM14/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:4-17 HFP-11 "E/L4/5F/SD17/ELECT RM SD"
					-- 7:4-18 HFP-11 "E/L4/5F/SD18/AHU RM SD"
					-- 7:4-19 HTRI-R "E/L4/5F/CM19/AHU RM CM"
					-- Switch ""
					-- Relay
					-- 7:4-20 HFP-11 "E/L4/5F/SD20/LIFT LOBBY SD "
					-- 7:4-21 HMS-S/D/M/SA "E/L4/5F/MCP21/FIRE SHAFT L.L."
					-- 7:4-22 HTRI-R "E/L4/5F/CM22/FIRE SHAFT L.L."
					-- Switch ""
					-- Relay
					-- 7:4-23 HTRI-S "E/L4/5F/MM23/FIRE SHAFT L.L."
					-- 7:4-24 HTRI-R "E/L4/4F/CM24/DR RELESE CM"
					-- Switch ""
					-- Relay
					-- 7:4-25 HFP-11 "E/L4/4F/SD25/CORR NR E.R."
					-- 7:4-26 HFP-11 "E/L4/4F/SD26/CORR NR E.R."
					-- 7:4-27 HFP-11 "E/L4/4F/SD27/CORR NR EC 4051"
					-- 7:4-28 HFP-11 "E/L4/4F/SD28/CORR NR EC 4051"
					-- 7:4-29 HFP-11 "E/L4/4F/SD29/CORR NR FIRE EXIT"
					-- 7:4-30 HMS-S/D/M/SA "E/L4/4F/MCP30/FIRE ESC STR"
					-- 7:4-31 HTRI-R "E/L4/4F/CM31/FIRE ESC STR"
					-- Switch ""
					-- Relay
					-- 7:4-32 HFP-11 "E/L4/4F/SD32/CORR NR 4060"
					-- 7:4-33 HFP-11 "E/L4/4F/SD33/CORR NR EC4 S/20"
					-- 7:4-34 HFP-11 "E/L4/4F/SD34/CORR NR 4071"
					-- 7:4-35 HFP-11 "E/L4/4F/SD35/CORR NR 4072"
					-- 7:4-36 HFP-11 "E/L4/4F/SD36/CORR NR 4072"
					-- 7:4-37 HFP-11 "E/L4/4F/SD37/CORR NR 4080"
					-- 7:4-38 HTRI-R "E/L4/4F/CM38/DR RELESE CM"

```
7 Desigo Fire Safety Modular "BDB TOWER E" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      7:4 XDLC "DLC @ address 4 L4"
        7:4-38 HTRI-R "E/L4/4F/CM38/DR RELESE CM"
```

```
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-39 HFP-11 "E/L4/4F/SD39/LIFT LOBBY SD"
| | | | |-- 7:4-40 HFP-11 "E/L4/4F/SD40/LIFT LOBBY SD"
| | | | |-- 7:4-41 HFP-11 "E/L4/4F/SD41/ELEC.RM"
| | | | |-- 7:4-42 HFP-11 "E/L4/4F/SD42/AHU RM SD"
| | | | |-- 7:4-43 HTRI-R "E/L4/4F/CM43/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-44 HFP-11 "E/L4/4F/SD44/CORR NR 4101"
| | | | |-- 7:4-45 HFP-11 "E/L4/4F/SD45/CORR NR 4101"
| | | | |-- 7:4-46 HFP-11 "E/L4/4F/SD46/CORR NR 4013"
| | | | |-- 7:4-47 HFP-11 "E/L4/4F/SD47/CORR NR 4013"
| | | | |-- 7:4-50 HFP-11 "E/L4/4F/SD50/ELECT RM SD"
| | | | |-- 7:4-51 HFP-11 "E/L4/4F/SD51/AHU RM SD"
| | | | |-- 7:4-52 HTRI-R "E/L4/4F/CM52/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-53 HFP-11 "E/L4/4F/SD53/LIFT LOBBY SD"
| | | | |-- 7:4-54 HTRI-S "E/L4/4F/MM54/FIRE SHAFT L.L."
| | | | |-- 7:4-55 XTRI-R "E/L4/4F/CM55/FIRE SHAFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-56 HMS-S/D/M/SA "E/L4/4F/MCP56/FIRE SHAFT L.L."
| | | | |-- 7:4-57 HMS-S/D/M/SA "E/L4/4F/MCP57/FIRE SHAFT L.L."
| | | | |-- 7:4-58 HTRI-R "E/L4/4F/CM58/FIRE SHATFT L.L."
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-59 HTRI-S "E/L4/4F/MM59/FIRE SHAFT L.L."
| | | | |-- 7:4-60 HTRI-R "E/L4/4F/CM60/DR RELELSE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:4-70 HTRI-S "E/L4/5F/MM70/EC5021"
| | | | |-- 7:4-71 HTRI-S "E/L4/4F/MM71/EE4014"
| | | | |-- 7:4-72 HTRI-S "E/L4/5F/MM72/EC5010"
| | | | |-- 7:4-75 HTRI-S "E/L4/4F/MM75/EC4016 ""
| | | | |-- 7:4-77 HTRI-S "E/L4/4F/MM77/EC4013A"
| | | | |-- 7:4-78 HTRI-S "E/L4/4F/MM78/EC4102 ""
| | | | |-- 7:4-79 HTRI-S "E/L4/4F/MM79/EC4091"
| | | | |-- 7:4-80 HTRI-S "E/L4/4F/MM80/EC4101"
| | | | |-- 7:4-81 HTRI-S "E/L4/4F/MM81/EC4080B ""
| | | | |-- 7:4-82 HTRI-S "E/L4/4F/MM82/EC4011"
| | | | |-- 7:4-83 HTRI-S "E/L4/4F/MM83/EC4072"
| | | | |-- 7:4-87 HTRI-S "E/L4/4F/MM87/EC4060"
| | | | |-- 7:4-88 HTRI-S "E/L4/4F/MM88/EC4030"
| | | | |-- 7:4-89 HTRI-S "E/L4/4F/MM89/EC4051"
| | | | |-- 7:4-90 HTRI-S "E/L4/4F/MM90/EC4040"
| | | | |-- 7:4-91 HTRI-S "E/L4/5F/MM91/EE5011"
| | | | |-- 7:4-92 HTRI-S "E/L4/4F/MM92/EE4011"
| | | | |-- 7:4-93 HFP-11 "E/L4/EC4012/SD93/Main cab"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:4 XDLC "DLC @ address 4 L4"

					-- 7:4-94 HFP-11 "E/L4/EC4012/SD94/Main cab"
					-- 7:4-95 HFP-11 "E/L4/EC4012/SD95/Account cab"
					-- 7:4-96 HFP-11 "E/L4/EC4012/SD96/Assorter cab"
					-- 7:4-97 HFP-11 "E/L4/EC4012/SD97/Psg nr Account "
					-- 7:4-98 HFP-11 "E/L4/EC4012/SD98/Pantry"
					-- 7:4-99 HTRI-R "E/L4/EC4012/CM99/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:4-100 HMS-S/D/M/SA "E/L4/EC4012/MCP100/Entry dr Psg"
					-- 7:4-101 HFP-11 "E/L4/EC4071/SD101/Assorter cab n"
					-- 7:4-102 HFP-11 "E/L4/EC4071/SD102/Pantry"
					-- 7:4-103 HFP-11 "E/L4/EC4071/SD103/Assorter cab"
					-- 7:4-104 HFP-11 "E/L4/EC4071/SD104/Main cab1"
					-- 7:4-105 HFP-11 "E/L4/EC4071/SD105/Main cab2"
					-- 7:4-106 HFP-11 "E/L4/EC4071/SD106/Accounts cab"
					-- 7:4-107 HTRI-R "E/L4/EC4071/CM107/AFC Entry dr P"
					-- Switch ""
					-- Relay
					-- 7:4-108 HMS-S/D/M/SA "E/L4/EC4071/MCP108/Entry dr Psg"
					-- 7:4-109 HFP-11 "E/L4/EC4020/SD109/Reception"
					-- 7:4-110 HFP-11 "E/L4/EC4020/SD110/Assorter cab"
					-- 7:4-111 HFP-11 "E/L4/EC4020/SD111/Main cab"
					-- 7:4-112 HFP-11 "E/L4/EC4020/SD112/Main cab"
					-- 7:4-113 HFP-11 "E/L4/EC4020/SD113/Buyers cab1"
					-- 7:4-114 HFP-11 "E/L4/EC4020/SD114/Accounts cab"
					-- 7:4-115 HFPT-11 "E/L4/EC4020/HD115/Pantry"
					-- 7:4-116 HFP-11 "E/L4/EC4020/SD116/Buyers cab2"
					-- 7:4-117 HFP-11 "E/L4/EC4020/SD117/Psg nr Buyers "
					-- 7:4-118 HFP-11 "E/L4/EC4020/SD118/Entry Psg"
					-- 7:4-119 HTRI-R "E/L4/EC4020/CM119/Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:4-120 HMS-S/D/M/SA "E/L4/EC4020/MCP120/Accounts cab"
					-- 7:4-121 HFP-11 "E/L4/EC4091/SD121/Main cab 1"
					-- 7:4-122 HFP-11 "E/L4/EC4091/SD122/Main cab 2"
					-- 7:4-123 HFP-11 "E/L4/EC4091/SD123/Main cab 3"
					-- 7:4-124 HFP-11 "E/L4/EC4091/SD124/Accounts cab"
					-- 7:4-125 HFP-11 "E/L4/EC4091/SD125/Assorter cab"
					-- 7:4-126 HFP-11 "E/L4/EC4091/SD126/Psg nr Assort."
					-- 7:4-127 HFP-11 "E/L4/EC4091/SD127/Psg nr Main ca"
					-- 7:4-128 HFP-11 "E/L4/EC4091/SD128/Accounts cab"
					-- 7:4-129 HFP-11 "E/L4/EC4091/SD129/Pantry"
					-- 7:4-130 HFP-11 "E/L4/EC4091/SD130/Entry psg"
					-- 7:4-131 HTRI-R "E/L4/EC4091/CM131/Entry psg"
					-- Switch ""
					-- Relay
					-- 7:4-132 HMS-S/D/M/SA "E/L4/EC4091/MCP132/Entry psg"
					-- 7:4-133 HFP-11 "E/L4/EC4071/SD133/ENTRY PSG"
					-- 7:4-134 HFP-11 "E/L4/EC4071/SD134/MAIN CABIN 2"
					-- 7:4-135 HTRI-S "E/L4/4F/MM135/EE4015"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:4 XDLC "DLC @ address 4 L4"

					-- 7:4-61	FDOT421	"E/L4/EC4011/SD61/Main Cab"
					-- 7:4-62	FDOT421	"E/L4/EC4011/SD62/Account Cab"
					-- 7:4-63	FDOT421	"E/L4/EC4011/SD63/PsgNrAccntCab"
					-- 7:4-64	FDOT421	"E/L4/EC4011/SD64/Pantry"
					-- 7:4-65	HTRI-R	"E/L4/EC4011/CM65/Entry Door"
					--	Switch	" "
					--	Relay	
					-- 7:4-66	HMS-S/D/M/SA	"E/L4/EC4011/MCP66/Entry Door"
					-- 7:5	XDLC	"DLC @ address 5 L5"
					-- 7:5-1	HFP-11	"E/L5/WC/4F/SD1/CORR NR 4130"
					-- 7:5-2	HFP-11	"E/L5/WC/4F/SD2/CORR NR 4150"
					-- 7:5-3	HFP-11	"E/L5/WC/4F/SD3/CORR NR 4150"
					-- 7:5-4	HFP-11	"E/L5/WC/4F/SD4/CORR NR 4170"
					-- 7:5-5	HFP-11	"E/L5/WC/4F/SD5/CORR NR 4190"
					-- 7:5-6	HFP-11	"E/L5/WC/4F/SD6/CORR NR 4190"
					-- 7:5-7	HFP-11	"E/L5/WC/4F/SD7/CORR NR 4220"
					-- 7:5-8	HTRI-R	"E/L5/WC/4F/CM8/DR RELESE 5 TO 4 "
					--	Switch	" "
					--	Relay	
					-- 7:5-9	HMS-S/D/M/SA	"E/L5/WC/4F/MCP9/FIRE SHAFT L.L."
					-- 7:5-10	HTRI-R	"E/L5/WC/4F/CM10/FIRE SHAFT L.L."
					--	Switch	" "
					--	Relay	
					-- 7:5-11	HTRI-S	"E/L5/WC/4F/MM11/FIRE SHAFT L.L."
					-- 7:5-12	HFP-11	"E/L5/WC/4F/SD12/LIFT LOBBY SD"
					-- 7:5-13	HFP-11	"E/L5/WC/4F/SD13/LIFT LOBBY SD"
					-- 7:5-14	HFP-11	"E/L5/WC/4F/SD14/ELECT RM SD"
					-- 7:5-15	HTRI-R	"E/L5/WC/4F/CM15/DR RELESE 5 TO 6"
					--	Switch	" "
					--	Relay	
					-- 7:5-16	HFP-11	"E/L5/WC/4F/SD16/CORR NR 4010"
					-- 7:5-17	HFP-11	"E/L5/WC/4F/SD17/CORR NR 4020"
					-- 7:5-18	HFP-11	"E/L5/WC/4F/SD18/CORR NR 4050"
					-- 7:5-19	HFP-11	"E/L5/WC/4F/SD19/CORR NR 4060"
					-- 7:5-20	HFP-11	"E/L5/WC/4F/SD20/CORR NR 4080"
					-- 7:5-21	HFP-11	"E/L5/WC/3F/SD21/CORR NR EW S/11"
					-- 7:5-22	HFP-11	"E/L5/WC/3F/SD22/CORR NR EW S/11"
					-- 7:5-23	HFP-11	"E/L5/WC/3F/SD23/CORR NR DW 3240"
					-- 7:5-24	HFP-11	"E/L5/WC/3F/SD24/CORR NR 3260"
					-- 7:5-25	HFP-11	"E/L5/WC/3F/SD25/CORR NR 3270"
					-- 7:5-26	HFP-11	"E/L5/WC/3F/SD26/CORR NR EW3/S13"
					-- 7:5-27	HFP-11	"E/L5/WC/3F/SD27/CORR NR 3301"
					-- 7:5-28	HFP-11	"E/L5/WC/3F/SD28/CORR NR DR"
					-- 7:5-29	HTRI-R	"E/L5/WC/3F/CM29/DR RELESE CM"
					--	Switch	" "
					--	Relay	
					-- 7:5-30	HMS-S/D/M/SA	"E/L5/WC/3F/MCP30/FIRE SHAFT L.L."
					-- 7:5-31	HTRI-R	"E/L5/WC/3F/CM31/FIRE SHAFT L.L."
					--	Switch	" "
					--	Relay	

7 Desigo Fire Safety Modular "BDB TOWER E" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
7:5 XDLC "DLC @ address 5 L5"

			-- 7:5-32 HTRI-S "E/L5/WC/3F/MM32/FIRE SHAFT L.L."
			-- 7:5-33 HFP-11 "E/L5/WC/3F/SD33/LIFT LOBBY SD"
			-- 7:5-34 HFP-11 "E/L5/WC/3F/SD34/LIFT LOBBY SD"
			-- 7:5-35 HFP-11 "E/L5/WC/3F/SD35/ELECT RM SD"
			-- 7:5-36 HTRI-R "E/L5/WC/3F/CM36/DR RELEASE CM"
			-- Switch ""
			-- Relay
			-- 7:5-37 HFP-11 "E/L5/WC/3F/SD37/CORR NR "
			-- 7:5-38 HFP-11 "E/L5/WC/3F/SD38/CORR NR 3020"
			-- 7:5-39 HFP-11 "E/L5/WC/3F/SD39/CORR NR 3051"
			-- 7:5-40 HFP-11 "E/L5/WC/3F/SD40/CORR NR 3052"
			-- 7:5-41 HFP-11 "E/L5/WC/3F/SD41/CORR NR EW S/17"
			-- 7:5-42 HTRI-R "E/L5/WC/4F/CM42/FIRE SHAFT "
			-- Switch ""
			-- Relay
			-- 7:5-43 HMS-S/D/M/SA "E/L5/WC/4F/MCP43/FIRE STR"
			-- 7:5-44 HTRI-R "E/L5/WC/4F/CM44/AHU ROOM"
			-- Switch ""
			-- Relay
			-- 7:5-45 HFP-11 "E/L5/WC/4F/SD45/AHU ROOM "
			-- 7:5-46 HTRI-R "E/L5/WC/3F/CM46/FIRE STR."
			-- Switch ""
			-- Relay
			-- 7:5-47 HMS-S/D/M/SA "E/L5/WC/3F/MCP47/FIRE STR"
			-- 7:5-48 HTRI-R "E/L5/WC/3F/CM48/AHU ROOM"
			-- Switch ""
			-- Relay
			-- 7:5-49 HFP-11 "E/L5/WC/3F/SD49/AHU ROOM"
			-- 7:5-50 HTRI-S "E/L5/4F/MM50/EW4080"
			-- 7:5-52 HTRI-S "E/L5/4F/MM52/EW4070"
			-- 7:5-53 HTRI-S "E/L5/4F/MM53/EW4060"
			-- 7:5-54 HTRI-S "E/L5/4F/MM54/EW4180"
			-- 7:5-55 HTRI-S "E/L5/4F/MM55/EW4050"
			-- 7:5-57 HTRI-S "E/W/4F/MM57/EW4010"
			-- 7:5-58 HTRI-S "E/L5/4F/MM58/EW4020"
			-- 7:5-59 HFP-11 "E/L5/DW4210/SD59/Account Cab"
			-- 7:5-60 HFP-11 "E/L5/DW4210/SD60/Assortor Cab"
			-- 7:5-61 HFP-11 "E/L5/DW4210/SD61/Main Cab 1"
			-- 7:5-62 HFP-11 "E/L5/DW4210/SD62/Store RM"
			-- 7:5-63 HFP-11 "E/L5/DW4210/SD63/Main Cab2"
			-- 7:5-64 HTRI-S "E/L5/4F/MM64/DW4170"
			-- 7:5-65 HFP-11 "E/L5/DW4210/SD65/PSG NR Pantry"
			-- 7:5-66 HFP-11 "E/L5/DW4210/SD66/Pantry"
			-- 7:5-67 HTRI-S "E/L5/4F/MM67/DW4150"
			-- 7:5-68 HTRI-S "E/L5/4F/MM68/DW4240"
			-- 7:5-69 HTRI-S "E/L5/4F/MM69/DW4140"
			-- 7:5-70 HTRI-R "E/L5/DW4210/CM70/Entry Psg"
			-- Switch ""
			-- Relay
			-- 7:5-71 HTRI-S "E/L5/4F/MM71/DW4250"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

```
| | | |-- 7:5-72 HTRI-S "E/L5/4F/MM72/DW4120"
| | | |-- 7:5-73 HMS-S/D/M/SA "E/L5/DW4210/MCP73/Entry Psg"
| | | |-- 7:5-74 HTRI-S "E/L5/3F/MM74/DW3330"
| | | |-- 7:5-75 HTRI-S "E/L5/3F/MM75/DW3220"
| | | |-- 7:5-76 HFP-11 "E/L5/EW3060/SD76/Assoter cabin"
| | | |-- 7:5-77 HFP-11 "E/L5/EW3060/SD77/Assoter cabin"
| | | |-- 7:5-78 HTRI-S "E/L5/3F/MM78/DW3320"
| | | |-- 7:5-79 HTRI-S "E/L5/3F/MM79/DW3250"
| | | |-- 7:5-80 HFP-11 "E/L5/EW3060/SD80/Account cabin"
| | | |-- 7:5-81 HTRI-S "E/L5/3F/MM81/DW3260"
| | | |-- 7:5-82 HFP-11 "E/L5/EW3060/SD82/main cabin"
| | | |-- 7:5-83 HFP-11 "E/L5/EW3060/SD83/Assoter cabin"
| | | |-- 7:5-84 HFP-11 "E/L5/EW3060/SD84/pantry"
| | | |-- 7:5-85 HTRI-R "E/L5/EW3060/CM85/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-86 HTRI-S "E/L5/3F/MM86/DW3290"
| | | |-- 7:5-87 HMS-S/D/M/SA "E/L5/EW3060/MCP87/Entry dr Psg"
| | | |-- 7:5-90 HTRI-S "E/L5/3F/MM90/EW3040"
| | | |-- 7:5-91 HTRI-S "E/L5/W/3F/MM91/EW3051/52"
| | | |-- 7:5-92 HTRI-S "E/L5/3F/MM92/EW3170"
| | | |-- 7:5-94 HMS-S/D/M/SA "E/L5/DW3270/MCP94/Psg nr Entry"
| | | |-- 7:5-95 HFP-11 "E/L5/DW4160/SD95/Main cab"
| | | |-- 7:5-96 HFP-11 "E/L5/DW4160/SD96/Assorter cab"
| | | |-- 7:5-97 HFP-11 "E/L5/DW4160/SD97/Accounts cab"
| | | |-- 7:5-98 HFP-11 "E/L5/DW4160/SD98/Psg nr MC"
| | | |-- 7:5-99 HFP-11 "E/L5/DW4160/SD99/Pantry"
| | | |-- 7:5-100 HTRI-R "E/L5/DW4160/CM100/AFC Entry Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-101 HMS-S/D/M/SA "E/L5/DW4160/MCP101/Entry Psg"
| | | |-- 7:5-102 HFP-11 "E/L5/DW4130/SD102/Assorter cab"
| | | |-- 7:5-103 HFP-11 "E/L5/DW4130/SD103/Main Cab"
| | | |-- 7:5-104 HFP-11 "E/L5/DW4130/SD104/Account cab"
| | | |-- 7:5-105 HFPT-11 "E/L5/DW4130/HD105/Pantry"
| | | |-- 7:5-106 HTRI-R "E/L5/DW4130/CM106/Psg nr Entry d"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-107 HMS-S/D/M/SA "E/L5/DW4130/MCP107/Psg nr Entry "
| | | |-- 7:5-108 HFP-11 "E/L5/DW4230/SD108/Main cab"
| | | |-- 7:5-109 HFP-11 "E/L5/DW4230/SD109/Main cab"
| | | |-- 7:5-110 HFPT-11 "E/L5/DW4230/HD110/Pantry"
| | | |-- 7:5-111 HTRI-R "E/L5/DW4230/CM111/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-112 HMS-S/D/M/SA "E/L5/DW4230/MCP112/Psg nr Entry"
| | | |-- 7:5-113 HFPT-11 "E/L5/DW4180/HD113/Pantry"
| | | |-- 7:5-114 HFP-11 "E/L5/DW4180/SD114/Accounts cab"
| | | |-- 7:5-115 HFP-11 "E/L5/DW4180/SD115/Assorter cab"
| | | |-- 7:5-116 HFP-11 "E/L5/DW4180/SD116/Main cab"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

```
| | | |-- 7:5-117 HFP-11 "E/L5/DW4180/SD117/Psg nr Account"
| | | |-- 7:5-118 HTRI-R "E/L5/DW4180/CM118/Psg nr Entry d"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-119 HMS-S/D/M/SA "E/L5/DW4180/MCP119/Psg nr Entry "
| | | |-- 7:5-120 HFP-11 "E/L5/DW4190/SD120/Main cab"
| | | |-- 7:5-121 HFP-11 "E/L5/DW4190/SD121/Assorter cab"
| | | |-- 7:5-122 HFP-11 "E/L5/DW4190/SD122/Account cab"
| | | |-- 7:5-123 HFP-11 "E/L5/DW4190/SD123/Psg nr Entry"
| | | |-- 7:5-124 HFP-11 "E/L5/DW4190/SD124/Pantry"
| | | |-- 7:5-125 HTRI-R "E/L5/DW4190/CM125/Psg nr Entry d"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-126 HMS-S/D/M/SA "E/L5/DW4190/MCP126/Psg nr Entry "
| | | |-- 7:5-127 HFPT-11 "E/L5/DW4220/HD127/Pantry"
| | | |-- 7:5-128 HFP-11 "E/L5/DW4220/SD128/Psg nr Pantry"
| | | |-- 7:5-129 HFP-11 "E/L5/DW4220/SD129/Accounts cab"
| | | |-- 7:5-130 HFP-11 "E/L5/DW4220/SD130/Psg nr buyer c"
| | | |-- 7:5-131 HFP-11 "E/L5/DW4220/SD131/Buyer cab 1"
| | | |-- 7:5-132 HFP-11 "E/L5/DW4220/SD132/Buyer cab 2"
| | | |-- 7:5-133 HFP-11 "E/L5/DW4220/SD133/Sales Cab"
| | | |-- 7:5-134 HFP-11 "E/L5/DW4220/SD134/Main cab"
| | | |-- 7:5-135 HFP-11 "E/L5/DW4220/SD135/GIA Cab"
| | | |-- 7:5-136 HFP-11 "E/L5/DW4220/SD136/Buyer Cab 3"
| | | |-- 7:5-137 HFP-11 "E/L5/DW4220/SD137/Buyer Cab 3"
| | | |-- 7:5-138 HFP-11 "E/L5/DW4220/SD138/Reception"
| | | |-- 7:5-139 HTRI-R "E/L5/DW4220/CM139/AFC Entry Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-140 HMS-S/D/M/SA "E/L5/DW4220/MCP140/Psg nr Entry"
| | | |-- 7:5-142 HFP-11 "E/L5/EW4030/SD142/Main cab"
| | | |-- 7:5-143 HFP-11 "E/L5/EW4030/SD143/Assorter cab"
| | | |-- 7:5-144 HFP-11 "E/L5/EW4030/SD144/Psg nr Assorte"
| | | |-- 7:5-145 HFPT-11 "E/L5/EW4030/HD145/Pantry"
| | | |-- 7:5-146 HTRI-R "E/L5/EW4030/CM146/Entry dr PSg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-147 HMS-S/D/M/SA "E/L5/EW4030/MCP147/Entry dr PSg"
| | | |-- 7:5-148 HFP-11 "E/L5/EW3020/SD148/Main cab"
| | | |-- 7:5-149 HFP-11 "E/L5/EW3020/SD149/Account cab"
| | | |-- 7:5-150 HFP-11 "E/L5/EW3020/SD150/Assorter cab"
| | | |-- 7:5-151 HFP-11 "E/L5/EW3020/SD151/Pantry"
| | | |-- 7:5-152 HTRI-R "E/L5/EW3020/CM152/Entry dr PSg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-153 HMS-S/D/M/SA "E/L5/EW3020/MCP153/Entry dr PSg"
| | | |-- 7:5-154 HFP-11 "E/L5/EW3160/SD154/Main cab"
| | | |-- 7:5-155 HFP-11 "E/L5/EW3160/SD155/Account cab"
| | | |-- 7:5-156 HFP-11 "E/L5/EW3160/SD156/Assorter cab"
| | | |-- 7:5-157 HFPT-11 "E/L5/EW3160/HD157/Entry dr PSg"
```


7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

```
| | | |-- 7:5-158 HTRI-R "E/L5/EW3160/CM158/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-159 HMS-S/D/M/SA "E/L5/EW3160/MCP159/Entry dr Psg"
| | | |-- 7:5-160 HFP-11 "E/L5/EW4040/SD160/Main cab"
| | | |-- 7:5-161 HFP-11 "E/L5/EW4040/SD161/Account cab"
| | | |-- 7:5-162 HFP-11 "E/L5/EW4040/SD162/Psg nr Cab2"
| | | |-- 7:5-163 HFP-11 "E/L5/EW4040/SD163/Cab 2"
| | | |-- 7:5-164 HFP-11 "E/L5/EW4040/SD164/Pantry"
| | | |-- 7:5-165 HTRI-R "E/L5/EW4040/CM165/Entry psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-166 HMS-S/D/M/SA "E/L5/EW4040/MCP166/Entry psg"
| | | |-- 7:5-168 HFP-11 "E/L5/DW3210/SD168/Pantry "
| | | |-- 7:5-169 HFP-11 "E/L5/DW3210/SD169/Accounts cab"
| | | |-- 7:5-170 HFP-11 "E/L5/DW3210/SD170/Assorter cab"
| | | |-- 7:5-171 HFP-11 "E/L5/DW3210/SD171/Main cab"
| | | |-- 7:5-172 HFP-11 "E/L5/DW3210/SD172/Psg nr Account"
| | | |-- 7:5-173 HTRI-R "E/L5/DW3210/CM173/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-174 HMS-S/D/M/SA "E/L5/DW3210/MCP174/Psg nr Entry"
| | | |-- 7:5-175 HFP-11 "E/L5/DW3230/SD175/Pantry "
| | | |-- 7:5-176 HFP-11 "E/L5/DW3230/SD176/Psg nr Account"
| | | |-- 7:5-177 HFP-11 "E/L5/DW3230/SD177/Accounts cab"
| | | |-- 7:5-178 HFP-11 "E/L5/DW3230/SD178/Assorter cab"
| | | |-- 7:5-179 HFP-11 "E/L5/DW3230/SD179/Executive cab"
| | | |-- 7:5-180 HTRI-R "E/L5/DW3230/CM180/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-181 HMS-S/D/M/SA "E/L5/DW3230/MCP181/Psg nr Entry"
| | | |-- 7:5-182 HFP-11 "E/L5/DW3240/SD182/Pantry "
| | | |-- 7:5-183 HFP-11 "E/L5/DW3240/SD183/Cab 1"
| | | |-- 7:5-184 HFP-11 "E/L5/DW3240/SD184/Cab 2"
| | | |-- 7:5-185 HFP-11 "E/L5/DW3240/SD185/Main cab"
| | | |-- 7:5-186 HFP-11 "E/L5/DW3240/SD186/Psg nr Cab 2"
| | | |-- 7:5-188 HTRI-R "E/L5/DW3240/CM188/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-189 HMS-S/D/M/SA "E/L5/DW3240/MCP189/Psg nr Entry"
| | | |-- 7:5-190 HFP-11 "E/L5/DW3310/SD190/Pantry "
| | | |-- 7:5-191 HFP-11 "E/L5/DW3310/SD191/Main cab"
| | | |-- 7:5-192 HTRI-R "E/L5/DW3310/CM192/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-193 HMS-S/D/M/SA "E/L5/DW3310/MCP193/Psg nr Entry"
| | | |-- 7:5-194 HFP-11 "E/L5/DW3270/SD194/Main cab"
| | | |-- 7:5-195 HFP-11 "E/L5/DW3270/SD195/Assorter cab"
| | | |-- 7:5-196 HFP-11 "E/L5/DW3270/SD196/Entry Psg "
| | | |-- 7:5-197 HFP-11 "E/L5/DW3270/SD197/Account cab"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

```
| | | |-- 7:5-198 HFP-11 "E/L5/DW3270/SD198/Pantry"
| | | |-- 7:5-199 HTRI-R "E/L5/DW3270/CM199/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-200 HFP-11 "E/L5/DW3280/SD200/Pantry "
| | | |-- 7:5-201 HFP-11 "E/L5/DW3280/SD201/Entry Psg"
| | | |-- 7:5-202 HFP-11 "E/L5/DW3280/SD202/Accounts cab"
| | | |-- 7:5-203 HFP-11 "E/L5/DW3280/SD203/Main cab"
| | | |-- 7:5-204 HFP-11 "E/L5/DW3280/SD204/Assorter cab"
| | | |-- 7:5-205 HTRI-R "E/L5/DW3280/CM205/Psg nr Assorte"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-206 HMS-S/D/M/SA "E/L5/DW3280/MCP206/Psg nr Assort"
| | | |-- 7:5-207 HFP-11 "E/L5/DW4200/SD207/Reception psg"
| | | |-- 7:5-208 HFP-11 "E/L5/DW4200/SD208/Buyer cab3"
| | | |-- 7:5-209 HFP-11 "E/L5/DW4200/SD209/Buyer cab4"
| | | |-- 7:5-210 HFP-11 "E/L5/DW4200/SD210/Acc cab"
| | | |-- 7:5-211 HFP-11 "E/L5/DW4200/SD211/Acc cab"
| | | |-- 7:5-212 HFP-11 "E/L5/DW4200/SD212/Account cab"
| | | |-- 7:5-213 HFP-11 "E/L5/DW4200/SD213/Marketing cab"
| | | |-- 7:5-214 HFP-11 "E/L5/DW4200/SD214/Kiran Shah cab"
| | | |-- 7:5-215 HFP-11 "E/L5/DW4200/SD215/Stock cab"
| | | |-- 7:5-216 HFP-11 "E/L5/DW4200/SD216/Buyer cab1"
| | | |-- 7:5-217 HFP-11 "E/L5/DW4200/SD217/Psgnr buyerC1"
| | | |-- 7:5-218 HFP-11 "E/L5/DW4200/SD218/Buyer cab2"
| | | |-- 7:5-219 HFP-11 "E/L5/DW4200/SD219/Psgnr buyer C2"
| | | |-- 7:5-220 HFP-11 "E/L5/DW4200/SD220/Pantry"
| | | |-- 7:5-221 HMS-S/D/M/SA "E/L5/DW4200/MCP221/Psg nr Entry"
| | | |-- 7:5-222 HTRI-R "E/L5/DW4200/CM222/Psg nr Entry"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-223 HFP-11 "E/L5/EW3030/SD223/MAIN CAB"
| | | |-- 7:5-224 HFP-11 "E/L5/EW3030/SD224/Cab 1"
| | | |-- 7:5-225 HFP-11 "E/L5/EW3030/SD225/Cab 2"
| | | |-- 7:5-226 HFP-11 "E/L5/EW3030/SD226/account cab"
| | | |-- 7:5-227 HFP-11 "E/L5/EW3030/SD227/assoter cab"
| | | |-- 7:5-228 HFP-11 "E/L5/EW3030/SD/228/pantry"
| | | |-- 7:5-229 HMS-S/D/M/SA "E/L5/EW3030/MCP229/Entry dr Psg"
| | | |-- 7:5-230 HTRI-R "E/L5/EW3030/CM230/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-231 HFP-11 "E/L5/EW4170/SD231/Cab 1"
| | | |-- 7:5-232 HFP-11 "E/L5/EW4170/SD232/Cab 2"
| | | |-- 7:5-233 HFP-11 "E/L5/EW4170/SD233/Cab 3"
| | | |-- 7:5-234 HFP-11 "E/L5/EW4170/SD234/Psg nr Cab 3"
| | | |-- 7:5-235 HFP-11 "E/L5/EW4170/SD235/AFC Entry dr P"
| | | |-- 7:5-236 HTRI-R "E/L5/EW4170/CM236/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-237 HMS-S/D/M/SA "E/L5/EW4170/MCP237/Entry dr Psg"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:5 XDLC "DLC @ address 5 L5"

```
| | | |-- 7:5-238 HFP-11 "E/L5/EW4090/SD238/Main cab"
| | | |-- 7:5-239 HFP-11 "E/L5/EW4090/SD239/Assorter Cab"
| | | |-- 7:5-240 HFP-11 "E/L5/EW4090/SD240/Assorter Cab p"
| | | |-- 7:5-241 HFP-11 "E/L5/EW4090/SD241/Pantry "
| | | |-- 7:5-242 HTRI-R "E/L5/EW4090/CM242/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-243 HMS-S/D/M/SA "E/L5/EW4090/MCP243/Entry dr Psg"
| | | |-- 7:5-244 HFP-11 "E/L5/EW3010/SD244/Main cab"
| | | |-- 7:5-245 HFP-11 "E/L5/EW3010/SD245/account cab"
| | | |-- 7:5-246 HFP-11 "E/L5/EW3010/SD246/Entry Psg"
| | | |-- 7:5-247 HFPT-11 "E/L5/EW3010/HD247/Pantry"
| | | |-- 7:5-248 HTRI-R "E/L5/EW3010/CM248/Entry dr Psg"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- 7:5-249 HMS-S/D/M/SA "E/L5/EW3010/MCP249/Entry dr Psg"
| | | |-- 7:5-250 HFP-11 "E/L5/EW4090/SD250/Pantry"
| | | |-- 7:5-251 HFP-11 "E/L5/DW4130/SD251/Psg. Nr Accoun"
| | |-- CC-5 "Card Cage 5 Slots"
| | | |-- 7:6 XDLC "DLC @ address 6 L6"
| | | | |-- 7:6-1 HTRI-R "E/L6/7F/CM1/EC door release"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-2 HFP-11 "E/L6/7F/SD2/Corr. Nr EC plumbing"
| | | | |-- 7:6-3 HFP-11 "E/L6/7F/SD3/Corr. Nr EC plumbing"
| | | | |-- 7:6-4 HFP-11 "E/L6/7F/SD4/EC Small Corridor"
| | | | |-- 7:6-5 HFP-11 "E/L6/7F/SD5/EC Small Corridor"
| | | | |-- 7:6-6 HFP-11 "E/L6/7F/SD6/Corr. Nr EC7050"
| | | | |-- 7:6-7 HFP-11 "E/L6/7F/SD7/Corr. Nr EC7060"
| | | | |-- 7:6-8 HFP-11 "E/L6/7F/SD8/Corr. Nr EC7060"
| | | | |-- 7:6-9 HMS-S/D/M/SA "E/L6/7F/MCP9/EC Fire Esacpe dr"
| | | | |-- 7:6-10 HTRI-R "E/L6/7F/CM10/EC Fire Esacpe str"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-11 HFP-11 "E/L6/7F/SD11/Corr. Nr EC7031"
| | | | |-- 7:6-12 HFP-11 "E/L6/7F/SD12/Corr. Nr EC7020"
| | | | |-- 7:6-13 HFP-11 "E/L6/7F/SD13/Corr. Nr EC7020"
| | | | |-- 7:6-14 HFP-11 "L6/E/7F/SD14/CORR NR EC 7081"
| | | | |-- 7:6-15 HFP-11 "L6/E/7F/SD15/CORR NR EC 7081"
| | | | |-- 7:6-16 HFP-11 "E/L6/7F/SD16/EC Electric rm"
| | | | |-- 7:6-17 HFP-11 "E/L6/7F/SD17/EC Lift Lobby"
| | | | |-- 7:6-18 HFP-11 "E/L6/7F/SD18/EC Lift Lobby"
| | | | |-- 7:6-19 HMS-S/D/M/SA "E/L6/7F/MCP19/EC Lift Lobby"
| | | | |-- 7:6-20 HTRI-R "E/L6/7F/CM20/EC Fire shaft dr"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-21 HTRI-S "E/L6/7F/MM21/EC Fire shaft dr"
| | | | |-- 7:6-22 HFP-11 "E/L6/7F/SD22/EC AHU Rm"
| | | | |-- 7:6-23 HTRI-R "E/L6/7F/CM23/EC AHU Rm"
| | | | | |-- Switch ""
```

```
7 Desigo Fire Safety Modular "BDB TOWER E" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      7:6 XDLC "DLC @ address 6 L6"
        7:6-23 HTRI-R "E/L6/7F/CM23/EC AHU Rm"
```

```
| | | | | |-- Relay
| | | | |-- 7:6-26 HFP-11 "E/L6/7F/SD26/EE Electric Rm"
| | | | |-- 7:6-27 HFP-11 "E/L6/7F/SD27/EE AHU Rm"
| | | | |-- 7:6-28 HTRI-R "E/L6/7F/CM28/EE AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-29 HMS-S/D/M/SA "E/L6/7F/MCP29/EE Fire shaft Lift"
| | | | |-- 7:6-30 HTRI-R "E/L6/7F/CM30/EE Fire shaft Lift "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-31 HTRI-S "E/L6/7F/MM31/EE Fire shaft Lift "
| | | | |-- 7:6-32 HFP-11 "E/L6/7F/SD32/EE Lift Lobby"
| | | | |-- 7:6-33 HTRI-R "E/L6/6F/CM33/EE Fire Shaft"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-34 HTRI-S "E/L6/6F/MM34/EE Fire Shaft"
| | | | |-- 7:6-35 HMS-S/D/M/SA "E/L6/6F/MCP35/EE Fire Shaft"
| | | | |-- 7:6-36 HFP-11 "E/L6/6F/SD36/EE Lift Lobby"
| | | | |-- 7:6-37 HTRI-R "E/L6/6F/CM37/EE AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-38 HFP-11 "E/L6/6F/SD38/EE AHU Rm"
| | | | |-- 7:6-39 HFP-11 "E/L6/6F/SD39/EE Electric Rm"
| | | | |-- 7:6-40 HTRI-R "E/L6/6F/CM40/Near EW Electric rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-41 HFP-11 "E/L6/6F/SD41/Near EW Electric rm"
| | | | |-- 7:6-42 HFP-11 "E/L6/6F/SD42/Near EC Electric rm"
| | | | |-- 7:6-43 HFP-11 "E/L6/6F/SD43/Corr Nr EC6040"
| | | | |-- 7:6-44 HFP-11 "E/L6/6F/SD44/Corr Nr EC6032"
| | | | |-- 7:6-45 HTRI-R "E/L6/6F/CM45/EC Fire shaft"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-46 HMS-S/D/M/SA "E/L6/6F/MCP46/EC Fire shaft"
| | | | |-- 7:6-47 HFP-11 "E/L6/6F/SD47/EC Fire shaft"
| | | | |-- 7:6-48 HFP-11 "E/L6/6F/SD48/Corr Nr EC6060"
| | | | |-- 7:6-49 HFP-11 "E/L6/6F/SD49/Corr Nr EC6070"
| | | | |-- 7:6-50 HFP-11 "E/L6/6F/SD50/Corr Nr EC6070"
| | | | |-- 7:6-51 HFP-11 "E/L6/6F/SD51/Corr Nr EC6090"
| | | | |-- 7:6-52 HFP-11 "E/L6/6F/SD52/Corr Nr EC6010"
| | | | |-- 7:6-53 HFP-11 "E/L6/6F/SD53/EC Electric rm"
| | | | |-- 7:6-54 HTRI-R "E/L6/6F/CM54/EC Fire escape dr"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-55 HTRI-R "E/L6/6F/CM55/EC Fire shaft Lift "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:6-56 HTRI-S "E/L6/6F/MM56/EC Fire shaft Lift "
| | | | |-- 7:6-57 HMS-S/D/M/SA "E/L6/6F/MCP57/EC Fire shaft Lift"
| | | | |-- 7:6-58 HFP-11 "E/L6/6F/SD58/EC Lift lobby"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:6 XDLC "DLC @ address 6 L6"

					-- 7:6-59 HFP-11 "E/L6/6F/SD59/EC Lift lobby"
					-- 7:6-60 HTRI-R "E/L6/6F/CM60/EC AHU RM"
					-- Switch ""
					-- Relay
					-- 7:6-61 HFP-11 "E/L6/6F/SD61/EC AHU RM"
					-- 7:6-62 HFP-11 "E/L6/6F/SD62/Corr nr EC6130"
					-- 7:6-63 HFP-11 "E/L6/6F/SD63/Corr nr EC6100"
					-- 7:6-64 HTRI-R "E/L6/6F/CM64/EC Fire Escape dr"
					-- Switch ""
					-- Relay
					-- 7:6-68 HTRI-R "E/L6/7F/CM68/nr EC door release"
					-- Switch ""
					-- Relay
					-- 7:6-69 HTRI-S "E/L6/C/7F/MM69/EC7091"
					-- 7:6-81 HTRI-S "E/L6/7F/MM81/EC7092"
					-- 7:6-82 HTRI-S "E/L6/7F/MM82/EC7082"
					-- 7:6-83 HTRI-S "E/L6/7F/MM83/EC7081"
					-- 7:6-84 HTRI-S "E/L6/7F/MM84/EC7010"
					-- 7:6-85 HTRI-S "E/L6/7F/MM85/EC7020"
					-- 7:6-87 HTRI-S "E/L6/7F/MM87/EC7032"
					-- 7:6-88 HTRI-S "E/L6/7F/MM88/EC7070"
					-- 7:6-89 HTRI-S "E/L6/7F/MM89/EC7060"
					-- 7:6-90 HTRI-S "E/L6/7F/MM90/EC7050"
					-- 7:6-91 HTRI-S "E/L6/7F/MM91/EC7041"
					-- 7:6-92 HTRI-S "E/L6/6F/MM92/EC6040"
					-- 7:6-95 HTRI-S "E/L6/6F/MM95/EC6031"
					-- 7:6-96 HTRI-S "E/L6/6F/MM96/EC6060"
					-- 7:6-98 HTRI-S "E/L6/6F/MM98/EC6070"
					-- 7:6-100 HTRI-S "E/L6/6F/MM100/EC6010"
					-- 7:6-101 HTRI-S "E/L6/6F/MM101/EC6090"
					-- 7:6-102 HTRI-S "E/L6/6F/MM102/EC6130"
					-- 7:6-103 HTRI-S "E/L6/6F/MM103/EC6100"
					-- 7:6-105 HTRI-S "E/L6/7F/MM105/EE7010"
					-- 7:6-106 HFP-11 "E/L6/EC6080/SD106/Main cab"
					-- 7:6-107 HFP-11 "E/L6/EC6080/SD107/Assorter cab"
					-- 7:6-108 HFP-11 "E/L6/EC6080/SD108/Account cab"
					-- 7:6-109 HFP-11 "E/L6/EC6080/SD109/Account cab"
					-- 7:6-110 HFP-11 "E/L6/EC6080/SD110/Psg nr Account"
					-- 7:6-111 HFPT-11 "E/L6/EC6080/HD111/Psg nr Account"
					-- 7:6-112 HFP-11 "E/L6/EC6080/SD112/Entry dr Psg"
					-- 7:6-113 HTRI-R "E/L6/EC6080/CM113/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:6-114 HMS-S/D/M/SA "E/L6/EC6080/MCP114/Entry dr Psg"
					-- 7:6-115 HFP-11 "E/L6/EC6032/SD115/Assorter cab"
					-- 7:6-116 HFP-11 "E/L6/EC6032/SD116/Psg nr Assorte"
					-- 7:6-117 HFP-11 "E/L6/EC6032/SD117/Jewellery cab"
					-- 7:6-118 HFP-11 "E/L6/EC6032/SD118/Buyer cab"
					-- 7:6-119 HFP-11 "E/L6/EC6032/SD119/Lunch cab"
					-- 7:6-120 HFP-11 "E/L6/EC6032/SD120/Accounts cab"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:6 XDLC "DLC @ address 6 L6"

					-- 7:6-121 HFP-11 "E/L6/EC6032/SD121/Psg nr pantry"
					-- 7:6-122 HFP-11 "E/L6/EC6032/SD122/Reception"
					-- 7:6-123 HFP-11 "E/L6/EC6032/SD123/Entry psg"
					-- 7:6-124 HFP-11 "E/L6/EC6032/HD124/Pantry"
					-- 7:6-125 HFP-11 "E/L6/EC6032/SD125/Main cab 1"
					-- 7:6-126 HFP-11 "E/L6/EC6032/SD126/Main cab 2"
					-- 7:6-127 HFP-11 "E/L6/EC6032/SD127/Main cab 3"
					-- 7:6-128 HTRI-R "E/L6/EC6032/CM128/AFC Entry Psg"
					-- Switch ""
					-- Relay
					-- 7:6-129 HMS-S/D/M/SA "E/L6/EC6032/MCP129/Entry Psg"
					-- 7:8 XDLC "DLC @ address 8 L8"
					-- 7:8-9 HFP-11 "E/L8/9F/SD9/EC Electricct rm"
					-- 7:8-10 HFP-11 "E/L8/9F/SD10/EC LiftLobby"
					-- 7:8-11 HFP-11 "E/L8/9F/SD11/EC LiftLobby"
					-- 7:8-12 HMS-S/D/M/SA "E/L8/9F/MCP12/EC LiftLobby"
					-- 7:8-13 HTRI-R "E/L8/9F/CM13/EC Fire Shaft LiftL"
					-- Switch ""
					-- Relay
					-- 7:8-14 HTRI-S "E/L8/9F/MM14/EC Fire Shaft LiftL"
					-- 7:8-15 HFP-11 "E/L8/9F/SD15/EC AHU Rm"
					-- 7:8-16 HTRI-R "E/L8/9F/CM16/EC AHU Rm"
					-- Switch ""
					-- Relay
					-- 7:8-17 HFP-11 "E/L8/9F/SD17/EC corr nr AHU Rm"
					-- 7:8-18 HFP-11 "E/L8/9F/SD18/EC corr nr AHU Rm"
					-- 7:8-19 HTRI-R "E/L8/9F/CM19/nr EC Dr release"
					-- Switch ""
					-- Relay
					-- 7:8-23 HFP-11 "E/L8/9F/SD23/EE Corr nr S0/2"
					-- 7:8-24 HFP-11 "E/L8/9F/SD24/EE Corr nr S0/2"
					-- 7:8-25 HFP-11 "E/L8/9F/SD25/EE Electric Rm"
					-- 7:8-26 HFP-11 "E/L8/9F/SD26/EE AHU Rm"
					-- 7:8-27 HTRI-R "E/L8/9F/CM27/EE AHU Rm"
					-- Switch ""
					-- Relay
					-- 7:8-28 HFP-11 "E/L8/9F/SD28/EE LiftLobby"
					-- 7:8-29 HMS-S/D/M/SA "E/L8/9F/MCP29/EE Fire Shaft Lift"
					-- 7:8-30 HTRI-R "E/L8/9F/CM30/EE Fire Shaft LiftL"
					-- Switch ""
					-- Relay
					-- 7:8-31 HTRI-S "E/L8/9F/MM31/EE Fire Shaft LiftL"
					-- 7:8-40 HFP-11 "E/L8/8F/SD40/EC Electric RM"
					-- 7:8-41 HFP-11 "E/L8/8F/SD41/EC LiftLobby"
					-- 7:8-42 HFP-11 "E/L8/8F/SD42/EC LiftLobby"
					-- 7:8-43 HMS-S/D/M/SA "E/L8/8F/MCP43/EC Fire shaft Lift"
					-- 7:8-44 HTRI-R "E/L8/8F/CM44/EC Fire shaft LiftL"
					-- Switch ""
					-- Relay
					-- 7:8-45 HTRI-S "E/L8/8F/MM45/EC Fire shaft LiftL"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:8 XDLC "DLC @ address 8 L8"

					-- 7:8-46 HFP-11 "E/L8/8F/SD46/EC AHU Rm"
					-- 7:8-47 HTRI-R "E/L8/8F/CM47/EC AHU Rm"
					-- Switch ""
					-- Relay
					-- 7:8-48 HTRI-R "E/L8/8F/CM48/EC Nr AHU Rm"
					-- Switch ""
					-- Relay
					-- 7:8-49 HFP-11 "E/L8/8F/SD49/Corr nr EE8070"
					-- 7:8-50 HFP-11 "E/L8/8F/SD50/Corr nr EE8090"
					-- 7:8-51 HFP-11 "E/L8/8F/SD51/Corr nr EE8060"
					-- 7:8-52 HFP-11 "E/L8/8F/SD52/Corr nr EE8040"
					-- 7:8-53 HFP-11 "E/L8/8F/SD53/Corr nr EE8040"
					-- 7:8-54 HMS-S/D/M/SA "E/L8/8F/MCP54/EE Fr Esc dr"
					-- 7:8-55 HTRI-R "E/L8/8F/CM55/EE Fr Esc dr"
					-- Switch ""
					-- Relay
					-- 7:8-56 HFP-11 "E/L8/8F/SD56/Corr nr EE8112"
					-- 7:8-57 HFP-11 "E/L8/8F/SD57/Corr nr EE8114"
					-- 7:8-58 HFP-11 "E/L8/8F/SD58/Corr nr EE8114"
					-- 7:8-59 HFP-11 "E/L8/8F/SD59/EE nr Electric Rm"
					-- 7:8-60 HFP-11 "E/L8/8F/SD60/EE Esc Door"
					-- 7:8-61 HFP-11 "E/L8/8F/SD61/EE Electric Rm"
					-- 7:8-62 HFP-11 "E/L8/8F/SD62/EE AHU Rm"
					-- 7:8-63 HTRI-R "E/L8/8F/CM63/EE AHU Rm"
					-- Switch ""
					-- Relay
					-- 7:8-64 HFP-11 "E/L8/8F/SD64/EE LiftLobby"
					-- 7:8-65 HMS-S/D/M/SA "E/L8/8F/MCP65/EE LiftLobby"
					-- 7:8-66 HTRI-R "E/L8/8F/CM66/EE Fire shaft LiftL"
					-- Switch ""
					-- Relay
					-- 7:8-67 HTRI-S "E/L8/8F/MM67/EE Fire shaft LiftL"
					-- 7:8-69 HFP-11 "E/L8/9F/SD69/EC TERENCE LIFT RM"
					-- 7:8-70 HFP-11 "E/L8/9F/SD70/EC TERENCE LIFT RM"
					-- 7:8-71 HFP-11 "E/L8/9F/SD71/EC TERENCE LIFT RM"
					-- 7:8-72 HFP-11 "E/L8/9F/SD72/EC TERENCE LIFT RM"
					-- 7:8-73 HFP-11 "E/L8/9F/SD73/EC TERENCE LIFT RM"
					-- 7:8-74 HTRI-R "E/L8/9F/CM74/EC TERENCE LIFT RM"
					-- Switch ""
					-- Relay
					-- 7:8-77 HTRI-S "E/L8/9F/MM77/EC9012"
					-- 7:8-79 HTRI-S "E/L8/9F/MM79/EC8010"
					-- 7:8-80 HTRI-S "E/L8/9F/MM80/EE9011"
					-- 7:8-88 HTRI-S "E/L8/8F/MM88/EE8050"
					-- 7:8-90 HTRI-S "E/L8/8F/MM90/EE8100"
					-- 7:8-91 HFP-11 "E/L8/EE8090/SD91/AFC Assorter ca"
					-- 7:8-92 HFP-11 "E/L8/EE8090/SD92/AFC Lunch room"
					-- 7:8-93 HFP-11 "E/L8/EE8090/SD93/AFC Accounts ca"
					-- 7:8-94 HFP-11 "E/L8/EE8090/SD94/AFC Reception c"
					-- 7:8-95 HFP-11 "E/L8/EE8090/SD95/AFC Entry dr Ps"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:8 XDLC "DLC @ address 8 L8"

					-- 7:8-96 HFP-11 "E/L8/EE8090/SD96/AFC Entry Psg"
					-- 7:8-99 HTRI-S "E/L8/8F/MM99/EE8020"
					-- 7:8-101 HFP-11 "E/L8/EE8120/SD101/Main cab"
					-- 7:8-102 HFP-11 "E/L8/EE8120/SD102/Account cab"
					-- 7:8-103 HFP-11 "E/L8/EE8120/SD103/Psg nr Account"
					-- 7:8-104 HFP-11 "E/L8/EE8120/SD104/Pantry"
					-- 7:8-105 HTRI-R "E/L8/EE8120/CM105/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:8-106 HMS-S/D/M/SA "E/L8/EE8120/MCP106/Entry dr Psg"
					-- 7:8-107 HFP-11 "E/L8/EE8111/SD107/Main cab"
					-- 7:8-108 HFP-11 "E/L8/EE8111/SD108/Assorter cab"
					-- 7:8-109 HFP-11 "E/L8/EE8111/SD109/Psg nr Assorte"
					-- 7:8-110 HFP-11 "E/L8/EE8111/SD110/Accounts cab"
					-- 7:8-111 HFP-11 "E/L8/EE8111/SD111/Pantry"
					-- 7:8-112 HTRI-R "E/L8/EE8111/CM112/Entry dr psg"
					-- Switch ""
					-- Relay
					-- 7:8-113 HMS-S/D/M/SA "E/L8/EE8111/MCP113/Entry dr psg"
					-- 7:8-114 HFP-11 "E/L8/EE8112/SD114/Main cab"
					-- 7:8-115 HFP-11 "E/L8/EE8112/SD115/Accounts cab"
					-- 7:8-116 HFP-11 "E/L8/EE8112/SD116/Psg nr Account"
					-- 7:8-117 HFP-11 "E/L8/EE8112/SD117/Assorter cab"
					-- 7:8-118 HFP-11 "E/L8/EE8112/SD118/Pantry Psg"
					-- 7:8-119 HTRI-R "E/L8/EE8112/CM119/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:8-120 HMS-S/D/M/SA "E/L8/EE8112/MCP120/Entry dr Psg"
					-- 7:8-121 HFP-11 "E/L8/EE8080/SD121/Buyer cab"
					-- 7:8-122 HFP-11 "E/L8/EE8080/SD122/Cabin 2"
					-- 7:8-123 HFP-11 "E/L8/EE8080/SD123/Account cab1"
					-- 7:8-124 HFP-11 "E/L8/EE8080/SD124/Main cab"
					-- 7:8-125 HFP-11 "E/L8/EE8080/SD125/Account cab2"
					-- 7:8-126 HFP-11 "E/L8/EE8080/SD126/Psg nr Buyer c"
					-- 7:8-127 HFP-11 "E/L8/EE8080/SD127/Pantry"
					-- 7:8-128 HFP-11 "E/L8/EE8080/SD128/Entry dr Psg"
					-- 7:8-129 HTRI-R "E/L8/EE8080/CM129/Entry dr Psg"
					-- Switch ""
					-- Relay
					-- 7:8-130 HMS-S/D/M/SA "E/L8/EE8080/MCP130/Entry dr Psg"
					-- 7:8-131 HFP-11 "E/L8/EE8070/SD131/Pantry"
					-- 7:8-132 HFP-11 "E/L8/EE8070/SD132/Lunch room"
					-- 7:8-133 HFP-11 "E/L8/EE8070/SD133/Accounts cab"
					-- 7:8-134 HFP-11 "E/L8/EE8070/SD134/Assorter cab"
					-- 7:8-135 HFP-11 "E/L8/EE8070/SD135/Assorter cab"
					-- 7:8-136 HFP-11 "E/L8/EE8070/SD136/Main cab"
					-- 7:8-137 FDOT421 "E/L8/EE8070/SD137/Main cab"
					-- 7:8-138 HFP-11 "E/L8/EE8070/SD138/Entry dr Psg"
					-- 7:8-139 HTRI-R "E/L8/EE8070/CM139/Entry dr Psg"
					-- Switch ""

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:8 XDLC "DLC @ address 8 L8"

7:8-139 HTRI-R "E/L8/EE8070/CM139/Entry dr Psg"

| | | | | | |-- Relay

| | | | | |-- 7:8-140 HMS-S/D/M/SA "E/L8/EE8070/MCP140/Entry dr Psg"

| | | | | |-- 7:8-141 HFP-11 "E/L8/EE8114/SD141/Main cab"

| | | | | |-- 7:8-142 HFP-11 "E/L8/EE8114/SD142/Cab 1"

| | | | | |-- 7:8-143 HFP-11 "E/L8/EE8114/SD143/Cab 2"

| | | | | |-- 7:8-144 HFP-11 "E/L8/EE8114/SD144/Psg nr MC"

| | | | | |-- 7:8-145 HFP-11 "E/L8/EE8114/SD145/Pantry Psg"

| | | | | |-- 7:8-146 HTRI-R "E/L8/EE8114/CM146/AFC Entry dr P"

| | | | | | |-- Switch ""

| | | | | | |-- Relay

| | | | | |-- 7:8-147 HMS-S/D/M/SA "E/L8/EE8114/MCP147/Entry dr Psg"

| | | | | |-- 7:8-148 HFP-11 "E/L8/EE8130/SD148/Assorter cab"

| | | | | |-- 7:8-149 HFP-11 "E/L8/EE8130/SD149/Psg nr MC"

| | | | | |-- 7:8-150 HFP-11 "E/L8/EE8130/SD150/Entry Psg"

| | | | | |-- 7:8-151 HFP-11 "E/L8/EE8130/SD151/Main cab"

| | | | | |-- 7:8-152 HTRI-R "E/L8/EE8130/CM152/Entry Psg"

| | | | | | |-- Switch ""

| | | | | | |-- Relay

| | | | | |-- 7:8-153 HMS-S/D/M/SA "E/L8/EE8130/MCP153/Entry Psg"

| | | | | |-- 7:8-154 HFP-11 "E/L8/EE8113/SD154/Main cab"

| | | | | |-- 7:8-155 HFP-11 "E/L8/EE8113/SD155/Assorter cab"

| | | | | |-- 7:8-156 HFP-11 "E/L8/EE8113/SD156/Account cab"

| | | | | |-- 7:8-157 HFP-11 "E/L8/EE8113/SD157/Psg nr Accout "

| | | | | |-- 7:8-158 HFP-11 "E/L8/EE8113/SD158/Pantry"

| | | | | |-- 7:8-159 HTRI-R "E/L8/EE8113/CM159/Entry Psg"

| | | | | | |-- Switch ""

| | | | | | |-- Relay

| | | | | |-- 7:8-160 HMS-S/D/M/SA "E/L8/EE8113/MCP160/Entry Psg"

| | | | | |-- 7:8-161 HFP-11 "E/L8/EE8090/SD161/Storage cab"

| | | | | |-- 7:8-162 HFP-11 "E/L8/EE8090/SD162/Pantry"

| | | | | |-- 7:8-163 HFP-11 "E/L8/EE8090/SD163/Main cab"

| | | | | |-- 7:8-164 HFP-11 "E/L8/EE8090/SD164/Rajbhai cab"

| | | | | |-- 7:8-165 HFP-11 "E/L8/EE8090/SD165/Assorter cab"

| | | | | |-- 7:8-166 HFP-11 "E/L8/EE8090/SD166/Psg nr Assorte"

| | | | | |-- 7:8-167 HFP-11 "E/L8/EE8090/SD167/Lunch room"

| | | | | |-- 7:8-168 HFP-11 "E/L8/EE8090/SD168/Accounts cab"

| | | | | |-- 7:8-169 HFP-11 "E/L8/EE8090/SD169/Reception cab"

| | | | | |-- 7:8-171 HMS-S/D/M/SA "E/L8/EE8090/MCP171/Entry dr Psg"

| | | | | |-- 7:8-172 HFP-11 "E/L8/EE8090/SD172/AFC storage ro"

| | | | | |-- 7:8-173 HFP-11 "E/L8/EE8090/SD173/AFC Main cab"

| | | | | |-- 7:8-174 HFPT-11 "E/L8/EE8130/HD174/Pantry"

| | | | | |-- 7:8-195 HTRI-S "E/L8/8F/MM195/EE8030"

| | | | | |-- 7:8-196 HTRI-S "E/L8/8F/MM196/EE8010B2"

| | | | | |-- 7:8-238 HTRI-R "E/L8/EE8090/CM238/Entry dr Psg"

| | | | | | |-- Switch ""

| | | | | | |-- Relay

| | | | | |-- 7:8-240 HFP-11 "E/L8/EE8090/SD240/AFC"

| | | | | |-- 7:9 XDLC "DLC @ address 9 L9"

| | | | | |-- 7:9-1 HTRI-R "E/L9/9F/CM1/EW LiftLobby"

| | | | | | |-- Switch ""

```
7 Desigo Fire Safety Modular "BDB TOWER E" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      7:9 XDLC "DLC @ address 9 L9"
        7:9-1 HTRI-R "E/L9/9F/CM1/EW LiftLobby"
```

```
| | | | | |-- Relay
| | | | |-- 7:9-2 HTRI-S "E/L9/9F/MM2/EW LiftLobby"
| | | | |-- 7:9-3 HMS-S/D/M/SA "E/L9/9F/MCP3/EW LiftLobby"
| | | | |-- 7:9-4 HFP-11 "E/L9/9F/SD4/EW AHU Rm"
| | | | |-- 7:9-5 HTRI-R "E/L9/9F/CM5/EW AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-6 HFP-11 "E/L9/9F/SD6/EW Lift Lobby"
| | | | |-- 7:9-7 HFP-11 "E/L9/9F/SD7/EW Lift Lobby"
| | | | |-- 7:9-8 HFP-11 "E/L9/9F/SD8/EW Electric rm"
| | | | |-- 7:9-9 HTRI-R "E/L9/9F/CM9/nr EW door release"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-10 HFP-11 "E/L9/9F/SD10/Corr.nr EW9010"
| | | | |-- 7:9-11 HFP-11 "E/L9/9F/SD11/CORR NR 9021"
| | | | |-- 7:9-12 HFP-11 "E/L9/9F/SD12/Corr.nr EW9020"
| | | | |-- 7:9-13 HFP-11 "E/L9/9F/SD13/Corr.nr EW9051"
| | | | |-- 7:9-14 HFP-11 "E/L9/9F/SD14/Corr.nr EW9032"
| | | | |-- 7:9-15 HTRI-R "E/L9/9F/CM15/EW Escape dr"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-16 HMS-S/D/M/SA "E/L9/9F/MCP16/EW Esc str"
| | | | |-- 7:9-17 HTRI-R "E/L9/9F/CM17/EW Shaft LiftLobby"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-18 HMS-S/D/M/SA "E/L9/8F/MCP18/EW Shaft LiftLobby"
| | | | |-- 7:9-19 HTRI-S "E/L9/8F/MM19/EW Shaft LiftLobby"
| | | | |-- 7:9-20 HFP-11 "E/L9/8F/SD20/EW LiftLobby"
| | | | |-- 7:9-21 HFP-11 "E/L9/8F/SD21/EW LiftLobby"
| | | | |-- 7:9-22 HFP-11 "E/L9/8F/SD22/EW AHU Rm"
| | | | |-- 7:9-23 HTRI-R "E/L9/8F/CM23/EW AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-24 HFP-11 "E/L9/8F/SD24/EW Electricct Rm"
| | | | |-- 7:9-25 HFP-11 "E/L9/8F/SD25/EW nr Electric rm"
| | | | |-- 7:9-26 HFP-11 "E/L9/8F/SD26/AFC EW"
| | | | |-- 7:9-27 HFP-11 "E/L9/8F/SD27/AFC EW"
| | | | |-- 7:9-28 HFP-11 "E/L9/8F/SD28/Corr nr EW8021"
| | | | |-- 7:9-29 HTRI-R "E/L9/7F/CM29/EW Shaft LiftLobby"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-30 HMS-S/D/M/SA "E/L9/7F/MCP30/EW shaft LiftLobby"
| | | | |-- 7:9-31 HTRI-S "E/L9/7F/MM31/EW shaft LiftLobby"
| | | | |-- 7:9-32 HFP-11 "E/L9/7F/SD32/EW LiftLobby"
| | | | |-- 7:9-33 HFP-11 "E/L9/7F/SD33/EW LiftLobby "
| | | | |-- 7:9-34 HFP-11 "E/L9/7F/SD34/EW AHU Rm"
| | | | |-- 7:9-35 HFP-11 "E/L9/7F/SD35/EW AHU Rm"
| | | | |-- 7:9-36 HTRI-R "E/L9/7F/CM36/EW AHU Rm"
| | | | | |-- Switch ""
| | | | | |-- Relay
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

7:9 XDLC "DLC @ address 9 L9"

```
| | | | |-- 7:9-37 HFP-11 "E/L9/7F/SD37/EW Electric rm"
| | | | |-- 7:9-38 HFP-11 "E/L9/SD38/EW Terrace Lift Mch RM"
| | | | |-- 7:9-39 HFP-11 "E/L9/SD39/EW Terrace Lift Mch RM"
| | | | |-- 7:9-40 HFP-11 "E/L9/SD40/EW Terrace Lift Mch RM"
| | | | |-- 7:9-41 HFP-11 "E/L9/SD41/EW Terrace Lift Mch RM"
| | | | |-- 7:9-42 HFP-11 "E/L9/SD42/EW Terrace Lift Mch RM"
| | | | |-- 7:9-43 HTRI-R "E/L9/CM43/EW Terrace Lift Mch RM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:9-44 HTRI-S "E/L9/8F/MM44/EW8012"
| | | | |-- 7:9-50 HTRI-S "E/L9/9F/MM50/EW9010"
| | | | |-- 7:9-51 HTRI-S "E/L9/9F/MM51/EW9020"
| | | | |-- 7:9-54 HTRI-S "E/L9/9F/MM54/EW9051"
| | | | |-- 7:9-55 HTRI-S "E/L9/9F/MM55/EW9031"
| | | | |-- 7:9-58 HTRI-S "E/L9/9F/MM58/EW9040B"
| | | | |-- 7:9-59 HTRI-S "E/L9/8F/MM59/EW8010"
| | | | |-- 7:9-60 HTRI-S "E/L9/8F/MM60/EW8011"
| | | | |-- 7:9-62 HTRI-S "E/L9/7F/MM62/EW 7010"NR ELE RM"
| | | | |-- 7:9-63 HTRI-S "E/L9/9F/MM63/EW 9060"
| | | |-- 7:10 NIC-C(XNet) "NIC_Xnet @ address 10"
| | | |-- 7:11 NIC-C(HNet) "NIC @ address 11"
| | |-- 7:249 PSC-12 "PSC-12 @ address 249"
| | | |-- 7:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
| | | |-- 7:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
| | |-- Inner Door
| | | |-- 7:253 PMI-D "PMI-D Tower E -7"
| |-- CAB-1 "CAB-1 Enclosure #2"
| | |-- CC-5 "Card Cage 5 Slots"
| | | |-- 7:7 XDLC "DLC @ address 7 L7"
| | | | |-- 7:7-1 HFP-11 "E/L7/6F/SD1/CORR NR 6280"
| | | | |-- 7:7-2 HFP-11 "E/L7/6F/SD2/CORR NR 6280"
| | | | |-- 7:7-3 HTRI-R "E/L7/6F/CM3/FIRE ESC STR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:7-4 HMS-S/D/M/SA "E/L7/6F/MCP4/FIRE ESC STR"
| | | | |-- 7:7-5 HFP-11 "E/L7/6F/SD5/CORR NR DW 6270"
| | | | |-- 7:7-6 HFP-11 "E/L7/6F/SD6/CORR NR 6260"
| | | | |-- 7:7-7 HFP-11 "E/L7/6F/SD7/CORR NR 6260"
| | | | |-- 7:7-8 HFP-11 "E/L7/6F/SD8/CORR NR 6260"
| | | | |-- 7:7-9 HFP-11 "E/L7/6F/SD9/CORR NR 6251"
| | | | |-- 7:7-10 HFP-11 "E/L7/6F/SD10/CORR NR 6251"
| | | | |-- 7:7-11 HFP-11 "E/L7/6F/SD11/AHU RM SD"
| | | | |-- 7:7-12 HTRI-R "E/L7/6F/CM12/AHU RM CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:7-13 HTRI-R "E/L7/6F/CM13/DR RELESE CM"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | |-- 7:7-14 HMS-S/D/M/SA "E/L7/6F/MCP14/FIRE SHAFT L.L."
| | | | |-- 7:7-15 HTRI-R "E/L7/6F/CM15/FIRE SHAFT L.L."
```

```

7 Desigo Fire Safety Modular "BDB TOWER E" Local
  CAB-1 "CAB-1 Enclosure #2"
    CC-5 "Card Cage 5 Slots"
      7:7 XDLC "DLC @ address 7 L7"
        7:7-15 HTRI-R "E/L7/6F/CM15/FIRE SHAFT L.L."

```

```
| | | | Switch ""
| | | | |-- Relay
| | | | |-- 7:7-16 HTRI-S "E/L7/6F/MM16/FIRE SHAFT L.L."
| | | | |-- 7:7-17 HFP-11 "E/L7/6F/SD17/LIFT LOBBY SD"
| | | | |-- 7:7-18 HFP-11 "E/L7/6F/SD18/LIFT LOBBY SD"
| | | | |-- 7:7-19 HFP-11 "E/L7/6F/SD19/ELECT RM SD"
| | | | |-- 7:7-20 HTRI-R "E/L7/6F/CM20/DR RELESE CM "
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 7:7-21 HFP-11 "E/L7/6F/SD21/CORR NR DR"
| | | | |-- 7:7-22 HFP-11 "E/L7/6F/SD22/CORR NR EW 6050"
| | | | |-- 7:7-23 HFP-11 "E/L7/6F/SD23/CORR NR 6060"
| | | | |-- 7:7-24 HFP-11 "E/L7/6F/SD24/CORR NR EW 6070"
| | | | |-- 7:7-25 HFP-11 "E/L7/5F/SD25/CORR NR DW 5280"
| | | | |-- 7:7-26 HFP-11 "E/L7/5F/SD26/CORR NR 5280"
| | | | |-- 7:7-27 HTRI-R "E/L7/5F/CM27/FIRE ESC STR"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 7:7-28 HMS-S/D/M/SA "E/L7/5F/MCP28/FIRE ESC STR"
| | | | |-- 7:7-29 HFP-11 "E/L7/5F/SD29/CORR NR DW 5210"
| | | | |-- 7:7-30 HFP-11 "E/L7/5F/SD30/CORR NR 5210"
| | | | |-- 7:7-31 HFP-11 "E/L7/5F/SD31/CORR NR 5263"
| | | | |-- 7:7-32 HFP-11 "E/L7/5F/SD32/CORR NR 5261"
| | | | |-- 7:7-33 HTRI-R "E/L7/5F/CM33/AHU RM CM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 7:7-34 HFP-11 "E/L7/5F/SD34/AHU RM SD"
| | | | |-- 7:7-35 HFP-11 "E/L7/5F/SD35/CORR NR DR"
| | | | |-- 7:7-36 HTRI-R "E/L7/5F/CM36/DR RELESE CM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 7:7-37 HTRI-R "E/L7/5F/CM37/FIRE SHAFT L.L."
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 7:7-38 HMS-S/D/M/SA "E/L7/5F/MCP38/FIRE SHAFT L.L."
| | | | |-- 7:7-39 HTRI-S "E/L7/5F/MM39/FIRE SHAFT L.L."
| | | | |-- 7:7-40 HFP-11 "E/L7/5F/SD40/LIFT LOBBY SD"
| | | | |-- 7:7-41 HFP-11 "E/L7/5F/SD41/LIFT LOBBY SD"
| | | | |-- 7:7-42 HFP-11 "E/L7/5F/SD42/ELECT RM SD"
| | | | |-- 7:7-43 HTRI-R "E/L7/5F/CM43/DR RELESE 5 TO 6"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 7:7-44 HFP-11 "E/L7/5F/SD44/CORR NR 5010"
| | | | |-- 7:7-45 HFP-11 "E/L7/5F/SD45/CORR NR 5020"
| | | | |-- 7:7-46 HFP-11 "E/L7/5F/SD46/CORR NR 5181"
| | | | |-- 7:7-47 HFP-11 "E/L7/5F/SD47/CORR NR 5170"
| | | | |-- 7:7-48 HFP-11 "E/L7/5F/SD48/CORR NR EW 5/S17"
| | | | |-- 7:7-49 HTRI-R "E/L7/EW/5F/CM49/DR RELESE CM"
| | | | |-- Switch ""
| | | | |-- Relay
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:7 XDLC "DLC @ address 7 L7"

				--	7:7-50	HFP-11	"E/L7/EW/5F/SD50/CORR NR EW5050"
				--	7:7-51	HFP-11	"E/L7/EW/5F/SD51/CORR NR EW5030"
				--	7:7-52	HFP-11	"E/L7/EW/5F/SD52/CORR NR EW5020"
				--	7:7-53	HFP-11	"E/L7/EW/5F/SD53/CORR NR EW5010"
				--	7:7-54	HFP-11	"E/L7/EW/5F/SD54/CORR NR LL"
				--	7:7-55	HTRI-R	"E/L7/EW/5F/CM55/FIRE ESC DR"
				--	Switch	"	"
				--	Relay		
				--	7:7-56	HMS-S/D/M/SA	"E/L7/EW/5F/MCP56/FIRE ESC DR"
				--	7:7-57	FDOT421	"E/L7/EW5201/SD57/Assorter cab"
				--	7:7-59	HTRI-S	"E/L7/6F/MM59/DW6251"
				--	7:7-60	HTRI-S	"E/L7/6F/MM60/EW6070"
				--	7:7-62	HTRI-S	"E/L7/6F/MM62/EW6090"
				--	7:7-63	HTRI-S	"E/L7/6F/MM63/EW6060"
				--	7:7-64	HTRI-S	"E/L7/6F/MM64/EW6050"
				--	7:7-66	HTRI-S	"E/L7/6F/MM66/EW6040"
				--	7:7-67	HTRI-S	"E/L7/6F/MM67/EW6030"
				--	7:7-68	HTRI-S	"E/L7/6F/MM68/EW6020"
				--	7:7-71	HFP-11	"E/L7/DW6240/SD71/AFC Entry Psg"
				--	7:7-72	HFP-11	"E/L7/DW6240/SD72/Entry Psg"
				--	7:7-73	HTRI-S	"E/W/6F/MM73/DW6220"
				--	7:7-74	HTRI-S	"E/L7/W/6F/MM74/DW6210"
				--	7:7-75	HTRI-S	"E/L7/6F/MM75/DW6260"
				--	7:7-77	HTRI-S	"E/L7/6F/MM77/DW6270"
				--	7:7-78	HTRI-S	"E/L7/6F/MM78/DW6200"
				--	7:7-79	HTRI-S	"E/L7/6F/MM79/DW6190"
				--	7:7-80	HTRI-S	"E/L7/6F/MM80/DW6180"
				--	7:7-81	HTRI-S	"E/L7/6F/MM81/DW6280"
				--	7:7-82	HTRI-S	"E/L7/6F/MM82/DW6170"
				--	7:7-84	HTRI-S	"E/L7/5F/MM84/DW5280"
				--	7:7-90	HTRI-S	"E/L7/5F/MM90/DW5230"
				--	7:7-91	HTRI-S	"E/L7/5F/MM91/DW5240/50"
				--	7:7-93	HTRI-S	"E/L7/5F/MM93/DW5262/63"
				--	7:7-94	HTRI-S	"E/L7/5F/MM94/DW5261"
				--	7:7-97	HTRI-S	"E/L7/5F/MM97/EW5190"
				--	7:7-98	HTRI-S	"E/L7/5F/MM98/EW5010"
				--	7:7-99	FDOT421	"E/L7/EW5071/SD99/Reception"
				--	7:7-100	HTRI-R	"E/L7/EW5071/CM100/Entry Psg"
				--	Switch	"	"
				--	Relay		
				--	7:7-101	HMS-S/D/M/SA	"E/L7/EW5071/MCP101/Entry Psg"
				--	7:7-102	HFP-11	"E/L7/EW5071/SD102/Executive cab"
				--	7:7-103	HFP-11	"E/L7/EW5071/SD103/Display rm"
				--	7:7-104	HFP-11	"E/L7/EW5071/SD104/Pantry"
				--	7:7-105	HFP-11	"E/L7/EW5071/SD105/Assorter cab"
				--	7:7-106	HFP-11	"E/L7/EW5071/SD106/Accounts cab"
				--	7:7-107	HFP-11	"E/L7/EW5270/SD107/assoter cab"
				--	7:7-108	HFP-11	"E/L7/EW5270/SD108/Main cab"
				--	7:7-109	HFP-11	"E/L7/EW5270/SD109/psg nr pantry"
				--	7:7-110	HFP-11	"E/L7/DW5270/SD110/Account cab"

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:7 XDLC "DLC @ address 7 L7"

```
|      |      |      | 7:7-111 HFP-11 "E/L7/DW5270/SD111/Pantry"
|      |      |      | 7:7-112 HTRI-R "E/L7/DW5270/CM112/Psg nr Entry"
|      |      |      | | 7:7-113 HMS-S/D/M/SA "E/L7/DW5270/MCP113/Psg nr Entry"
|      |      |      | | 7:7-114 HFP-11 "E/L7/DW5220/SD114/Main cab"
|      |      |      | | 7:7-115 HFP-11 "E/L7/DW5220/SD115/Buyers cab"
|      |      |      | | 7:7-116 HFP-11 "E/L7/DW5220/SD116/Psg nr Buyers "
|      |      |      | | 7:7-117 HFP-11 "E/L7/DW5220/SD117/Accounts cab"
|      |      |      | | 7:7-118 HFP-11 "E/L7/DW5220/SD118/Psg nr Entry"
|      |      |      | | 7:7-119 HTRI-R "E/L7/DW5220/CM119/Psg nr Entry"
|      |      |      | | | 7:7-120 HMS-S/D/M/SA "E/L7/DW5220/MCP120/Psg nr Entry"
|      |      |      | | | 7:7-121 HFP-11 "E/L7/DW5210/SD121/Pantry"
|      |      |      | | | 7:7-122 HFP-11 "E/L7/DW5210/SD122/Accounts cab"
|      |      |      | | | 7:7-123 HFP-11 "E/L7/DW5210/SD123/Assorter cab"
|      |      |      | | | 7:7-124 HFP-11 "E/L7/DW5210/SD124/Main cab"
|      |      |      | | | 7:7-125 HFP-11 "E/L7/DW5210/SD125/Psg nr Entry D"
|      |      |      | | | 7:7-126 HTRI-R "E/L7/DW5210/CM126/Psg nr Entry D"
|      |      |      | | | | 7:7-127 HMS-S/D/M/SA "E/L7/DW5210/MCP127/Psg nr Entry "
|      |      |      | | | | 7:7-128 HFP-11 "E/L7/DW5190/SD128/Psg nr Pantry"
|      |      |      | | | | 7:7-129 HFP-11 "E/L7/DW5190/SD129/Reception"
|      |      |      | | | | 7:7-130 HFP-11 "E/L7/DW5190/SD130/Cab 1"
|      |      |      | | | | 7:7-131 HFP-11 "E/L7/DW5190/SD131/Main Cab"
|      |      |      | | | | 7:7-132 HFP-11 "E/L7/DW5190/SD132/Account Cab"
|      |      |      | | | | 7:7-133 HFP-11 "E/L7/DW5190/SD133/Cab 2"
|      |      |      | | | | 7:7-134 HTRI-R "E/L7/DW5190/CM134/Entry Psg AFC"
|      |      |      | | | | | 7:7-135 HMS-S/D/M/SA "E/L7/DW5190/MCP135/Entry Psg"
|      |      |      | | | | | 7:7-142 HFP-11 "E/L7/EW5060/SD142/Psg Nr Sales C"
|      |      |      | | | | | 7:7-143 HFP-11 "E/L7/EW5060/SD143/Pantry"
|      |      |      | | | | | 7:7-161 HFP-11 "E/L7/DW6240/SD161/Buyers cab 1"
|      |      |      | | | | | 7:7-162 HFP-11 "E/L7/DW6240/SD162/Buyers cab 2"
|      |      |      | | | | | 7:7-163 HFP-11 "E/L7/DW6240/SD163/Main cab"
|      |      |      | | | | | 7:7-164 HFP-11 "E/L7/DW6240/SD164/Psg nr Main ca"
|      |      |      | | | | | 7:7-165 HTRI-R "E/L7/DW6240/CM165/Psg nr Entry d"
|      |      |      | | | | | | 7:7-166 HMS-S/D/M/SA "E/L7/DW6240/MCP166/Psg nr Entry "
|      |      |      | | | | | | 7:7-167 HFP-11 "E/L7/EW5181/SD167/Cab 13"
|      |      |      | | | | | | 7:7-168 HFP-11 "E/L7/EW5181/SD168/Cab 14"
|      |      |      | | | | | | 7:7-169 HFP-11 "E/L7/EW5181/SD169/Cab 15"
|      |      |      | | | | | | 7:7-170 HFP-11 "E/L7/EW5181/SD170/Cab 11"
|      |      |      | | | | | | 7:7-171 HFP-11 "E/L7/EW5181/SD171/Cab 11"
|      |      |      | | | | | | 7:7-172 HFP-11 "E/L7/EW5181/SD172/Reception Psg"
|      |      |      | | | | | | 7:7-173 HMS-S/D/M/SA "E/L7/EW5181/MCP173/Psg nr cab 9"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:7 XDLC "DLC @ address 7 L7"

```
|      |      |      | 7:7-174 HMS-S/D/M/SA "E/L7/EW5181/MCP174/Psg nr cab 14"
|      |      |      | 7:7-175 HTRI-R "E/L7/EW5181/CM175/Entry dr Psg"
|      |      |      | | 7:7-176 HFP-11 "E/L7/DW6230/SD176/Main Cabin"
|      |      |      | | 7:7-177 HFP-11 "E/L7/DW6230/SD177/Psg nr Account"
|      |      |      | | 7:7-178 HFP-11 "E/L7/DW6230/SD178/Account cab"
|      |      |      | | 7:7-179 HFP-11 "E/L7/DW6230/SD179/Assorter cab"
|      |      |      | | 7:7-180 HFPT-11 "E/L7/DW6230/HD180/Pantry"
|      |      |      | | 7:7-181 HTRI-R "E/L7/DW6230/CM181/Entry dr psg"
|      |      |      | | | 7:7-182 HMS-S/D/M/SA "E/L7/DW6230/MCP182/Entry dr psg"
|      |      |      | | | 7:7-183 HFP-11 "E/L7/DW6230/SD183/Main cab"
|      |      |      | | | 7:7-190 HFP-11 "E/L7/EW6010/SD190/Main cab"
|      |      |      | | | 7:7-191 HFP-11 "E/L7/EW6010/SD191/Assorter cab"
|      |      |      | | | 7:7-192 HFP-11 "E/L7/EW6010/SD192/Assorter cab"
|      |      |      | | | 7:7-193 HFP-11 "E/L7/EW6010/SD193/Psg nr Assorte"
|      |      |      | | | 7:7-194 HFP-11 "E/L7/EW6010/SD194/Pantry"
|      |      |      | | | 7:7-195 HTRI-R "E/L7/EW6010/CM195/Entry dr Psg"
|      |      |      | | | | 7:7-196 HMS-S/D/M/SA "E/L7/EW6010/MCP196/Entry dr Psg"
|      |      |      | | | | 7:7-197 HFP-11 "E/L7/EW5030/SD197/Main cab"
|      |      |      | | | | 7:7-198 HFP-11 "E/L7/EW5030/SD198/Assorter cab"
|      |      |      | | | | 7:7-199 HFP-11 "E/L7/EW5030/SD199/Account cab"
|      |      |      | | | | 7:7-200 HFP-11 "E/L7/EW5030/SD200/Entry dr Psg"
|      |      |      | | | | 7:7-201 HTRI-R "E/L7/EW5030/CM201/Entry dr Psg"
|      |      |      | | | | | 7:7-202 HMS-S/D/M/SA "E/L7/EW5030/MCP202/Entry dr Psg"
|      |      |      | | | | | 7:7-203 HFP-11 "E/L7/EW5060/SD203/Staff rm"
|      |      |      | | | | | 7:7-204 HFP-11 "E/L7/EW5060/SD204/Staff dinning "
|      |      |      | | | | | 7:7-205 HFP-11 "E/L7/EW5060/SD205/Staff dinning "
|      |      |      | | | | | 7:7-206 HTRI-R "E/L7/EW5060/CM206/Entry dr Psg"
|      |      |      | | | | | | 7:7-207 HMS-S/D/M/SA "E/L7/EW5060/MCP207/Entry dr Psg"
|      |      |      | | | | | | 7:7-208 HFP-11 "E/L7/EW5040/SD208/Assorter cab"
|      |      |      | | | | | | 7:7-209 HFP-11 "E/L7/EW5040/SD209/Account cab"
|      |      |      | | | | | | 7:7-210 HFP-11 "E/L7/EW5040/SD210/Psg nr Main ca"
|      |      |      | | | | | | 7:7-211 HFP-11 "E/L7/EW5040/SD211/Main cab"
|      |      |      | | | | | | 7:7-212 HFP-11 "E/L7/EW5040/SD212/Pantry"
|      |      |      | | | | | | 7:7-213 HTRI-R "E/L7/EW5040/CM213/Entry dr Psg"
|      |      |      | | | | | | | 7:7-214 HMS-S/D/M/SA "E/L7/EW5040/MCP214/Entry dr Psg"
|      |      |      | | | | | | | 7:7-215 HFP-11 "E/L7/EW5201/SD215/Big cab"
|      |      |      | | | | | | | 7:7-216 HFP-11 "E/L7/EW5201/SD216/Manager cab"
|      |      |      | | | | | | | 7:7-217 HFP-11 "E/L7/EW5201/SD217/Psg nr Manager"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:7 XDLC "DLC @ address 7 L7"

```
|      |      |  |-- 7:7-218 HFP-11 "E/L7/EW5201/SD218/lunch rm"
|      |      |  |-- 7:7-219 HFP-11 "E/L7/EW5201/SD219/Pantry"
|      |      |  |-- 7:7-220 HFP-11 "E/L7/EW5201/SD220/Assorter cab"
|      |      |  |-- 7:7-221 HFP-11 "E/L7/EW5201/SD221/Psg nr Assorte"
|      |      |  |-- 7:7-222 HFP-11 "E/L7/EW5201/SD222/Reception cab"
|      |      |  |-- 7:7-223 HFP-11 "E/L7/EW5201/SD223/Accounts cab"
|      |      |  |-- 7:7-224 HFP-11 "E/L7/EW5201/SD224/Assorter cab"
|      |      |  |-- 7:7-225 HFP-11 "E/L7/EW5201/SD225/Main cab"
|      |      |  |-- 7:7-226 HFP-11 "E/L7/EW5201/SD226/Main cab"
|      |      |  |-- 7:7-227 HFP-11 "E/L7/EW5201/SD227/Stock cab"
|      |      |  |-- 7:7-228 HFP-11 "E/L7/EW5201/SD228/Assorter cab"
|      |      |  |-- 7:7-229 HTRI-R "E/L7/EW5201/CM229/Entry Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-230 HMS-S/D/M/SA "E/L7/EW5201/MCP230/Entry Psg"
|      |      |  |-- 7:7-231 HFP-11 "E/L7/EW5201/SD231/Big cab"
|      |      |  |-- 7:7-232 HFP-11 "E/L7/EW5020/SD232/Main cab"
|      |      |  |-- 7:7-233 HFP-11 "E/L7/EW5020/SD233/Assorter cab"
|      |      |  |-- 7:7-234 HFP-11 "E/L7/EW5020/SD234/Psg nr Assorte"
|      |      |  |-- 7:7-235 HFP-11 "E/L7/EW5020/SD235/Accounts cab"
|      |      |  |-- 7:7-236 HFPT-11 "E/L7/EW5020/HD236/Pantry"
|      |      |  |-- 7:7-237 HTRI-R "E/L7/EW5020/CM237/Entry dr Psg"
|      |      |  |  |-- Switch ""
|      |      |  |  |-- Relay
|      |      |  |-- 7:7-238 HMS-S/D/M/SA "E/L7/EW5020/MCP238/Entry dr Psg"
|      |      |  |-- 7:7-239 HFP-11 "E/L7/EW5181/SD239/Cab 2"
|      |      |  |-- 7:7-240 HFP-11 "E/L7/EW5181/SD240/Cab 3"
|      |      |  |-- 7:7-241 HFP-11 "E/L7/EW5181/SD241/Cab 4"
|      |      |  |-- 7:7-242 HFP-11 "E/L7/EW5181/SD242/Cab 5"
|      |      |  |-- 7:7-243 HFP-11 "E/L7/EW5181/SD243/Psg nr Cab 5"
|      |      |  |-- 7:7-244 HFP-11 "E/L7/EW5181/SD244/Cab 6"
|      |      |  |-- 7:7-245 HFP-11 "E/L7/EW5181/SD245/Cab 7"
|      |      |  |-- 7:7-246 HFP-11 "E/L7/EW5181/SD246/Psg nr Cab 7"
|      |      |  |-- 7:7-247 HFP-11 "E/L7/EW5181/SD247/Cab 8"
|      |      |  |-- 7:7-248 HFP-11 "E/L7/EW5181/SD248/Cab 9"
|      |      |  |-- 7:7-249 HFP-11 "E/L7/EW5181/SD249/Cab 10"
|      |      |  |-- 7:7-250 HFP-11 "E/L7/EW5181/SD250/Cab 10"
|      |      |  |-- 7:7-251 HFP-11 "E/L7/EW5181/SD251/Psg nr Cab 10"
|      |      |  |-- 7:7-252 HFP-11 "E/L7/EW5181/SD252/Cab 12"
|      |      |  |-- 7:12 NIC-C(HNet) "NIC @ address 12"
|      |      |  |-- 7:13 XDLC "DLC @ address 13 L10"
|      |      |  |  |-- 7:13-8 HFP-11 "E/L10/EE3030/SD8/Main cab"
|      |      |  |  |-- 7:13-9 HFP-11 "E/L10/EE3030/SD9/Main cab"
|      |      |  |  |-- 7:13-10 HFP-11 "E/L10/EE3030/SD10/Entry Psg""
|      |      |  |  |-- 7:13-11 HTRI-R "E/L10/EE3030/CM11/Entry Psg"
|      |      |  |  |  |-- Switch ""
|      |      |  |  |  |-- Relay
|      |      |  |-- 7:13-12 HMS-S/D/M/SA "E/L10/EE3030/MCP12/Entry Psg"
|      |      |  |-- 7:13-13 HFP-11 "E/L10/EE3050/SD13/Main cab"
|      |      |  |-- 7:13-14 HFP-11 "E/L10/EE3050/SD14/Assorter cab"
```


7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

```
|      |      |-- 7:13-15 HFP-11 "E/L10/EE3050/SD15/Account cab"
|      |      |-- 7:13-16 HFP-11 "E/L10/EE3050/SD16/Pantry"
|      |      |-- 7:13-18 HTRI-R "E/L10/EE3050/CM18/AFC Entry dr P"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-19 HMS-S/D/M/SA "E/L10/EE3050/MCP19/Entry dr Psg"
|      |      |-- 7:13-26 HFP-11 "E/L10/EE3100/SD26/Main cab"
|      |      |-- 7:13-27 HFP-11 "E/L10/EE3100/SD27/GIA cab1"
|      |      |-- 7:13-28 HFP-11 "E/L10/EE3100/SD28/Accounts cab"
|      |      |-- 7:13-29 HFP-11 "E/L10/EE3100/SD29/GIA cab2"
|      |      |-- 7:13-30 HFP-11 "E/L10/EE3100/SD30/Pantry"
|      |      |-- 7:13-31 HTRI-R "E/L10/EE3100/CM31/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-32 HMS-S/D/M/SA "E/L10/EE3100/MCP32/Entry dr Psg"
|      |      |-- 7:13-33 HFP-11 "E/L10/EE2030/SD33/Main cab"
|      |      |-- 7:13-34 HFP-11 "E/L10/EE2030/SD34/Main cab"
|      |      |-- 7:13-35 HFP-11 "E/L10/EE2030/SD35/Assorter cab"
|      |      |-- 7:13-36 HFP-11 "E/L10/EE2030/SD36/Psg nr MC"
|      |      |-- 7:13-37 HFP-11 "E/L10/EE2030/SD37/Pantry"
|      |      |-- 7:13-38 HTRI-R "E/L10/EE2030/CM38/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-39 HMS-S/D/M/SA "E/L10/EE2030/MCP39/Entry dr Psg"
|      |      |-- 7:13-40 HFP-11 "E/L10/EE3020/SD40/Accounts cab"
|      |      |-- 7:13-41 HFP-11 "E/L10/EE3020/SD41/Rishilbhai cab"
|      |      |-- 7:13-42 HFP-11 "E/L10/EE3020/SD42/Main cab"
|      |      |-- 7:13-43 HFP-11 "E/L10/EE3020/SD43/Assorter cab"
|      |      |-- 7:13-44 HFP-11 "E/L10/EE3020/SD44/Planning cab"
|      |      |-- 7:13-45 HFP-11 "E/L10/EE3020/SD45/Cab nr buyers "
|      |      |-- 7:13-46 HFP-11 "E/L10/EE3020/SD46/buyers cab"
|      |      |-- 7:13-47 HFP-11 "E/L10/EE3020/SD47/Psg nr MC"
|      |      |-- 7:13-48 HFP-11 "E/L10/EE3020/SD48/Pantry Psg"
|      |      |-- 7:13-49 HFP-11 "E/L10/EE3020/SD49/Entry Psg"
|      |      |-- 7:13-50 HFP-11 "E/L10/EE3020/SD50/Assorter cab 1"
|      |      |-- 7:13-51 HFP-11 "E/L10/EE3020/SD51/Assorter cab 2"
|      |      |-- 7:13-52 HFP-11 "E/L10/EE3020/SD52/Assorter cab 3"
|      |      |-- 7:13-53 HMS-S/D/M/SA "E/L10/EE3020/MCP53/Reception Psg"
|      |      |-- 7:13-54 HTRI-R "E/L10/EE3020/CM54/Reception Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-55 HFP-11 "E/L10/EC3021/SD55/Reception Psg"
|      |      |-- 7:13-56 HFP-11 "E/L10/EC3021/SD56/Psg nr Fauna c"
|      |      |-- 7:13-57 HFP-11 "E/L10/EC3021/SD57/Pricing cab"
|      |      |-- 7:13-58 HFP-11 "E/L10/EC3021/SD58/Sales dept"
|      |      |-- 7:13-59 HFP-11 "E/L10/EC3021/SD59/Grading cab"
|      |      |-- 7:13-60 HFP-11 "E/L10/EC3021/SD60/Export cab"
|      |      |-- 7:13-61 HFP-11 "E/L10/EC3021/SD61/Export cab"
|      |      |-- 7:13-62 HFP-11 "E/L10/EC3021/SD62/Buyers cab1"
|      |      |-- 7:13-63 HFP-11 "E/L10/EC3021/SD63/Buyers cab2"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

```
|      |      |-- 7:13-64 HFP-11 "E/L10/EC3021/SD64/Fauna cab"
|      |      |-- 7:13-65 HFP-11 "E/L10/EC3021/SD65/Sales dept"
|      |      |-- 7:13-66 HFP-11 "E/L10/EC3021/SD66/Boss cab"
|      |      |-- 7:13-67 HFP-11 "E/L10/EC3021/SD67/Boss cab"
|      |      |-- 7:13-68 HFP-11 "E/L10/EC3021/SD68/Psg nr MC"
|      |      |-- 7:13-69 HFP-11 "E/L10/EC3021/SD69/Sant Kabir cab"
|      |      |-- 7:13-70 HFP-11 "E/L10/EC3021/SD70/Cust Relatn ca"
|      |      |-- 7:13-71 HFP-11 "E/L10/EC3021/SD71/Sales direct. "
|      |      |-- 7:13-72 HFP-11 "E/L10/EC3021/SD72/Vivekanand cab"
|      |      |-- 7:13-73 HFP-11 "E/L10/EC3021/SD73/Budha cab"
|      |      |-- 7:13-74 FDOT421 "E/L10/EC3021/SD74/osho cab"
|      |      |-- 7:13-75 HFP-11 "E/L10/EC3021/SD75/IT room"
|      |      |-- 7:13-76 HFP-11 "E/L10/EC3021/SD76/stock cab"
|      |      |-- 7:13-77 HFP-11 "E/L10/EC3021/SD77/Psg nr stock c"
|      |      |-- 7:13-78 HFP-11 "E/L10/EC3021/SD78/Pramukh cab"
|      |      |-- 7:13-79 HFPT-11 "E/L10/EC3021/HD79/Pantry"
|      |      |-- 7:13-80 XTRI-R "E/L10/EC3021/CM80/Reception Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-81 HMS-S/D/M/SA "E/L10/EC3021/MCP81/Reception Psg"
|      |      |-- 7:13-82 HFP-11 "E/L10/EC2030/SD82/Main cab"
|      |      |-- 7:13-83 HFP-11 "E/L10/EC2030/SD83/Pantry Psg"
|      |      |-- 7:13-84 HFP-11 "E/L10/EC2030/SD84/Cab 1"
|      |      |-- 7:13-85 HTRI-R "E/L10/EC2030/CM85/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-86 HMS-S/D/M/SA "E/L10/EC2030/MCP86/Entry dr Psg"
|      |      |-- 7:13-87 HFP-11 "E/L10/EC2050/SD87/Main cab"
|      |      |-- 7:13-88 HFP-11 "E/L10/EC2050/SD88/Pantry Psg"
|      |      |-- 7:13-89 HFP-11 "E/L10/EC2050/SD89/Cab 1"
|      |      |-- 7:13-90 HTRI-R "E/L10/EC2050/CM90/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-91 HMS-S/D/M/SA "E/L10/EC2050/MCP91/Entry dr Psg"
|      |      |-- 7:13-92 HFP-11 "E/L10/EC2070/SD92/Main cab"
|      |      |-- 7:13-93 HFP-11 "E/L10/EC2070/SD93/Cab 1"
|      |      |-- 7:13-94 HFP-11 "E/L10/EC2070/SD94/Cab 2"
|      |      |-- 7:13-95 HFP-11 "E/L10/EC2070/SD95/Entry Psg"
|      |      |-- 7:13-96 HFPT-11 "E/L10/EC2070/HD96/Pantry"
|      |      |-- 7:13-97 HTRI-R "E/L10/EC2070/CM97/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-98 HMS-S/D/M/SA "E/L10/EC2070/MCP98/Entry Psg"
|      |      |-- 7:13-99 HFP-11 "E/L10/EC2110/SD99/Main cab"
|      |      |-- 7:13-100 HFP-11 "E/L10/EC2110/SD100/Assorter cab"
|      |      |-- 7:13-101 HFP-11 "E/L10/EC2110/SD101/Psg nr Assort"
|      |      |-- 7:13-102 HFP-11 "E/L10/EC2110/SD102/Pantry Psg"
|      |      |-- 7:13-103 HTRI-R "E/L10/EC2110/CM103/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

```
|      |      |-- 7:13-104 HMS-S/D/M/SA "E/L10/EC2110/MCP104/Entry Psg"
|      |      |-- 7:13-105 HFP-11 "E/L10/EC1010/SD105/Main cab"
|      |      |-- 7:13-106 HFP-11 "E/L10/EC1010/SD106/Assorter cab"
|      |      |-- 7:13-107 HFP-11 "E/L10/EC1010/SD107/Psg nr MC"
|      |      |-- 7:13-108 HFP-11 "E/L10/EC1010/SD108/Pantry"
|      |      |-- 7:13-109 HTRI-R "E/L10/EC1010/CM109/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-110 HMS-S/D/M/SA "E/L10/EC1010/MCP110/Entry dr Psg"
|      |      |-- 7:13-111 HFP-11 "E/L10/EC1030/SD111/Main cab"
|      |      |-- 7:13-112 HFP-11 "E/L10/EC1030/SD112/Pantry Psg"
|      |      |-- 7:13-113 HTRI-R "E/L10/EC1030/CM113/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-114 HMS-S/D/M/SA "E/L10/EC1030/MCP114/Entry dr Psg"
|      |      |-- 7:13-115 HFP-11 "E/L10/EE3010/SD115/Accounts cab"
|      |      |-- 7:13-116 HFP-11 "E/L10/EE3010/SD116/Jewellery cab"
|      |      |-- 7:13-117 HFP-11 "E/L10/EE3010/SD117/Cab 3"
|      |      |-- 7:13-118 HFP-11 "E/L10/EE3010/SD118/Cab 2"
|      |      |-- 7:13-119 HFP-11 "E/L10/EE3010/SD119/Cab 1"
|      |      |-- 7:13-120 HFP-11 "E/L10/EE3010/SD120/Assorter cab"
|      |      |-- 7:13-121 HFP-11 "E/L10/EE3010/SD121/Entry Psg"
|      |      |-- 7:13-122 HFP-11 "E/L10/EE3010/SD122/Pantry"
|      |      |-- 7:13-123 HTRI-R "E/L10/EE3010/CM123/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-124 HMS-S/D/M/SA "E/L10/EE3010/MCP124/Entry Psg"
|      |      |-- 7:13-125 HFP-11 "E/L10/EC1140/SD125/Cab 1"
|      |      |-- 7:13-126 HFP-11 "E/L10/EC1140/SD126/Cab 2"
|      |      |-- 7:13-127 HFP-11 "E/L10/EC1140/SD127/Cab 3"
|      |      |-- 7:13-128 HFP-11 "E/L10/EC1140/SD128/Entry Psg"
|      |      |-- 7:13-129 HTRI-R "E/L10/EC1140/CM129/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-130 HMS-S/D/M/SA "E/L10/EC1140/MCP130/Entry Psg"
|      |      |-- 7:13-131 HFP-11 "E/L10/EC2081/SD131/Cab 1"
|      |      |-- 7:13-132 HFP-11 "E/L10/EC2081/SD132/Cab 2"
|      |      |-- 7:13-133 HFP-11 "E/L10/EC2081/SD133/Cab 3"
|      |      |-- 7:13-134 HFP-11 "E/L10/EC2081/SD134/Cab 4"
|      |      |-- 7:13-135 HFPT-11 "E/L10/EC2081/HD135/Pantry"
|      |      |-- 7:13-136 HFP-11 "E/L10/EC2081/SD136/AFC Pantry"
|      |      |-- 7:13-137 HTRI-R "E/L10/EC2081/CM137/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-138 HMS-S/D/M/SA "E/L10/EC2081/MCP138/Entry dr Psg"
|      |      |-- 7:13-139 HFP-11 "E/L10/EC1040/SD139/Assorter cab"
|      |      |-- 7:13-140 HFP-11 "E/L10/EC1040/SD140/Main cab"
|      |      |-- 7:13-141 HFP-11 "E/L10/EC1040/SD141/Accounts cab"
|      |      |-- 7:13-142 HFP-11 "E/L10/EC1040/SD142/Pantry"
|      |      |-- 7:13-143 HFP-11 "E/L10/EC1040/SD143/Pantry"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

```
|      |      |-- 7:13-144 HTRI-R "E/L10/EC1040/CM144/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-145 HMS-S/D/M/SA "E/L10/EC1040/MCP145/Entry dr Psg"
|      |      |-- 7:13-146 HFP-11 "E/L10/EC3040/SD146/Main cab"
|      |      |-- 7:13-147 HFP-11 "E/L10/EC3040/SD147/Main cab"
|      |      |-- 7:13-148 HFP-11 "E/L10/EC3040/SD148/Accounts cab"
|      |      |-- 7:13-149 HFPT-11 "E/L10/EC3040/HD149/Pantry"
|      |      |-- 7:13-150 HFP-11 "E/L10/EC3040/SD150/Pantry"
|      |      |-- 7:13-151 HTRI-R "E/L10/EC3040/CM151/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-152 HMS-S/D/M/SA "E/L10/EC3040/MCP152/Entry dr Psg"
|      |      |-- 7:13-153 HFP-11 "E/L10/EC3040/SD153/Reception"
|      |      |-- 7:13-154 HFP-11 "E/L10/EC3040/SD154/Assorter cab"
|      |      |-- 7:13-155 HFP-11 "E/L10/EC2083/SD155/Entry Psg"
|      |      |-- 7:13-156 HFP-11 "E/L10/EC2083/SD156/Psg nr Acct c"
|      |      |-- 7:13-157 HFP-11 "E/L10/EC2083/SD157/Accounts cab"
|      |      |-- 7:13-158 HFPT-11 "E/L10/EC2083/HD158/Pantry"
|      |      |-- 7:13-159 HFP-11 "E/L10/EC2083/SD159/Accounts cab"
|      |      |-- 7:13-160 HFP-11 "E/L10/EC2083/SD160/Main cab 1"
|      |      |-- 7:13-161 HFP-11 "E/L10/EC2083/SD161/Main cab 1"
|      |      |-- 7:13-162 HFP-11 "E/L10/EC2083/SD162/Main cab 2"
|      |      |-- 7:13-163 HFP-11 "E/L10/EC2083/SD163/Main cab 3"
|      |      |-- 7:13-164 HFP-11 "E/L10/EC2083/SD164/Main cab 3"
|      |      |-- 7:13-165 HFP-11 "E/L10/EC2083/SD165/Psg nr Pantry"
|      |      |-- 7:13-166 HTRI-R "E/L10/EC2083/CM166/Entry Psg "
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-167 HMS-S/D/M/SA "E/L10/EC2083/MCP167/Entry Psg "
|      |      |-- 7:13-168 HFP-11 "E/L10/EC2090/SD168/Main cab1"
|      |      |-- 7:13-169 HFP-11 "E/L10/EC2090/SD169/Main cab2"
|      |      |-- 7:13-170 HFP-11 "E/L10/EC2090/SD170/Entry Psg"
|      |      |-- 7:13-171 HTRI-R "E/L10/EC2090/CM171/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-172 HMS-S/D/M/SA "E/L10/EC2090/MCP172/Entry Psg"
|      |      |-- 7:13-211 HFP-11 "E/L10/EE2020/SD211/Main cab"
|      |      |-- 7:13-212 HFP-11 "E/L10/EE2020/SD212/Assorter cab"
|      |      |-- 7:13-213 HFP-11 "E/L10/EE2020/SD213/Psg nr Assort"
|      |      |-- 7:13-214 HFPT-11 "E/L10/EE2020/HD214/Pantry"
|      |      |-- 7:13-215 HTRI-R "E/L10/EE2020/CM215/Pantry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 7:13-216 HMS-S/D/M/SA "E/L10/EE2020/MCP216/Pantry Psg"
|      |      |-- 7:13-217 HFP-11 "E/L10/EC2131/SD217/Cab 4"
|      |      |-- 7:13-218 HFP-11 "E/L10/EC2131/SD218/Cab 3"
|      |      |-- 7:13-219 HFP-11 "E/L10/EC2131/SD219/Cab 2"
|      |      |-- 7:13-220 HFP-11 "E/L10/EC2131/SD220/Cab 1"
|      |      |-- 7:13-221 HFP-11 "E/L10/EC2131/SD221/Cab 5"
```

7 Desigo Fire Safety Modular "BDB TOWER E" Local

CAB-1 "CAB-1 Enclosure #2"

CC-5 "Card Cage 5 Slots"

7:13 XDLC "DLC @ address 13 L10"

```
|      |      |-- 7:13-222 HFP-11 "E/L10/EC2131/SD222/Cab 6"
|      |      |-- 7:13-223 HFP-11 "E/L10/EC2131/SD223/Cab 7"
|      |      |-- 7:13-224 HFP-11 "E/L10/EC2131/SD224/Psg nr Cab 3"
|      |      |-- 7:13-225 HFP-11 "E/L10/EC2131/SD225/Reception"
|      |      |-- 7:13-226 HFP-11 "E/L10/EC2131/SD226/Pantry"
|      |      |-- 7:13-227 HTRI-R "E/L10/EC2131/CM227/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 7:13-228 HMS-S/D/M/SA "E/L10/EC2131/MCP228/Entry dr psg"
|      |      |-- 7:13-229 HFP-11 "E/L10/EE3090/SD229/Cab 2"
|      |      |-- 7:13-230 HFP-11 "E/L10/EE3090/SD230/Cab 3"
|      |      |-- 7:13-231 HFP-11 "E/L10/EE3090/SD231/Account cab"
|      |      |-- 7:13-232 HFP-11 "E/L10/EE3090/SD232/Psg nr Accoun"
|      |      |-- 7:13-233 HFP-11 "E/L10/EE3090/SD233/Entry psg"
|      |      |-- 7:13-234 HFP-11 "E/L10/EE3090/SD234/Main cab"
|      |      |-- 7:13-235 HTRI-R "E/L10/EE3090/CM235/Entry psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 7:13-236 HMS-S/D/M/SA "E/L10/EE3090/MCP236/Entry psg"
|      |      |-- 7:13-237 HFP-11 "E/L10/EE3090/SD237/Pantry"
|      |      |-- 7:13-238 HFP-11 "E/L10/EE3080/SD238/Entry psg"
|      |      |-- 7:13-239 HFP-11 "E/L10/EE3080/SD239/Psg nr sales "
|      |      |-- 7:13-240 HFP-11 "E/L10/EE3080/SD240/Psg nr Assort"
|      |      |-- 7:13-241 HFP-11 "E/L10/EE3080/SD241/Sales cab"
|      |      |-- 7:13-242 HFP-11 "E/L10/EE3080/SD242/Assorter cab"
|      |      |-- 7:13-243 HFP-11 "E/L10/EE3080/SD243/Lunch cab"
|      |      |-- 7:13-244 HFP-11 "E/L10/EE3080/SD244/Pantry"
|      |      |-- 7:13-245 HFP-11 "E/L10/EE3080/SD245/Main cab 1"
|      |      |-- 7:13-246 HFP-11 "E/L10/EE3080/SD246/Main cab 2"
|      |      |-- 7:13-247 HFP-11 "E/L10/EE3080/SD247/Main cab 2"
|      |      |-- 7:13-248 HTRI-R "E/L10/EE3080/CM248/Entry psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |-- 7:13-249 HMS-S/D/M/SA "E/L10/EE3080/MCP249/Entry psg"
|      |      |-- 7:13-250 HFP-11 "E/L10/EC1140/SD250/AFC"
|      |      |-- 7:13-251 HFP-11 "E/L10/EC1140/SD251/AFC"
|      |-- 7:18 PSC-12 "PSC-12 @ address 18"
|      |      |-- 7:18-1 PSC Relay "Relay @ 011:001 - Common Alarm"
|      |      |-- 7:18-2 PSC Relay "Relay @ 011:002 - Common Trouble"
|-- 8 Desigo Fire Safety Modular "BDB TOWER F" Local
|      |-- System Flags
|      |-- History Log
|      |-- Behavior
|      |-- Voice
|      |-- Maintenance
|      |-- Field Devices
|      |-- Miscellaneous
|      |-- CAB-2 "CAB-2 Enclosure #1"
|      |      |-- CC-5 "Card Cage 5 Slots"
|      |      |-- 8:1 XDLC "XDLC @ address 1 L1"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:1 XDLC "XDLC @ address 1 L1"

```
|      |      |      |-- 8:1-1 HMS-S/D/M/SA "F/L1/EC/GND/MCP1/LIFT LOBBY"
|      |      |      |-- 8:1-2 HTRI-R "F/L1/EC/GND/CM2/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-3 HTRI-S "F/L1/EC/GND/MM3/LIFT LOBBY"
|      |      |      |-- 8:1-4 HFP-11 "F/L1/EC/GND/SD4/ERM"
|      |      |      |-- 8:1-5 HFP-11 "F/L1/EC/GND/SD5/LIFT LOBBY"
|      |      |      |-- 8:1-6 HFP-11 "F/L1/EC/GND/SD6/LIFT LOBBY"
|      |      |      |-- 8:1-7 HFP-11 "F/L1/EC/GND/SD7/LIFT LOBBY"
|      |      |      |-- 8:1-8 HFP-11 "F/L1/EC/GND/SD8/LIFT LOBBY"
|      |      |      |-- 8:1-9 HTRI-R "F/L1/EC/GND/CM9/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-10 HFP-11 "F/L1/EC/GND/SD10/AHU RM"
|      |      |      |-- 8:1-11 HMS-S/D/M/SA "F/L1/CC/GND/MCP11/LIFT LOBBY"
|      |      |      |-- 8:1-12 HTRI-R "F/L1/CC/GND/CM12/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-13 HTRI-S "F/L1/CC/GND/MM13/LIFT LOBBY"
|      |      |      |-- 8:1-14 HFP-11 "F/L1/CC/GND/SD14/LIFT LOBBY"
|      |      |      |-- 8:1-15 HFP-11 "F/L1/CC/GND/SD15/LIFT LOBBY"
|      |      |      |-- 8:1-16 HFP-11 "F/L1/CC/GND/SD16/LIFT LOBBY"
|      |      |      |-- 8:1-17 HFP-11 "F/L1/CC/GND/SD17/ELEC RM"
|      |      |      |-- 8:1-18 HTRI-S "F/L1/UB/MM18/Nr Fire panel AC "
|      |      |      |-- 8:1-20 HMS-S/D/M/SA "F/L1/FW/GND/MCP20/LIFT LOBBY"
|      |      |      |-- 8:1-21 HTRI-R "F/L1/WC/GND/CM21/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-22 HTRI-S "F/L1/WC/GND/MM22/LIFT LOBBY"
|      |      |      |-- 8:1-23 HFP-11 "F/L1/WC/GND/SD23/ELECT RM"
|      |      |      |-- 8:1-24 HFP-11 "F/L1/WC/GND/SD24/LIFT LOBBY"
|      |      |      |-- 8:1-25 HFP-11 "F/L1/WC/GND/SD25/LIFT LOBBY"
|      |      |      |-- 8:1-26 HFP-11 "F/L1/WC/GND/SD26/LIFT LOBBY"
|      |      |      |-- 8:1-27 HTRI-R "F/L1/WC/GND/CM27/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-28 HFP-11 "F/L1/WC/GND/SD28/AHU RM"
|      |      |      |-- 8:1-29 HFP-11 "F/L1/WC/GND/SD29/LIFT LOBBY"
|      |      |      |-- 8:1-30 HFP-11 "F/L1/FE2100/SD30/Main cab"
|      |      |      |-- 8:1-31 HFP-11 "F/L1/FE2100/SD31/Assorter cab"
|      |      |      |-- 8:1-32 HFP-11 "F/L1/FE2100/SD32/Assorter cab"
|      |      |      |-- 8:1-33 HFP-11 "F/L1/FE2100/SD33/Pantry"
|      |      |      |-- 8:1-34 HTRI-R "F/L1/FE2100/CM34/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-35 HMS-S/D/M/SA "F/L1/FE2100/MCP35/Entry dr Psg"
|      |      |      |-- 8:1-36 HFP-11 "F/L1/FE1040/SD36/Pantry"
|      |      |      |-- 8:1-37 HFP-11 "F/L1/FE1040/SD37/Account cab"
|      |      |      |-- 8:1-38 HFP-11 "F/L1/FE1040/SD38/Main cab"
|      |      |      |-- 8:1-39 HFP-11 "F/L1/FE1040/SD39/Assorter cab"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:1 XDLC "XDLC @ address 1 L1"

```
|      |      |      |-- 8:1-40 HTRI-R "F/L1/FE1040/CM40/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:1-41 HMS-S/D/M/SA "F/L1/FE1040/MCP41/Entry dr Psg"
|      |      |      |-- 8:1-42 HFP-11 "F/L1/FE2010/SD42/Main cab"
|      |      |      |-- 8:1-43 HTRI-R "F/L1/FE2010/CM43/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:1-44 HMS-S/D/M/SA "F/L1/FE2010/MCP44/Entry dr Psg"
|      |      |      |-- 8:1-45 HFP-11 "F/L1/FE2070/SD45/Main cab"
|      |      |      |-- 8:1-46 HFP-11 "F/L1/FE2070/SD46/Main cab"
|      |      |      |-- 8:1-47 HFP-11 "F/L1/FE2070/SD47/Account cab"
|      |      |      |-- 8:1-48 HFP-11 "F/L1/FE2070/SD48/Psg nr Account "
|      |      |      |-- 8:1-49 HFP-11 "F/L1/FE2070/SD49/Assorter cab"
|      |      |      |-- 8:1-50 HFP-11 "F/L1/FE2070/SD50/Pantry"
|      |      |      |-- 8:1-51 HTRI-R "F/L1/FE2070/CM51/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:1-52 HMS-S/D/M/SA "F/L1/FE2070/MCP52/Entry dr Psg"
|      |      |      |-- 8:1-58 HFP-11 "F/L1/FE2110/SD58/Main cab"
|      |      |      |-- 8:1-59 HFP-11 "F/L1/FE2110/SD59/Cab 2 "
|      |      |      |-- 8:1-60 HFP-11 "F/L1/FE2110/SD60/Cab 1"
|      |      |      |-- 8:1-61 HFP-11 "F/L1/FE2110/SD61/Entry Psg"
|      |      |      |-- 8:1-62 HTRI-R "F/L1/FE2110/CM62/Entry dr psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:1-63 HMS-S/D/M/SA "F/L1/FE2110/MCP63/Entry dr psg"
|      |      |      |-- 8:1-64 HFP-11 "F/L1/FE2090/SD64/Main cab"
|      |      |      |-- 8:1-65 HFP-11 "F/L1/FE2090/SD65/Assorter cab"
|      |      |      |-- 8:1-66 HFP-11 "F/L1/FE2090/SD66/Pantry Psg"
|      |      |      |-- 8:1-67 HFP-11 "F/L1/FE2090/SD67/Psg nr MC"
|      |      |      |-- 8:1-68 HTRI-R "F/L1/FE2090/CM68/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:1-69 HMS-S/D/M/SA "F/L1/FE2090/MCP69/Entry dr Psg"
|      |      |      |-- 8:1-70 HFP-11 "F/L1/FE1010/SD70/Main cab"
|      |      |      |-- 8:1-71 HFP-11 "F/L1/FE1010/SD71/Assorter cab"
|      |      |      |-- 8:1-72 HFP-11 "F/L1/FE1010/SD72/Entry dr Psg"
|      |      |      |-- 8:1-73 HTRI-R "F/L1/FE1010/CM73/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:1-74 HMS-S/D/M/SA "F/L1/FE1010/MCP74/Entry dr Psg"
|      |      |      |-- 8:1-102 HTRI-S "F/L1/CC/UB/MM102/ELEC ROOM"
|      |      |      |-- 8:1-103 HTRI-R "F/L1/EC/UB/CM103/FD COLUMN F717"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:1-106 HTRI-R "F/L1/WC/UB/CM106/RAMP NO. 5"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:1-107 HMS-S/D/M/SA "F/L1/WC/UB/MCP107/RAMP NO. 5"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:1 XDLC "XDLC @ address 1 L1"

```
|      |      |      |-- 8:1-108 HTRI-R "F/L1/WC/UB/CM108/RAMP NO 5"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-109 HMS-S/D/M/SA "F/L1/WC/UB/MCP109/RAMP NO 5"
|      |      |      |-- 8:1-110 HTRI-R "F/L1/WC/UB/CM110/Near Ramp 6""
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-111 HMS-S/D/M/SA "F/L1/WC/UB/MCP111/Near Ramp 6""
|      |      |      |-- 8:1-112 HTRI-S "F/L1/WC/UB/MM112/ELEC ROOM"
|      |      |      |-- 8:1-113 HTRI-R "F/L1/CC/UB/CM113/ST COLUMN F694"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-114 HMS-S/D/M/SA "F/L1/CC/UB/MCP114/ST COLUMN F694"
|      |      |      |-- 8:1-115 HTRI-R "F/L1/CC/UB/CM115/ST COLUMN F650"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-116 HMS-S/D/M/SA "F/L1/CC/UB/MCP116/ST COLUMN F650"
|      |      |      |-- 8:1-117 HTRI-R "F/L1/EC/UB/CM117/ST COLUMN F714"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-118 HMS-S/D/M/SA "F/L1/EC/UB/MCP118/ST COLUMN F714"
|      |      |      |-- 8:1-119 HTRI-R "F/L1/EC/UB/CM119/EMG EXIT 4"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-120 HMS-S/D/M/SA "F/L1/EC/UB/MCP120/EMG EXIT 4"
|      |      |      |-- 8:1-122 HTRI-R "F/L1/EC/UB/CM122/AC PLANT DOOR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:1-123 HMS-S/D/M/SA "F/L1/EC/UB/MCP123/AC PLANT DOOR"
|      |      |      |-- 8:1-124 HTRI-S "F/L1/EC/UB/MM124/ELEC ROOM"
|      |      |      |-- 8:1-125 HTRI-S "F/L1/EC/UB/MM125/LIFT ROOM"
|      |      |      |-- 8:1-126 HFP-11 "F/L1/CC/UB/SD126/ELEC ROOM"
|      |      |      |-- 8:1-127 HFP-11 "F/L1/WC/UB/SD127/ELEC ROOM"
|      |      |      |-- 8:1-132 HFP-11 "F/L1/EC/UB/SD132/ELEC ROOM"
|      |      |      |-- 8:1-133 HFP-11 "F/L1/EC/UB/SD133/FE Change Rm"
|      |      |      |-- 8:1-134 HFP-11 "F/L1/EC/UB/SD134/LIFT MC RM"
|      |      |      |-- 8:1-135 HTRI-S "F/L1/UB/MM135/Air N com office"
|      |      |      |-- 8:1-136 HTRI-S "F/L1/UB/MM136/vodafone office"
|      |      |      |-- 8:1-137 HTRI-S "F/L1/UB/MM137/Reliance office"
|      |      |      |-- 8:1-138 HTRI-S "F/L1/UB/MM138/QBC office"
|      |      |      |-- 8:1-139 HTRI-S "F/L1/UB/MM139/Hathway office"
|      |      |      |-- 8:1-140 HTRI-S "F/L1/UB/MM140/Airtel office"
|      |      |      |-- 8:1-141 HTRI-S "F/L1/UB/MM141/Tata power office"
|      |      |      |-- 8:1-142 HFP-11 "F/L1/UB/SD142/UPS power room"
|      |      |      |-- 8:1-143 HFP-11 "F/L1/UB/SD143/UPS power room"
|      |      |      |-- 8:1-144 HFP-11 "F/L1/UB/SD144/Old DC near Ac pla"
|      |      |      |-- 8:1-145 HFP-11 "F/L1/FE1010/SD145/Assorter Cabin"
|      |      |      |-- 8:1-146 HFP-11 "F/L1/FE2100/SD146/PSG NR PANTR"
|      |      |      |-- 8:2 XDLC "XDLC @ address 2 L2"
|      |      |      |-- 8:2-1 HFP-11 "F/L2/CC/3F/SD1/ELECT RM SD"
```


8 Desigo Fire Safety Modular "BDB TOWER F" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"
8:2 XDLC "XDLC @ address 2 L2"

				--	8:2-2	HMS-S/D/M/SA	"F/L2/CC/3F/MCP2/FIRE SHAFT L.L."
				--	8:2-3	HTRI-R	"F/L2/CC/3F/CM3/FIRE SHAFT L.L."
					--	Switch	" "
					--	Relay	
				--	8:2-4	HTRI-S	"F/L2/CC/3F/MM4/FIRE SHAFT L.L."
				--	8:2-5	HFP-11	"F/L2/CC/3F/SD5/LIFT LOBBY SD"
				--	8:2-6	HFP-11	"F/L2/CC/3F/SD6/LIFT LOBBY SD"
				--	8:2-7	HTRI-R	"F/L2/CC/3F/CM7/AHU RM CM"
					--	Switch	" "
					--	Relay	
				--	8:2-8	HFP-11	"F/L2/CC/3F/SD8/AHU RM SD"
				--	8:2-9	HTRI-R	"F/L2/CC/3F/CM9/ELECT RM SD"
					--	Switch	" "
					--	Relay	
				--	8:2-10	HFP-11	"F/L2/CC/3F/SD10/CORR NR FC 3023"
				--	8:2-11	HFP-11	"F/L2/CC/3F/SD11/CORR NR FC 3023"
				--	8:2-12	HFP-11	"F/L2/CC/3F/SD12/CORR NR FC3/S04"
				--	8:2-13	HFP-11	"F/L2/CC/3F/SD13/CORR NR FC3/S04"
				--	8:2-14	HFP-11	"F/L2/CC/3F/SD14/CORR NR FC 3014"
				--	8:2-15	HFP-11	"F/L2/CC/3F/SD15/CORR NR FC 3014"
				--	8:2-18	HFP-11	"F/L2/EC/3F/SD18/ELECT RM SD"
				--	8:2-19	HTRI-R	"F/L2/EC/3F/CM19/AHU RM CM"
					--	Switch	" "
					--	Relay	
				--	8:2-20	HFP-11	"F/L2/EC/3F/SD20/AHU RM SD"
				--	8:2-21	HFP-11	"F/L2/EC/3F/SD21/LIFT LOBBY SD"
				--	8:2-22	HMS-S/D/M/SA	"F/L2/EC/3F/MCP22/FIRE SHAFT L.L."
				--	8:2-23	HTRI-R	"F/L2/EC/3F/CM23/FIRE SHAFT L.L."
					--	Switch	" "
					--	Relay	
				--	8:2-24	HTRI-S	"F/L2/EC/3F/MM24/FIRE SHAFT L.L."
				--	8:2-26	HFP-11	"F/L2/CC/2F/SD26/CORR NR ELECT R."
				--	8:2-27	HFP-11	"F/L2/CC/2F/SD27/CORR NR FW2/S08"
				--	8:2-28	HFP-11	"F/L2/CC/2F/SD28/CORR NR FW2/S22"
				--	8:2-29	HFP-11	"F/L2/CC/2F/SD29/CORR NR FW2/S22"
				--	8:2-30	HMS-S/D/M/SA	"F/L2/2F/MCP30/FIRE ESCAPE STR"
				--	8:2-31	HTRI-R	"F/L2/CC/2F/CM31/FIRE ESC STR"
					--	Switch	" "
					--	Relay	
				--	8:2-32	HFP-11	"F/L2/CC/2F/SD32/NR FIRE SHAFT"
				--	8:2-33	HFP-11	"F/L2/CC/2F/SD33/NR FIRE SHAFT"
				--	8:2-34	HFP-11	"F/L2/CC/2F/SD34/CORR NR FC 2090"
				--	8:2-35	HFP-11	"F/L2/CC/2F/SD35/CORR NR FC 2090"
				--	8:2-36	HFP-11	"F/L2/CC/2F/SD36/CORR NR 2110"
				--	8:2-37	HFP-11	"F/L2/CC/2F/SD37/CORR NR FC 2110"
				--	8:2-38	HFP-11	"F/L2/CC/2F/SD38/CORR NR E.R."
				--	8:2-39	HTRI-R	"F/L2/CC/1F/CM39/DR RELEASE C TO E"
					--	Switch	" "
					--	Relay	
				--	8:2-40	HFP-11	"F/L2/CC/2F/SD40/ELECT RM SD"

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:2 XDLC "XDLC @ address 2 L2"

```
|      |      |      |-- 8:2-41 HTRI-R "F/L2/CC/2F/CM41/DR RELEASE CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:2-42 HMS-S/D/M/SA "F/L2/2F/MCP42/FIRE SHAFT L.L."
|      |      |      |-- 8:2-43 HTRI-R "F/L2/CC/2F/CM43/FIRE SHAFT L.L."
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:2-44 HTRI-S "F/L2/CC/2F/MM44/FIRE SHAFT L.L."
|      |      |      |-- 8:2-45 HFP-11 "F/L2/CC/2F/SD45/LIFT LOBBY SD"
|      |      |      |-- 8:2-46 HFP-11 "F/L2/CC/2F/SD46/LIFT LOBBY SD"
|      |      |      |-- 8:2-47 HTRI-R "F/L2/CC/2F/CM47/AHU RM CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:2-48 HFP-11 "F/L2/CC/2F/SD48/AHU RM SD"
|      |      |      |-- 8:2-50 HFP-11 "F/L2/CC/2F/SD50/CORR NR AHU"
|      |      |      |-- 8:2-51 HFP-11 "F/L2/CC/2F/SD51/CORR NR FC 2130"
|      |      |      |-- 8:2-52 HFP-11 "F/L2/CC/2F/SD52/CORR NR FC 2140"
|      |      |      |-- 8:2-55 HFP-11 "F/L2/EC/2F/SD55/CORR NR FE 2070"
|      |      |      |-- 8:2-56 HFP-11 "F/L2/EC/2F/SD56/CORR NR FE 2090"
|      |      |      |-- 8:2-57 HFP-11 "F/L2/EC/2F/SD57/CORR NR FE 2100"
|      |      |      |-- 8:2-58 HFP-11 "F/L2/EC/2F/SD58/CORR NR FE 2120"
|      |      |      |-- 8:2-59 HFP-11 "F/L2/EC/2F/SD59/CORR NR FE 2020"
|      |      |      |-- 8:2-60 HTRI-R "F/L2/EC/2F/CM60/DR RELEASE CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:2-61 HFP-11 "F/L2/EC/2F/SD61/ELECT RM SD"
|      |      |      |-- 8:2-62 HTRI-R "F/L2/EC/2F/CM62/AHU RM CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:2-63 HFP-11 "F/L2/EC/2F/SD63/AHU RM SD"
|      |      |      |-- 8:2-64 HFP-11 "F/L2/EC/2F/SD64/LIFT LOBBY SD"
|      |      |      |-- 8:2-65 HMS-S/D/M/SA "F/L2/EC/2F/MCP65/FIRE SHAFT L.L."
|      |      |      |-- 8:2-66 HTRI-R "F/L2/EC/2F/CM66/FIRE SHAFT L.L."
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:2-67 HTRI-S "F/L2/EC/2F/MM67/FIRE SHAFT L.L."
|      |      |      |-- 8:2-68 HFP-11 "F/L2/CC/1F/SD68/ELECT RM SD"
|      |      |      |-- 8:2-69 HFP-11 "F/L2/FC2100/SD69/main cab 1"
|      |      |      |-- 8:2-70 HFP-11 "F/L2/FC2100/SD70/Assoter cab 1"
|      |      |      |-- 8:2-71 HFP-11 "F/L2/FC2100/SD71/psg nr Assoter "
|      |      |      |-- 8:2-72 HFP-11 "F/L2/FC2100/SD72/Assorter cab 2"
|      |      |      |-- 8:2-73 HFP-11 "F/L2/FC2100/SD73/main Cab2"
|      |      |      |-- 8:2-74 HFP-11 "F/L2/FC2100/SD74/Account cab"
|      |      |      |-- 8:2-75 HFPT-11 "F/L2/FC2100/HD75/Pantry"
|      |      |      |-- 8:2-76 HTRI-R "F/L2/FC2100/CM76/AFC Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:2-77 HMS-S/D/M/SA "F/L2/FC2100/MCP77/Entry Psg"
|      |      |      |-- 8:2-78 HFP-11 "F/L2/EC/1F/SD78/CORR NR FE1/S27"
|      |      |      |-- 8:2-79 HFP-11 "F/L2/EC/1F/SD79/CORR NR FE 1052"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:2 XDLC "XDLC @ address 2 L2"

			-- 8:2-80 HFP-11 "F/L2/EC/1F/SD80/CORR NR FE 1060"
			-- 8:2-81 HFP-11 "F/L2/EC/1F/SD81/CORR NR FE1/S28"
			-- 8:2-82 HFP-11 "F/L2/EC/1F/SD82/CORR NR FE1/S28"
			-- 8:2-83 HFP-11 "F/L2/EC/1F/SD83/ELECT RM SD"
			-- 8:2-84 HTRI-R "F/L2/EC/1F/CM84/AHU RM CM"
			-- Switch ""
			-- Relay
			-- 8:2-85 HFP-11 "F/L2/EC/1F/SD85/AHU RM SD"
			-- 8:2-86 HFP-11 "F/L2/EC/1F/SD86/LIFT LOBBY SD"
			-- 8:2-87 HMS-S/D/M/SA "F/L2/1F/MCP87/FIRE SHAFT L.L."
			-- 8:2-88 HTRI-R "F/L2/EC/1F/CM88/FIRE SHAFT L.L."
			-- Switch ""
			-- Relay
			-- 8:2-89 HTRI-S "F/L2/EC/1F/MM89/FIRE SHAFT L.L."
			-- 8:2-90 HFP-11 "L2/FC3015/SD90/MANAGER CAB"
			-- 8:2-91 HFP-11 "L2/FC3015/SD91/LUNCH RM"
			-- 8:2-92 HFP-11 "L2/FC3015/SD92/CHARULATA MD CAB"
			-- 8:2-93 HFP-11 "L2/FC3015/SD93/PSG NR ASSOTER CA"
			-- 8:2-94 HFP-11 "L2/FC3015/SD94/ASSOTER CAB"
			-- 8:2-95 HFP-11 "L2/FC3015/SD95/MAIN CAB 1"
			-- 8:2-96 HFP-11 "L2/FC3015/SD96/MAIN CAB2"
			-- 8:2-97 HFP-11 "L2/FC3015/SD97/RECEPTION"
			-- 8:2-98 HFP-11 "L2/FC3015/SD98/PANTRY"
			-- 8:2-99 HMS-S/D/M/SA "L2/FC3015/MCP99/Entry dr psg"
			-- 8:2-100 HTRI-S "F/L2/EC/3F/MM100/FE3011"
			-- 8:2-101 HMS-S/D/M/SA "L2/FC3015/MCP101/Entry dr psg"
			-- 8:2-102 HTRI-S "F/L2/EC/2F/MM102/FE2050"
			-- 8:2-103 HTRI-S "F/L2/EC/2F/MM103/FE2080"
			-- 8:2-104 HTRI-R "L2/F/FC3015/CM104/ENTRY DR AFC"
			-- Switch ""
			-- Relay
			-- 8:2-105 HTRI-S "F/L2/EC/2F/MM105/FE2040"
			-- 8:2-107 HTRI-S "F/L2/EC/2F/MM107/FE2030"
			-- 8:2-109 HTRI-S "F/L2/EC/2F/MM109/FE2120"
			-- 8:2-110 HTRI-S "F/L2/EC/2F/MM110/FE2020"
			-- 8:2-114 HTRI-S "F/L2/EC/1F/MM114/FE1030"
			-- 8:2-115 HTRI-S "F/L2/EC/1F/MM115/FE1020"
			-- 8:2-117 HTRI-S "F/L2/EC/1F/MM117/FE1050A"
			-- 8:2-119 HTRI-S "F/L2/EC/1F/MM119/FE1060"
			-- 8:2-121 HTRI-S "F/L2/EC/3F/MM121/FC3011A""
			-- 8:2-123 HTRI-S "F/L2/EC/3F/MM123/FC3013""
			-- 8:2-125 HTRI-S "F/L2/CC/3F/MM125/FC3040"
			-- 8:2-126 HTRI-S "F/L2/CC/3F/MM126/FC3023"
			-- 8:2-127 HTRI-S "F/L2/CC/3F/MM127/FC3011"
			-- 8:2-129 HTRI-S "F/L2/CC/2F/MM129/FC2140"
			-- 8:2-130 HTRI-S "F/L2/CC/2F/MM130/FC2130"
			-- 8:2-133 HTRI-S "F/L2/CC/2F/MM133/FC2120"
			-- 8:2-134 HTRI-S "F/L2/CC/2F/MM134/FC2110"
			-- 8:2-135 HTRI-S "F/L2/CC/2F/MM135/FC2021"
			-- 8:2-138 HTRI-S "F/L2/CC/2F/MM138/FC2022"

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:2 XDLC "XDLC @ address 2 L2"

			-- 8:2-139	HTRI-S	"F/L2/CC/2F/MM139/FC2090"
			-- 8:2-140	HTRI-S	"F/L2/CC/2F/MM140/FC2030"
			-- 8:2-141	HTRI-S	"F/L2/CC/2F/MM141/FC2080"
			-- 8:2-142	HTRI-S	"F/L2/CC/2F/MM142/FC2040"
			-- 8:2-143	HTRI-S	"F/L2/CC/2F/MM143/FC2050"
			-- 8:2-146	HTRI-S	"F/L2/CC/1F/MM146/FC1010"
			-- 8:2-147	HFP-11	"F/L2/FE1051/SD147/Pantry"
			-- 8:2-148	HFP-11	"F/L2/FE1051/SD148/AFC pantry"
			-- 8:2-149	HFP-11	"F/L2/FE1051/SD149/AFC Accounts c"
			-- 8:2-150	HFP-11	"F/L2/FE1051/SD150/Account cab"
			-- 8:2-151	HFP-11	"F/L2/FE1051/SD151/Psg nr Banking"
			-- 8:2-152	HFP-11	"F/L2/FE1051/SD152/Banking cab"
			-- 8:2-153	HFP-11	"F/L2/FE1051/SD153/Assorter cab1"
			-- 8:2-154	HFP-11	"F/L2/FE1051/SD154/AFC main cab1"
			-- 8:2-155	HFP-11	"F/L2/FE1051/SD155/Main cab1"
			-- 8:2-156	HFP-11	"F/L2/FE1051/SD156/AFC Main cab2"
			-- 8:2-157	HFP-11	"F/L2/FE1051/SD157/Main cab2"
			-- 8:2-158	HFP-11	"F/L2/FE1051/SD158/Main cab3"
			-- 8:2-159	HFP-11	"F/L2/FE1051/SD159/AFC assorter c"
			-- 8:2-160	HFP-11	"F/L2/FE1051/SD160/Assorter cab2"
			-- 8:2-161	HFP-11	"F/L2/FE1051/SD161/Entry dr psg"
			-- 8:2-162	HTRI-R	"F/L2/FE1051/CM162/Entry dr psg"
				-- Switch	" "
				-- Relay	
			-- 8:2-163	HMS-S/D/M/SA	"F/L2/FE1051/MCP163/Entry dr psg"
			-- 8:2-164	HFP-11	"F/L2/FE1052/SD164/Main cab"
			-- 8:2-165	HFP-11	"F/L2/FE1052/SD165/Sales cab"
			-- 8:2-166	HFP-11	"F/L2/FE1052/SD166/Account cab"
			-- 8:2-167	HFP-11	"F/L2/FE1052/SD167/Pantry"
			-- 8:2-168	HFP-11	"F/L2/FE1052/SD168/AFC sales cab"
			-- 8:2-169	HFP-11	"F/L2/FE1052/SD169/AFC Accounts c"
			-- 8:2-170	HTRI-R	"F/L2/FE1052/CM170/Pantry"
				-- Switch	" "
				-- Relay	
			-- 8:2-171	HMS-S/D/M/SA	"F/L2/FE1052/MCP171/Entry dr Psg"
			-- 8:2-172	HFP-11	"F/L2/FE1052/SD172/Psg nr Main ca"
			-- 8:2-173	HFP-11	"F/L2/FC2021/SD173/Main cab"
			-- 8:2-174	HFP-11	"F/L2/FC2021/SD174/Entry Psg"
			-- 8:2-175	HFP-11	"F/L2/FC2021/SD175/Assorter cab"
			-- 8:2-176	HTRI-R	"F/L2/FC2021/CM176/AFC Entry dr"
				-- Switch	" "
				-- Relay	
			-- 8:2-177	HMS-S/D/M/SA	"F/L2/FC2021/MCP177/Entry dr"
			-- 8:2-199	HFP-11	"F/L2/FC2011/SD199/Main Cabin1"
			-- 8:2-200	HFP-11	"F/L2/FC2011/SD200/Main Cabin2"
			-- 8:2-201	HFP-11	"F/L2/FC2011/SD201/Account Cab 1"
			-- 8:2-202	HFP-11	"F/L2/FC2011/SD202/Account Cab 2"
			-- 8:2-203	HFP-11	"F/L2/FC2011/SD203/Pantry Psg"
			-- 8:2-204	HFP-11	"F/L2/FC2011/SD204/Reception Psg"
			-- 8:2-205	HTRI-R	"F/L2/FC2011/CM205/Entry dr Psg"

```
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 8:2-206 HMS-S/D/M/SA "F/L2/FC2011/MCP206/Entry dr Psg"
| | | |-- 8:2-213 HFP-11 "F/L2/FC2150/SD213/Main Cabin"
| | | |-- 8:2-214 HFP-11 "F/L2/FC2150/SD214/Assorting Cabi"
| | | |-- 8:2-215 HFP-11 "F/L2/FC2150/SD215/Account Cabin"
| | | |-- 8:2-216 HFP-11 "F/L2/FC2150/SD216/Account Cabin1"
| | | |-- 8:2-217 HFP-11 "F/L2/FC2150/SD217/Pantry"
| | | |-- 8:2-218 HTRI-R "F/L2/FC2150/CM218/Entry dr Psg"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 8:2-219 HMS-S/D/M/SA "F/L2/FC2150/MCP219/Entry dr Psg"
| | | |-- 8:2-220 HFP-11 "F/L2/FC3030/SD220/Main Cabin1"
| | | |-- 8:2-221 HFP-11 "F/L2/FC3030/SD221/Main Cabin2"
| | | |-- 8:2-222 HFP-11 "F/L2/FC3030/SD222/Assorter cab"
| | | |-- 8:2-223 HFP-11 "F/L2/FC3030/SD223/Psg nr Assorte"
| | | |-- 8:2-224 HFP-11 "F/L2/FC3030/SD224/Pantry"
| | | |-- 8:2-225 HTRI-R "F/L2/FC3030/CM225/Entry dr Psg"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 8:2-226 HMS-S/D/M/SA "F/L2/FC3030/MCP226/Entry dr Psg"
| | | |-- 8:2-227 HFP-11 "F/L2/FC2160/SD227/Accounts cab"
| | | |-- 8:2-228 HFP-11 "F/L2/FC2160/SD228/Assorter cab1"
| | | |-- 8:2-229 HFP-11 "F/L2/FC2160/SD229/Assorter cab2"
| | | |-- 8:2-230 HFP-11 "F/L2/FC2160/SD230/Main cab"
| | | |-- 8:2-231 HFPT-11 "F/L2/FC2160/HD231/Pantry"
| | | |-- 8:2-232 HFP-11 "F/L2/FC2160/SD232/Lunch rm"
| | | |-- 8:2-233 HFP-11 "F/L2/FC2160/SD233/Entry Psg"
| | | |-- 8:2-234 HTRI-R "F/L2/FC2160/CM234/Entry Psg"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 8:2-235 HMS-S/D/M/SA "F/L2/FC2160/MCP235/Entry Psg"
| | | |-- 8:2-236 HFP-11 "F/L2/FC2060/SD236/Pantry"
| | | |-- 8:2-237 HFP-11 "F/L2/FC2060/SD237/Accounts cab"
| | | |-- 8:2-238 HFP-11 "F/L2/FC2060/SD238/Accounts cab"
| | | |-- 8:2-239 FDOT421 "F/L2/FC2060/SD239/Assorter cab"
| | | |-- 8:2-240 HFP-11 "F/L2/FC2060/SD240/Main cab"
| | | |-- 8:2-241 HFP-11 "F/L2/FC2060/SD241/Main cab"
| | | |-- 8:2-242 HFP-11 "F/L2/FC2060/SD242/Main cab"
| | | |-- 8:2-243 HFP-11 "F/L2/FC2060/SD243/Psg nr Assorte"
| | | |-- 8:2-244 HFP-11 "F/L2/FC2060/SD244/Entry dr Psg"
| | | |-- 8:2-245 HTRI-R "F/L2/FC2060/CM245/Entry dr Psg"
| | | |-- Switch ""
| | | |-- Relay
| | | |-- 8:2-246 HMS-S/D/M/SA "F/L2/FC2060/MCP246/Entry dr Psg"
| | | |-- 8:2-247 HFP-11 "F/L2/FC2160/SD247/ACCOUNT CAB"
| | | |-- 8:2-248 HFP-11 "F/L2/FC2160/SD248/PSG NR ACC CAB"
| | |-- 8:3 XDLC "XDLC @ address 3 L3"
| | |-- 8:3-1 HFP-11 "F/L3/WC/2F/SD1/CORR NR FW2/S12"
| | |-- 8:3-2 HFP-11 "F/L3/WC/2F/SD2/CORR NR FW2/S12"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:3 XDLC "XDLC @ address 3 L3"

```
|      |      |      |-- 8:3-3 HMS-S/D/M/SA "F/L3/WC/2F/MCP3/FIRE ESC STR"
|      |      |      |-- 8:3-4 HTRI-R "F/L3/WC/2F/CM4/FIRE ESC STR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-5 HFP-11 "F/L3/WC/2F/SD5/CORR NR FW 2110"
|      |      |      |-- 8:3-6 HFP-11 "F/L3/WC/2F/SD6/CORR NR FW 2110"
|      |      |      |-- 8:3-7 HFP-11 "F/L3/WC/2F/SD7/AHU RM"
|      |      |      |-- 8:3-8 HTRI-R "F/L3/WC/2F/CM8/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-9 HFP-11 "F/L3/WC/2F/SD9/ CORR EW 2130"
|      |      |      |-- 8:3-10 HFP-11 "F/L3/WC/2F/SD10/ CORR EW 2120"
|      |      |      |-- 8:3-11 HTRI-R "F/L3/WC/2F/CM11/DR RELEASE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-12 HTRI-R "F/L3/WC/2F/CM12/FIRE ESC STR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-13 HTRI-S "F/L3/WC/2F/MM13/L.L FIRE SHAFT"
|      |      |      |-- 8:3-14 HMS-S/D/M/SA "F/L3/WC/2F/MCP14/LIFT LOBBY MCP"
|      |      |      |-- 8:3-15 HFP-11 "F/L3/WC/2F/SD15/LIFT LOBBY SD"
|      |      |      |-- 8:3-16 HFP-11 "F/L3/WC/2F/SD16/LIFT LOBBY SD"
|      |      |      |-- 8:3-17 HTRI-R "F/L3/WC/2F/CM17/DR RELEASE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-18 HFP-11 "F/L3/WC/2F/SD18/ELECT RM SD"
|      |      |      |-- 8:3-19 HTRI-R "F/L3/WC/2F/CM19/DR RELEASE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-20 HFP-11 "F/L3/WC/2F/SD20/CORR NR FW 2020"
|      |      |      |-- 8:3-21 HFP-11 "F/L3/WC/2F/SD21/CORR NR FW 2131"
|      |      |      |-- 8:3-22 HFP-11 "F/L3/WC/2F/SD22/CORR NR FW 2040"
|      |      |      |-- 8:3-23 HFP-11 "F/L3/WC/2F/SD23/CORR NR FW 2040"
|      |      |      |-- 8:3-24 HFP-11 "F/L3/WC/2F/SD24/ABC CORR NR 2160"
|      |      |      |-- 8:3-25 HFP-11 "F/L3/WC/2F/SD25/CORR NR FW2/S17"
|      |      |      |-- 8:3-26 HFP-11 "F/L3/WC/2F/SD26/CORR FW 2090"
|      |      |      |-- 8:3-27 HFP-11 "F/L3/WC/2F/SD27/CORR FW 2090"
|      |      |      |-- 8:3-28 HMS-S/D/M/SA "F/L3/WC/2F/MCP28/FIRE ESC STR"
|      |      |      |-- 8:3-29 HTRI-R "F/L3/WC/2F/CM29/FIRE ESC STR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-30 HFP-11 "F/L3/WC/2F/SD30/CORR FW 2140 AFC"
|      |      |      |-- 8:3-31 HFP-11 "F/L3/WC/1F/SD31/CORR NR FW 1050"
|      |      |      |-- 8:3-32 HFP-11 "F/L3/WC/1F/SD32/CORR NR FW/S10"
|      |      |      |-- 8:3-33 XTRI-R "F/L3/WC/1F/CM33/FIRE STR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-34 HTRI-S "F/L3/WC/1F/MM34/FIRE ESC STR"
|      |      |      |-- 8:3-35 HMS-S/D/M/SA "F/L3/WC/1F/MCP35/LIFT LOBBY MCP"
|      |      |      |-- 8:3-36 HFP-11 "F/L3/WC/1F/SD36/LIFT LOBBY SD"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:3 XDLC "XDLC @ address 3 L3"

```
|      |      |      |-- 8:3-37 HFP-11 "F/L3/WC/1F/SD37/LIFT LOBBY SD"
|      |      |      |-- 8:3-38 HTRI-R "F/L3/WC/1F/CM38/DR RELESE CM "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-39 HFP-11 "F/L3/WC/1F/SD39/ELECT RM CM"
|      |      |      |-- 8:3-40 HFP-11 "F/L3/WC/1F/SD40/CORR NR E.R."
|      |      |      |-- 8:3-41 HFP-11 "F/L3/WC/1F/SD41/CORR NR FW1/S08"
|      |      |      |-- 8:3-42 HFP-11 "F/L3/WC/1F/SD42/CORR NR FW 1010"
|      |      |      |-- 8:3-43 HFP-11 "F/L3/WC/1F/SD43/CORR NR FW 1011"
|      |      |      |-- 8:3-44 HMS-S/D/M/SA "F/L3/WC/1F/MCP44/FIRE ESC STR"
|      |      |      |-- 8:3-45 HTRI-R "F/L3/WC/1F/CM45/FIRE ESC STR"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-46 HFP-11 "F/L3/WC/1F/SD46/CORR NR FW_S07A"
|      |      |      |-- 8:3-47 HFP-11 "F/L3/WC/1F/SD47/CORR NR FW_S07A"
|      |      |      |-- 8:3-48 HTRI-R "F/L3/WC/1F/CM48/DR RELESE CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-49 HFP-11 "F/L3/WC/1F/SD49/CORR NR FW 1011"
|      |      |      |-- 8:3-50 HFP-11 "F/L3/WC/1F/SD50/CORR NR FW 1011"
|      |      |      |-- 8:3-51 HFP-11 "F/L3/WC/1F/SD51/CORR NR FW 1100"
|      |      |      |-- 8:3-52 HFP-11 "F/L3/WC/1F/SD52/CORR NR FW 1160"
|      |      |      |-- 8:3-53 HFP-11 "F/L3/WC/1F/SD53/CORR NR FW 1160"
|      |      |      |-- 8:3-54 HFP-11 "F/L3/WC/1F/SD54/AHU RM SD"
|      |      |      |-- 8:3-55 HTRI-R "F/L3/WC/1F/CM55/AHU RM CM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-56 HTRI-S "F/L3/WC/1F/MM56/FW1030A"
|      |      |      |-- 8:3-57 HTRI-S "F/L3/WC/2F/MM57/FC2071/72"
|      |      |      |-- 8:3-58 HTRI-S "F/L3/WC/1F/MM58/FW1150"
|      |      |      |-- 8:3-65 HTRI-S "F/L3/WC/2F/MM65/FW2110"
|      |      |      |-- 8:3-66 HTRI-S "F/L3/WC/2F/MM66/FW2140"
|      |      |      |-- 8:3-67 HTRI-S "F/L3/WC/2F/MM67/FW2100"
|      |      |      |-- 8:3-68 HTRI-S "F/L3/WC/2F/MM68/FW2090"
|      |      |      |-- 8:3-69 HTRI-S "F/L3/WC/2F/MM69/FW2150"
|      |      |      |-- 8:3-71 HTRI-S "F/L3/WC/2F/MM71/FW2070"
|      |      |      |-- 8:3-75 HTRI-S "F/L3/WC/2F/MM75/FW 2050"
|      |      |      |-- 8:3-77 HTRI-S "F/L3/WC/2F/MM77/FW 2032"
|      |      |      |-- 8:3-80 HTRI-S "F/L3/WC/2F/MM80/FW2010 ""
|      |      |      |-- 8:3-81 HTRI-S "F/L3/WC/2F/MM81/FW2120 ""
|      |      |      |-- 8:3-83 HTRI-S "F/L3/WC/2F/MM83/EW2140""
|      |      |      |-- 8:3-84 HTRI-S "F/L3/WC/2F/MM84/FW2110 ""
|      |      |      |-- 8:3-85 HTRI-S "F/L3/WC/2F/MM85/EW2150""
|      |      |      |-- 8:3-87 HTRI-S "F/L3/WC/2F/MM87/EW2090"
|      |      |      |-- 8:3-90 HTRI-S "F/L3/WC/1F/MM90/FW1060"
|      |      |      |-- 8:3-92 HTRI-S "F/L3/WC/1F/MM92/FW1040"
|      |      |      |-- 8:3-94 HTRI-S "F/L3/WC/1F/MM94/FW1020"
|      |      |      |-- 8:3-96 HTRI-S "F/L3/WC/1F/MM96/FW1012"
|      |      |      |-- 8:3-97 HTRI-S "F/L3/WC/1F/MM97/FW1030"
|      |      |      |-- 8:3-98 HTRI-S "F/L3/WC/1F/MM98/FW1011"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:3 XDLC "XDLC @ address 3 L3"

```
|      |      |      |-- 8:3-99 HTRI-S "F/L3/WC/1F/MM99/FW1070"
|      |      |      |-- 8:3-100 HTRI-S "F/L3/WC/1F/MM100/FW1080"
|      |      |      |-- 8:3-105 HTRI-S "F/L3/WC/1F/MM105/FW1120"
|      |      |      |-- 8:3-106 HTRI-S "F/L3/WC/1F/MM106/FW1170"
|      |      |      |-- 8:3-107 HTRI-S "F/L3/WC/1F/MM107/FW1160"
|      |      |      |-- 8:3-109 HTRI-S "F/L3/F/WC/1F/MM109/FW1140"
|      |      |      |-- 8:3-110 HFP-11 "F/L3/FW2031/SD110/Main cab"
|      |      |      |-- 8:3-111 HFP-11 "F/L3/FW2031/SD111/Assorter cab"
|      |      |      |-- 8:3-112 HFP-11 "F/L3/FW2031/SD112/Reception Psg"
|      |      |      |-- 8:3-113 HFP-11 "F/L3/FW2031/SD113/Entry Psg"
|      |      |      |-- 8:3-114 HTRI-R "F/L3/FW2031/CM114/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:3-115 HMS-S/D/M/SA "F/L3/FW2031/MCP115/Entry Psg"
|      |      |      |-- 8:3-116 HFP-11 "F/L3/FW2020/SD116/Main cab"
|      |      |      |-- 8:3-117 HFP-11 "F/L3/FW2020/SD117/Assorter cab"
|      |      |      |-- 8:3-118 HFP-11 "F/L3/FW2020/SD118/Psg nr Assorte"
|      |      |      |-- 8:3-119 HFP-11 "F/L3/FW2020/SD119/Entry dr Psg"
|      |      |      |-- 8:3-120 HTRI-R "F/L3/FW2020/CM120/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:3-121 HMS-S/D/M/SA "F/L3/FW2020/MCP121/Entry dr Psg"
|      |      |      |-- 8:3-122 HFP-11 "F/L3/FW2040/SD122/Main cab"
|      |      |      |-- 8:3-123 HFP-11 "F/L3/FW2040/SD123/Assorter cab1"
|      |      |      |-- 8:3-124 HFP-11 "F/L3/FW2040/SD124/Assorter cab2"
|      |      |      |-- 8:3-125 HFP-11 "F/L3/FW2040/SD125/Psg nr Ass cab"
|      |      |      |-- 8:3-126 HFP-11 "F/L3/FW2040/SD126/Pantry"
|      |      |      |-- 8:3-127 HTRI-R "F/L3/FW2040/CM127/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:3-128 HMS-S/D/M/SA "F/L3/FW2040/MCP128/Entry dr Psg"
|      |      |      |-- 8:3-129 HFP-11 "F/L3/FW2080/SD129/Main cab"
|      |      |      |-- 8:3-130 HFP-11 "F/L3/FW2080/SD130/Account cab"
|      |      |      |-- 8:3-131 HFP-11 "F/L3/FW2080/SD131/Entry dr Psg"
|      |      |      |-- 8:3-132 HFP-11 "F/L3/FW2080/SD132/Pantry"
|      |      |      |-- 8:3-133 HTRI-R "F/L3/FW2080/CM133/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:3-134 HMS-S/D/M/SA "F/L3/FW2080/MCP134/Entry dr Psg"
|      |      |      |-- 8:3-135 HFP-11 "F/L3/FW1090/SD135/Main cab"
|      |      |      |-- 8:3-136 HFP-11 "F/L3/FW1090/SD136/Assorter cab1"
|      |      |      |-- 8:3-137 HFP-11 "F/L3/FW1090/SD137/Assorter cab2"
|      |      |      |-- 8:3-138 HFP-11 "F/L3/FW1090/SD138/Psg nr Assorte"
|      |      |      |-- 8:3-139 HFP-11 "F/L3/FW1090/SD139/Entry dr Psg"
|      |      |      |-- 8:3-140 HTRI-R "F/L3/FW1090/CM140/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:3-141 HMS-S/D/M/SA "F/L3/FW1090/MCP141/Entry dr Psg"
|      |      |      |-- 8:3-142 HFP-11 "F/L3/FW1050/SD142/Main cab"
|      |      |      |-- 8:3-143 HFP-11 "F/L3/FW1050/SD143/Main cab"
```


8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:3 XDLC "XDLC @ address 3 L3"

```
|      |      |      |-- 8:3-144 HFPT-11 "F/L3/FW1050/HD144/pantry"
|      |      |      |-- 8:3-145 HTRI-R "F/L3/FW1050/CM145/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-146 HMS-S/D/M/SA "F/L3/FW1050/MCP146/Entry dr Psg "
|      |      |      |-- 8:3-147 HFP-11 "F/L3/FW1100/SD147/Main cab 1"
|      |      |      |-- 8:3-148 HFP-11 "F/L3/FW1100/SD148/Assorter cab"
|      |      |      |-- 8:3-149 HFP-11 "F/L3/FW1100/SD149/Pantry"
|      |      |      |-- 8:3-150 HTRI-R "F/L3/FW1100/CM150/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-151 HMS-S/D/M/SA "F/L3/FW1100/MCP151/Entry dr Psg"
|      |      |      |-- 8:3-152 HFP-11 "F/L3/FW1013/SD152/Assorter cab"
|      |      |      |-- 8:3-153 HFP-11 "F/L3/FW1013/SD153/Cab C"
|      |      |      |-- 8:3-154 HFP-11 "F/L3/FW1013/SD154/Cab A"
|      |      |      |-- 8:3-155 HFP-11 "F/L3/FW1013/SD155/Cab B"
|      |      |      |-- 8:3-156 HFP-11 "F/L3/FW1013/SD156/Pantry Psg"
|      |      |      |-- 8:3-157 HTRI-R "F/L3/FW1013/CM157/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-158 HMS-S/D/M/SA "F/L3/FW1013/MCP158/Entry Psg"
|      |      |      |-- 8:3-159 HFP-11 "F/L3/FW2160/SD159/Main cab"
|      |      |      |-- 8:3-160 HFP-11 "F/L3/FW2160/SD160/Main cab"
|      |      |      |-- 8:3-161 HFP-11 "F/L3/FW2160/SD161/Entry dr Psg"
|      |      |      |-- 8:3-162 HTRI-R "F/L3/FW2160/CM162/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-163 HMS-S/D/M/SA "F/L3/FW2160/MCP163/Entry dr Psg"
|      |      |      |-- 8:3-164 HFP-11 "F/L3/FW1130/SD164/Main cab"
|      |      |      |-- 8:3-165 HFP-11 "F/L3/FW1130/SD165/Assorter cab"
|      |      |      |-- 8:3-166 HFP-11 "F/L3/FW1130/SD166/Entry Psg"
|      |      |      |-- 8:3-167 HFP-11 "F/L3/FW1130/SD167/Pantry"
|      |      |      |-- 8:3-168 HTRI-R "F/L3/FW1130/CM168/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-169 HMS-S/D/M/SA "F/L3/FW1130/MCP169/Entry Psg"
|      |      |      |-- 8:3-170 HFP-11 "F/L3/FW1170/SD170/Main cab"
|      |      |      |-- 8:3-171 HFP-11 "F/L3/FW1170/SD171/Assorter cab"
|      |      |      |-- 8:3-172 HFP-11 "F/L3/FW1170/SD172/Entry dr psg"
|      |      |      |-- 8:3-173 HTRI-R "F/L3/FW1170/CM173/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:3-174 HMS-S/D/M/SA "F/L3/FW1170/MCP174/Entry dr psg"
|      |      |      |-- 8:3-175 HFP-11 "F/L3/FW1110/SD175/Psg nr Assorte"
|      |      |      |-- 8:3-176 HFP-11 "F/L3/FW1110/SD176/Main cab"
|      |      |      |-- 8:3-178 HFP-11 "F/L3/FW1110/SD178/Account cab"
|      |      |      |-- 8:3-179 HFP-11 "F/L3/FW1110/SD179/Pantry"
|      |      |      |-- 8:3-180 HTRI-R "F/L3/FW1110/CM180/AFC Pantry"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:3 XDLC "XDLC @ address 3 L3"

```
|      |      |  |-- 8:3-181 HMS-S/D/M/SA "F/L3/FW1110/MCP181/Entry psg"
|      |      |  |-- 8:3-182 FDOT421 "F/L3/FW2031/SD182/Entry Psg"
|      |      |  |-- 8:3-201 HFP-11 "F/L3/EW2160/SD201/Main cab"
|      |      |  |-- 8:3-202 HFP-11 "F/L3/EW2160/SD202/Main cab"
|      |      |  |-- 8:3-203 HFP-11 "F/L3/EW2160/SD203/Pantry"
|      |      |  |-- 8:3-204 HTRI-R "F/L3/EW2160/CM204/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:3-205 HMS-S/D/M/SA "F/L3/EW2160/MCP205/Entry dr Psg"
|      |      |  |-- 8:3-206 HFP-11 "F/L3/EW2100/SD206/Main cab"
|      |      |  |-- 8:3-207 HFP-11 "F/L3/EW2100/SD207/Cab 1"
|      |      |  |-- 8:3-208 HFP-11 "F/L3/EW2100/SD208/Cab 2"
|      |      |  |-- 8:3-209 HFP-11 "F/L3/EW2100/SD209/Psg nr cab 2"
|      |      |  |-- 8:3-210 HTRI-R "F/L3/EW2100/CM210/Entry dr psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:3-211 HMS-S/D/M/SA "F/L3/EW2100/MCP211/Entry dr psg"
|      |      |  |-- 8:3-212 HFP-11 "F/L3/EW2130/SD212/Main cab"
|      |      |  |-- 8:3-213 HFP-11 "F/L3/EW2130/SD213/Assorter cab"
|      |      |  |-- 8:3-214 HFP-11 "F/L3/EW2130/SD214/Entry dr psg"
|      |      |  |-- 8:3-215 HTRI-R "F/L3/EW2130/CM215/Entry dr psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:3-216 HMS-S/D/M/SA "F/L3/EW2130/MCP216/Entry dr psg"
|      |      |  |-- 8:3-217 HFP-11 "F/L3/FW2160/SD217/pantry Psg"
|      |      |  |-- 8:4 XDLC "XDLC @ address 4 L4"
|      |      |  |-- 8:4-1 HTRI-R "F/L4/CC/5F/CM1/DR RELEASE"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:4-2 HFP-11 "F/L4/CC/5F/SD2/FC_S08 Shaft"
|      |      |  |-- 8:4-3 FDOT421 "F/L4/CC/5F/SD3/FC5/S08 Shaft "
|      |      |  |-- 8:4-4 FDOT421 "F/L4/CC/5F/SD4/FC 5021"
|      |      |  |-- 8:4-5 HFP-11 "F/L4/CC/5F/SD5/FC 5021."
|      |      |  |-- 8:4-6 HMS-S/D/M/SA "F/L4/CC/5F/MCP 6/FIRE ESC STR."
|      |      |  |-- 8:4-7 HTRI-R "F/L4/CC/5F/CM7/FIRE SHAFT L.L."
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:4-8 HFP-11 "F/L4/CC/5F/SD8/FC 5041"
|      |      |  |-- 8:4-9 HFP-11 "F/L4/CC/5F/SD9/FC 5041"
|      |      |  |-- 8:4-10 FDOT421 "F/L4/CC/5F/SD10/FC5/S07"
|      |      |  |-- 8:4-11 HFP-11 "F/L4/CC/5F/SD11/FC 5011"
|      |      |  |-- 8:4-12 HFP-11 "F/L4/CC/5F/SD12/FC 5011."
|      |      |  |-- 8:4-13 FDOT421 "F/L4/CC/5F/SD13/CORR NR ELE RM"
|      |      |  |-- 8:4-14 HFP-11 "F/L4/CC/5F/SD14/ELEC RM."
|      |      |  |-- 8:4-15 HTRI-R "F/L4/CC/5F/CM15/DR RELEASE"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:4-16 HMS-S/D/M/SA "F/L4/CC/5F/MCP 16/FIRE SHAFT LL."
|      |      |  |-- 8:4-17 HTRI-R "F/L4/CC/5F/CM17/FIRE SHAFT L.L."
|      |      |  |-- Switch ""
```

```
| | | | | Relay
| | | | |
| | | | | |-- 8:4-18 HTRI-S "F/L4/CC/5F/MM 18/FIRE SHAFT"
| | | | |
| | | | | |-- 8:4-19 HTRI-R "F/L4/CC/5F/CM19/AHU RM"
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:4-20 HFP-11 "F/L4/CC/5F/SD20/AHU RM"
| | | | |
| | | | | |-- 8:4-21 FDOT421 "F/L4/CC/5F/SD21/LIFT Lobby"
| | | | |
| | | | | |-- 8:4-22 FDOT421 "F/L4/CC/5F/SD22/LIFT Lobby"
| | | | |
| | | | | |-- 8:4-23 HFP-11 "F/L4/FC3011/12/SD23/Main Ent Psg"
| | | | |
| | | | | |-- 8:4-24 HFP-11 "F/L4/FC3011/12/SD24/Psg.nr Cab 6"
| | | | |
| | | | | |-- 8:4-25 HFP-11 "F/L4/EC/5F/SD25/ELECTRIC RM."
| | | | |
| | | | | |-- 8:4-26 HTRI-R "F/L4/EC/5F/CM26/AHU RM"
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:4-27 HFP-11 "F/L4/EC/5F/SD27/AHU RM"
| | | | |
| | | | | |-- 8:4-28 HFP-11 "F/L4/EC/5F/SD28/LIFT LOBBY"
| | | | |
| | | | | |-- 8:4-29 HMS-S/D/M/SA "F/L4/EC/5F/MCP29/FIRE SHAFT"
| | | | |
| | | | | |-- 8:4-30 HTRI-R "F/L4/EC/5F/CM30/FIRE SHAFT L.L."
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:4-31 HTRI-S "F/L4/EC/5F/MM 31/FIRE SHAFT"
| | | | |
| | | | | |-- 8:4-32 HFP-11 "F/L4/FC3011/12/SD32/Psg.nr Cab 7"
| | | | |
| | | | | |-- 8:4-33 HFP-11 "F/L4/CC/4F/SD33/CORR NR E.R."
| | | | |
| | | | | |-- 8:4-34 HFP-11 "F/L4/CC/4F/SD34/CORR NR FC 4030"
| | | | |
| | | | | |-- 8:4-35 HFP-11 "F/L4/CC/4F/SD35/CORR NR FC 4030"
| | | | |
| | | | | |-- 8:4-36 HFP-11 "F/L4/CC/4F/SD36/CORR NR FC 4042"
| | | | |
| | | | | |-- 8:4-37 HMS-S/D/M/SA "F/L4/CC/4F/MCP37/FIRE ESC STR "
| | | | |
| | | | | |-- 8:4-38 HTRI-R "F/L4/CC/4F/CM38/FIRE ESC STR "
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:4-39 FDOT421 "F/L4/CC/4F/SD39/CORR NR FC 4020"
| | | | |
| | | | | |-- 8:4-40 HFP-11 "F/L4/CC/4F/SD40/CORR NR FC 4020"
| | | | |
| | | | | |-- 8:4-41 HFP-11 "F/L4/CC/4F/SD41/CORR NR FC 4010"
| | | | |
| | | | | |-- 8:4-42 HFP-11 "F/L4/CC/4F/SD42/CORR NR FC 4010"
| | | | |
| | | | | |-- 8:4-43 HFP-11 "F/L4/CC/4F/SD43/CORR NR FC 4050"
| | | | |
| | | | | |-- 8:4-44 HFP-11 "F/L4/CC/4F/SD44/ CORR NR E.R."
| | | | |
| | | | | |-- 8:4-45 HFP-11 "F/L4/CC/4F/SD45/ELECT RM SD"
| | | | |
| | | | | |-- 8:4-46 HTRI-R "F/L4/CC/4F/CM46/DR RELESE CM"
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:4-47 HMS-S/D/M/SA "F/L4/CC/4F/MCP47/FIRE SHAFT L.L."
| | | | |
| | | | | |-- 8:4-48 XTRI-R "F/L4/CC/4F/CM48/FIRE SHAFT L.L."
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:4-49 HTRI-S "F/L4/CC/4F/MM49/FIRE SHAFT L.L."
| | | | |
| | | | | |-- 8:4-50 HFP-11 "F/L4/CC/4F/SD50/LIFT LOBBY SD"
| | | | |
| | | | | |-- 8:4-51 FDOT421 "F/L4/CC/4F/SD51/LIFT LOBBY SD"
| | | | |
| | | | | |-- 8:4-52 HTRI-R "F/L4/CC/4F/CM52/AHU RM CM"
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:4 XDLC "XDLC @ address 4 L4"

| | | |-- 8:4-53 HFP-11 "F/L4/CC/4F/SD53/AHU RM SD"
| | | |-- 8:4-54 HTRI-R "F/L4/CC/4F/CM54/DR RELEASE CM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **8:4-55 HFP-11 "F/L4/CC/4F/SD55/CORR NR FC 4120"**
| | | |-- 8:4-56 HFP-11 "F/L4/CC/4F/SD56/CORR NR FC 4110"
| | | |-- 8:4-57 HFP-11 "F/L4/CC/4F/SD57/CORR NR FC 4100"
| | | |-- 8:4-58 HFP-11 "F/L4/CC/4F/SD58/CORR NR FC 4100"
| | | |-- 8:4-59 HFP-11 "F/L4/CC/4F/SD59/CORR NR FC 4090"
| | | |-- 8:4-60 HFP-11 "F/L4/CC/4F/SD60/ CORR NR FC 4090"
| | | |-- 8:4-61 HFP-11 "F/L4/CC/4F/SD61/ CORR NR FC 4080"
| | | |-- 8:4-62 HFP-11 "F/L4/CC/4F/SD62/CORR NR FC 4080"
| | | |-- 8:4-63 HMS-S/D/M/SA "F/L4/EC/4F/MCP63/FIRE ESC STR "
| | | |-- 8:4-64 HTRI-R "F/L4/EC/4F/CM64/FIRE ESC STR "
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **8:4-65 HFP-11 "F/L4/EC/4F/SD65/ELECT RM SD"**
| | | |-- 8:4-66 HTRI-R "F/L4/EC/4F/CM66/AHU RM SD"
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **8:4-67 HFP-11 "F/L4/EC/4F/SD67/AHU RM CM"**
| | | |-- 8:4-68 HFP-11 "F/L4/EC/4F/SD68/LIFT LOBBY SD"
| | | |-- 8:4-69 HMS-S/D/M/SA "F/L4/EC/4F/MCP69/FIRE SHAFT L.L."
| | | |-- 8:4-70 HTRI-R "F/L4/EC/4F/CM70/FIRE SHAFT L.L."
| | | | |-- Switch ""
| | | | |-- Relay
| | | |-- **8:4-71 HTRI-S "F/L4/EC/4F/MM71/FIRE SHAFT L.L."**
| | | |-- 8:4-72 HFP-11 "F/L4/FC4100/SD72/accont cab"
| | | |-- 8:4-73 HFP-11 "F/L4/FC3011/12/SD73/PsgNrCab10"
| | | |-- 8:4-74 HFP-11 "F/L4/FC5012/SD74/RECEPTION"
| | | |-- 8:4-75 HFP-11 "F/L4/FC5012/SD75/STRONG RM"
| | | |-- 8:4-76 HFP-11 "F/L4/FC5012/SD76/ABHISHEK Cabin"
| | | |-- 8:4-77 HFP-11 "F/L4/FC3011/12/SD77/Conf. RM"
| | | |-- 8:4-78 HFP-11 "F/L4/FC3011/12/SD78/Cab NR Cab 1"
| | | |-- 8:4-79 HFP-11 "F/L4/FC3011/12/SD79/Server nr Ca"
| | | |-- 8:4-80 HFP-11 "F/L4/FC3011/12/SD80/Psg nr Vijay"
| | | |-- 8:4-81 HFP-11 "F/L4/FC3011/12/SD81/Store nr Con"
| | | |-- 8:4-82 HTRI-S "F/L4/CC/5F/MM82/FC5043"
| | | |-- 8:4-83 HTRI-S "F/L4/CC/5F/MM83/FC5042"
| | | |-- 8:4-84 HTRI-S "F/L4/CC/5F/MM84/FC5011"
| | | |-- 8:4-85 HTRI-S "F/L4/CC/5F/MM 85/FC 5041"
| | | |-- 8:4-86 HTRI-S "F/L4/CC/5F/MM86/FC5022"
| | | |-- 8:4-87 HTRI-S "F/L4/CC/5F/MM87/FC5021"
| | | |-- 8:4-88 HTRI-S "F/L4/CC/5F/MM88/FC5030"
| | | |-- 8:4-89 HTRI-S "F/L4/CC/4F/MM89/FC4030"
| | | |-- 8:4-90 HTRI-S "F/L4/CC/4F/MM90/FC4041"
| | | |-- 8:4-91 HTRI-S "F/L4/CC/4F/MM91/FC 4041"
| | | |-- 8:4-92 HTRI-S "F/L4/CC/4F/MM92/FC4042"
| | | |-- 8:4-93 HTRI-S "F/L4/CC/4F/MM93/FC 4020"
| | | |-- 8:4-94 HTRI-S "F/L4/CC/4F/MM94/FW4/S22"

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:4 XDLC "XDLC @ address 4 L4"

```
|      |      |      |-- 8:4-95 HFP-11 "F/L4/FC3011/12/SD95/Cupboard 1 -"
|      |      |      |-- 8:4-96 HTRI-S "F/L4/CC/4F/MM96/FC4010"
|      |      |      |-- 8:4-97 HTRI-S "F/L4/CC/4F/MM97/FC4060"
|      |      |      |-- 8:4-98 HTRI-R "F/L4/FC3011/12/CM98/Afc Pantry A"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:4-99 HTRI-S "F/L4/CC/4F/MM99/FC4110"
|      |      |      |-- 8:4-100 HMS-S/D/M/SA "F/L4/FC3011/12/MCP100/ FW Back D"
|      |      |      |-- 8:4-102 HMS-S/D/M/SA "F/L4/FC3011/12/MCP102/ Main Entr"
|      |      |      |-- 8:4-103 HTRI-S "F/L4/CC/4F/MM103/FC 4080"
|      |      |      |-- 8:4-104 HTRI-R "F/L4/FC3011/12/CM104/Afc Entry D"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:4-105 HFP-11 "F/L4/FC3011/12/SD105/Reception A"
|      |      |      |-- 8:4-106 HTRI-S "F/L4/CC/4F/MM106/FE 4013""
|      |      |      |-- 8:4-107 HFP-11 "F/L4/FC4100/SD107/Pantry"
|      |      |      |-- 8:4-108 HFP-11 "F/L4/FC4100/SD108/Cabin2"
|      |      |      |-- 8:4-109 HFP-11 "F/L4/FC4100/SD109/Main cabin"
|      |      |      |-- 8:4-110 HFP-11 "F/L4/FC4100/SD110/Assorting cab"
|      |      |      |-- 8:4-111 HTRI-R "F/L4/FC4100/CM111/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:4-112 HMS-S/D/M/SA "F/L4/FC4100/MCP112/Entry dr Psg"
|      |      |      |-- 8:4-113 HFP-11 "F/L4/FC4012/SD113/Main Cabin1"
|      |      |      |-- 8:4-114 HFP-11 "F/L4/FC4012/SD114/Main Cabin2"
|      |      |      |-- 8:4-115 HFP-11 "F/L4/FC4012/SD115/Main Cabin3"
|      |      |      |-- 8:4-116 HFP-11 "F/L4/FC4012/SD116/Main Cabin4"
|      |      |      |-- 8:4-117 HFP-11 "F/L4/FC4012/SD117/Assorter cab"
|      |      |      |-- 8:4-118 HFP-11 "F/L4/FC4012/SD118/Pantry"
|      |      |      |-- 8:4-119 HFP-11 "F/L4/FC4012/SD119/Psg nr Assorte"
|      |      |      |-- 8:4-120 HFP-11 "F/L4/FC4012/SD120/Account cab"
|      |      |      |-- 8:4-121 HFP-11 "F/L4/FC4012/SD121/Reception"
|      |      |      |-- 8:4-122 HTRI-R "F/L4/FC4012/CM122/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:4-123 HMS-S/D/M/SA "F/L4/FC4012/MCP123/Entry dr Psg"
|      |      |      |-- 8:4-124 HFP-11 "F/L4/FC5012/SD124/Mihir Bhai Cab"
|      |      |      |-- 8:4-125 HFP-11 "F/L4/FC5012/SD125/Main cab"
|      |      |      |-- 8:4-126 HFP-11 "F/L4/FC5012/SD126/Main cab"
|      |      |      |-- 8:4-127 HFP-11 "F/L4/FC5012/SD127/Buyers cab1"
|      |      |      |-- 8:4-128 HFP-11 "F/L4/FC5012/SD128/Pragnesh Bhai "
|      |      |      |-- 8:4-129 HFP-11 "F/L4/FC5012/SD129/Buyers cab2"
|      |      |      |-- 8:4-130 HFP-11 "F/L4/FC5012/SD130/Psg nr Buyers "
|      |      |      |-- 8:4-131 HFP-11 "F/L4/FC5012/SD131/Psg nr Buyers "
|      |      |      |-- 8:4-132 HFP-11 "F/L4/FC5012/SD132/Amit Bhai cab"
|      |      |      |-- 8:4-133 HFP-11 "F/L4/FC5012/SD133/Account cab"
|      |      |      |-- 8:4-134 HFP-11 "F/L4/FC5012/SD134/Assorter cab"
|      |      |      |-- 8:4-135 HFP-11 "F/L4/FC5012/SD135/Assorter cab"
|      |      |      |-- 8:4-136 HFPT-11 "F/L4/FC5012/HD136/Pantry"
|      |      |      |-- 8:4-137 HFP-11 "F/L4/FC5012/SD137/Entry Dr Psg"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:4 XDLC "XDLC @ address 4 L4"

```
|      |      |      |-- 8:4-138 HTRI-R "F/L4/FC5012/CM138/Entry Dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:4-139 HMS-S/D/M/SA "F/L4/FC5012/MCP139/Entry Dr Psg"
|      |      |      |-- 8:4-140 HFP-11 "F/L4/FC4120/SD140/Account cab"
|      |      |      |-- 8:4-141 HFP-11 "F/L4/FC4120/SD141/Assorter cab1"
|      |      |      |-- 8:4-142 HFP-11 "F/L4/FC4120/SD142/Assorter cab2"
|      |      |      |-- 8:4-143 HFP-11 "F/L4/FC4120/SD143/Main Cab"
|      |      |      |-- 8:4-144 HFP-11 "F/L4/FC4120/SD144/Main Cab"
|      |      |      |-- 8:4-145 HFP-11 "F/L4/FC4120/SD145/Assorter cab3"
|      |      |      |-- 8:4-146 HFP-11 "F/L4/FC4120/SD146/Psg nr Account"
|      |      |      |-- 8:4-147 HFP-11 "F/L4/FC4120/SD147/Pantry psg"
|      |      |      |-- 8:4-148 HTRI-R "F/L4/FC4120/CM148/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:4-149 HMS-S/D/M/SA "F/L4/FC4120/MCP149/Entry dr Psg"
|      |      |      |-- 8:4-150 HFP-11 "F/L4/FE4011/SD150/Banking cab"
|      |      |      |-- 8:4-151 HFP-11 "F/L4/FE4011/SD151/Psg nr server "
|      |      |      |-- 8:4-152 HFP-11 "F/L4/FE4011/SD152/Admin cab"
|      |      |      |-- 8:4-153 HFP-11 "F/L4/FE4011/SD153/Buyers cab5"
|      |      |      |-- 8:4-154 HFP-11 "F/L4/FE4011/SD154/Boss cab"
|      |      |      |-- 8:4-155 HFP-11 "F/L4/FE4011/SD155/Buyers cab4"
|      |      |      |-- 8:4-156 HFP-11 "F/L4/FE4011/SD156/Buyers cab3"
|      |      |      |-- 8:4-157 HFP-11 "F/L4/FE4011/SD157/Buyers cab2"
|      |      |      |-- 8:4-158 HFP-11 "F/L4/FE4011/SD158/Buyers cab1"
|      |      |      |-- 8:4-159 HFP-11 "F/L4/FE4011/SD159/Psg nr Buyers "
|      |      |      |-- 8:4-160 HFP-11 "F/L4/FE4011/SD160/Ankur bhai cab"
|      |      |      |-- 8:4-161 HFP-11 "F/L4/FE4011/SD161/Sanjay shah ca"
|      |      |      |-- 8:4-162 HFP-11 "F/L4/FE4011/SD162/Reception Psg"
|      |      |      |-- 8:4-163 HFP-11 "F/L4/FE4011/SD163/Reception cab"
|      |      |      |-- 8:4-164 HFP-11 "F/L4/FE4011/SD164/Accounts cab1"
|      |      |      |-- 8:4-165 HFP-11 "F/L4/FE4011/SD165/Sales cab"
|      |      |      |-- 8:4-166 HFP-11 "F/L4/FE4011/SD166/Psg nr Sales c"
|      |      |      |-- 8:4-167 HFP-11 "F/L4/FE4011/SD167/Stock control "
|      |      |      |-- 8:4-168 HFP-11 "F/L4/FE4011/SD168/Psg nr stock c"
|      |      |      |-- 8:4-169 HFP-11 "F/L4/FE4011/SD169/store rm"
|      |      |      |-- 8:4-170 HFP-11 "F/L4/FE4011/SD170/Psg nr banking"
|      |      |      |-- 8:4-171 HFP-11 "F/L4/FE4011/SD171/Assorter cab"
|      |      |      |-- 8:4-172 HFP-11 "F/L4/FE4011/SD172/Assorter cab"
|      |      |      |-- 8:4-173 HFP-11 "F/L4/FE4011/SD173/Assorter cab"
|      |      |      |-- 8:4-174 HFP-11 "F/L4/FE4011/SD174/Assorter cab"
|      |      |      |-- 8:4-175 HFP-11 "F/L4/FE4011/SD175/Pantry Psg"
|      |      |      |-- 8:4-176 HFPT-11 "F/L4/FE4011/HD176/Pantry"
|      |      |      |-- 8:4-177 HMS-S/D/M/SA "F/L4/FE4011/MCP177/Reception Psg"
|      |      |      |-- 8:4-178 HMS-S/D/M/SA "F/L4/FE4011/MCP178/pantry area"
|      |      |      |-- 8:4-179 HTRI-R "F/L4/FE4011/CM179/Reception Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:4-180 HFP-11 "F/L4/FC4050/SD180/Account cab"
|      |      |      |-- 8:4-181 HFP-11 "F/L4/FC4050/SD181/Pantry"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:4 XDLC "XDLC @ address 4 L4"

```
|      |      |      |-- 8:4-182 HFP-11 "F/L4/FC4050/SD182/Psg nr Pantry"
|      |      |      |-- 8:4-183 HFP-11 "F/L4/FC4050/SD183/GIG Cab"
|      |      |      |-- 8:4-184 HFP-11 "F/L4/FC4050/SD184/Cab 1"
|      |      |      |-- 8:4-185 HFP-11 "F/L4/FC4050/SD185/Cab 2"
|      |      |      |-- 8:4-186 HFP-11 "F/L4/FC4050/SD186/Conference Cab"
|      |      |      |-- 8:4-187 HFP-11 "F/L4/FC4050/SD187/Psg nr Conf. C"
|      |      |      |-- 8:4-188 HTRI-R "F/L4/FC4050/CM188/AFC Reception "
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:4-189 HMS-S/D/M/SA "F/L4/FC4050/MCP189/Reception Psg"
|      |      |      |-- 8:4-190 HFP-11 "F/L4/FC4090/SD190/Main cab 1"
|      |      |      |-- 8:4-191 HFP-11 "F/L4/FC4090/SD191/Main cab 2"
|      |      |      |-- 8:4-192 HFP-11 "F/L4/FC4090/SD192/Accounts cab"
|      |      |      |-- 8:4-193 HFP-11 "F/L4/FC4090/SD193/bonded cab"
|      |      |      |-- 8:4-194 HFP-11 "F/L4/FC4090/SD194/Pantry"
|      |      |      |-- 8:4-195 HFP-11 "F/L4/FC4090/SD195/Accounts cab"
|      |      |      |-- 8:4-196 HTRI-R "F/L4/FC4090/CM196/AFC Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:4-197 HMS-S/D/M/SA "F/L4/FC4090/MCP197/Entry Psg"
|      |      |      |-- 8:4-198 HFP-11 "F/L4/FC5051/SD198/Account cab"
|      |      |      |-- 8:4-199 HFP-11 "F/L4/FC5051/SD199/Main cab 1"
|      |      |      |-- 8:4-200 HFP-11 "F/L4/FC5051/SD200/Main cab 2"
|      |      |      |-- 8:4-201 HFP-11 "F/L4/FC5051/SD201/Main cab 3"
|      |      |      |-- 8:4-202 HFP-11 "F/L4/FC5051/SD202/Main cab 4"
|      |      |      |-- 8:4-203 HFP-11 "F/L4/FC5051/SD203/Reception Psg"
|      |      |      |-- 8:4-204 HFPT-11 "F/L4/FC5051/HD204/Pantry"
|      |      |      |-- 8:4-205 HTRI-R "F/L4/FC5051/CM205/Entry dr psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:4-206 HMS-S/D/M/SA "F/L4/FC5051/MCP206/Entry dr psg"
|      |      |      |-- 8:4-207 HFP-11 "F/L4/FC3011/12/SD207/Buyer Cab 1"
|      |      |      |-- 8:4-208 HFP-11 "F/L4/FC3011/12/SD208/Buyer Cab 2"
|      |      |      |-- 8:4-209 HFP-11 "F/L4/FC3011/12/SD209/Buyer Cab 3"
|      |      |      |-- 8:4-210 HFP-11 "F/L4/FC3011/12/SD210/Buyer Cab 4"
|      |      |      |-- 8:4-211 HFP-11 "F/L4/FC3011/12/SD211/Buyer Cab 5"
|      |      |      |-- 8:4-212 HFP-11 "F/L4/FC3011/12/SD212/Psg Nr Buye"
|      |      |      |-- 8:4-213 HFP-11 "F/L4/FC3011/12/SD213/Psg Nr Buye"
|      |      |      |-- 8:4-214 HFP-11 "F/L4/FC3011/12/SD214/Buyer Cab 6"
|      |      |      |-- 8:4-215 HFP-11 "F/L4/FC3011/12/SD215/Buyer Cab 7"
|      |      |      |-- 8:4-216 HFP-11 "F/L4/FC3011/12/SD216/Buyer Cab 8"
|      |      |      |-- 8:4-217 HFP-11 "F/L4/FC3011/12/SD217/Buyer Cab 9"
|      |      |      |-- 8:4-218 HFP-11 "F/L4/FC3011/12/SD218/Buyer Cab 1"
|      |      |      |-- 8:4-219 HFP-11 "F/L4/FC3011/12/SD219/Meeting RM"
|      |      |      |-- 8:4-220 HFP-11 "F/L4/FC3011/12/SD220/Buyer Cab 1"
|      |      |      |-- 8:4-221 HFP-11 "F/L4/FC3011/12/SD221/Buyer Cab 1"
|      |      |      |-- 8:4-222 HFP-11 "F/L4/FC3011/12/SD222/Buyer Cab 1"
|      |      |      |-- 8:4-223 HFP-11 "F/L4/FC3011/12/SD223/Buyer Cab 1"
|      |      |      |-- 8:4-224 HFP-11 "F/L4/FC3011/12/SD224/Buyer Cab 1"
|      |      |      |-- 8:4-225 HFP-11 "F/L4/FC3011/12/SD225/Psg Nr Buye"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:4 XDLC "XDLC @ address 4 L4"

```
|      |      |  |-- 8:4-226 HFP-11 "F/L4/FC3011/12/SD226/Visitor cab"
|      |      |  |-- 8:4-227 HFP-11 "F/L4/FC3011/12/SD227/Marketing C"
|      |      |  |-- 8:4-228 HFP-11 "F/L4/FC3011/12/SD228/Marketing C"
|      |      |  |-- 8:4-229 HFP-11 "F/L4/FC3011/12/SD229/Marketing C"
|      |      |  |-- 8:4-230 HFP-11 "F/L4/FC3011/12/SD230/Marketing C"
|      |      |  |-- 8:4-231 HFP-11 "F/L4/FC3011/12/SD231/Pantry Area"
|      |      |  |-- 8:4-232 HFP-11 "F/L4/FC3011/12/SD232/Pantry Area"
|      |      |  |-- 8:4-233 HFP-11 "F/L4/FC3011/12/SD233/Pantry Area"
|      |      |  |-- 8:4-234 HFP-11 "F/L4/FC3011/12/SD234/Goods Picku"
|      |      |  |-- 8:4-235 HFP-11 "F/L4/FC3011/12/SD235/Goods Picku"
|      |      |  |-- 8:4-236 HFP-11 "F/L4/FC3011/12/SD236/Goods Picku"
|      |      |  |-- 8:4-237 HFP-11 "F/L4/FC3011/12/SD237/Goods Picku"
|      |      |  |-- 8:4-238 HFP-11 "F/L4/FC3011/12/SD238/Goods Picku"
|      |      |  |-- 8:4-239 HFP-11 "F/L4/FC3011/12/SD239/Psg Nr Good"
|      |      |  |-- 8:4-240 HFP-11 "F/L4/FC3011/12/SD240/Psg Nr Mark"
|      |      |  |-- 8:4-241 HFP-11 "F/L4/FC3011/12/SD241/Cupboard 2 "
|      |      |  |-- 8:4-242 HFP-11 "F/L4/FC3011/12/SD242/Conference "
|      |      |  |-- 8:4-243 HFP-11 "F/L4/FC3011/12/SD243/Vijay Shah "
|      |      |  |-- 8:4-244 HFP-11 "F/L4/FC3011/12/SD244/Sanjay Shah"
|      |      |  |-- 8:4-245 HFP-11 "F/L4/FC3011/12/SD245/Rishil Shah"
|      |      |  |-- 8:4-246 HFP-11 "F/L4/FC3011/12/SD246/Vatsal Shah"
|      |      |  |-- 8:4-247 HFP-11 "F/L4/FC3011/12/SD247/Psg Nr Vats"
|      |      |  |-- 8:4-248 HFP-11 "F/L4/FC3011/12/SD248/Purvi Shah "
|      |      |  |-- 8:4-249 HFP-11 "F/L4/FC3011/12/SD249/Premal Shah"
|      |      |  |-- 8:4-250 HFP-11 "F/L4/FC3011/12/SD250/Premal Shah"
|      |      |  |-- 8:4-251 HFP-11 "F/L4/FC3011/12/SD251/Waiting Roo"
|      |      |  |-- 8:4-252 HFP-11 "F/L4/FC3011/12/SD252/Psg Nr Wait"
|      |      |  |-- 8:4-101 HFP-11 "HFP-11 @ address 4-101"
|      |  |-- 8:5 XDLC "XDLC @ address 5 L5"
|      |      |  |-- 8:5-1 FDOT421 "F/L5/4F/SD1/Corr.Nr EW4160"
|      |      |  |-- 8:5-2 HMS-S/D/M/SA "F/L5/4F/MCP2/EW Fire Esc dr"
|      |      |  |-- 8:5-3 HTRI-R "F/L5/4F/CM3/EW Fire Esc dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |  |-- 8:5-4 FDOT421 "F/L5/4F/SD4/EW Fire Esc dr"
|      |      |  |-- 8:5-5 FDOT421 "F/L5/4F/SD5/Corr.Nr EW4150"
|      |      |  |-- 8:5-6 FDOT421 "F/L5/4F/SD6/FW AHU Rm"
|      |      |  |-- 8:5-7 HTRI-R "F/L5/4F/CM7/FW AHU Rm"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |  |-- 8:5-8 FDOT421 "F/L5/4F/SD8/Corr.Nr EW4430"
|      |      |  |-- 8:5-9 HTRI-R "F/L5/4F/CM9/FW door release"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |  |-- 8:5-10 HTRI-R "F/L5/4F/CM10/FW Lift Lobby"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |  |-- 8:5-11 HTRI-S "F/L5/4F/MM11/FW Lift Lobby"
|      |      |  |-- 8:5-12 HMS-S/D/M/SA "F/L5/4F/MCP12/FW Lift Lobby"
|      |      |  |-- 8:5-13 FDOT421 "F/L5/4F/SD13/FW Lift Lobby"
```


8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:5 XDLC "XDLC @ address 5 L5"

		-- 8:5-14 FDOT421 "F/L5/4F/SD14/FW Lift Lobby"
		-- 8:5-15 HTRI-R "F/L5/4F/CM15/FW Door Release"
		-- Switch ""
		-- Relay
		-- 8:5-16 FDOT421 "F/L5/4F/SD16/FW Electric Rm"
		-- 8:5-17 HTRI-R "F/L5/4F/CM17/FW door release"
		-- Switch ""
		-- Relay
		-- 8:5-18 FDOT421 "F/L5/4F/SD18/Corr.Nr FW4050"
		-- 8:5-19 FDOT421 "F/L5/4F/SD19/Corr.Nr FW4050"
		-- 8:5-20 FDOT421 "F/L5/4F/SD20/Corr.Nr FW4050"
		-- 8:5-21 FDOT421 "F/L5/4F/SD21/Corr.Nr FW4160"
		-- 8:5-22 FDOT421 "F/L5/4F/SD22/Corr.Nr EW S20"
		-- 8:5-23 FDOT421 "F/L5/4F/SD23/Corr.Nr FW4100"
		-- 8:5-24 FDOT421 "F/L5/4F/SD24/Corr.Nr FW4100"
		-- 8:5-25 HMS-S/D/M/SA "F/L5/4F/MCP25/FW Fire Esc door"
		-- 8:5-26 HTRI-R "F/L5/4F/CM26/FW Fire Esc door"
		-- Switch ""
		-- Relay
		-- 8:5-27 FDOT421 "F/L5/4F/SD27/Corr.Nr FW4120"
		-- 8:5-28 FDOT421 "F/L5/3F/SD28/Corr.Nr EW3090"
		-- 8:5-29 FDOT421 "F/L5/3F/SD29/Corr.Nr FW S12"
		-- 8:5-30 HMS-S/D/M/SA "F/L5/3F/MCP30/EW Fire Esc Door"
		-- 8:5-31 HTRI-R "F/L5/3F/CM31/EW Fire Esc Door"
		-- Switch ""
		-- Relay
		-- 8:5-32 FDOT421 "F/L5/3F/SD32/EW Fire Esc Door"
		-- 8:5-33 FDOT421 "F/L5/3F/SD33/FW AHU Rm"
		-- 8:5-34 HTRI-R "F/L5/3F/CM34/FW AHU Rm"
		-- Switch ""
		-- Relay
		-- 8:5-35 FDOT421 "F/L5/3F/SD35/Corr.Nr FW/S10"
		-- 8:5-36 FDOT421 "F/L5/3F/SD36/Corr.Nr FW/S10"
		-- 8:5-37 HTRI-R "F/L5/3F/CM37/FW Door Release"
		-- Switch ""
		-- Relay
		-- 8:5-38 HTRI-R "F/L5/3F/CM38/FW Lift Lobby"
		-- Switch ""
		-- Relay
		-- 8:5-39 HTRI-S "F/L5/3F/MM39/FW Lift Lobby"
		-- 8:5-40 HMS-S/D/M/SA "F/L5/3F/MCP40/FW Lift Lobby"
		-- 8:5-41 FDOT421 "F/L5/3F/SD41/FW Lift Lobby"
		-- 8:5-42 FDOT421 "F/L5/3F/SD42/FW Lift Lobby"
		-- 8:5-43 HTRI-R "F/L5/3F/CM43/FW Door release"
		-- Switch ""
		-- Relay
		-- 8:5-44 FDOT421 "F/L5/3F/SD44/FW Electric Rm"
		-- 8:5-45 FDOT421 "F/L5/3F/SD45/Corr.Nr FW3010"
		-- 8:5-46 FDOT421 "F/L5/3F/SD46/Corr.Nr FW3010"
		-- 8:5-47 FDOT421 "F/L5/3F/SD47/Corr.Nr FW/S22"

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:5 XDLC "XDLC @ address 5 L5"

```
|      |      |-- 8:5-48 FDOT421 "F/L5/3F/SD48/Corr.Nr FW/S22"
|      |      |-- 8:5-49 HMS-S/D/M/SA "F/L5/3F/MCP49/FW Fire Esc STR"
|      |      |-- 8:5-50 HTRI-R "F/L5/3F/CM50/FW Fire Esc STR"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-51 HTRI-R "F/L5/3F/CM51/FW door release"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-52 FDOT421 "F/L5/3F/SD52/Corr.Nr FW3070"
|      |      |-- 8:5-53 FDOT421 "F/L5/3F/SD53/Corr.Nr FW3090"
|      |      |-- 8:5-54 FDOT421 "F/L5/3F/SD54/Corr.Nr FW3090"
|      |      |-- 8:5-55 FDOT421 "F/L5/3F/SD55/Corr.Nr FW3200"
|      |      |-- 8:5-56 FDOT421 "F/L5/3F/SD56/Corr.Nr FW3200"
|      |      |-- 8:5-57 FDOT421 "F/L5/3F/SD57/Corr.Nr FW3140"
|      |      |-- 8:5-58 FDOT421 "F/L5/3F/SD58/Corr.Nr FW3140"
|      |      |-- 8:5-59 HMS-S/D/M/SA "F/L5/3F/MCP59/FW Fire Esc dr"
|      |      |-- 8:5-60 HTRI-R "F/L5/3F/CM60/FW Fire Esc dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-61 HFP-11 "F/L5/3F/SD61/Corr.Nr FW/S18"
|      |      |-- 8:5-62 HFP-11 "F/L5/EW4130/SD62/Pantry"
|      |      |-- 8:5-63 HFP-11 "F/L5/EW4130/SD63/Buyers cab"
|      |      |-- 8:5-64 HFP-11 "F/L5/EW4130/SD64/Buyers cab"
|      |      |-- 8:5-65 HFP-11 "F/L5/EW4130/SD65/Psg nr buyers c"
|      |      |-- 8:5-66 HFP-11 "F/L5/EW4130/SD66/Main cab"
|      |      |-- 8:5-67 HFP-11 "F/L5/EW4130/SD67/Psg nr Main cab"
|      |      |-- 8:5-68 HFP-11 "F/L5/EW4130/SD68/Assorter cab"
|      |      |-- 8:5-69 HFP-11 "F/L5/EW4130/SD69/Assorter cab"
|      |      |-- 8:5-70 HFP-11 "F/L5/EW4130/SD70/Assorter cab"
|      |      |-- 8:5-71 HTRI-S "F/L5/4F/MM71/FW4131"
|      |      |-- 8:5-72 HFP-11 "F/L5/EW4160/SD72/Pantry"
|      |      |-- 8:5-73 HTRI-S "F/L5/4F/MM73/FW4120"
|      |      |-- 8:5-74 HFP-11 "F/L5/EW4130/SD74/Reception cab"
|      |      |-- 8:5-75 HTRI-S "F/L5/FW/4F/MM75/FW 4110"
|      |      |-- 8:5-76 HTRI-R "F/L5/EW4130/CM76/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-77 HMS-S/D/M/SA "F/L5/EW4130/MCP77/Entry dr Psg"
|      |      |-- 8:5-78 HTRI-S "F/L5/4F/MM78/FW4150"
|      |      |-- 8:5-79 HFP-11 "F/L5/FW3160/SD79/Main cab"
|      |      |-- 8:5-80 HTRI-S "F/L5/MM80/FW4080"
|      |      |-- 8:5-81 HTRI-S "F/L5/4F/MM81/FW4070"
|      |      |-- 8:5-82 HTRI-R "F/L5/FW3140/CM82/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-83 HTRI-R "F/L5/EW3120/CM83/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-84 HMS-S/D/M/SA "F/L5/EW3120/MCP84/Entry Psg"
|      |      |-- 8:5-85 HTRI-S "F/L5/4F/MM85/FW4050"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:5 XDLC "XDLC @ address 5 L5"

		-- 8:5-86 HFP-11 "F/L5/EW3130/SD86/Main cab"
		-- 8:5-87 HTRI-S "F/L5/4F/MM87/FW4030"
		-- 8:5-88 HTRI-S "F/L5/4F/MM88/FW4041"
		-- 8:5-89 HTRI-S "F/L5/4F/MM89/FW 4020"
		-- 8:5-90 HFP-11 "F/L5/FW3140/SD90/Account cab"
		-- 8:5-91 HFP-11 "F/L5/EW3130/SD91/Assorter cab"
		-- 8:5-92 HTRI-S "F/L5/4F/MM92/FW 4041"
		-- 8:5-93 HMS-S/D/M/SA "F/L5/FW3140/MCP93/Entry Psg"
		-- 8:5-94 HTRI-S "F/L5/4F/MM94/EW4120"
		-- 8:5-95 HTRI-S "F/L5/4F/MM95/EW4110"
		-- 8:5-96 HFPT-11 "F/L5/EW3130/HD96/Pantry"
		-- 8:5-97 HFP-11 "F/L5/FW4170/SD97/Main cab"
		-- 8:5-98 HTRI-S "F/L5/4F/MM98/EW4090"
		-- 8:5-99 HTRI-R "F/L5/FW3160/CM99/AFC Pantry"
		-- Switch ""
		-- Relay
		-- 8:5-100 HTRI-S "F/L5/3F/MM100/FW 3011"
		-- 8:5-101 FDOT421 "F/L5/EW4100/SD101/Ent Psg AFC"
		-- 8:5-102 HMS-S/D/M/SA "F/L5/FW3160/MCP102/Pantry Psg"
		-- 8:5-103 HTRI-S "F/L5/3F/MM103/EW3100"
		-- 8:5-104 HTRI-S "F/L5/3F/MM104/EW3140"
		-- 8:5-105 HTRI-S "F/L5/3F/MM105/EW 3080"
		-- 8:5-106 HFP-11 "F/L5/FW4170/SD106/Pantry"
		-- 8:5-107 HFP-11 "F/L5/FW4090/SD107/Pantry"
		-- 8:5-110 HTRI-S "F/L5/3F/MM110/FW3020"
		-- 8:5-111 HTRI-S "F/L5/3F/MM111/FW3030"
		-- 8:5-112 HTRI-S "F/L5/MM112/FW3030A"
		-- 8:5-113 HTRI-R "F/L5/EW3130/CM113/Entry dr psg"
		-- Switch ""
		-- Relay
		-- 8:5-114 HFP-11 "F/L5/FW3140/SD114/Assorter cab"
		-- 8:5-115 HTRI-S "F/L5/3F/MM115/FW3050"
		-- 8:5-116 HMS-S/D/M/SA "F/L5/EW3130/MCP116/Entry dr psg"
		-- 8:5-117 HFP-11 "F/L5/FW3060/SD117/Pantry"
		-- 8:5-118 HTRI-S "F/L5/3F/MM118/FW3080"
		-- 8:5-119 HTRI-S "F/L5/3F/MM119/FW3090"
		-- 8:5-120 HTRI-S "F/L5/3F/MM120/FW3100"
		-- 8:5-121 HTRI-S "F/L5/3F/MM121/FW 3110"
		-- 8:5-122 HTRI-S "F/L5/3F/MM122/FW3120"
		-- 8:5-123 HTRI-S "F/L5/WC/3F/MM123/FW3200"
		-- 8:5-124 HFP-11 "F/L5/FW3160/SD124/Accounts cab"
		-- 8:5-125 HTRI-R "F/L5/FW4170/CM125/Entry Psg"
		-- Switch ""
		-- Relay
		-- 8:5-126 HFP-11 "F/L5/FW3160/SD126/Accounts cab"
		-- 8:5-127 HTRI-S "F/L5/WC/3F/MM127/FW3190"
		-- 8:5-128 HMS-S/D/M/SA "F/L5/FW4170/MCP128/Entry Psg"
		-- 8:5-129 HFP-11 "F/L5/FW3160/SD129/Entry Psg"
		-- 8:5-130 HFP-11 "F/L5/FW4040/SD130/Main Cab 1"
		-- 8:5-131 HFP-11 "F/L5/FW4040/SD131/Main Cab 2"

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:5 XDLC "XDLC @ address 5 L5"

```
|      |      |-- 8:5-132 HFP-11 "F/L5/FW4040/SD132/Psg nr Main Ca"
|      |      |-- 8:5-133 HFP-11 "F/L5/FW4040/SD133/Pantry"
|      |      |-- 8:5-134 HTRI-R "F/L5/FW4040/CM134/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-135 HMS-S/D/M/SA "F/L5/FW4040/MCP135/Entry dr Psg"
|      |      |-- 8:5-136 HFP-11 "F/L5/FW4060/SD136/Main Cab "
|      |      |-- 8:5-137 HFP-11 "F/L5/FW4060/SD137/Main Cab "
|      |      |-- 8:5-138 HFP-11 "F/L5/FW4060/SD138/Accounts cab"
|      |      |-- 8:5-139 HFP-11 "F/L5/FW4060/SD139/Pantry"
|      |      |-- 8:5-140 HTRI-R "F/L5/FW4060/CM140/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-141 HMS-S/D/M/SA "F/L5/FW4060/MCP141/Entry dr Psg"
|      |      |-- 8:5-142 HFP-11 "F/L5/FW4100/SD142/Main Cab "
|      |      |-- 8:5-143 HFP-11 "F/L5/FW4100/SD143/Cab 1"
|      |      |-- 8:5-144 HFP-11 "F/L5/FW4100/SD144/Assorter cab"
|      |      |-- 8:5-145 HFP-11 "F/L5/FW4100/SD145/Cab 2"
|      |      |-- 8:5-146 HTRI-R "F/L5/FW4100/CM146/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-147 HMS-S/D/M/SA "F/L5/FW4100/MCP147/Entry dr Psg"
|      |      |-- 8:5-148 HFP-11 "F/L5/FW4160/SD148/Main Cab "
|      |      |-- 8:5-149 HTRI-R "F/L5/FW4160/CM149/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-150 HMS-S/D/M/SA "F/L5/FW4160/MCP150/Entry dr Psg"
|      |      |-- 8:5-151 HFP-11 "F/L5/FW4180/SD151/Main Cab "
|      |      |-- 8:5-152 HFP-11 "F/L5/FW4180/SD152/Pantry"
|      |      |-- 8:5-153 HTRI-R "F/L5/FW4180/CM153/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-154 HMS-S/D/M/SA "F/L5/FW4180/MCP154/Entry dr Psg"
|      |      |-- 8:5-155 HFP-11 "F/L5/FW3140/SD155/Main cab"
|      |      |-- 8:5-156 HFP-11 "F/L5/FW3140/SD156/Entry Psg"
|      |      |-- 8:5-157 HFP-11 "F/L5/FW4170/SD157/Entry Psg"
|      |      |-- 8:5-158 HFP-11 "F/L5/FW3160/SD158/Pantry"
|      |      |-- 8:5-159 HFPT-11 "F/L5/FW4100/HD159/Pantry"
|      |      |-- 8:5-160 HFP-11 "F/L5/FW4140/SD160/AFC PANTRY"
|      |      |-- 8:5-161 HFPT-11 "F/L5/FW4140/HD161/PANTRY"
|      |      |-- 8:5-162 HFP-11 "F/L5/FW3070/SD162/Accounts cab"
|      |      |-- 8:5-163 HFP-11 "F/L5/FW3070/SD163/Main cab"
|      |      |-- 8:5-164 HFP-11 "F/L5/FW3070/SD164/Assorter cab"
|      |      |-- 8:5-165 HFP-11 "F/L5/FW3070/SD165/Psg nr Assorte"
|      |      |-- 8:5-166 HFP-11 "F/L5/FW3070/SD166/Entry dr Psg"
|      |      |-- 8:5-167 HTRI-R "F/L5/FW3070/CM167/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-168 HMS-S/D/M/SA "F/L5/FW3070/MCP168/Entry dr Psg"
|      |      |-- 8:5-169 HFP-11 "F/L5/FW3130/SD169/Main cab"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:5 XDLC "XDLC @ address 5 L5"

```
|      |      |-- 8:5-170 HFP-11 "F/L5/FW3130/SD170/Assorter C"
|      |      |-- 8:5-171 HFP-11 "F/L5/FW3130/SD171/Psg Nr Assorte"
|      |      |-- 8:5-172 HFP-11 "F/L5/FW3130/SD172/Pantry"
|      |      |-- 8:5-173 HTRI-R "F/L5/FW3130/CM173/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-174 HMS-S/D/M/SA "F/L5/FW3130/MCP174/Pantry"
|      |      |-- 8:5-175 HFP-11 "F/L5/FW3150/SD175/Main cab1"
|      |      |-- 8:5-176 HFP-11 "F/L5/FW3150/SD176/Main cab2"
|      |      |-- 8:5-177 HFP-11 "F/L5/FW3150/SD177/Main cab3"
|      |      |-- 8:5-178 HFP-11 "F/L5/FW3150/SD178/Pantry"
|      |      |-- 8:5-179 HTRI-R "F/L5/FW3150/CM179/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-180 HMS-S/D/M/SA "F/L5/FW3150/MCP180/Entry dr Psg"
|      |      |-- 8:5-181 HFP-11 "F/L5/FW3040/SD181/Assorter cab"
|      |      |-- 8:5-182 HFP-11 "F/L5/FW3040/SD182/Pantry"
|      |      |-- 8:5-183 HFP-11 "F/L5/FW3040/SD183/Pantry"
|      |      |-- 8:5-184 HFP-11 "F/L5/FW3040/SD184/Conference rm"
|      |      |-- 8:5-185 HFP-11 "F/L5/FW3040/SD185/Psg ne conf. r"
|      |      |-- 8:5-186 HFP-11 "F/L5/FW3040/SD186/Main cab"
|      |      |-- 8:5-187 HFP-11 "F/L5/FW3040/SD187/Entry dr Psg"
|      |      |-- 8:5-188 HTRI-R "F/L5/FW3040/CM188/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-189 HMS-S/D/M/SA "F/L5/FW3040/MCP189/Entry dr Psg"
|      |      |-- 8:5-190 HFP-11 "F/L5/FW4140/SD190/Account cab"
|      |      |-- 8:5-191 HFP-11 "F/L5/FW4140/SD191/Main cab"
|      |      |-- 8:5-192 HFP-11 "F/L5/FW4140/SD192/Psg nr MC"
|      |      |-- 8:5-193 HTRI-R "F/L5/FW4140/CM193/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-194 HMS-S/D/M/SA "F/L5/FW4140/MCP194/Entry dr Psg"
|      |      |-- 8:5-195 HFP-11 "F/L5/FW4090/SD195/Lunch cab"
|      |      |-- 8:5-196 HFP-11 "F/L5/FW4090/SD196/Main cab"
|      |      |-- 8:5-197 HFP-11 "F/L5/FW4090/SD197/Pantry"
|      |      |-- 8:5-198 HTRI-R "F/L5/FW4090/CM198/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-199 HMS-S/D/M/SA "F/L5/FW4090/MCP199/Entry dr Psg"
|      |      |-- 8:5-200 HFP-11 "F/L5/FW3060/SD200/Main cab"
|      |      |-- 8:5-201 HFP-11 "F/L5/FW3060/SD201/Assorter cab"
|      |      |-- 8:5-202 HFP-11 "F/L5/FW3060/SD202/Pantry"
|      |      |-- 8:5-203 HTRI-R "F/L5/FW3060/CM203/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-204 HMS-S/D/M/SA "F/L5/FW3060/MCP204/Entry dr Psg"
|      |      |-- 8:5-205 HFP-11 "F/L5/FW4010/SD205/Main cab"
|      |      |-- 8:5-206 HFP-11 "F/L5/FW4010/SD206/Psg nr Main ca"
|      |      |-- 8:5-207 HFP-11 "F/L5/FW4010/SD207/Assorter cab"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:5 XDLC "XDLC @ address 5 L5"

```
|      |      |-- 8:5-208 HFP-11 "F/L5/FW4010/SD208/Pantry Psg"
|      |      |-- 8:5-209 HTRI-R "F/L5/FW4010/CM209/AFC Pantry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-210 HMS-S/D/M/SA "F/L5/FW4010/MCP210/Entry Psg"
|      |      |-- 8:5-211 HFP-11 "F/L5/EW4100/SD211/Main cab"
|      |      |-- 8:5-212 HFP-11 "F/L5/EW4100/SD212/Accounts cab"
|      |      |-- 8:5-213 HFP-11 "F/L5/EW4100/SD213/Psg nr Account"
|      |      |-- 8:5-214 HFP-11 "F/L5/EW4100/SD214/Pantry"
|      |      |-- 8:5-215 HTRI-R "F/L5/EW4100/CM215/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-216 HMS-S/D/M/SA "F/L5/EW4100/MCP216/Entry dr Psg"
|      |      |-- 8:5-217 HFP-11 "F/L5/EW3090/SD217/Main cab"
|      |      |-- 8:5-218 HFP-11 "F/L5/EW3090/SD218/Assorter cab"
|      |      |-- 8:5-219 HFP-11 "F/L5/EW3090/SD219/Pantry"
|      |      |-- 8:5-220 HTRI-R "F/L5/EW3090/CM220/AFC Entry dr"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-221 HMS-S/D/M/SA "F/L5/EW3090/MCP221/Entry dr Psg"
|      |      |-- 8:5-222 HFP-11 "F/L5/EW4150/SD222/Rajveer gems c"
|      |      |-- 8:5-223 HFP-11 "F/L5/EW4150/SD223/Main cab"
|      |      |-- 8:5-224 HFP-11 "F/L5/EW4150/SD224/Jigar Impex ca"
|      |      |-- 8:5-225 HFP-11 "F/L5/EW4150/SD225/Pantry Psg"
|      |      |-- 8:5-226 HTRI-R "F/L5/EW4150/CM226/AFC Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-227 HMS-S/D/M/SA "F/L5/EW4150/MCP227/Entry Psg"
|      |      |-- 8:5-229 HFP-11 "F/L5/EW4160/SD229/Cab 1"
|      |      |-- 8:5-230 HFP-11 "F/L5/EW4160/SD230/Cab 2"
|      |      |-- 8:5-231 HFP-11 "F/L5/EW4160/SD231/Cab 3"
|      |      |-- 8:5-232 HFP-11 "F/L5/EW4160/SD232/Entry Psg"
|      |      |-- 8:5-233 HTRI-R "F/L5/EW4160/CM233/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-234 HMS-S/D/M/SA "F/L5/EW4160/MCP234/Entry Psg"
|      |      |-- 8:5-235 HFP-11 "F/L5/EW3070/SD235/Main cab"
|      |      |-- 8:5-236 HFP-11 "F/L5/EW3070/SD236/Assorter cab1"
|      |      |-- 8:5-237 HFP-11 "F/L5/EW3070/SD237/Assorter cab2"
|      |      |-- 8:5-238 HFP-11 "F/L5/EW3070/SD238/Psg nr Assorte"
|      |      |-- 8:5-239 HFP-11 "F/L5/EW3070/SD239/Pantry Psg"
|      |      |-- 8:5-240 HTRI-R "F/L5/EW3070/CM240/AFC Entry dr P"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-241 HMS-S/D/M/SA "F/L5/EW3070/MCP241/Entry dr Psg"
|      |      |-- 8:5-242 HFP-11 "F/L5/FW4160/SD242/Psg Nr Assorte"
|      |      |-- 8:5-243 HFP-11 "F/L5/EW3110/SD243/Main Cab"
|      |      |-- 8:5-244 HFP-11 "F/L5/EW3110/SD244/Main Cab 2"
|      |      |-- 8:5-245 HFP-11 "F/L5/EW3110/SD245/Psg Nr Cab 2"
|      |      |-- 8:5-246 HFPT-11 "F/L5/EW3110/HD246/Pantry"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:5 XDLC "XDLC @ address 5 L5"

```
|      |      |-- 8:5-247 XTRI-R "F/L5/EW3110/CM247/Entry psg AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 8:5-248 HMS-S/D/M/SA "F/L5/EW3110/MCP248/Entry dr psg"
|      |      |-- 8:5-250 HFP-11 "F/L5/EW3120/SD250/Assorter cab"
|      |      |-- 8:5-251 HFP-11 "F/L5/EW3120/SD251/Pantry Psg"
|      |      |-- 8:5-252 HFP-11 "F/L5/EW3120/SD252/Pantry Psg"
|      |-- CC-5 "Card Cage 5 Slots"
|      |  |-- 8:6 XDLC "XDLC @ address 6 L6"
|      |  |  |-- 8:6-6 HMS-S/D/M/SA "F/L6/CC/7F/MCP6/FIRE ESC STR MCP"
|      |  |  |-- 8:6-7 HTRI-R "F/L6/CC/7F/CM7/FIRE ESC STR CM"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 8:6-8 HFP-11 "F/L6/CC/7F/SD8/CORR NR FC 7010"
|      |  |  |-- 8:6-9 HFP-11 "F/L6/CC/7F/SD9/CORR NR FC 7010"
|      |  |  |-- 8:6-10 HFP-11 "F/L6/CC/7F/SD10/CORR NR FC7/S07"
|      |  |  |-- 8:6-11 HFP-11 "F/L6/CC/7F/SD11/CORR NR FC7/S07"
|      |  |  |-- 8:6-12 HFP-11 "F/L6/CC/7F/SD12/CORR NR FC 7010"
|      |  |  |-- 8:6-13 HFP-11 "F/L6/CC/7F/SD13/CORR NR FC 7010"
|      |  |  |-- 8:6-14 HFP-11 "F/L6/CC/7F/SD14/CORR NR FC 7060"
|      |  |  |-- 8:6-15 HFP-11 "F/L6/CC/7F/SD15/CORR NR FC 7060"
|      |  |  |-- 8:6-16 HFP-11 "F/L6/CC/7F/SD16/ELECT RM SD"
|      |  |  |-- 8:6-17 HTRI-R "F/L6/CC/7F/CM17/DR RELESE CM"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 8:6-18 HMS-S/D/M/SA "F/L6/CC/7F/MCP18/FIRE SHAFT L.L."
|      |  |  |-- 8:6-19 HTRI-R "F/L6/CC/7F/CM19/FIRE SHAFT L.L."
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 8:6-20 HTRI-S "F/L6/CC/7F/MM20/FIRE SHAFT L.L."
|      |  |  |-- 8:6-21 HFP-11 "F/L6/CC/7F/SD21/LIFT LOBBY SD"
|      |  |  |-- 8:6-22 HFP-11 "F/L6/CC/7F/SD22/LIFT LOBBY SD"
|      |  |  |-- 8:6-23 HTRI-R "F/L6/EC/7F/CM23/AHU RM CM"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 8:6-24 HFP-11 "F/L6/EC/7F/SD24/AHU RM SD"
|      |  |  |-- 8:6-25 HTRI-R "F/L6/EC/7F/CM25/DR RELESE CM"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 8:6-26 HFP-11 "F/L6/EC/7F/SD26/CORR NR AHU RM"
|      |  |  |-- 8:6-27 HFP-11 "F/L6/EC/7F/SD27/CORR NR FC 7091"
|      |  |  |-- 8:6-28 HFP-11 "F/L6/EC/7F/SD28/CORR NR FC7/S04"
|      |  |  |-- 8:6-29 HFP-11 "F/L6/EC/7F/SD29/CORR NR FC 7081"
|      |  |  |-- 8:6-30 HFP-11 "F/L6/EC/7F/SD30/CORR NR FC7/S03"
|      |  |  |-- 8:6-31 HFP-11 "F/L6/EC/7F/SD31/CORR NR FC7/S03"
|      |  |  |-- 8:6-32 HFP-11 "F/L6/EC/7F/SD32/CORR NR FC 7082"
|      |  |  |-- 8:6-33 HFP-11 "F/L6/EC/7F/SD33/CORR NR FC 7082"
|      |  |  |-- 8:6-34 HMS-S/D/M/SA "F/L6/EC/7F/MCP34/FIRE ESC STR "
|      |  |  |-- 8:6-35 HTRI-R "F/L6/EC/7F/CM35/FIRE ESC STR "
|      |  |  |  |-- Switch ""
```

8:6-35 HTRI-R "F/L6/EC/7F/CM35/FIRE ESC STR "

```
| | | | | Relay
| | | | |
| | | | | |-- 8:6-36 HFP-11 "F/L6/EC/7F/SD36/ELECT RM SD"
| | | | |
| | | | | |-- 8:6-37 HTRI-R "F/L6/EC/7F/CM37/AHU RM CM"
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:6-38 HFP-11 "F/L6/EC/7F/SD38/AHU RM SD"
| | | | |
| | | | | |-- 8:6-39 HFP-11 "F/L6/EC/7F/SD39/LIFT LOBBY SD"
| | | | |
| | | | | |-- 8:6-40 HMS-S/D/M/SA "F/L6/EC/7F/MCP40/FIRE SHAFT L.L."
| | | | |
| | | | | |-- 8:6-41 HTRI-R "F/L6/EC/7F/CM41/FIRE SHAFT L.L."
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:6-42 HTRI-S "F/L6/EC/7F/MM42/FIRE SHAFT L.L."
| | | | |
| | | | | |-- 8:6-43 HFP-11 "F/L6/CC/6F/SD43/CORR NR E.R."
| | | | |
| | | | | |-- 8:6-44 HFP-11 "F/L6/CC/6F/SD44/CORR NR E.R."
| | | | |
| | | | | |-- 8:6-45 HFP-11 "F/L6/CC/6F/SD45/ELECT RM SD"
| | | | |
| | | | | |-- 8:6-46 HMS-S/D/M/SA "F/L6/CC/6F/MCP46/FIRE ESC STR"
| | | | |
| | | | | |-- 8:6-47 HTRI-R "F/L6/CC/6F/CM47/FIRE ESC STR"
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:6-48 HTRI-S "F/L6/CC/6F/MM48/FIRE ESC STR"
| | | | |
| | | | | |-- 8:6-49 HTRI-R "F/L6/CC/6F/CM49/AHU RM CM"
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:6-50 HFP-11 "F/L6/CC/6F/SD50/AHU RM SD"
| | | | |
| | | | | |-- 8:6-51 HFP-11 "F/L6/CC/6F/SD51/LIFT LOBBY SD"
| | | | |
| | | | | |-- 8:6-52 HFP-11 "F/L6/CC/6F/SD52/LIFT LOBBY SD"
| | | | |
| | | | | |-- 8:6-55 HFP-11 "F/L6/EC/6F/SD55/ELECT RM SD"
| | | | |
| | | | | |-- 8:6-56 HTRI-R "F/L6/EC/6F/CM56/AHU RM CM"
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:6-57 HFP-11 "F/L6/EC/6F/SD57/AHU RM SD"
| | | | |
| | | | | |-- 8:6-58 HFP-11 "F/L6/EC/6F/SD58/LIFT LOBBY SD"
| | | | |
| | | | | |-- 8:6-59 HMS-S/D/M/SA "F/L6/EC/6F/MCP59/FIRE SHAFT L.L."
| | | | |
| | | | | |-- 8:6-60 HTRI-R "F/L6/EC/6F/CM60/FIRE SHAFT L.L."
| | | | |
| | | | | | |-- Switch ""
| | | | |
| | | | | | |-- Relay
| | | | |
| | | | | |-- 8:6-61 HTRI-S "F/L6/EC/6F/MM61/FIRE SHAFT L.L."
| | | | |
| | | | | |-- 8:6-71 HTRI-S "F/L6/7F/MM71/FE7011"
| | | | |
| | | | | |-- 8:6-72 HTRI-S "F/L6/7F/MM72/FE6017"
| | | | |
| | | | | |-- 8:6-73 HTRI-S "F/L6/CC/7F/MM73/FC7042"
| | | | |
| | | | | |-- 8:6-74 HTRI-S "F/L6/CC/7F/MM74/FC7011"
| | | | |
| | | | | |-- 8:6-75 HTRI-S "F/L6/CC/7F/MM75/FC7041"
| | | | |
| | | | | |-- 8:6-76 HTRI-S "F/L6/7F/MM76/FC7050"
| | | | |
| | | | | |-- 8:6-81 HTRI-S "F/L6/CC/7F/MM81/FC7071"
| | | | |
| | | | | |-- 8:6-83 HTRI-S "F/L6/CC/7F/MM83/FC7081"
| | | | |
| | | | | |-- 8:6-84 HTRI-S "F/L6/CC/7F/MM84/FC7092B"
| | | | |
| | | | | |-- 8:6-85 HTRI-S "F/L6/CC/7F/MM85/FC7082"
| | | | |
| | | | | |-- 8:6-86 HTRI-S "F/L6/CC/7F/MM86/FC7192A"
| | | | |
| | | | | |-- 8:6-88 HTRI-S "F/L6/CC/6F/MM88/FC6041"
| | | | |
| | | | | |-- 8:6-89 HFP-11 "F/L6/FC6017/SD89/Biq conf Rm"
```


8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:6 XDLC "XDLC @ address 6 L6"

			-- 8:6-90 HFP-11 "F/L6/FC6017/SD90/Dining Rm"
			-- 8:6-91 HFP-11 "F/L6/FC6017/SD91/Big Kitchen Rm"
			-- 8:6-92 HFP-11 "F/L6/FC6017/SD92/Lab Rm"
			-- 8:6-93 HFP-11 "F/L6/FC6017/SD93/Psg nr Entrance"
			-- 8:6-94 HFP-11 "F/L6/FC6017/SD94/Server Rm"
			-- 8:6-95 HFP-11 "F/L6/FC6017/SD95/Waiting Area"
			-- 8:6-96 HFP-11 "F/L6/FC6017/SD96/Reception"
			-- 8:6-97 HFP-11 "F/L6/FC6017/SD97/Conference Rm"
			-- 8:6-98 HFP-11 "F/L6/FC6017/SD98/Nehal bhai cab"
			-- 8:6-99 HFP-11 "F/L6/FC6017/SD99/Psg nr Pantry"
			-- 8:6-100 HFPT-11 "F/L6/FC6017/HD100/Pantry"
			-- 8:6-101 HFP-11 "F/L6/FC6017/SD101/Ashishbhai cab"
			-- 8:6-102 HFP-11 "F/L6/FC6017/SD102/Hemant bhai ca"
			-- 8:6-103 HFP-11 "F/L6/FC6017/SD103/Psg nr hemantb"
			-- 8:6-104 HFP-11 "F/L6/FC6017/SD104/Anshubhai cab"
			-- 8:6-105 HFP-11 "F/L6/FC6017/SD105/Parag bhai cab"
			-- 8:6-106 HFP-11 "F/L6/FC6017/SD106/Premal bhai ca"
			-- 8:6-107 HFP-11 "F/L6/FC6017/SD107/darshan bhai c"
			-- 8:6-108 HFP-11 "F/L6/FC6017/SD108/Anuj bhai cab"
			-- 8:6-109 HFP-11 "F/L6/FC6017/SD109/Rahul bhai cab"
			-- 8:6-110 HFP-11 "F/L6/FC6017/SD110/vikram bhai ca"
			-- 8:6-111 HFP-11 "F/L6/FC6017/SD111/chirag shah ca"
			-- 8:6-112 HFP-11 "F/L6/FC6017/SD112/Chirag shah ca"
			-- 8:6-113 HFP-11 "F/L6/FC6017/SD113/buyers cab"
			-- 8:6-114 HFP-11 "F/L6/FC6017/SD114/Client Rm 1"
			-- 8:6-115 HFP-11 "F/L6/FC6017/SD115/Vinayak bhai c"
			-- 8:6-116 HFP-11 "F/L6/FC6017/SD116/psg nr client "
			-- 8:6-117 HFP-11 "F/L6/FC6017/SD117/client rm 2"
			-- 8:6-118 HFP-11 "F/L6/FC6017/SD118/psg nr client "
			-- 8:6-119 HFP-11 "F/L6/FC6017/SD119/laxmi madam ca"
			-- 8:6-120 HFP-11 "F/L6/FC6017/SD120/Psg nr keyur b"
			-- 8:6-121 HFP-11 "F/L6/FC6017/SD121/Keyur bhai cab"
			-- 8:6-122 HFP-11 "F/L6/FC6017/SD122/Vijaya madam c"
			-- 8:6-123 HFP-11 "F/L6/FC6017/SD123/Launge area ps"
			-- 8:6-124 FDOT421 "F/L6/FC6017/SD124/launge area ps"
			-- 8:6-125 HFP-11 "F/L6/FC6017/SD125/Russel bhai ca"
			-- 8:6-126 HFP-11 "F/L6/FC6017/SD126/Arun bhai cab"
			-- 8:6-127 HFP-11 "F/L6/FC6017/SD127/Arun bhai cab "
			-- 8:6-128 HFP-11 "F/L6/FC6017/SD128/Shanay bhai ca"
			-- 8:6-129 HFP-11 "F/L6/FC6017/SD129/Client rm 3"
			-- 8:6-130 HFP-11 "F/L6/FC6017/SD130/client rm 4"
			-- 8:6-131 HFP-11 "F/L6/FC6017/SD131/Admin cab"
			-- 8:6-132 HMS-S/D/M/SA "F/L6/FC6017/MCP132/Psg nr FC Ent"
			-- 8:6-133 HMS-S/D/M/SA "F/L6/FC6017/MCP133/Launge Area"
			-- 8:6-134 HMS-S/D/M/SA "F/L6/FC6017/MCP134/Psg nr FE Ent"
			-- 8:6-135 HTRI-R "F/L6/FC6017/CM135/Admin cab"
			-- Switch ""
			-- Relay
			-- 8:6-136 HTRI-R "F/L6/FC6017/CM136/Passage Nr Fir"
			-- Switch ""

```

8 Desigo Fire Safety Modular "BDB TOWER F" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      8:6 XDLC "XDLC @ address 6 L6"
        8:6-136 HTRI-R "F/L6/FC6017/CM136/Passage Nr Fir"

```

```
| | | | | Relay  
| | | | |  
| | | | | -- 8:6-137 HTRI-R "F/L6/FC6017/CM137/Passage Nr FC "  
| | | | | | | | | Switch ""  
| | | | | | | | | Relay  
| | | | |  
| | | | | -- 8:6-138 HFP-11 "F/L6/FC7010/SD138/Account cab"  
| | | | | | | | | 8:6-139 HFP-11 "F/L6/FC7010/SD139/Main cab"  
| | | | | | | | | 8:6-140 HFP-11 "F/L6/FC7010/SD140/Cab 1"  
| | | | | | | | | 8:6-141 HFP-11 "F/L6/FC7010/SD141/Cab 2"  
| | | | | | | | | 8:6-142 HFP-11 "F/L6/FC7010/SD142/Cab 3"  
| | | | | | | | | 8:6-143 HFP-11 "F/L6/FC7010/SD143/Pantry"  
| | | | | | | | | 8:6-144 HFP-11 "F/L6/FC7010/SD144/Cab 4"  
| | | | | | | | | 8:6-145 HFP-11 "F/L6/FC7010/SD145/Cab 5"  
| | | | | | | | | 8:6-146 HFP-11 "F/L6/FC7010/SD146/Cab 6"  
| | | | | | | | | 8:6-147 HFP-11 "F/L6/FC7010/SD147/Psg nr Pantry"  
| | | | | | | | | 8:6-148 HFP-11 "F/L6/FC7010/SD148/Psg nr Cab 4"  
| | | | | | | | | 8:6-149 HFP-11 "F/L6/FC7010/SD149/Reception"  
| | | | | | | | | 8:6-150 HTRI-R "F/L6/FC7010/CM150/Entry Psg"  
| | | | | | | | | | | Switch ""  
| | | | | | | | | | | Relay  
| | | | |  
| | | | | -- 8:6-151 HMS-S/D/M/SA "F/L6/FC7010/MCP151/Entry Psg"  
| | | | | | | | | 8:6-152 HFP-11 "F/L6/FC7100/SD152/Assorter cab"  
| | | | | | | | | 8:6-153 HFP-11 "F/L6/FC7100/SD153/Main cab"  
| | | | | | | | | 8:6-154 HFP-11 "F/L6/FC7100/SD154/Psg nr Main ca"  
| | | | | | | | | 8:6-155 HFP-11 "F/L6/FC7100/SD155/Assorter Psg"  
| | | | | | | | | 8:6-156 HFP-11 "F/L6/FC7100/SD156/Entry dr Psg"  
| | | | | | | | | 8:6-157 HTRI-R "F/L6/FC7100/CM157/Entry dr Psg"  
| | | | | | | | | | | Switch ""  
| | | | | | | | | | | Relay  
| | | | |  
| | | | | -- 8:6-158 HMS-S/D/M/SA "F/L6/FC7100/MCP158/Entry dr Psg"  
| | | | | | | | | 8:6-159 HFP-11 "F/L6/FC7091/SD159/Cab 1"  
| | | | | | | | | 8:6-160 HFP-11 "F/L6/FC7091/SD160/Main cab1"  
| | | | | | | | | 8:6-161 HFP-11 "F/L6/FC7091/SD161/Lunch cab"  
| | | | | | | | | 8:6-162 HFP-11 "F/L6/FC7091/SD162/Psg nr Lunch c"  
| | | | | | | | | 8:6-163 HFP-11 "F/L6/FC7091/SD163/Pantry"  
| | | | | | | | | 8:6-164 HFP-11 "F/L6/FC7091/SD164/Account cab"  
| | | | | | | | | 8:6-165 HTRI-R "F/L6/FC7091/CM165/Entry Psg"  
| | | | | | | | | | | Switch ""  
| | | | | | | | | | | Relay  
| | | | |  
| | | | | -- 8:6-166 HMS-S/D/M/SA "F/L6/FC7091/MCP166/Entry Psg"  
| | | | | | | | | 8:6-167 HFP-11 "F/L6/FC7060/SD167/Assorter cab"  
| | | | | | | | | 8:6-168 HFP-11 "F/L6/FC7060/SD168/Assorter cab"  
| | | | | | | | | 8:6-169 HFP-11 "F/L6/FC7060/SD169/Main cab"  
| | | | | | | | | 8:6-170 HFP-11 "F/L6/FC7060/SD170/Main cab"  
| | | | | | | | | 8:6-171 HFP-11 "F/L6/FC7060/SD171/Psg nr Pantry"  
| | | | | | | | | 8:6-172 HFP-11 "F/L6/FC7060/SD172/Reception Psg"  
| | | | | | | | | 8:6-173 HFP-11 "F/L6/FC7060/SD173/Pantry"  
| | | | | | | | | 8:6-174 HTRI-R "F/L6/FC7060/CM174/Entry dr Psg"  
| | | | | | | | | | | Switch ""  
| | | | | | | | | | | Relay  
| | | | |  
| | | | | -- 8:6-175 HMS-S/D/M/SA "F/L6/FC7060/MCP175/Entry dr Psq"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:6 XDLC "XDLC @ address 6 L6"

```
|      |      |      |-- 8:6-176 HFP-11 "F/L6/FC7060/SD176/Psg nr entry"
|      |      |      |-- 8:6-177 HFP-11 "F/L6/FC7060/SD177/ psg nr assote"
|      |      |      |-- 8:6-178 HFP-11 "F/L6/FC7060/SD178/assoter cab 4"
|      |      |      |-- 8:6-179 HFP-11 "F/L6/FC7060/SD179/assoter cab 3"
|      |      |      |-- 8:7 XDLC "XDLC @ address 7 L7"
|      |      |      |-- 8:7-1 FDOT421 "F/L7/WC/6F/SD1/CORR NR 6070"
|      |      |      |-- 8:7-2 HMS-S/D/M/SA "F/L7/WC/6F/MCP2/FIRE STR STR"
|      |      |      |-- 8:7-3 HTRI-R "F/L7/WC/6F/CM3/FIRE STR STR"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-4 FDOT421 "F/L7/WC/6F/SD4/CORR NR FW6/S13"
|      |      |      |-- 8:7-5 FDOT421 "F/L7/WC/6F/SD5/AHU RM SD"
|      |      |      |-- 8:7-6 HTRI-R "F/L7/WC/6F/CM6/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-7 FDOT421 "F/L7/WC/6F/SD7/CORR NR FW6/S10"
|      |      |      |-- 8:7-8 HTRI-R "F/L7/WC/6F/CM8/DR RELESE CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-9 HTRI-R "F/L7/WC/6F/CM9/L.L. FIRE SHAFT "
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-10 HTRI-S "F/L7/WC/6F/MM10/L.L. FIRE SHAFT "
|      |      |      |-- 8:7-11 HMS-S/D/M/SA "F/L7/WC/6F/MCP11/L.L. MCP"
|      |      |      |-- 8:7-12 FDOT421 "F/L7/WC/6F/SD12/LIFT LOBBY"
|      |      |      |-- 8:7-13 FDOT421 "F/L7/WC/6F/SD13/LIFT LOBBY"
|      |      |      |-- 8:7-14 FDOT421 "F/L7/WC/6F/SD14/ELECTRICAL RM"
|      |      |      |-- 8:7-15 FDOT421 "F/L7/WC/6F/SD15/CORR NR FW6/S08"
|      |      |      |-- 8:7-16 HTRI-R "F/L7/WC/6F/CM16/DR RELESE CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-17 FDOT421 "F/L7/WC/6F/SD17/CORR NR FW 6032"
|      |      |      |-- 8:7-18 FDOT421 "F/L7/WC/6F/SD18/CORR NR FW 6032"
|      |      |      |-- 8:7-19 FDOT421 "F/L7/WC/6F/SD19/CORR NR FW6/S21"
|      |      |      |-- 8:7-20 FDOT421 "F/L7/WC/6F/SD20/CORR NR FW6/S21"
|      |      |      |-- 8:7-21 FDOT421 "F/L7/WC/6F/SD21/CORR NR FW 6022"
|      |      |      |-- 8:7-22 FDOT421 "F/L7/WC/6F/SD22/CORR NR FW 6022"
|      |      |      |-- 8:7-23 FDOT421 "F/L7/WC/5F/SD23/CORR NR EW 5150"
|      |      |      |-- 8:7-24 HMS-S/D/M/SA "F/L7/WC/5F/MCP24/FIRE ESC STR"
|      |      |      |-- 8:7-25 HTRI-R "F/L7/5F/CM25/EW fire esc dr"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-26 FDOT421 "F/L7/WC/5F/SD26/CORR NR EW 5110"
|      |      |      |-- 8:7-27 FDOT421 "F/L7/WC/5F/SD27/CORR NR EW 5110"
|      |      |      |-- 8:7-28 FDOT421 "F/L7/WC/5F/SD28/AHU RM SD"
|      |      |      |-- 8:7-29 HTRI-R "F/L7/WC/5F/CM29/AHU RM CM"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-30 FDOT421 "F/L7/WC/5F/SD30/CORR NR FW5/S10"
|      |      |      |-- 8:7-31 HTRI-R "F/L7/WC/5F/CM31/DR RELESE CM"
```

8:7-31 HTRI-R "F/L7/WC/5F/CM31/DR RELEASE CM"

```
| | | | Switch ""
| | | | |-- Relay
| | | | |-- 8:7-32 HTRI-R "F/L7/WC/5F/CM32/L.L. FIRE SHAFT"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 8:7-33 HTRI-S "F/L7/WC/5F/MM33/L.L. FIRE SHAFT"
| | | | |-- 8:7-34 HMS-S/D/M/SA "F/L7/WC/5F/MCP34/L.L MCP"
| | | | |-- 8:7-35 FDOT421 "F/L7/WC/5F/SD35/LIFT LOBBY SD"
| | | | |-- 8:7-36 FDOT421 "F/L7/WC/5F/SD36/LIFT LOBBY SD"
| | | | |-- 8:7-37 FDOT421 "F/L7/WC/5F/SD37/ELECTRICAL RM SD"
| | | | |-- 8:7-38 HTRI-R "F/L7/WC/5F/CM38/DR RELESE CM"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 8:7-39 FDOT421 "F/L7/WC/5F/SD39/CORR NR FW 5030"
| | | | |-- 8:7-40 FDOT421 "F/L7/WC/5F/SD40/CORR NR FW 5020"
| | | | |-- 8:7-41 FDOT421 "F/L7/WC/5F/SD41/CORR NR FW5/S16"
| | | | |-- 8:7-42 FDOT421 "F/L7/WC/5F/SD42/CORR NR FW 5050"
| | | | |-- 8:7-43 FDOT421 "F/L7/WC/5F/SD43/CORR NR FW 5160"
| | | | |-- 8:7-44 FDOT421 "F/L7/WC/5F/SD44/CORR NR FW 5160"
| | | | |-- 8:7-45 FDOT421 "F/L7/WC/5F/SD45/CORR NR FW 5100"
| | | | |-- 8:7-46 HMS-S/D/M/SA "F/L7/WC/5F/MCP46/FIRE ESC STR"
| | | | |-- 8:7-47 HTRI-R "F/L7/WC/5F/CM47/FIRE ESC STR"
| | | | |-- Switch ""
| | | | |-- Relay
| | | | |-- 8:7-48 FDOT421 "F/L7/WC/5F/SD48/CORR NR FW 5110"
| | | | |-- 8:7-49 FDOT421 "F/L7/WC/5F/SD49/CORR NR FW 5120"
| | | | |-- 8:7-65 HTRI-S "F/L7/6F/MM65/FW6031"
| | | | |-- 8:7-66 HTRI-S "F/L7/6F/MM66/FW6010B"
| | | | |-- 8:7-67 HTRI-S "F/L7/6F/MM67/FW6032A"
| | | | |-- 8:7-68 HTRI-S "F/L7/6F/MM68/FW6010A"
| | | | |-- 8:7-69 HTRI-S "F/L7/6F/MM69/FW6041"
| | | | |-- 8:7-70 HTRI-S "F/L7/5F/MM70/EW5110"
| | | | |-- 8:7-71 HTRI-S "F/L7/6F/MM71/FW6051"
| | | | |-- 8:7-72 HTRI-S "F/L7/6F/MM72/FW6060"
| | | | |-- 8:7-74 HTRI-S "F/L7/MM74/FW6070"
| | | | |-- 8:7-75 HTRI-S "F/L7/MM75/EW5080"
| | | | |-- 8:7-76 HTRI-S "F/L7/MM76/EW5150"
| | | | |-- 8:7-77 HTRI-S "F/L7/MM77/EW5090"
| | | | |-- 8:7-78 XTRI-S "F/L7/5F/MM78/FW5050"
| | | | |-- 8:7-79 HTRI-S "F/L7/5F/MM79/EW5140"
| | | | |-- 8:7-81 HTRI-S "F/L7/5F/MM81/EW5130"
| | | | |-- 8:7-85 HTRI-S "F/L7/5F/MM85/FW5020"
| | | | |-- 8:7-87 HTRI-S "F/L7/5F/MM87/FW5140"
| | | | |-- 8:7-89 HTRI-S "F/L7/5F/MM89/FW5170"
| | | | |-- 8:7-90 HTRI-S "F/L7/5F/MM90/FW5060"
| | | | |-- 8:7-96 HTRI-S "F/L7/5F/MM96/FW5100"
| | | | |-- 8:7-97 HTRI-S "F/L7/5F/MM97/FW5110"
| | | | |-- 8:7-99 HTRI-S "F/L7/5F/MM99/FW5120"
| | | | |-- 8:7-100 HTRI-S "F/L7/6F/MM100/FW6032B"
| | | | |-- 8:7-110 HFP-11 "F/L7/FW6021/SD110/Main cab1"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:7 XDLC "XDLC @ address 7 L7"

```
|      |      |  |-- 8:7-111 HFP-11 "F/L7/FW6021/SD111/Main Cab 2"
|      |      |  |-- 8:7-112 HFP-11 "F/L7/FW6021/SD112/Cab 1"
|      |      |  |-- 8:7-113 HFP-11 "F/L7/FW6021/SD113/Cab 2"
|      |      |  |-- 8:7-114 HFP-11 "F/L7/FW6021/SD114/Entry Psg"
|      |      |  |-- 8:7-115 HFP-11 "F/L7/FW6021/SD115/Pantry"
|      |      |  |-- 8:7-116 HTRI-R "F/L7/FW6021/CM116/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:7-117 HMS-S/D/M/SA "F/L7/FW6021/MCP117/Entry dr Psg"
|      |      |  |-- 8:7-118 HFP-11 "F/L7/FW6080/SD118/Smolensk cab"
|      |      |  |-- 8:7-119 HFP-11 "F/L7/FW6080/SD119/bernaul cab"
|      |      |  |-- 8:7-120 HFP-11 "F/L7/FW6080/SD120/Pantry"
|      |      |  |-- 8:7-121 HFP-11 "F/L7/FW6080/SD121/Gokhran cab"
|      |      |  |-- 8:7-122 HFP-11 "F/L7/FW6080/SD122/Gokhran cab"
|      |      |  |-- 8:7-123 HFP-11 "F/L7/FW6080/SD123/Gokhran cab"
|      |      |  |-- 8:7-124 HFP-11 "F/L7/FW6080/SD124/Psg nr Mimny c"
|      |      |  |-- 8:7-125 HFP-11 "F/L7/FW6080/SD125/Mimny cab"
|      |      |  |-- 8:7-126 HFP-11 "F/L7/FW6080/SD126/Yacutsk cab"
|      |      |  |-- 8:7-127 HFP-11 "F/L7/FW6080/SD127/Moscow cab"
|      |      |  |-- 8:7-128 HFP-11 "F/L7/FW6080/SD128/Reception Psg"
|      |      |  |-- 8:7-129 HTRI-R "F/L7/FW6080/CM129/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:7-130 HMS-S/D/M/SA "F/L7/FW6080/MCP130/Entry dr Psg"
|      |      |  |-- 8:7-131 HFP-11 "F/L7/FW6022/SD131/Accounts cab"
|      |      |  |-- 8:7-132 HFP-11 "F/L7/FW6022/SD132/Cab 1"
|      |      |  |-- 8:7-133 HFP-11 "F/L7/FW6022/SD133/Cab 2"
|      |      |  |-- 8:7-134 HFP-11 "F/L7/FW6022/SD134/Cab 3"
|      |      |  |-- 8:7-135 HFP-11 "F/L7/FW6022/SD135/Cab 4"
|      |      |  |-- 8:7-136 HFP-11 "F/L7/FW6022/SD136/Reception desk"
|      |      |  |-- 8:7-137 HFP-11 "F/L7/FW6022/SD137/Entry dr Psg"
|      |      |  |-- 8:7-138 HTRI-R "F/L7/FW6022/CM138/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:7-139 HMS-S/D/M/SA "F/L7/FW6022/MCP139/Entry dr Psg"
|      |      |  |-- 8:7-140 HFP-11 "F/L7/GW6140/SD140/Nurba cab"
|      |      |  |-- 8:7-141 HFP-11 "F/L7/GW6140/SD141/Anabar cab"
|      |      |  |-- 8:7-142 HFP-11 "F/L7/GW6140/SD142/Orel cab"
|      |      |  |-- 8:7-143 HFP-11 "F/L7/GW6140/SD143/Alrosa cab"
|      |      |  |-- 8:7-144 HFP-11 "F/L7/GW6140/SD144/Mihir cab"
|      |      |  |-- 8:7-145 HFPT-11 "F/L7/GW6140/HD145/Pantry"
|      |      |  |-- 8:7-146 HFP-11 "F/L7/GW6140/SD146/Psg nr Anabar "
|      |      |  |-- 8:7-147 HFP-11 "F/L7/GW6140/SD147/Udanchan cab"
|      |      |  |-- 8:7-148 HFP-11 "F/L7/GW6140/SD148/Entry dr Psg"
|      |      |  |-- 8:7-149 HTRI-R "F/L7/GW6140/CM149/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 8:7-150 HMS-S/D/M/SA "F/L7/GW6140/MCP150/Entry dr Psg"
|      |      |  |-- 8:7-151 HFP-11 "F/L7/FW5010/SD151/Main cab"
|      |      |  |-- 8:7-152 HFP-11 "F/L7/FW5010/SD152/Assorter cab1"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:7 XDLC "XDLC @ address 7 L7"

```
|      |      |      |-- 8:7-153 HFP-11 "F/L7/FW5010/SD153/Assorter cab2"
|      |      |      |-- 8:7-154 HFP-11 "F/L7/FW5010/SD154/Psg nr assorte"
|      |      |      |-- 8:7-155 HFPT-11 "F/L7/FW5010/HD155/Pantry"
|      |      |      |-- 8:7-156 HTRI-R "F/L7/FW5010/CM156/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-157 HMS-S/D/M/SA "F/L7/FW5010/MCP157/Entry dr Psg"
|      |      |      |-- 8:7-159 HFP-11 "F/L7/GW6130/SD159/Main cab"
|      |      |      |-- 8:7-160 HFP-11 "F/L7/GW6130/SD160/Account cab"
|      |      |      |-- 8:7-161 HFP-11 "F/L7/GW6130/SD161/Entry Psg"
|      |      |      |-- 8:7-162 HFP-11 "F/L7/GW6130/SD162/AFC Entry Psg"
|      |      |      |-- 8:7-163 HTRI-R "F/L7/GW6130/CM163/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-164 HMS-S/D/M/SA "F/L5/GW6130/MCP164/Entry Psg"
|      |      |      |-- 8:7-165 HFP-11 "F/L7/FW5030/SD165/Main cab 1"
|      |      |      |-- 8:7-166 HFP-11 "F/L7/FW5030/SD166/Main cab 2"
|      |      |      |-- 8:7-167 HFP-11 "F/L7/FW5030/SD167/Entry Psg"
|      |      |      |-- 8:7-168 HTRI-R "F/L7/FW5030/CM168/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-169 HMS-S/D/M/SA "F/L7/FW5030/MCP169/Entry Psg"
|      |      |      |-- 8:7-170 HFP-11 "F/L7/FW5040/SD170/Main cab"
|      |      |      |-- 8:7-171 HFP-11 "F/L7/FW5040/SD171/Assorter cab"
|      |      |      |-- 8:7-172 HFP-11 "F/L7/FW5040/SD172/Entry Psg"
|      |      |      |-- 8:7-173 HTRI-R "F/L7/FW5040/CM173/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-174 HMS-S/D/M/SA "F/L7/FW5040/MCP174/Entry Psg"
|      |      |      |-- 8:7-175 HFP-11 "F/L7/FW5070/SD175/Main cab"
|      |      |      |-- 8:7-176 HFP-11 "F/L7/FW5070/SD176/Assorter cab"
|      |      |      |-- 8:7-177 HFP-11 "F/L7/FW5070/SD177/Psg nr Main ca"
|      |      |      |-- 8:7-178 HFP-11 "F/L7/FW5070/SD178/Pantry Psg"
|      |      |      |-- 8:7-179 HTRI-R "F/L7/FW5070/CM179/Entry psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-180 HMS-S/D/M/SA "F/L7/FW5070/MCP180/Entry psg"
|      |      |      |-- 8:7-181 HFP-11 "F/L7/FW5160/SD181/Cab 3"
|      |      |      |-- 8:7-182 HFP-11 "F/L7/FW5160/SD182/Cab 4"
|      |      |      |-- 8:7-183 HFP-11 "F/L7/FW5160/SD183/Cab 2"
|      |      |      |-- 8:7-184 HFP-11 "F/L7/FW5160/SD184/Cab 1"
|      |      |      |-- 8:7-185 HFPT-11 "F/L7/FW5160/HD185/Entry Psg"
|      |      |      |-- 8:7-186 HTRI-R "F/L7/FW5160/CM186/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 8:7-187 HMS-S/D/M/SA "F/L7/FW5160/MCP187/Entry Psg"
|      |      |      |-- 8:7-188 HFP-11 "F/L7/F/FW5080/SD188/Main cab"
|      |      |      |-- 8:7-189 HFP-11 "F/L7/F/FW5080/SD189/Assorter cab"
|      |      |      |-- 8:7-190 HFP-11 "F/L7/F/FW5080/SD190/Psg nr Assor"
|      |      |      |-- 8:7-191 HFP-11 "F/L7/F/FW5080/SD191/Pantry"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:7 XDLC "XDLC @ address 7 L7"

```
|      |      |      |-- 8:7-192 HTRI-R "F/L7/F/FW5080/CM192/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:7-193 HMS-S/D/M/SA "F/L7/F/FW5080/MCP193/Entry dr Ps"
|      |      |      |-- 8:7-194 HFP-11 "F/L7/FW5150/SD194/Cab 1"
|      |      |      |-- 8:7-195 HFP-11 "F/L7/FW5150/SD195/Cab 2"
|      |      |      |-- 8:7-196 HFP-11 "F/L7/FW5150/SD196/Cab 3"
|      |      |      |-- 8:7-197 HFP-11 "F/L7/FW5150/SD197/Pantry"
|      |      |      |-- 8:7-198 HFP-11 "F/L7/FW5150/SD198/Psg nr cab1"
|      |      |      |-- 8:7-199 HTRI-R "F/L7/FW5150/CM199/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:7-200 HMS-S/D/M/SA "F/L7/FW5150/MCP200/Entry dr Psg"
|      |      |      |-- 8:7-214 HFP-11 "F/L7/FW5090/SD214/Main cab"
|      |      |      |-- 8:7-215 HFP-11 "F/L7/FW5090/SD215/Assorter cab"
|      |      |      |-- 8:7-216 HFP-11 "F/L7/FW5090/SD216/AFC Pantry"
|      |      |      |-- 8:7-217 HTRI-R "F/L7/FW5090/CM217/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:7-218 HMS-S/D/M/SA "F/L7/FW5090/MCP218/Entry dr Psg"
|      |      |      |-- 8:7-221 HFP-11 "F/L7/GW6120/SD221/Main cab"
|      |      |      |-- 8:7-222 HFP-11 "F/L7/GW6120/SD222/Assorter cab"
|      |      |      |-- 8:7-223 HFP-11 "F/L7/GW6120/SD223/Pantry"
|      |      |      |-- 8:7-224 HFP-11 "F/L7/GW6120/SD224/Entry dr Psg"
|      |      |      |-- 8:7-225 HTRI-R "F/L7/GW6120/CM225/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:7-226 HMS-S/D/M/SA "F/L7/GW6120/MCP226/Entry dr Psg"
|      |      |      |-- 8:7-227 HFP-11 "F/L7/EW5120/SD227/Accounts cab"
|      |      |      |-- 8:7-228 HFP-11 "F/L7/EW5120/SD228/Main cab 2"
|      |      |      |-- 8:7-229 HFP-11 "F/L7/EW5120/SD229/Main cab 2"
|      |      |      |-- 8:7-230 HFP-11 "F/L7/EW5120/SD230/Main cab 1"
|      |      |      |-- 8:7-231 HFP-11 "F/L7/EW5120/SD231/Assorter cab"
|      |      |      |-- 8:7-232 HFP-11 "F/L7/EW5120/SD232/Assorter cab"
|      |      |      |-- 8:7-233 HFP-11 "F/L7/EW5120/SD233/Main cab 3"
|      |      |      |-- 8:7-234 HFP-11 "F/L7/EW5120/SD234/Psg nr Acc cab"
|      |      |      |-- 8:7-235 HFP-11 "F/L7/EW5120/SD235/Pantry"
|      |      |      |-- 8:7-236 HFP-11 "F/L7/EW5120/SD236/Entry dr Psg"
|      |      |      |-- 8:7-237 HTRI-R "F/L7/EW5120/CM237/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:7-238 HMS-S/D/M/SA "F/L7/EW5120/MCP238/Entry dr Psg"
|      |      |      |-- 8:7-239 HFP-11 "F/L7/EW5100/SD239/Main cab"
|      |      |      |-- 8:7-240 HFP-11 "F/L7/EW5100/SD240/Assorter cab"
|      |      |      |-- 8:7-241 HFP-11 "F/L7/EW5100/SD241/Account cab"
|      |      |      |-- 8:7-242 HFP-11 "F/L7/EW5100/SD242/Entry Psg"
|      |      |      |-- 8:7-243 HMS-S/D/M/SA "F/L7/EW5100/MCP243/Entry Psg"
|      |      |      |-- 8:7-244 HTRI-R "F/L7/EW5100/CM244/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"

```
|      |  |-- 8:8 XDLC "XDLC @ address 8 L8"
|      |  |-- 8:8-1 HFP-11 "F/L8/CC/9F/SD1/CORR NR FC 9020"
|      |  |-- 8:8-2 HFP-11 "F/L8/CC/9F/SD2/CORR NR ELECT RM"
|      |  |-- 8:8-3 HFP-11 "F/L8/CC/9F/SD3/CORR NR ELECT RM"
|      |  |-- 8:8-4 HFP-11 "F/L8/CC/9F/SD4/ELECT RM SD"
|      |  |-- 8:8-5 HTRI-R "F/L8/CC/9F/CM5/DR RELESE CM"
|      |  |-- Switch ""
|      |  |-- Relay
|      |  |-- 8:8-6 HMS-S/D/M/SA "F/L8/CC/9F/MCP6/FIRE SHAFT MCP"
|      |  |-- 8:8-7 HTRI-R "F/L8/CC/9F/CM7/FIRE SHAFT CM"
|      |  |-- Switch ""
|      |  |-- Relay
|      |  |-- 8:8-8 HTRI-S "F/L8/CC/9F/MM8/FIRE SHAFT MM"
|      |  |-- 8:8-9 HFP-11 "F/L8/CC/9F/SD9/LIFT LOBBY SD"
|      |  |-- 8:8-10 HFP-11 "F/L8/CC/9F/SD10/LIFT LOBBY SD"
|      |  |-- 8:8-11 HTRI-R "F/L8/CC/9F/CM11/AHU RM CM"
|      |  |-- Switch ""
|      |  |-- Relay
|      |  |-- 8:8-12 HFP-11 "F/L8/CC/9F/SD12/AHU RM SD"
|      |  |-- 8:8-13 HTRI-R "F/L8/EC/9F/CM13/DR RELESE CM"
|      |  |-- Switch ""
|      |  |-- Relay
|      |  |-- 8:8-14 HFP-11 "F/L8/9F/SD14/FC AHU Rm"
|      |  |-- 8:8-15 HFP-11 "F/L8/9F/SD15/Corr.Nr FC9030"
|      |  |-- 8:8-16 HFP-11 "F/L8/9F/SD16/Corr.Nr FC9033"
|      |  |-- 8:8-17 HFP-11 "F/L8/9F/SD17/Corr.Nr FC9033"
|      |  |-- 8:8-20 HFP-11 "F/L8/9F/SD20/Corr.Nr FE9012"
|      |  |-- 8:8-21 HFP-11 "F/L8/9F/SD21/Corr.Nr FE Electric"
|      |  |-- 8:8-22 HFP-11 "F/L8/9F/SD22/FE Corridor"
|      |  |-- 8:8-23 HFP-11 "F/L8/9F/SD23/FE Electric RM"
|      |  |-- 8:8-24 HTRI-R "F/L8/9F/CM24/FE AHU Rm"
|      |  |-- Switch ""
|      |  |-- Relay
|      |  |-- 8:8-25 HFP-11 "F/L8/9F/SD25/FE AHU Rm"
|      |  |-- 8:8-26 HFP-11 "F/L8/9F/SD26/FE Lift Lobby"
|      |  |-- 8:8-27 HMS-S/D/M/SA "F/L8/9F/MCP27/FE Lift Lobby"
|      |  |-- 8:8-28 HTRI-R "F/L8/9F/CM28/FE Lift Lobby"
|      |  |-- Switch ""
|      |  |-- Relay
|      |  |-- 8:8-29 HTRI-S "F/L8/9F/MM29/FE Lift Lobby"
|      |  |-- 8:8-31 HFP-11 "F/L8/8F/SD31/Corr.Nr FC8010"
|      |  |-- 8:8-32 HFP-11 "F/L8/8F/SD32/Corr.Nr FC8010"
|      |  |-- 8:8-33 HFP-11 "F/L8/8F/SD33/Corr.Nr FC8042"
|      |  |-- 8:8-34 HFP-11 "F/L8/8F/SD34/Corr.Nr FC8041"
|      |  |-- 8:8-35 HMS-S/D/M/SA "F/L8/8F/MCP35/FC Fire Esc door"
|      |  |-- 8:8-36 HTRI-R "F/L8/8F/CM36/FC Fire Esc door"
|      |  |-- Switch ""
|      |  |-- Relay
|      |  |-- 8:8-37 HFP-11 "F/L8/CC/8F/SD37/CORR NR FC 8061"
|      |  |-- 8:8-38 HFP-11 "F/L8/CC/8F/SD38/CORR NR FC 8061"
```


8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:8 XDLC "XDLC @ address 8 L8"

				--	8:8-39	HFP-11	"F/L8/CC/8F/SD39/CORR NR FC 8071"
				--	8:8-40	HFP-11	"F/L8/CC/8F/SD40/CORR NR FC 8071"
				--	8:8-41	HFP-11	"F/L8/CC/8F/SD41/CORR NR FC 8012"
				--	8:8-42	HFP-11	"F/L8/CC/8F/SD42/CORR NR FC 8012"
				--	8:8-43	HFP-11	"F/L8/CC/8F/SD43/CORR NR FC 8090"
				--	8:8-44	HFP-11	"F/L8/CC/8F/SD44/CORR NR FC 8090"
				--	8:8-45	HFP-11	"F/L8/CC/8F/SD45/ELECT RM SD"
				--	8:8-46	HTRI-R	"F/L8/CC/8F/CM46/DR RELESE CM"
							-- Switch ""
							-- Relay
				--	8:8-47	HMS-S/D/M/SA	"F/L8/CC/8F/MCP47/FIRE SHAFT L.L."
				--	8:8-48	HTRI-R	"F/L8/CC/8F/CM48/FIRE SHAFT L.L."
							-- Switch ""
							-- Relay
				--	8:8-49	HTRI-S	"F/L8/CC/8F/MM49/FIRE SHAFT L.L."
				--	8:8-50	HFP-11	"F/L8/CC/8F/SD50/LIFT LOBBY SD"
				--	8:8-51	HFP-11	"F/L8/CC/8F/SD51/LIFT LOBBY SD"
				--	8:8-52	HTRI-R	"F/L8/CC/8F/CM52/AHU RM CM"
							-- Switch ""
							-- Relay
				--	8:8-53	HFP-11	"F/L8/CC/8F/SD53/AHU RM SD"
				--	8:8-54	HTRI-R	"F/L8/EC/8F/CM54/DR RELESE CM"
							-- Switch ""
							-- Relay
				--	8:8-55	HFP-11	"F/L8/EC/8F/SD55/CORR NR AHU RM "
				--	8:8-56	HFP-11	"F/L8/EC/8F/SD56/CORR NR FC 8180"
				--	8:8-57	HFP-11	"F/L8/EC/8F/SD57/CORR NR FC 8171"
				--	8:8-58	HFP-11	"F/L8/EC/8F/SD58/CORR NR FC 8172"
				--	8:8-59	HFP-11	"F/L8/EC/8F/SD59/CORR NR FC8/S03"
				--	8:8-60	HFP-11	"F/L8/8F/SD60/FC Fire Staircase"
				--	8:8-61	HMS-S/D/M/SA	"F/L8/8F/MCP61/FC Fire Staircase"
				--	8:8-62	HTRI-R	"F/L8/8F/CM62/FC Fire Staircase"
							-- Switch ""
							-- Relay
				--	8:8-63	HFP-11	"F/L8/8F/SD63/Corr.Nr FC8104"
				--	8:8-64	HFP-11	"F/L8/8F/SD64/Corr.Nr FC8104"
				--	8:8-65	HFP-11	"F/L8/8F/SD65/FE Electric Rm"
				--	8:8-66	HTRI-R	"F/L8/8F/CM66/FE AHU Rm"
							-- Switch ""
							-- Relay
				--	8:8-67	HFP-11	"F/L8/8F/SD67/FE AHU Rm"
				--	8:8-68	HFP-11	"F/L8/8F/SD68/FE Lift Lobby"
				--	8:8-69	HMS-S/D/M/SA	"F/L8/8F/MCP69/FE Lift Lobby"
				--	8:8-70	HTRI-R	"F/L8/8F/CM70/FE Lift Lobby"
							-- Switch ""
							-- Relay
				--	8:8-71	HTRI-S	"F/L8/8F/MM71/FE Lift Lobby"
				--	8:8-82	HTRI-S	"F/L8/9F/MM82/FC9020"
				--	8:8-83	HTRI-S	"F/L8/9F/MM83/FC9020A"
				--	8:8-84	HTRI-S	"F/L8/9F/MM84/FC9040"

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:8 XDLC "XDLC @ address 8 L8"

			-- 8:8-86 HTRI-S "F/L8/9F/MM86/FC9033"
			-- 8:8-88 HTRI-S "F/L8/FC9032/MM88"
			-- 8:8-89 HTRI-S "F/L8/CC/8F/MM89/FC8010"
			-- 8:8-93 HTRI-S "F/L8/CC/8F/MM93/FC8150"
			-- 8:8-96 HTRI-S "F/L8/CC/8F/MM96/FC8162"
			-- 8:8-97 HTRI-S "F/L8/CC/8F/MM97/FC8110"
			-- 8:8-98 HTRI-S "F/L8/CC/8F/MM98/FC8110A"
			-- 8:8-99 HTRI-S "F/L8/CC/8F/MM99/FC8160"
			-- 8:8-101 HTRI-S "F/L8/CC/8F/MM101/FC8103"
			-- 8:8-103 HTRI-S "F/L8/CC/8F/MM103/FC8171"
			-- 8:8-104 HTRI-S "F/L8/CC/8F/MM104/FC8101"
			-- 8:8-106 HTRI-S "F/L8/CC/8F/MM106/FC8010A"
			-- 8:8-107 HTRI-S "F/L8/CC/8F/MM107/FC8090"
			-- 8:8-108 HTRI-S "F/L8/CC/8F/MM108/FC8011"
			-- 8:8-109 HTRI-S "F/L8/CC/8F/MM109/FC8012"
			-- 8:8-110 HTRI-S "F/L8/CC/8F/MM110/FC8080A"
			-- 8:8-111 HTRI-S "F/L8/CC/8F/MM111/FC8080"
			-- 8:8-114 HTRI-S "F/L8/CC/8F/MM114/FC 8071"
			-- 8:8-118 HTRI-S "F/L8/8F/MM118/FC8030"
			-- 8:8-120 HTRI-S "F/L8/CC/8F/MM120/FC8051"
			-- 8:8-124 HTRI-S "F/L8/9F/MM124/FE9030"
			-- 8:8-125 HTRI-S "F/L8/9F/MM125/FE9020"
			-- 8:8-126 HFP-11 "F/L8/FC8052/SD126/Lunch RM"
			-- 8:8-127 HFPT-11 "F/L8/FC8052/HD127/Pantry"
			-- 8:8-128 HTRI-S "F/L8/8F/MM128/FE8010"
			-- 8:8-129 HFP-11 "F/L8/FC9011/SD129/Reception"
			-- 8:8-130 HFP-11 "F/L8/FC9011/SD130/Accounts cab"
			-- 8:8-131 HFPT-11 "F/L8/FC9011/HD131/Pantry"
			-- 8:8-132 HFPT-11 "F/L8/FC9011/HD132/Mohammad bhai "
			-- 8:8-133 HFP-11 "F/L8/FC9011/SD133/Conference rm"
			-- 8:8-134 HFP-11 "F/L8/FC9011/SD134/Main cab 1"
			-- 8:8-135 HFP-11 "F/L8/FC9011/SD135/Main cab 1"
			-- 8:8-136 HFP-11 "F/L8/FC9011/SD136/Main cab 2"
			-- 8:8-137 HFP-11 "F/L8/FC9011/SD137/Client cab 2"
			-- 8:8-138 HFP-11 "F/L8/FC9011/SD138/Sales cab"
			-- 8:8-139 HFP-11 "F/L8/FC9011/SD139/Sales cab"
			-- 8:8-140 HFP-11 "F/L8/FC9011/SD140/Psg nr sales c"
			-- 8:8-141 HFP-11 "F/L8/FC9011/SD141/Client cab 1"
			-- 8:8-142 HFP-11 "F/L8/FC9011/SD142/Purchase cab"
			-- 8:8-143 HFP-11 "F/L8/FC9011/SD143/Cab 1"
			-- 8:8-144 HFP-11 "F/L8/FC9011/SD144/Psg nr cab 1"
			-- 8:8-145 HTRI-R "F/L8/FC9011/CM145/Psg nr Entry"
			-- Switch ""
			-- Relay
			-- 8:8-146 HMS-S/D/M/SA "F/L8/FC9011/MCP146/Psg nr Entry"
			-- 8:8-147 HFP-11 "F/L8/FC8061/SD147/Main cab1"
			-- 8:8-148 HFP-11 "F/L8/FC8061/SD148/Main cab2"
			-- 8:8-149 HFP-11 "F/L8/FC8061/SD149/Account cab"
			-- 8:8-150 HFP-11 "F/L8/FC8061/SD150/Assorter cab"
			-- 8:8-151 HFP-11 "F/L8/FC8061/SD151/Pantry"

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:8 XDLC "XDLC @ address 8 L8"

```
|      |      |      |-- 8:8-152 HFP-11 "F/L8/FC8061/SD152/Entry dr Psg"
|      |      |      |-- 8:8-153 HTRI-R "F/L8/FC8061/CM153/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:8-154 HMS-S/D/M/SA "F/L8/FC8061/MCP154/Entry dr Psg"
|      |      |      |-- 8:8-155 HFP-11 "F/L8/FC8140/SD155/Main cab"
|      |      |      |-- 8:8-156 HFP-11 "F/L8/FC8140/SD156/Meeting cab"
|      |      |      |-- 8:8-157 HFP-11 "F/L8/FC8140/SD157/Psg nr Main ca"
|      |      |      |-- 8:8-158 HFP-11 "F/L8/FC8140/SD158/Pantry"
|      |      |      |-- 8:8-159 HTRI-R "F/L8/FC8140/CM159/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:8-160 HMS-S/D/M/SA "F/L8/FC8140/MCP160/Entry dr Psg"
|      |      |      |-- 8:8-161 HFP-11 "F/L8/FC8052/SD161/Account cab"
|      |      |      |-- 8:8-162 HFP-11 "F/L8/FC8052/SD162/Main cab"
|      |      |      |-- 8:8-163 HFP-11 "F/L8/FC8052/SD163/Entry Psg"
|      |      |      |-- 8:8-164 HTRI-R "F/L8/FC8052/CM164/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:8-165 HMS-S/D/M/SA "F/L8/FC8052/MCP165/Entry Psg"
|      |      |      |-- 8:8-166 HFP-11 "F/L8/FC8041/SD166/Account cab"
|      |      |      |-- 8:8-167 HFP-11 "F/L8/FC8041/SD167/Main cab"
|      |      |      |-- 8:8-168 HFP-11 "F/L8/FC8041/SD168/Cab 1"
|      |      |      |-- 8:8-169 HFP-11 "F/L8/FC8041/SD169/Cab 2"
|      |      |      |-- 8:8-170 HFP-11 "F/L8/FC8041/SD170/Cab 3"
|      |      |      |-- 8:8-171 HFP-11 "F/L8/FC8041/SD171/Psg nr cab 3"
|      |      |      |-- 8:8-172 HFP-11 "F/L8/FC8041/SD172/Pantry"
|      |      |      |-- 8:8-173 HFP-11 "F/L8/FC8041/SD173/Psg nr conf.rm"
|      |      |      |-- 8:8-174 HFP-11 "F/L8/FC8041/SD174/Conference cab"
|      |      |      |-- 8:8-175 HFP-11 "F/L8/FC8041/SD175/Reception Psg"
|      |      |      |-- 8:8-176 HTRI-R "F/L8/FC8041/CM176/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:8-177 HMS-S/D/M/SA "F/L8/FC8041/MCP177/Entry dr Psg"
|      |      |      |-- 8:8-178 HFP-11 "F/L8/FC8021/SD178/Account cab"
|      |      |      |-- 8:8-179 HFP-11 "F/L8/FC8021/SD179/Account cab"
|      |      |      |-- 8:8-180 HFP-11 "F/L8/FC8021/SD180/Stock cab"
|      |      |      |-- 8:8-181 HFP-11 "F/L8/FC8021/SD181/Psg nr Stock c"
|      |      |      |-- 8:8-182 HFP-11 "F/L8/FC8021/SD182/Buyer cab1"
|      |      |      |-- 8:8-183 HFP-11 "F/L8/FC8021/SD183/Main cab"
|      |      |      |-- 8:8-184 HFP-11 "F/L8/FC8021/SD184/Main cab"
|      |      |      |-- 8:8-185 HFP-11 "F/L8/FC8021/SD185/Psg nr Main ca"
|      |      |      |-- 8:8-186 HFP-11 "F/L8/FC8021/SD186/Pantry"
|      |      |      |-- 8:8-187 HFP-11 "F/L8/FC8021/SD187/Psg nr Pantry"
|      |      |      |-- 8:8-188 HFP-11 "F/L8/FC8021/SD188/Reception Psg"
|      |      |      |-- 8:8-189 HTRI-R "F/L8/FC8021/CM189/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:8-190 HMS-S/D/M/SA "F/L8/FC8021/MCP190/Entry Psg"
|      |      |      |-- 8:8-191 HFP-11 "F/L8/FC9030A/SD191/Main cab"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:8 XDLC "XDLC @ address 8 L8"

			-- 8:8-192 HFP-11 "F/L8/FC9030A/SD192/Main cab"
			-- 8:8-193 HFP-11 "F/L8/FC9030A/SD193/Account cab"
			-- 8:8-194 HFP-11 "F/L8/FC9030A/SD194/Assorter cab"
			-- 8:8-195 HFP-11 "F/L8/FC9030A/SD195/Entry dr Psg"
			-- 8:8-196 HFP-11 "F/L8/FC9030A/SD196/Pantry"
			-- 8:8-197 HTRI-R "F/L8/FC9030A/CM197/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 8:8-198 HMS-S/D/M/SA "F/L8/FC9030A/MCP198/Entry dr Psg"
			-- 8:8-199 HFP-11 "F/L8/FE9012/SD199/Conference cab"
			-- 8:8-200 HFP-11 "F/L8/FE9012/SD200/Director cab1"
			-- 8:8-201 HFP-11 "F/L8/FE9012/SD201/Director cab2"
			-- 8:8-202 HFP-11 "F/L8/FE9012/SD202/Director cab3"
			-- 8:8-203 HFP-11 "F/L8/FE9012/SD203/Accounts cab"
			-- 8:8-204 HFP-11 "F/L8/FE9012/SD204/Accounts cab"
			-- 8:8-205 HFP-11 "F/L8/FE9012/SD205/Psg nr Account"
			-- 8:8-206 HFP-11 "F/L8/FE9012/SD206/Assorter cab"
			-- 8:8-207 HFP-11 "F/L8/FE9012/SD207/Pantry"
			-- 8:8-208 HFP-11 "F/L8/FE9012/SD208/Psg nr Washrm"
			-- 8:8-209 HFP-11 "F/L8/FE9012/SD209/Entry dr Psg"
			-- 8:8-210 HTRI-R "F/L8/FE9012/CM210/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 8:8-211 HMS-S/D/M/SA "F/L8/FE9012/MCP211/Entry dr Psg"
			-- 8:8-212 HFP-11 "F/L8/FC8101A/SD212/Main cab"
			-- 8:8-213 HTRI-R "F/L8/FC8101A/CM213/Entry dr psg"
			-- Switch ""
			-- Relay
			-- 8:8-214 HMS-S/D/M/SA "F/L8/FC8101A/MCP214/Entry dr psg"
			-- 8:8-215 HFP-11 "F/L8/FC8120A/SD215/Main cab"
			-- 8:8-216 HFP-11 "F/L8/FC8120A/SD216/Main cab"
			-- 8:8-217 HFP-11 "F/L8/FC8120A/SD217/Psg nr Pantry"
			-- 8:8-218 HFP-11 "F/L8/FC8120A/SD218/Account cab"
			-- 8:8-219 HTRI-R "F/L8/FC8120A/CM219/AFC account c"
			-- Switch ""
			-- Relay
			-- 8:8-220 HMS-S/D/M/SA "F/L8/FC8120A/MCP220/Entry dr Psg"
			-- 8:8-226 HFPT-11 "F/L8/FC8120A/HD226/Pantry"
			-- 8:8-227 HFP-11 "F/L8/FC8030A/SD227/Main cab"
			-- 8:8-228 HFP-11 "F/L8/FC8030A/SD228/Assorter cab"
			-- 8:8-229 HFP-11 "F/L8/FC8030A/SD229/Pantry Psg"
			-- 8:8-230 HTRI-R "F/L8/FC8030A/CM230/AFC Entry Psg"
			-- Switch ""
			-- Relay
			-- 8:8-231 HMS-S/D/M/SA "F/L8/FC8030A/MCP231/Entry Psg"
			-- 8:8-232 HFP-11 "F/L8/FC8130/SD232/Main cab"
			-- 8:8-233 HFP-11 "F/L8/FC8130/SD233/Assorter cab"
			-- 8:8-234 HFP-11 "F/L8/FC8130/SD234/Psg nr MC"
			-- 8:8-235 HFP-11 "F/L8/FC8130/SD235/Accounts cab"
			-- 8:8-236 HFP-11 "F/L8/FC8130/SD236/Pantry"

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:8 XDLC "XDLC @ address 8 L8"

```
|      |      |      |-- 8:8-237 HTRI-R "F/L8/FC8130/CM237/Entry dr psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:8-238 HMS-S/D/M/SA "F/L8/FC8130/MCP238/Entry dr psg"
|      |      |      |-- 8:8-239 HFP-11 "F/L8/FC8101/SD239/Accounts cab"
|      |      |      |-- 8:8-240 HFP-11 "F/L8/FC8101/SD240/Assorter cab"
|      |      |      |-- 8:8-241 HFP-11 "F/L8/FC8101/SD241/Assorter cab"
|      |      |      |-- 8:8-242 HFP-11 "F/L8/FC8101/SD242/Main cab"
|      |      |      |-- 8:8-243 HFP-11 "F/L8/FC8101/SD243/Main cab"
|      |      |      |-- 8:8-244 HFP-11 "F/L8/FC8101/SD244/Lunch cab"
|      |      |      |-- 8:8-245 HFP-11 "F/L8/FC8101/SD245/Main cab 1"
|      |      |      |-- 8:8-246 HFP-11 "F/L8/FC8101/SD246/Pantry"
|      |      |      |-- 8:8-247 HFP-11 "F/L8/FC8101/SD247/Psg nr pantry"
|      |      |      |-- 8:8-248 HFP-11 "F/L8/FC8101/SD248/Psg nr account"
|      |      |      |-- 8:8-249 HFP-11 "F/L8/FC8101/SD249/Reception psg"
|      |      |      |-- 8:8-250 HTRI-R "F/L8/FC8101/CM250/AFC Entry psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:8-251 HMS-S/D/M/SA "F/L8/FC8101/MCP251/Nr Washroom"
|      |      |      |-- 8:8-73 HTRI-S "F/L8/8F/MM73/FC8180"
|      |      |  |-- 8:9 XDLC "XDLC @ address 9 L9"
|      |      |      |-- 8:9-1 HTRI-R "F/L9/WC/9F/CM1/ STR NR FW 9030"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:9-2 HMS-S/D/M/SA "F/L9/WC/9F/MCP2/STR NR FW 9030"
|      |      |      |-- 8:9-3 HFP-11 "F/L9/WC/9F/SD3/CORR NR FW 9040"
|      |      |      |-- 8:9-4 HFP-11 "F/L9/WC/9F/SD4/CORR NR FW 9040"
|      |      |      |-- 8:9-5 HFP-11 "F/L9/WC/9F/SD5/CORR NR FW 9012"
|      |      |      |-- 8:9-6 HFP-11 "F/L9/WC/9F/SD6/CORR NR E.R."
|      |      |      |-- 8:9-7 HFP-11 "F/L9/WC/9F/SD7/ELECT RM SD"
|      |      |      |-- 8:9-8 HTRI-R "F/L9/WC/9F/CM8/DR RELESE CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:9-9 HFP-11 "F/L9/WC/9F/SD9/LIFT LOBBY SD"
|      |      |      |-- 8:9-10 HFP-11 "F/L9/WC/9F/SD10/LIFT LOBBY SD"
|      |      |      |-- 8:9-11 HFP-11 "F/L9/WC/9F/SD11/AHU RM SD"
|      |      |      |-- 8:9-12 HTRI-R "F/L9/WC/9F/CM12/AHU RM CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:9-13 HMS-S/D/M/SA "F/L9/WC/9F/MCP13/L.L. MCP"
|      |      |      |-- 8:9-14 HTRI-R "F/L9/WC/9F/CM14/L.L. FIRE SHAFT"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:9-15 HTRI-S "F/L9/WC/9F/MM15/L.L. FIRE SHAFT"
|      |      |      |-- 8:9-16 HFP-11 "F/L9/WC/8F/SD16/ELECT RM SD"
|      |      |      |-- 8:9-17 HTRI-R "F/L9/WC/8F/CM17/DR RELESE CM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 8:9-18 HFP-11 "F/L9/WC/8F/SD18/L.L. SD"
|      |      |      |-- 8:9-19 HFP-11 "F/L9/WC/8F/SD19/L.L. SD"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:9 XDLC "XDLC @ address 9 L9"

```
|      |      |      |-- 8:9-20 HFP-11 "F/L9/WC/8F/SD20/AHU RM"
|      |      |      |-- 8:9-21 HTRI-R "F/L9/WC/8F/CM21/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:9-22 HMS-S/D/M/SA "F/L9/WC/8F/MCP22/L.L.MCP"
|      |      |      |-- 8:9-23 XTRI-R "F/WC/8F/CM23/L.L. FIRE SHAFT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:9-24 HTRI-S "F/L9/WC/8F/MM24/L.L. FIRE SHAFT "
|      |      |      |-- 8:9-25 HFP-11 "F/L9/WC/7F/SD25/CORR NR FC 7021"
|      |      |      |-- 8:9-26 HFP-11 "F/L9/WC/7F/SD26/CORR NR FC 7021"
|      |      |      |-- 8:9-27 HFP-11 "F/L9/WC/7F/SD27/CORR NR FW 7020"
|      |      |      |-- 8:9-28 HFP-11 "F/L9/WC/7F/SD28/CORR NR FW 7020"
|      |      |      |-- 8:9-29 HFP-11 "F/L9/WC/7F/SD29/ELECT RM SD"
|      |      |      |-- 8:9-30 HTRI-R "F/L9/WC/7F/CM30/DR RELELSE NR L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:9-31 HFP-11 "F/L9/WC/7F/SD31/LIFT LOBBY SD"
|      |      |      |-- 8:9-32 HFP-11 "F/L9/WC/7F/SD32/LIFT LOBBY SD"
|      |      |      |-- 8:9-33 HFP-11 "F/L9/WC/7F/SD33/AHU RM SD L.L."
|      |      |      |-- 8:9-34 HTRI-R "F/L9/WC/7F/CM34/AHU RM CM L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:9-35 HMS-S/D/M/SA "F/L9/WC/7F/MCP35/FIRE SHAFT L.L."
|      |      |      |-- 8:9-36 HTRI-R "F/L9/WC/7F/CM36/FIRE SHAFT L.L."
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:9-37 HTRI-S "F/L9/WC/7F/MM37/FIRE SHAFT L.L."
|      |      |      |-- 8:9-38 XTRI-S "F/L9/9F/MM38/FW9050"
|      |      |      |-- 8:9-39 HTRI-S "F/L9/9F/MM39/FW7010"
|      |      |      |-- 8:9-51 HTRI-S "F/L9/WC/9F/MM51/FW9010"
|      |      |      |-- 8:9-52 HTRI-S "F/L9/WC/9F/MM52/FW9030"
|      |      |      |-- 8:9-54 HTRI-S "F/L9/WC/9F/MM54/FW9020"
|      |      |      |-- 8:9-55 HTRI-S "F/L9/WC/9F/MM55/FW9040"
|      |      |      |-- 8:9-58 HTRI-S "F/L9/WC/9F/MM58/FW9011"
|      |      |      |-- 8:9-61 HTRI-S "F/L9/WC/7F/MM61/FW7030"
|      |      |      |-- 8:9-62 HTRI-S "F/L9/WC/7F/MM62/FW7021"
|      |      |      |-- 8:9-63 HTRI-S "F/L9/WC/7F/MM63/FW7022"
|      |      |      |-- 8:9-64 HFP-11 "F/L9/FW9012/SD64/Main cab"
|      |      |      |-- 8:9-65 HFP-11 "F/L9/FW9012/SD65/Account cab"
|      |      |      |-- 8:9-66 HFP-11 "F/L9/FW9012/SD66/Assorter cab"
|      |      |      |-- 8:9-67 HFP-11 "F/L9/FW9012/SD67/Psg nr Assorter"
|      |      |      |-- 8:9-68 HFP-11 "F/L9/FW9012/SD68/Pantry"
|      |      |      |-- 8:9-69 HTRI-R "F/L9/FW9012/CM69/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 8:9-70 HMS-S/D/M/SA "F/L9/FW9012/MCP70/Entry dr Psg"
|      |      |      |-- 8:9-71 HFP-11 "F/L9/FW8010/SD71/Manager cab"
|      |      |      |-- 8:9-72 HFP-11 "F/L9/FW8010/SD72/Guest cab1"
|      |      |      |-- 8:9-73 HFP-11 "F/L9/FW8010/SD73/Guest cab2"
```

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:9 XDLC "XDLC @ address 9 L9"

				--	8:9-74	HFP-11	"F/L9/FW8010/SD74/Pantry"
				--	8:9-75	HFP-11	"F/L9/FW8010/SD75/Xerox rm"
				--	8:9-76	HFP-11	"F/L9/FW8010/SD76/Psg nr Xerox rm"
				--	8:9-77	HFP-11	"F/L9/FW8010/SD77/Psg nr conf. rm"
				--	8:9-78	HFP-11	"F/L9/FW8010/SD78/Conf. rm"
				--	8:9-79	HFP-11	"F/L9/FW8010/SD79/Entry Psg"
				--	8:9-80	HTRI-R	"F/L9/FW8010/CM80/Reception Psg"
				--	Switch	" "	
				--	Relay		
				--	8:9-81	HMS-S/D/M/SA	"F/L9/FW8010/MCP81/Reception Psg"
				--	8:9-82	HFP-11	"F/L9/FW7020/SD82/Assorter cab"
				--	8:9-83	HFP-11	"F/L9/FW7020/SD83/Accounts cab"
				--	8:9-84	HFP-11	"F/L9/FW7020/SD84/Main cab"
				--	8:9-85	HFP-11	"F/L9/FW7020/SD85/Main cab"
				--	8:9-86	HFP-11	"F/L9/FW7020/SD86/Psg nr Account "
				--	8:9-87	HFP-11	"F/L9/FW7020/SD87/Pantry"
				--	8:9-88	HTRI-R	"F/L9/FW7020/CM88/Entry Psg"
				--	Switch	" "	
				--	Relay		
				--	8:9-89	HMS-S/D/M/SA	"F/L9/FW7020/MCP89/Entry Psg"
				--	8:9-90	HFP-11	"F/L9/FW7020/SD90/Psg account cab"
				--	8:9-91	HFP-11	"F/L9/FC9031/SD91/Reception Area"
				--	8:9-92	HFP-11	"F/L9/FC9031/SD92/Reception Area"
				--	8:9-93	HFP-11	"F/L9/FC9031/SD93/Assorter Cabin "
				--	8:9-94	HFP-11	"F/L9/FC9031/SD94/Assorter Cabin "
				--	8:9-95	HFP-11	"F/L9/FC9031/SD95/Buyer Cabin 1"
				--	8:9-96	HFP-11	"F/L9/FC9031/SD96/Buyer Cabin 2"
				--	8:9-97	HFP-11	"F/L9/FC9031/SD97/Buyer Cabin 3"
				--	8:9-98	HFP-11	"F/L9/FC9031/SD98/Sales Cabin"
				--	8:9-99	HFP-11	"F/L9/FC9031/SD99/Sales Cabin"
				--	8:9-100	HFP-11	"F/L9/FC9031/SD100/Boss Cabin"
				--	8:9-101	HFP-11	"F/L9/FC9031/SD101/Boss Cabin"
				--	8:9-102	HFP-11	"F/L9/FC9031/SD102/Boss Cabin"
				--	8:9-103	HFP-11	"F/L9/FC9031/SD103/Save Room"
				--	8:9-104	HFP-11	"F/L9/FC9031/SD104/Conference Roo"
				--	8:9-105	HFP-11	"F/L9/FC9031/SD105/Assorter Cabin"
				--	8:9-106	HFP-11	"F/L9/FC9031/SD106/Assorter Cabin"
				--	8:9-107	HFP-11	"F/L9/FC9031/SD107/FE Enterance P"
				--	8:9-108	HFP-11	"F/L9/FC9031/SD108/Psg Nr Main Ca"
				--	8:9-109	HFP-11	"F/L9/FC9031/SD109/Asst Manager C"
				--	8:9-110	HFP-11	"F/L9/FC9031/SD110/Manager Cabin"
				--	8:9-111	HFP-11	"F/L9/FC9031/SD111/Account Cabin"
				--	8:9-112	HFP-11	"F/L9/FC9031/SD112/Psg Nr Account"
				--	8:9-113	HFP-11	"F/L9/FC9031/SD113/Psg Nr Pantry"
				--	8:9-114	HFP-11	"F/L9/FC9031/SD114/FC pantry"
				--	8:9-115	HFP-11	"F/L9/FC9031/SD115/FE pantry"
				--	8:9-116	HMS-S/D/M/SA	"F/L9/FC9031/MCP116/FC Entrance"
				--	8:9-117	HMS-S/D/M/SA	"F/L9/FC9031/MCP117/FE Entrance"
				--	8:9-118	HTRI-R	"F/L9/FC9031/CM118/AFC Reception "
				--	Switch	" "	

8 Desigo Fire Safety Modular "BDB TOWER F" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

8:9 XDLC "XDLC @ address 9 L9"

8:9-118 HTRI-R "F/L9/FC9031/CM118/AFC Reception "

```
|      | | | | -- Relay
|      | | | | -- 8:9-119 HTRI-R "F/L9/FC9031/CM119/AFC Entrance"
|      | | | | -- Switch ""
|      | | | | -- Relay
|      | | | | -- 8:10 NIC-C(XNet) "NIC_Xnet @ address 10"
|      | | | | -- 8:249 PSC-12 "PSC-12 @ address 249"
|      | | | | -- 8:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      | | | | -- 8:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      | | | | -- Inner Door
|      | | | | -- 8:253 PMI-D "PMI-D Tower F -8"
|-- 9 Desigo Fire Safety Modular "BDB TOWER G/H" Local
|  |-- System Flags
|  |-- History Log
|  |-- Behavior
|  |-- Voice
|  |-- Maintenance
|  |-- Field Devices
|  |-- Miscellaneous
|  |-- CAB-2 "CAB-2 Enclosure #1"
|      |-- CC-5 "Card Cage 5 Slots"
|          |-- 9:1 XDLC "XDLC @ address L1"
|              |-- 9:1-1 HTRI-R "G/L1/2F/CM1/GW AHU Rm"
|                  |-- Switch ""
|                  |-- Relay
|                      |-- 9:1-2 HFP-11 "G/L1/2F/SD2/GW AHU Rm"
|                          |-- 9:1-3 HFP-11 "G/L1/2F/SD3/Corr. Nr HW2130"
|                              |-- 9:1-4 HTRI-R "G/L1/2F/CM4/GW dr release"
|                                  |-- Switch ""
|                                  |-- Relay
|                                      |-- 9:1-5 HTRI-R "G/L1/2F/CM5/GW Lift Lobby"
|                                          |-- Switch ""
|                                          |-- Relay
|                                              |-- 9:1-6 HMS-S/D/M/SA "G/L1/2F/MCP6/GW Lift Lobby"
|                                                  |-- 9:1-7 HTRI-S "G/L1/2F/MM7/GW Lift Lobby"
|                                                      |-- 9:1-8 HFP-11 "G/L1/2F/SD8/GW Lift Lobby"
|                                                          |-- 9:1-9 HFP-11 "G/L1/2F/SD9/GW Lift Lobby"
|                                                              |-- 9:1-10 HFP-11 "G/L1/2F/SD10/Corr.Nr GW2021"
|                                                                  |-- 9:1-11 HFP-11 "G/L1/2F/SD11/Corr.Nr GW2022"
|                                                                      |-- 9:1-12 HTRI-R "G/L1/2F/CM12/GW dr release"
|                                                                          |-- Switch ""
|                                                                          |-- Relay
|                                                                              |-- 9:1-13 HFP-11 "G/L1/2F/SD13/GW Electric rm"
|                                                                                  |-- 9:1-14 HFP-11 "G/L1/2F/SD14/COR NR GW2110"
|                                                                                          |-- 9:1-15 HFP-11 "G/L1/2F/SD15/COR NR GW2070"
|                                                                                              |-- 9:1-16 HFP-11 "G/L1/2F/SD16/Corr.Nr GW2071"
|                                                                                                  |-- 9:1-17 HFP-11 "G/L1/2F/SD17/Corr.Nr GW2071"
|                                                                                                      |-- 9:1-18 HTRI-R "G/L1/2F/CM18/GE NR FIRE ESC"
|                                                                                                          |-- Switch ""
|                                                                                                          |-- Relay
|                                                                                                              |-- 9:1-19 HMS-S/D/M/SA "G/L1/2F/MCP19/GE NR FIRE ESC"
```


9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:1 XDLC "XDLC @ address L1"

```
|      |      |      |-- 9:1-20 HTRI-S "G/L1/2F/MM20/GE Lift Lobby"
|      |      |      |-- 9:1-21 HFP-11 "G/L1/2F/SD21/GE Lift Lobby"
|      |      |      |-- 9:1-22 HFP-11 "G/L1/2F/SD22/GE Lift Lobby"
|      |      |      |-- 9:1-23 HTRI-R "G/L1/2F/CM23/ GE CORR NR DR REL"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-24 HFP-11 "G/L1/2F/SD24/Corr.Nr GE2011"
|      |      |      |-- 9:1-25 HFP-11 "G/L1/2F/SD25/AFC Corr.Nr GE2011"
|      |      |      |-- 9:1-26 HFP-11 "G/L1/2F/SD26/Corr.Nr GE2011"
|      |      |      |-- 9:1-27 HFP-11 "G/L1/2F/SD27/AFC Corr.Nr GE2022"
|      |      |      |-- 9:1-28 HFP-11 "G/L1/2F/SD28/Corr.Nr GE2022"
|      |      |      |-- 9:1-29 HFP-11 "G/L1/2F/SD29/Corr.Nr GE2/S12"
|      |      |      |-- 9:1-30 HFP-11 "G/L1/2F/SD30/Corr.Nr GE2041"
|      |      |      |-- 9:1-31 HFP-11 "G/L1/2F/SD31/Corr.Nr GE2041"
|      |      |      |-- 9:1-32 HFP-11 "G/L1/2F/SD32/Corr.Nr HW2060"
|      |      |      |-- 9:1-33 HTRI-S "G/L1/2F/MM33/GE2011"
|      |      |      |-- 9:1-34 HTRI-S "G/L1/2F/MM34/GE2012"
|      |      |      |-- 9:1-35 HTRI-S "G/L1/1F/MM35/GE1010A"
|      |      |      |-- 9:1-36 HTRI-S "G/L1/1F/MM36/GE1010"
|      |      |      |-- 9:1-37 HTRI-S "G/L1/1F/MM37/GE1020A"
|      |      |      |-- 9:1-38 HTRI-S "G/L1/1F/MM38/GE1020"
|      |      |      |-- 9:1-39 HTRI-S "G/L1/1F/MM39/GE1030"
|      |      |      |-- 9:1-40 HTRI-S "G/L1/1F/MM40/GE1050"
|      |      |      |-- 9:1-41 HTRI-S "G/L1/2F/MM41/GW2060"
|      |      |      |-- 9:1-42 HTRI-R "G/L1/2F/CM42/GE AHU Rm"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-43 HFP-11 "G/L1/2F/SD43/GE AHU Rm"
|      |      |      |-- 9:1-44 HFP-11 "G/L1/2F/SD44/GE Electric rm"
|      |      |      |-- 9:1-45 HTRI-R "G/L1/1F/CM45/GW AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-46 HFP-11 "G/L1/1F/SD46/GW AHU Rm"
|      |      |      |-- 9:1-47 HTRI-S "G/L1/2F/MM47/GW2070"
|      |      |      |-- 9:1-48 HTRI-S "G/L1/2F/MM48/GW2080"
|      |      |      |-- 9:1-49 HTRI-R "G/L1/1F/CM49/GW Lift Lobby"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-50 HMS-S/D/M/SA "G/L1/1F/MCP50/GW Lift Lobby"
|      |      |      |-- 9:1-51 HTRI-S "G/L1/1F/MM51/GW Lift Lobby"
|      |      |      |-- 9:1-52 HTRI-S "G/L1/2F/MM52/GW2090"
|      |      |      |-- 9:1-53 HFP-11 "G/L1/1F/SD53/GW Electric Rm"
|      |      |      |-- 9:1-54 HFP-11 "G/L1/1F/SD54/GW Small corr."
|      |      |      |-- 9:1-55 HFP-11 "G/L1/1F/SD55/GW Small corr."
|      |      |      |-- 9:1-56 HTRI-S "G/L1/2F/MM56/GW2010"
|      |      |      |-- 9:1-57 HTRI-S "G/L1/1F/MM57/GW2040"
|      |      |      |-- 9:1-58 HTRI-R "G/L1/1F/CM58/GE Lift Lobby"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-59 HMS-S/D/M/SA "G/L1/1F/MCP59/GE Lift Lobby"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:1 XDLC "XDLC @ address L1"

				--	9:1-60	HTRI-S	"G/L1/1F/MM60/GE Lift Lobby"
				--	9:1-61	HFP-11	"G/L1/1F/SD61/GE Lift Lobby"
				--	9:1-62	HFP-11	"G/L1/1F/SD62/GE Lift Lobby"
				--	9:1-63	HTRI-R	"G/L1/1F/CM63/GE AHU Rm"
				--	Switch	"	"
				--	Relay		
				--	9:1-64	HFP-11	"G/L1/1F/SD64/GE AHU Rm"
				--	9:1-65	HTRI-R	"G/L1/1F/CM65/GE dr release"
				--	Switch	"	"
				--	Relay		
				--	9:1-66	HFP-11	"G/L1/1F/SD66/GE Electric rm"
				--	9:1-67	HFP-11	"G/L1/1F/SD67/GE CORR NR ELCT RM"
				--	9:1-68	HFP-11	"G/L1/1F/SD68/GE CORR NR GE1010"
				--	9:1-69	HFP-11	"G/L1/1F/SD69/GE CORR NR GE1050AF"
				--	9:1-70	HTRI-S	"G/L1/GW/2F/MM70/GW2050"
				--	9:1-73	HMS-S/D/M/SA	"G/L1/HW/GND/MCP73/Corr Nr BVC Ca"
				--	9:1-74	HTRI-S	"G/L1/2F/MM74/HW2070"
				--	9:1-75	HTRI-S	"G/L1/2F/MM75/GE2042"
				--	9:1-76	HTRI-R	"G/L1/HW/GND/CM76/CorrNrBVCCabAFC"
				--	Switch	"	"
				--	Relay		
				--	9:1-77	HFP-11	"G/L1/GW1010/SD77/AFC Nr Cab 2"
				--	9:1-78	HTRI-S	"G/L1/2F/MM078/GE2031"
				--	9:1-79	FDOT421	"G/L1/HW/GND/SD79/Corr Nr Habib H"
				--	9:1-80	XTRI-S	"G/L1/2F/MM080/FW2120"
				--	9:1-82	FDOT421	"G/L1/HW/GND/SD82/Corr Nr Habib H"
				--	9:1-83	FDOT421	"G/L1/HW/GND/SD83/Corr Nr B.K Fre"
				--	9:1-84	FDOT421	"G/L1/HW/GND/SD84/CorrNrB.KFreAFC"
				--	9:1-85	FDOT421	"G/L1/HW/GND/SD85/Corr Nr Sequel "
				--	9:1-86	HFP-11	"G/L1/HW/SD86/Food court washrm"
				--	9:1-87	HFP-11	"G/L1/HW/SD87/Food court washrm"
				--	9:1-88	FDOT421	"G/L1/HW/GND/SD88/B.K Freight Mai"
				--	9:1-89	FDOT421	"G/L1/HW/GND/SD89/B.K Freight Psg"
				--	9:1-90	HFP-11	"G/L1/HW/SD90/AFC Wagh bakri tea "
				--	9:1-91	FDOT421	"G/L1/HW/GND/SD91/B.K Freight Psg"
				--	9:1-93	HMS-S/D/M/SA	"G/L1/HW/GND/MCP93/B.K Freight En"
				--	9:1-94	HFPT-11	"G/L1/HW/HD94/HARI OM BHELPURI"
				--	9:1-95	HFPT-11	"G/L1/HW/HD95/SAINATH SNAKS"
				--	9:1-96	HFPT-11	"G/L1/HW/HD96/NIDI JUICE CANTER"
				--	9:1-97	HFPT-11	"G/L1/HW/HD97/DEEPAK SANDWITCH"
				--	9:1-98	HFPT-11	"G/L1/HW/HD98/SOLLY PAV BHAJI"
				--	9:1-99	HFPT-11	"G/L1/HW/HD99/JAIHIND SNACKS"
				--	9:1-100	HFP-11	"G/L1/HW/SD100/FOOD COURT BACK PS"
				--	9:1-101	HFP-11	"G/L1/HW/SD101/FOOD COURT BACK PS"
				--	9:1-103	HTRI-S	"G/L1/1F/MM103/GW1060"
				--	9:1-104	HTRI-S	"G/L1/1F/MM104/GW1050"
				--	9:1-105	HFP-11	"G/L1/HW/SD105/FOOD COURT FRONT P"
				--	9:1-106	HFP-11	"G/L1/HW/SD106/FOOD COURT FRONT P"
				--	9:1-108	HFP-11	"G/L1/HW/SD108/FOOD COURT FRONT P"
				--	9:1-109	HTRI-R	"G/L1/HW/GND/CM109/B.K Freight En"

9:1-109 HTRI-R "G/L1/HW/GND/CM109/B.K Freight En"

```
| | | | | Switch ""
| | | | | |-- Relay
| | | | | |-- 9:1-110 HTRI-S "G/L1/E/UB/MM110/ELEC RM NR G BMS"
| | | | | |-- 9:1-111 HFP-11 "G/L1/E/UB/SD111/ELEC RM G BMS"
| | | | | |-- 9:1-112 HFP-11 "G/L1/W/UB/SD112/ELE RM PILER 791"
| | | | | |-- 9:1-113 HFP-11 "G/L1/E/UB/SD113/LIFT MC RM G BMS"
| | | | | |-- 9:1-114 HFP-11 "G/L1/E/UB/SD114/G BMS ROOM"
| | | | | |-- 9:1-115 HTRI-S "G/L1/E/UB/MM115/ELEC ROOM"
| | | | | |-- 9:1-116 HMS-S/D/M/SA "G/L1/W/UB/MCP116/STRCAS NR P805"
| | | | | |-- 9:1-117 HTRI-R "G/L1/W/UB/CM117/STRCAS NR P805"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:1-118 HMS-S/D/M/SA "G/L1/W/UB/MCP118/RAMP 6 FIRE DR"
| | | | | |-- 9:1-119 XTRI-R "G/L1/W/UB/CM119/RAMP 6 FIRE DR"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:1-120 HMS-S/D/M/SA "G/L1/W/UB/MCP120/PSG P789 RAMP6 "
| | | | | |-- 9:1-121 HTRI-R "G/L1/W/UB/CM121/PSG P789 RAMP 6"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:1-122 HMS-S/D/M/SA "G/L1/W/UB/MCP122/STR CAS NR P766"
| | | | | |-- 9:1-123 XTRI-R "G/L1/W/UB/CM123/STR CAS NR P766"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:1-124 HTRI-S "G/L1/7/EC/UB/MM124/ELEC RM NR P7"
| | | | | |-- 9:1-125 XTRI-R "G/L1/G/E/UB/CM125/STR CAS NR P84"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:1-126 HMS-S/D/M/SA "G/L1/E/UB/MCP126/STR CAS NR P840"
| | | | | |-- 9:1-127 HMS-S/D/M/SA "G/L1/E/LB/MCP127/RAMP 6 P-815"
| | | | | |-- 9:1-128 HTRI-R "G/L1/E/LB/CM128/RAMP 6 P-815"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:1-129 HTRI-S "G/L1/HW/GND/MM129/Jasraj Kalianj"
| | | | | |-- 9:1-130 XTRI-S "G/L1/HW/GND/MM130/Inmovers Cargo"
| | | | | |-- 9:1-131 XTRI-S "G/L1/HW/GND/MM131/Habib Haji Cab"
| | | | | |-- 9:1-133 XTRI-S "G/L1/HW/GND/MM133/Adarsh Clearin"
| | | | | |-- 9:1-134 HMS-S/D/M/SA "G/L1/GE/GND/MCPl34/LIFT LOBBY"
| | | | | |-- 9:1-135 HTRI-R "G/L1/GE/GND/CM135/LIFT LOBBY"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:1-136 HTRI-S "G/L1/GE/GND/MM136/LIFT LOBBY"
| | | | | |-- 9:1-137 HFP-11 "G/L1/GE/GND/SD137/ELECT.RM"
| | | | | |-- 9:1-138 HFP-11 "G/L1/GE/GND/SD138/LIFT LOBBY"
| | | | | |-- 9:1-139 HFP-11 "G/L1/GE/GND/SD139/LIFT LOBBY"
| | | | | |-- 9:1-140 HFP-11 "G/L1/GE/GND/SD140/LIFT LOBBY"
| | | | | |-- 9:1-141 HFP-11 "G/L1/GE/GND/SD141/LIFT LOBBY"
| | | | | |-- 9:1-142 HTRI-R "G/L1/GE/GND/CM142AHU RM"
| | | | | |-- Switch ""
| | | | | |-- Relay
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:1 XDLC "XDLC @ address L1"

```
|      |      |      |-- 9:1-143 HFP-11 "G/L1/GE/GND/SD143/AHU RM"
|      |      |      |-- 9:1-144 HMS-S/D/M/SA "G/L1/GW/GND/MCP144/LIFT LOBBY"
|      |      |      |-- 9:1-145 HTRI-R "G/L1/GW/GND/CM145/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-146 HTRI-S "G/L1/GW/GND/MM146/LIFT LOBBY"
|      |      |      |-- 9:1-147 HFP-11 "G/L1/GW/GND/SD147/ELECT.RM"
|      |      |      |-- 9:1-148 HFP-11 "G/L1/GW/GND/SD148/LIFT LOBBY"
|      |      |      |-- 9:1-149 HFP-11 "G/L1/GW/GND/SD149/LIFT LOBBY"
|      |      |      |-- 9:1-150 HFP-11 "G/L1/GW/GND/SD150/LIFT LOBBY"
|      |      |      |-- 9:1-151 HFP-11 "G/L1/GW/GND/SD151/LIFT LOBBY"
|      |      |      |-- 9:1-152 HFP-11 "G/L1/GW/GND/SD152/LIFT LOBBY"
|      |      |      |-- 9:1-153 HTRI-R "G/L1/GW/GND/CM153/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-154 HFP-11 "G/L1/GW/GND/SD154/AHU RM"
|      |      |      |-- 9:1-156 HMS-S/D/M/SA "H/L1/HW/GND/MCP156/LIFT LOBBY"
|      |      |      |-- 9:1-157 HTRI-R "H/L1/HW/GND/CM157/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-158 HTRI-S "H/L1/HW/GND/MM158/LIFT LOBBY"
|      |      |      |-- 9:1-159 HFP-11 "G/L1/GF/SD159/Electric Rm"
|      |      |      |-- 9:1-160 HFP-11 "H/L1/HW/GND/SD160/LIFT LOBBY"
|      |      |      |-- 9:1-161 HFP-11 "H/L1/HW/GND/SD161/LIFT LOBBY"
|      |      |      |-- 9:1-162 HFP-11 "H/L1/HW/GND/SD162/LIFT LOBBY"
|      |      |      |-- 9:1-163 HFP-11 "H/L1/HW/GND/SD163/LIFT LOBBY"
|      |      |      |-- 9:1-164 HFP-11 "G/L1/GW2020/SD164/cab 1"
|      |      |      |-- 9:1-165 HFP-11 "G/L1/GW2020/SD165/cab 2"
|      |      |      |-- 9:1-166 HFP-11 "G/L1/GW2020/SD166/cab 3"
|      |      |      |-- 9:1-167 HFP-11 "G/L1/GW2020/SD167/cab 4"
|      |      |      |-- 9:1-168 HFP-11 "G/L1/GW2020/SD168/Entry Psg"
|      |      |      |-- 9:1-169 HTRI-R "G/L1/GW2020/CM169/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-170 HMS-S/D/M/SA "G/L1/GW2020/MCP170/Entry Psg"
|      |      |      |-- 9:1-171 HFP-11 "G/L1/GW2110/SD171/cab 1"
|      |      |      |-- 9:1-172 HFP-11 "G/L1/GW2110/SD172/cab 2"
|      |      |      |-- 9:1-173 HFP-11 "G/L1/GW2110/SD173/cab 3"
|      |      |      |-- 9:1-174 HFP-11 "G/L1/GW2110/SD174/Accounts cab"
|      |      |      |-- 9:1-175 HFP-11 "G/L1/GW2110/SD175/Psg nr accouts"
|      |      |      |-- 9:1-176 HTRI-R "G/L1/GW2110/CM176/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-177 HMS-S/D/M/SA "G/L1/GW2110/MCP177/Entry dr Psg"
|      |      |      |-- 9:1-178 HFP-11 "G/L1/GW1040/SD178/Main cab"
|      |      |      |-- 9:1-179 HFP-11 "G/L1/GW1040/SD179/Entry Psg"
|      |      |      |-- 9:1-180 HTRI-R "G/L1/GW1040/CM180/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:1-181 HMS-S/D/M/SA "G/L1/GW1040/MCP181/Entry Psg"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:1 XDLC "XDLC @ address L1"

```
|      |      |  |-- 9:1-182 HFP-11 "G/L1/GW1010/SD182/Designer cab"
|      |      |  |-- 9:1-183 HFP-11 "G/L1/GW1010/SD183/Accounts cab1"
|      |      |  |-- 9:1-184 HFP-11 "G/L1/GW1010/SD184/Accounts cab1"
|      |      |  |-- 9:1-185 HFP-11 "G/L1/GW1010/SD185/Accounts cab2"
|      |      |  |-- 9:1-186 HFP-11 "G/L1/GW1010/SD186/Entry dr Psg"
|      |      |  |-- 9:1-187 HTRI-R "G/L1/GW1010/CM187/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:1-188 HMS-S/D/M/SA "G/L1/GW1010/MCP188/Entry dr Psg"
|      |      |  |-- 9:1-189 HFP-11 "G/L1/GE/SD189/Psg MR Washrm"
|      |      |  |-- 9:1-190 HFP-11 "G/L1/GE/SD190/MR Executive area"
|      |      |  |-- 9:1-192 HFP-11 "G/L1/GE/SD192/MR Call centre are"
|      |      |  |-- 9:1-193 HFP-11 "G/L1/GE/SD193/MR Security"
|      |      |  |-- 9:1-194 HFP-11 "G/L1/GE/SD194/MR AM cab"
|      |      |  |-- 9:1-195 HMS-S/D/M/SA "G/L1/GE/MCP195/Psg nr MR AM cab"
|      |      |  |-- 9:1-196 HFP-11 "G/L1/GE/SD196/Cab nr MR AM cab"
|      |      |  |-- 9:1-197 HTRI-R "G/L1/GE/CM197/AFC MR Exec.cab"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:1-199 HFP-11 "G/L1/G/GW1020/SD199/Main cab"
|      |      |  |-- 9:1-200 HFP-11 "G/L1/GW1020/SD200/Assorter cab"
|      |      |  |-- 9:1-201 HFP-11 "G/L1/GW1020/SD201/Entry Psg"
|      |      |  |-- 9:1-202 HFP-11 "G/L1/GW1020/SD202/Entry Psg"
|      |      |  |-- 9:1-203 HFP-11 "G/L1/GW1020/SD203/Entry Psg"
|      |      |  |-- 9:1-204 HTRI-R "G/L1/GW1020/CM204/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:1-205 HMS-S/D/M/SA "G/L1/GW1020/MCP205/Entry Psg"
|      |      |  |-- 9:1-206 HFP-11 "G/L1/FW2130/SD206/Main cab"
|      |      |  |-- 9:1-207 HFP-11 "G/L1/FW2130/SD207/Assorter cab"
|      |      |  |-- 9:1-208 HFP-11 "G/L1/FW2130/SD208/Entry dr Psg"
|      |      |  |-- 9:1-209 HFP-11 "G/L1/FW2130/SD209/Pantry"
|      |      |  |-- 9:1-210 HTRI-R "G/L1/FW2130/CM210/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:1-211 HMS-S/D/M/SA "G/L1/FW2130/MCP211/Entry dr Psg"
|      |      |  |-- 9:1-212 HFP-11 "G/L1/GE2022/SD212/Main Cab"
|      |      |  |-- 9:1-213 HFP-11 "G/L1/GE2022/SD213/PSG NR MAIN CA"
|      |      |  |-- 9:1-214 HFPT-11 "G/L1/GE2022/HD214/PANTRY"
|      |      |  |-- 9:1-215 HFP-11 "G/L1/GE2022/SD215/ACCOUNT CABIN"
|      |      |  |-- 9:1-216 HFP-11 "G/L1/GE2022/SD216/BAGKAR CABIN"
|      |      |  |-- 9:1-217 HFP-11 "G/L1/GE2022/SD217/CVD CABIN"
|      |      |  |-- 9:1-218 HFP-11 "G/L1/GE2021/SD218/ROUGH ASSORTO"
|      |      |  |-- 9:1-219 HFP-11 "G/L1/GE2022/SD219/MANAGER CABIN"
|      |      |  |-- 9:1-220 HFP-11 "G/L1/GE2022/SD220/POLISH ASSORTOR"
|      |      |  |-- 9:1-221 HFP-11 "G/L1/GE2021/SD221/MANAGER CABIN"
|      |      |  |-- 9:1-222 HTRI-R "G/L1/GE2022/CM222/ENTRY PSG AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:1-223 HFP-11 "G/L1/GW2030/SD223/Main Cabin"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:1 XDLC "XDLC @ address L1"

```
|      |      |  |-- 9:1-224 HFP-11 "G/L1/GW2030/SD224/Cabin 2"
|      |      |  |-- 9:1-225 HFP-11 "G/L1/GW2030/SD225/Cabin 3"
|      |      |  |-- 9:1-226 HFP-11 "G/L1/GW2030/SD226/PsgNrCabin 2"
|      |      |  |-- 9:1-227 HFP-11 "G/L1/GW2030/SD227/Pantry"
|      |      |  |-- 9:1-228 HMS-S/D/M/SA "G/L1/GW2030/MCP228/Entry dr Psg"
|      |      |  |-- 9:1-229 HTRI-R "G/L1/GW2030/CM229/Entry Psg AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:1-230 HMS-S/D/M/SA "G/L1/GE2022/MCP230/ENTRY PSG"
|      |      |  |-- 9:1-231 XTRI-S "G/L1/HW/GND/MM231/Sequel Cab"
|      |      |  |-- 9:1-232 XTRI-S "G/L1/HW/GND/MM232/BVC Chinai Pvt"
|      |      |  |-- 9:1-233 XTRI-S "G/L1/HW/GND/MM233/Ferrari Cab"
|      |      |  |-- 9:1-235 HFP-11 "G/L1/GE1080/SD235/Cab 1"
|      |      |  |-- 9:1-236 HFP-11 "G/L1/GE1080/SD236/Cab 2"
|      |      |  |-- 9:1-237 HFP-11 "G/L1/GE1080/SD237/Cab 3"
|      |      |  |-- 9:1-238 HFP-11 "G/L1/GE1080/SD238/Cab 4"
|      |      |  |-- 9:1-239 HFP-11 "G/L1/GE1080/SD239/Cab 5"
|      |      |  |-- 9:1-240 HFP-11 "G/L1/GE1080/SD240/Cab 6"
|      |      |  |-- 9:1-241 HFP-11 "G/L1/GE1080/SD241/Pantry"
|      |      |  |-- 9:1-242 HFP-11 "G/L1/GE1080/SD242/Cab 7"
|      |      |  |-- 9:1-243 HFP-11 "G/L1/GE1080/SD243/Cab 8"
|      |      |  |-- 9:1-244 HTRI-R "G/L1/GE1080/CM244/AFC Entry psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:1-245 HMS-S/D/M/SA "G/L1/GE1080/MCP245/Entry psg"
|      |      |  |-- 9:1-246 HFPT-11 "G/L1/FW2130/HD246/Pantry"
|      |      |  |-- 9:2 XDLC "XDLC @ address L2"
|      |      |  |-- 9:2-1 HTRI-R "G/L2/HE/2F/CM1/ HE LIFT LOBY"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:2-2 HMS-S/D/M/SA "G/L2/HE/2F/MCP2/HE LIFT LOBY"
|      |      |  |-- 9:2-3 HTRI-S "G/L2/HE/2F/MM3/LIFT LOBY"
|      |      |  |-- 9:2-4 HFP-11 "G/L2/HE/2F/SD4/LIFT LOBBY"
|      |      |  |-- 9:2-6 HFP-11 "G/L2/HE/2F/SD6/CORR NR HW2090"
|      |      |  |-- 9:2-7 HFP-11 "G/L2/HE/2F/SD7/CORR NR HW2090"
|      |      |  |-- 9:2-8 HTRI-R "G/L2/HE/2F/CM8/AHU RM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:2-9 HFP-11 "G/L2/HE/2F/SD9/AHU RM"
|      |      |  |-- 9:2-10 HFP-11 "G/L2/HE/2F/SD10/ELECT RM"
|      |      |  |-- 9:2-11 HTRI-R "G/L2/HW/2F/CM11/LIFT LOBY"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:2-12 HMS-S/D/M/SA "G/L2/HW/2F/MCP12/LIFT LOBY"
|      |      |  |-- 9:2-13 HTRI-S "G/L2/HW/2F/MM13/LIFT LOBY"
|      |      |  |-- 9:2-14 HFP-11 "G/L2/HW/2F/SD14/LIFT LOBBY"
|      |      |  |-- 9:2-15 HTRI-R "G/L2/HW/2F/CM15/DR RELEASE"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:2-16 HTRI-R "G/L2/HW/2F/CM16/AHU RM"
```

```
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 9:2-17 HFP-11 "G/L2/HW/2F/SD17/AHU RM"  
| | | |-- 9:2-18 HFP-11 "G/L2/HW/2F/SD18/ELECT RM"  
| | | |-- 9:2-19 HFP-11 "G/L2/HW/2F/SD19/CORR NR HW 2130"  
| | | |-- 9:2-20 HFP-11 "G/L2/HW/2F/SD20/CORR NR HW 2130"  
| | | |-- 9:2-21 HFP-11 "G/L2/HW/2F/SD21/CORR NR HW 2110"  
| | | |-- 9:2-22 HFP-11 "G/L2/HW/2F/SD22/CORR NR S/15"  
| | | |-- 9:2-23 HFP-11 "G/L2/HW/2F/SD23/CORR NR S/15"  
| | | |-- 9:2-24 HTRI-R "G/L2/HE/1F/CM24/FIRE SHAFT L.L."  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 9:2-25 HMS-S/D/M/SA "G/L2/HE/1F/MCP25/FIRE SHAFT L.L."  
| | | |-- 9:2-26 HTRI-S "G/L2/HE/1F/MM26/FIRE SHAFT L.L."  
| | | |-- 9:2-27 HFP-11 "G/L2/HE/1F/SD27/LIFT LOBBY SD E"  
| | | |-- 9:2-28 HTRI-S "G/L2/HW/2F/MM28/HW2010"  
| | | |-- 9:2-30 HFP-11 "G/L2/HE/1F/SD30/ELECT RM SD"  
| | | |-- 9:2-31 HTRI-R "G/L2/HW/1F/CM31/FIRE SHAFT L.L."  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 9:2-32 HMS-S/D/M/SA "G/L2/HW/1F/MCP32/FIRE SHAFT L.L."  
| | | |-- 9:2-33 HTRI-S "G/L2/HW/1F/MM33/FIRE SHAFT L.L."  
| | | |-- 9:2-34 HFP-11 "G/L2/HW/1F/SD34/LIFT LOBBY SD E"  
| | | |-- 9:2-35 HTRI-R "G/L2/HW/1F/CM35/AHU RM CM"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 9:2-36 HFP-11 "G/L2/HW/1F/SD36/AHU RM SD"  
| | | |-- 9:2-37 HTRI-R "G/L2/HW/1F/CM37/DR RELESE CM"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 9:2-38 HFP-11 "G/L2/HW/1F/SD38/ELECT RM SD"  
| | | |-- 9:2-39 HFP-11 "G/L2/HW/1F/SD39/CORR NR E.R."  
| | | |-- 9:2-40 HFP-11 "G/L2/HW/1F/SD40/CORR NR HW 1120"  
| | | |-- 9:2-41 HFP-11 "G/L2/HW/1F/SD41/CORR NR HW 1120"  
| | | |-- 9:2-42 HFP-11 "G/L2/HW/1F/SD42/CORR NR MIDDLE"  
| | | |-- 9:2-43 HFP-11 "G/L2/HW/1F/SD43/CORR NR MIDDLE"  
| | | |-- 9:2-44 HTRI-R "G/L2/HW/1F/CM44/FIRE ESC STR"  
| | | |-- Switch ""  
| | | |-- Relay  
| | | |-- 9:2-46 HFP-11 "G/L2/HW/1F/SD46/CORR NR S/24"  
| | | |-- 9:2-47 HFP-11 "G/L2/ HW/1F/SD47/CORR NR S/24"  
| | | |-- 9:2-48 HFP-11 "G/L2/HW/1F/SD48/CORR NR HW1030"  
| | | |-- 9:2-49 HFP-11 "G/L2/HW/1F/SD49/CORR NR HW1030"  
| | | |-- 9:2-50 HFP-11 "G/L2/HW/1F/SD50/CORR NR HW1118"  
| | | |-- 9:2-51 HFP-11 "G/L2/HW/1F/SD51/CORR NR HW1210"  
| | | |-- 9:2-52 HFP-11 "G/L2/HW/1F/SD52/CORR NR HW1210"  
| | | |-- 9:2-53 HFP-11 "G/L2/HW/1F/SD53/CORR NR HW1190"  
| | | |-- 9:2-54 HFP-11 "G/L2/HW/1F/SD54/CORR NR HW1190"  
| | | |-- 9:2-55 HFP-11 "G/L2/HW/1F/SD55/CORR NR HW1170"  
| | | |-- 9:2-56 HFP-11 "G/L2/HW/1F/SD56/CORR NR HW1150"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:2 XDLC "XDLC @ address L2"

```
|      |      |      |-- 9:2-57 HFP-11 "G/L2/HW/1F/SD57/CORR NR HW1150"
|      |      |      |-- 9:2-58 HFP-11 "G/L2/HW/1F/SD58/CORR NR HW 1140"
|      |      |      |-- 9:2-59 HFP-11 "G/L2/HW/1F/SD59/CORR NR HW1130"
|      |      |      |-- 9:2-60 HFP-11 "G/L2/HW/1F/SD60/CORR NR HW1130"
|      |      |      |-- 9:2-61 HFP-11 "G/L2/HW/2F/SD61/ HW2091"
|      |      |      |-- 9:2-62 HFP-11 "G/L2/HW/2F/SD62/ HW2092"
|      |      |      |-- 9:2-63 HFP-11 "G/L2/HW/2F/SD63/CORR NR HW2040"
|      |      |      |-- 9:2-64 HFP-11 "G/L2/HW/2F/SD64/CORR NR HW2030"
|      |      |      |-- 9:2-65 HFP-11 "G/L2/HW/2F/SD65/CORR NR HW2030"
|      |      |      |-- 9:2-66 HTRI-R "G/L2/HW/2F/CM66/FIRE SHAFT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-67 HMS-S/D/M/SA "G/L2/HW/2F/MCP67/FIRE SHAFT"
|      |      |      |-- 9:2-68 HTRI-S "G/L2/1F/MM68/HW1150"
|      |      |      |-- 9:2-69 HTRI-S "G/L2/2F/MM69/HW2030"
|      |      |      |-- 9:2-70 HTRI-S "G/L2/2F/MM70/HW2040""
|      |      |      |-- 9:2-71 HTRI-S "G/L2/2F/MM71/HW2092"
|      |      |      |-- 9:2-72 HTRI-S "G/L2/2F/MM72/HW2091"
|      |      |      |-- 9:2-76 HTRI-S "G/L2/2F/MM76/HW2080"
|      |      |      |-- 9:2-77 HTRI-S "G/L2/1F/MM77/HW1040"
|      |      |      |-- 9:2-80 HTRI-S "G/L2/7/EC3/1F/MM80/HW2130A"
|      |      |      |-- 9:2-81 HTRI-S "G/L2/7/EC3/1F/MM81/HW2130"
|      |      |      |-- 9:2-82 HTRI-S "G/L2/7/EC3/1F/MM82/HW2120"
|      |      |      |-- 9:2-83 HTRI-S "G/L2/7/EC3/1F/MM83/HW2110"
|      |      |      |-- 9:2-84 HTRI-S "G/L2/7/EC3/1F/MM84/HW2100"
|      |      |      |-- 9:2-85 HTRI-S "G/L2/HW/1F/MM85/HW1120"
|      |      |      |-- 9:2-90 HTRI-S "G/L2/1F/MM90/HW1020"
|      |      |      |-- 9:2-91 HTRI-S "G/L2/1F/MM91/HW1030"
|      |      |      |-- 9:2-92 HTRI-S "G/L2/1F/MM92/HW1060"
|      |      |      |-- 9:2-93 HTRI-S "G/L2/1F/MM93/HW1122"
|      |      |      |-- 9:2-94 HTRI-S "G/L2/1F/MM94/HW1140"
|      |      |      |-- 9:2-95 HTRI-S "G/L2/1F/MM95/HW1200"
|      |      |      |-- 9:2-96 HTRI-S "G/L2/1F/MM96/HW1180"
|      |      |      |-- 9:2-166 HMS-S/D/M/SA "H/L2/HE/GND/MCP166/LIFT LOBBY"
|      |      |      |-- 9:2-167 HTRI-R "H/L2/HE/GND/CM167/LIFT LOBBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-168 HTRI-S "H/L2/HE/GND/MM168/LIFT LOBBY"
|      |      |      |-- 9:2-169 HFP-11 "H/L2/HE/GND/SD169/HE GND AHU RM"
|      |      |      |-- 9:2-170 HFP-11 "H/L2/HE/GND/SD170/LIFT LOBBY"
|      |      |      |-- 9:2-198 HFP-11 "G/L2/HW1160/SD198/Main cab1"
|      |      |      |-- 9:2-199 HFP-11 "G/L2/HW1160/SD199/Main cab2"
|      |      |      |-- 9:2-200 HFP-11 "G/L2/HW1160/SD200/Assorter cab"
|      |      |      |-- 9:2-201 HFP-11 "G/L2/HW1160/SD201/Entry dr Psg"
|      |      |      |-- 9:2-202 HTRI-R "G/L2/HW1160/CM202/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-203 HMS-S/D/M/SA "G/L2/HW1160/MCP203/Entry dr Psg"
|      |      |      |-- 9:2-204 HFP-11 "G/L2/HW1190/SD204/Account cab"
|      |      |      |-- 9:2-205 HFP-11 "G/L2/HW1190/SD205/Main cab"
```


9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:2 XDLC "XDLC @ address L2"

```
|      |      |      |-- 9:2-206 HFP-11 "G/L2/HW1190/SD206/Assorter cab"
|      |      |      |-- 9:2-207 HFP-11 "G/L2/HW1190/SD207/Entry dr Psg"
|      |      |      |-- 9:2-208 HFP-11 "G/L2/HW1190/SD208/Pantry"
|      |      |      |-- 9:2-209 HTRI-R "G/L2/HW1190/CM209/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-210 HMS-S/D/M/SA "G/L2/HW1190/MCP210/Entry dr Psg"
|      |      |      |-- 9:2-211 HFP-11 "G/L2/HW1170/SD211/Main cab"
|      |      |      |-- 9:2-212 HFP-11 "G/L2/HW1170/SD212/Account cab"
|      |      |      |-- 9:2-213 HFP-11 "G/L2/HW1170/SD213/Psg nr Acc cab"
|      |      |      |-- 9:2-214 HFP-11 "G/L2/HW1170/SD214/Assorter cab"
|      |      |      |-- 9:2-215 HFP-11 "G/L2/HW1170/SD215/Pantry"
|      |      |      |-- 9:2-216 HTRI-R "G/L2/HW1170/CM216/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-217 HMS-S/D/M/SA "G/L2/HW1170/MCP217/Entry dr Psg"
|      |      |      |-- 9:2-218 HFP-11 "G/L2/HW1090/SD218/Main cab"
|      |      |      |-- 9:2-219 HFP-11 "G/L2/HW1090/SD219/Assorter cab"
|      |      |      |-- 9:2-220 HFP-11 "G/L2/HW1090/SD220/Pantry"
|      |      |      |-- 9:2-221 HTRI-R "G/L2/HW1090/CM221/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-222 HMS-S/D/M/SA "G/L2/HW1090/MCP222/Entry Psg"
|      |      |      |-- 9:2-223 HFP-11 "G/L2/HW1130/SD223/Main cab1"
|      |      |      |-- 9:2-224 HFP-11 "G/L2/HW1130/SD224/Main cab2"
|      |      |      |-- 9:2-225 HFP-11 "G/L2/HW1130/SD225/Main cab3"
|      |      |      |-- 9:2-226 HFP-11 "G/L2/HW1130/SD226/Pantry"
|      |      |      |-- 9:2-227 HFP-11 "G/L2/HW1130/SD227/Psg nr Pantry"
|      |      |      |-- 9:2-228 HTRI-R "G/L2/HW1130/CM228/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-229 HMS-S/D/M/SA "G/L2/HW1130/MCP229/Entry dr Psg"
|      |      |      |-- 9:2-230 HFP-11 "G/L2/HW1210/SD230/Account cab"
|      |      |      |-- 9:2-231 HFP-11 "G/L2/HW1210/SD231/Main cab"
|      |      |      |-- 9:2-232 HFP-11 "G/L2/HW1210/SD232/Entry Psg"
|      |      |      |-- 9:2-233 HTRI-R "G/L2/HW1210/CM233/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-234 HMS-S/D/M/SA "G/L2/HW1210/MCP234/Entry Psg"
|      |      |      |-- 9:2-235 HFP-11 "H/L2/WC/1F/HW1050/SD235/MainCab"
|      |      |      |-- 9:2-236 HFP-11 "H/L2/WC/1F/HW1050/SD236/AcountCa"
|      |      |      |-- 9:2-237 HFP-11 "H/L2/WC/1F/HW1050/SD237/AcountCa"
|      |      |      |-- 9:2-238 HFPT-11 "H/L2/WC/1F/HW1050/HD238/Pantry"
|      |      |      |-- 9:2-239 HFP-11 "H/L2/WC/1F/HW1050/SD239/Entry Ps"
|      |      |      |-- 9:2-240 HTRI-R "H/L2/WC/1F/HW1050/CM240/Entry Ps"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:2-241 HMS-S/D/M/SA "H/L2/WC/1F/HW1050/MCP241/MainEnt"
|      |      |      |-- 9:3 XDLC "XDLC @ address L3"
|      |      |      |-- 9:3-1 HTRI-R "G/L3/W/4F/CM1/AHU RM "
```

9:3-1 HTRI-R "G/L3/W/4F/CM1/AHU RM "

```
| | | | | Switch ""
| | | | | |-- Relay
| | | | | |-- 9:3-2 HFP-11 "G/L3/W/4F/SD2/AHU RM "
| | | | | |-- 9:3-3 HFP-11 "L3/G/HW/4F/SD3/COR NR AHU RM"
| | | | | |-- 9:3-4 XTRI-R "G/L3/W/4F/CM4/NR LIFT LOBY"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:3-5 HMS-S/D/M/SA "G/L3/W/4F/MCP5/LIFT LOBY"
| | | | | |-- 9:3-6 HTRI-S "G/L3/W/4F/MM6/LIFT LOBY"
| | | | | |-- 9:3-7 HFP-11 "G/L3/W/4F/SD7/LIFT LOBBY"
| | | | | |-- 9:3-8 HFP-11 "G/L3/W/4F/SD8/LIFT LOBBY"
| | | | | |-- 9:3-9 HTRI-R "G/L3/W/4F/CM9/DR RELEASE"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:3-10 HFP-11 "G/L3/W/4F/SD10/ELECT RM"
| | | | | |-- 9:3-11 HFP-11 "G/L3/W/4F/SD11/ CORR NR GW 4050"
| | | | | |-- 9:3-12 HFP-11 "G/L3/W/4F/SD12/ CORR NR GW 4050"
| | | | | |-- 9:3-13 HFP-11 "G/L3/W/4F/SD13/ CORR NR GW 4040"
| | | | | |-- 9:3-14 HFP-11 "G/L3/W/4F/SD14/ CORR NR GW4031"
| | | | | |-- 9:3-15 HFP-11 "G/L3/W/4F/SD15/CORR NR GW4031"
| | | | | |-- 9:3-16 HFP-11 "G/L3/W/4F/SD16/MIDDLE PASSAGE"
| | | | | |-- 9:3-17 HTRI-R "G/L3/E/4F/CM17/GE LOFT LOBY"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:3-18 HMS-S/D/M/SA "G/L3/E/4F/MCP18/NR FIRE EXIT"
| | | | | |-- 9:3-19 HTRI-S "G/L3/E/4F/MM19/NR FIRE EXIT"
| | | | | |-- 9:3-20 HFP-11 "G/L3/E/4F/SD20/LIFT LOBBY"
| | | | | |-- 9:3-21 HFP-11 "G/L3/E/4F/SD21/LIFT LOBBY"
| | | | | |-- 9:3-22 HTRI-R "G/L3/E/4F/CM22/DR RELEASE"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:3-23 HFP-11 "G/L3/E/4F/SD23/ELECT RM"
| | | | | |-- 9:3-24 HTRI-R "G/L3/E/4F/CM24/AHU RM "
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:3-25 HFP-11 "G/L3/E/4F/SD25/AHU RM "
| | | | | |-- 9:3-26 HFP-11 "G/L3/E/4F/SD26/ CORR NR 7/S02"
| | | | | |-- 9:3-27 HFP-11 "G/L3/E/4F/SD27/ CORR NR 7/S02"
| | | | | |-- 9:3-28 HFP-11 "G/L3/E/4F/SD28/MIDDLE PASSAGE"
| | | | | |-- 9:3-29 HFP-11 "G/L3/E/4F/SD29/CORR NR GW4/S12"
| | | | | |-- 9:3-30 HFP-11 "G/L3/E/4F/SD30/CORR NR GE4/S25"
| | | | | |-- 9:3-31 HFP-11 "G/L3/E/4F/SD31/CORR NR GE4/S13"
| | | | | |-- 9:3-32 HFP-11 "G/L3/E/4F/SD32/CORR NR GE4030"
| | | | | |-- 9:3-33 HFP-11 "G/L3/E/4F/SD33/CORR NR GE4030"
| | | | | |-- 9:3-34 HFP-11 "G/L3/E/4F/SD34/CORR NR S/14"
| | | | | |-- 9:3-35 HFP-11 "G/L3/E/4F/SD35/CORR NR HW4080"
| | | | | |-- 9:3-36 HTRI-R "G/L3/E/4F/CM36/LIFT LOBY"
| | | | | |-- Switch ""
| | | | | |-- Relay
| | | | | |-- 9:3-37 HMS-S/D/M/SA "G/L3/E/4F/MCP37/LIFT LOBY"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:3 XDLC "XDLC @ address L3"

```
|      |      |      |-- 9:3-38 XTRI-S "G/L3/GE/3F/MM112/GE3040"
|      |      |      |-- 9:3-39 HTRI-R "G/L3/W/3F/CM39/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-40 HFP-11 "G/L3/W/3F/SD40/AHU RM"
|      |      |      |-- 9:3-41 HFP-11 "G/L3/W/3F/SD41/CORR "
|      |      |      |-- 9:3-42 HTRI-R "G/L3/W/3F/CM42/DR RELEASE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-43 XTRI-R "G/L3/W/3F/CM43/LIFT LOBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-44 HMS-S/D/M/SA "G/L3/W/3F/MCP44/LIFT LOBY"
|      |      |      |-- 9:3-45 HTRI-S "G/L3/W/3F/MM45/LIFT LOBY"
|      |      |      |-- 9:3-46 HFP-11 "G/L3/W/3F/SD46/LIFT LOBBY"
|      |      |      |-- 9:3-47 HFP-11 "G/L3/W/3F/SD47/LIFT LOBBY"
|      |      |      |-- 9:3-48 HTRI-R "G/L3/W/3F/CM48/DR RELEASE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-49 HFP-11 "G/L3/W/3F/SD49/CORR NR GW 3080"
|      |      |      |-- 9:3-50 HFP-11 "G/L3/W/3F/SD50/CORR NR GW 3080"
|      |      |      |-- 9:3-51 HFP-11 "G/L3/W/3F/SD51/CORR NR GW 3020"
|      |      |      |-- 9:3-52 HFP-11 "G/L3/W/3F/SD52/CORR NR GW 3060"
|      |      |      |-- 9:3-53 HFP-11 "G/L3/W/3F/SD53/CORR NR GW 3060"
|      |      |      |-- 9:3-54 HTRI-R "G/L3/E/3F/CM54/LIFT LOBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-55 HMS-S/D/M/SA "G/L3/E/3F/MCP55/LIFT LOBY"
|      |      |      |-- 9:3-56 HTRI-S "G/L3/E/3F/MM56/LIFT LOBY"
|      |      |      |-- 9:3-57 HFP-11 "G/L3/E/3F/SD57/LIFT LOBBY"
|      |      |      |-- 9:3-58 HFP-11 "G/L3/E/3F/SD58/LIFT LOBBY"
|      |      |      |-- 9:3-59 HTRI-R "G/L3/E/3F/CM59/DR RELEASE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-60 HTRI-R "G/L3/E/3F/CM60/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-61 HFP-11 "G/L3/E/3F/SD61/AHU RM"
|      |      |      |-- 9:3-62 HFP-11 "G/L3/E/3F/SD62/ELECT RM"
|      |      |      |-- 9:3-63 HFP-11 "G/L3/E/3F/SD63/CORR NR GE 3010"
|      |      |      |-- 9:3-64 HFP-11 "G/L3/E/3F/SD64/CORR NR GE3030"
|      |      |      |-- 9:3-65 HFP-11 "G/L3/E/3F/SD65/CORR NR GW3031 "
|      |      |      |-- 9:3-66 HFP-11 "G/L3/E/3F/SD66/CORR NR GE3100B"
|      |      |      |-- 9:3-67 HFP-11 "G/L3/E/3F/SD67/CORR NR GE3100B"
|      |      |      |-- 9:3-68 HFP-11 "G/L3/E/3F/SD68/CORR NR GE3/S25 "
|      |      |      |-- 9:3-69 HFP-11 "G/L3/E/3F/SD69/CORR NR GW 3032"
|      |      |      |-- 9:3-70 HFP-11 "G/L3/E/3F/SD70/CORR NR S/13"
|      |      |      |-- 9:3-71 HFP-11 "G/L3/E/3F/SD71/CORR NR S/13"
|      |      |      |-- 9:3-72 HFP-11 "G/L3/E/3F/SD72/CORR NR GE3090"
|      |      |      |-- 9:3-73 HFP-11 "G/L3/E/3F/SD73/CORR NR GE3080"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:3 XDLC "XDLC @ address L3"

```
|      |      |      |-- 9:3-74 HFP-11 "G/L3/E/3F/SD74/CORR NR GE3070"
|      |      |      |-- 9:3-75 HFP-11 "G/L3/E/3F/SD75/CORR NR GE 3051"
|      |      |      |-- 9:3-76 XTRI-R "G/L3/E/3F/CM76/CORR NR GE3060"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-77 HMS-S/D/M/SA "G/L3/E/3F/MCP77/FIR EX NR GE3060"
|      |      |      |-- 9:3-78 HFP-11 "G/L3/W/3F/SD78/ELECT RM"
|      |      |      |-- 9:3-80 HTRI-S "G/L3/W/4F/MM80/GW3050"
|      |      |      |-- 9:3-81 HTRI-S "G/L3/W/4F/MM081/GW4050"
|      |      |      |-- 9:3-83 HTRI-S "G/L3/W/4F/MM083/GW4033"
|      |      |      |-- 9:3-86 HTRI-S "G/L3/W/4F/MM086/GW4010"
|      |      |      |-- 9:3-87 HTRI-S "G/L3/W/4F/MM087/GW4021"
|      |      |      |-- 9:3-90 HTRI-S "G/L3/E/4F/MM090/GE4041"
|      |      |      |-- 9:3-91 HTRI-S "G/L3/E/4F/MM091/GE4030"
|      |      |      |-- 9:3-92 HTRI-S "G/L3/E/4F/MM92/HW4030"
|      |      |      |-- 9:3-97 HTRI-S "G/L3/W/3F/MM097/FW3170"
|      |      |      |-- 9:3-99 HTRI-S "G/L3/W/3F/MM099/GW3080"
|      |      |      |-- 9:3-100 HTRI-S "G/L3/W/3F/MM100/GW3020"
|      |      |      |-- 9:3-102 HFP-11 "G/L3/W/SD102/CORR NR GW3060"
|      |      |      |-- 9:3-107 HTRI-S "G/L3/E/3F/MM107/GE3020"
|      |      |      |-- 9:3-108 XTRI-S "G/L3/GE/3F/MM108/GE3030"
|      |      |      |-- 9:3-109 HTRI-S "G/L3/E/3F/MM109/GE3100B"
|      |      |      |-- 9:3-111 HTRI-S "G/L3/E/3F/MM111/GE3100B"
|      |      |      |-- 9:3-112 HTRI-S "G/L3/E/3F/MM112/GE3040"
|      |      |      |-- 9:3-113 HTRI-S "G/L3/E/3F/MM113/GE3090"
|      |      |      |-- 9:3-115 HTRI-S "G/L3/E/3F/MM115/GE3080"
|      |      |      |-- 9:3-116 HTRI-S "G/L3/E/3F/MM116/GE3070"
|      |      |      |-- 9:3-117 HTRI-S "G/L3/E/3F/MM117/GE3051"
|      |      |      |-- 9:3-118 HTRI-S "G/L3/E/3F/MM118/GE3052"
|      |      |      |-- 9:3-119 HTRI-S "G/L3/E/3F/MM119/GE3060"
|      |      |      |-- 9:3-123 HFP-11 "G/L3/HW4040/SD123/Main cab"
|      |      |      |-- 9:3-124 HFP-11 "G/L3/HW4040/SD124/Assorter cab"
|      |      |      |-- 9:3-125 HFP-11 "G/L3/HW4040/SD125/Accounts cab"
|      |      |      |-- 9:3-126 HFP-11 "G/L3/HW4040/SD126/Pantry"
|      |      |      |-- 9:3-127 HTRI-R "G/L3/HW4040/CM127/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-128 HMS-S/D/M/SA "G/L3/HW4040/MCP128/Entry Psg"
|      |      |      |-- 9:3-129 HFP-11 "G/L3/HW4050/SD129/MC 1"
|      |      |      |-- 9:3-130 HFP-11 "G/L3/HW4050/SD130/MC 2"
|      |      |      |-- 9:3-131 HFP-11 "G/L3/HW4050/SD131/Pass Nr MC2"
|      |      |      |-- 9:3-132 HFP-11 "G/L3/HW4050/SD132/Pass Nr MC1"
|      |      |      |-- 9:3-133 HFP-11 "G/L3/HW4050/SD133/MC3"
|      |      |      |-- 9:3-134 HTRI-R "G/L3/HW4050/CM134/Entry Door Pas"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-135 HMS-S/D/M/SA "G/L3/HW4050/MCP135/Entry Door Pa"
|      |      |      |-- 9:3-143 HFP-11 "G/L3/HW4020/SD143/Main cab"
|      |      |      |-- 9:3-144 HFP-11 "G/L3/HW4020/SD144/Assorter cab"
|      |      |      |-- 9:3-145 HFP-11 "G/L3/HW4020/SD145/Entry dr Psg"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:3 XDLC "XDLC @ address L3"

```
|      |      |      |-- 9:3-146 HTRI-R "G/L3/HW4020/CM146/Entry dr Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 9:3-147 HMS-S/D/M/SA "G/L3/HW4020/MCP147/Entry dr Psg"
|      |      |      |-- 9:3-148 HFP-11 "G/L3/GW4032/SD148/Accounts cab1"
|      |      |      |-- 9:3-149 HFP-11 "G/L3/GW4032/SD149/Assorter cab1"
|      |      |      |-- 9:3-150 HFP-11 "G/L3/GW4032/SD150/Main cab"
|      |      |      |-- 9:3-151 HFP-11 "G/L3/GW4032/SD151/Accounts cab2"
|      |      |      |-- 9:3-152 HFP-11 "G/L3/GW4032/SD152/Entry Psg"
|      |      |      |-- 9:3-153 HTRI-R "G/L3/GW4032/CM153/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 9:3-154 HMS-S/D/M/SA "G/L3/GW4032/MCP154/Entry Psg"
|      |      |      |-- 9:3-155 HFP-11 "G/L3/GW3060/SD155/Main cab"
|      |      |      |-- 9:3-156 HFP-11 "G/L3/GW3060/SD156/Assorter cab"
|      |      |      |-- 9:3-157 HFP-11 "G/L3/GW3060/SD157/Entry Psg"
|      |      |      |-- 9:3-158 HFPT-11 "G/L3/GW3060/HD158/Pantry"
|      |      |      |-- 9:3-159 HTRI-R "G/L3/GW3060/CM159/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 9:3-160 HMS-S/D/M/SA "G/L3/GW3060/MCP160/Entry Psg"
|      |      |      |-- 9:3-161 HFP-11 "G/L3/GW3070/SD161/Main cab"
|      |      |      |-- 9:3-162 HFP-11 "G/L3/GW3070/SD162/Accounts cab"
|      |      |      |-- 9:3-163 HFP-11 "G/L3/GW3070/SD163/Psg nr Acct ca"
|      |      |      |-- 9:3-164 HFP-11 "G/L3/GW3070/SD164/Psg nr Acct ca"
|      |      |      |-- 9:3-165 HFP-11 "G/L3/GW3070/SD165/Pantry"
|      |      |      |-- 9:3-166 HTRI-R "G/L3/GW3070/CM166/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 9:3-167 HMS-S/D/M/SA "G/L3/GW3070/MCP167/Entry Psg"
|      |      |      |-- 9:3-168 HFP-11 "G/L3/GW3040/SD168/Main cab"
|      |      |      |-- 9:3-169 HFP-11 "G/L3/GW3040/SD169/Assorter cab 1"
|      |      |      |-- 9:3-170 HFP-11 "G/L3/GW3040/SD170/Account cab"
|      |      |      |-- 9:3-172 HFP-11 "G/L3/GW3040/SD172/Psg nr Assoert"
|      |      |      |-- 9:3-173 HFP-11 "G/L3/GW3040/SD173/Pantry Psg"
|      |      |      |-- 9:3-174 HTRI-R "G/L3/GW3040/CM174/Entry dr PSg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 9:3-175 HMS-S/D/M/SA "G/L3/GW3040/MCP175/Entry dr PSg"
|      |      |      |-- 9:3-176 HFP-11 "G/L3/GE3010/SD176/Main cab"
|      |      |      |-- 9:3-177 HFP-11 "G/L3/GE3010/SD177/Assorter cab"
|      |      |      |-- 9:3-178 HFP-11 "G/L3/GE3010/SD178/Entry Psg"
|      |      |      |-- 9:3-179 HTRI-R "G/L3/GE3010/CM179/Entry Psg"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 9:3-180 HMS-S/D/M/SA "G/L3/GE3010/MCP180/Entry Psg"
|      |      |      |-- 9:3-181 HFP-11 "G/L3/GW3031/SD181/Accounts cab"
|      |      |      |-- 9:3-182 HFP-11 "G/L3/GW3031/SD182/Boiling cab"
|      |      |      |-- 9:3-183 HFP-11 "G/L3/GW3031/SD183/Assorter cab 5"
|      |      |      |-- 9:3-184 HFP-11 "G/L3/GW3031/SD184/Assorter cab 5"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:3 XDLC "XDLC @ address L3"

```
|      |      |  |-- 9:3-185 HFP-11 "G/L3/GW3031/SD185/cab 4"
|      |      |  |-- 9:3-186 HFP-11 "G/L3/GW3031/SD186/Psg nr cab 4"
|      |      |  |-- 9:3-187 HFP-11 "G/L3/GW3031/SD187/cab 3"
|      |      |  |-- 9:3-188 HFP-11 "G/L3/GW3031/SD188/Psg nr cab 3"
|      |      |  |-- 9:3-189 HFP-11 "G/L3/GW3031/SD189/cab 2"
|      |      |  |-- 9:3-190 HFP-11 "G/L3/GW3031/SD190/cab 1"
|      |      |  |-- 9:3-191 HFP-11 "G/L3/GW3031/SD191/cab 2"
|      |      |  |-- 9:3-192 HFP-11 "G/L3/GW3031/SD192/cab 7"
|      |      |  |-- 9:3-193 HFP-11 "G/L3/GW3031/SD193/cab 7"
|      |      |  |-- 9:3-194 HFP-11 "G/L3/GW3031/SD194/Pantry"
|      |      |  |-- 9:3-195 HFP-11 "G/L3/GW3031/SD195/Entry Psg"
|      |      |  |-- 9:3-196 HMS-S/D/M/SA "G/L3/GW3031/MCP196/Pantry Psg"
|      |      |  |-- 9:3-197 HMS-S/D/M/SA "G/L3/GW3031/MCP197/Psg nr cab6"
|      |      |  |-- 9:3-198 HMS-S/D/M/SA "G/L3/GW3031/MCP198/Entry dr Psg"
|      |      |  |-- 9:3-200 HTRI-R "G/L3/GW3031/CM200/PsgNr Cab6 AFC"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:3-203 HFP-11 "G/L3/GW4031/SD203/Main cab1"
|      |      |  |-- 9:3-204 HFP-11 "G/L3/GW4031/SD204/Accounts cab1"
|      |      |  |-- 9:3-205 HFP-11 "G/L3/GW4031/SD205/Main cab2"
|      |      |  |-- 9:3-206 HFP-11 "G/L3/GW4031/SD206/Accounts cab2"
|      |      |  |-- 9:3-207 HFP-11 "G/L3/GW4031/SD207/Main cab Psg"
|      |      |  |-- 9:3-208 HFP-11 "G/L3/GW4031/SD208/Pantry"
|      |      |  |-- 9:3-209 HFP-11 "G/L3/GW4031/SD209/Entry dr Psg"
|      |      |  |-- 9:3-210 HTRI-R "G/L3/GW4031/CM210/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:3-211 HMS-S/D/M/SA "G/L3/GW4031/MCP211/Entry dr Psg"
|      |      |  |-- 9:3-212 HFP-11 "G/L3/GW3010/SD212/Pantry"
|      |      |  |-- 9:3-213 HFP-11 "G/L3/GW3010/SD213/Lunch cab"
|      |      |  |-- 9:3-214 HFP-11 "G/L3/GW3010/SD214/Account cab"
|      |      |  |-- 9:3-215 HFP-11 "G/L3/GW3010/SD215/Assorter cab"
|      |      |  |-- 9:3-216 HFP-11 "G/L3/GW3010/SD216/Boss cab3"
|      |      |  |-- 9:3-217 HFP-11 "G/L3/GW3010/SD217/Boss cab3"
|      |      |  |-- 9:3-218 HFP-11 "G/L3/GW3010/SD218/Buyer cab1"
|      |      |  |-- 9:3-219 HFP-11 "G/L3/GW3010/SD219/Psg nr Buyer c"
|      |      |  |-- 9:3-220 HFP-11 "G/L3/GW3010/SD220/Buyer cab2"
|      |      |  |-- 9:3-221 HFP-11 "G/L3/GW3010/SD221/Command rm"
|      |      |  |-- 9:3-222 HFP-11 "G/L3/GW3010/SD222/Meeting rm"
|      |      |  |-- 9:3-223 HFP-11 "G/L3/GW3010/SD223/Boss cab2"
|      |      |  |-- 9:3-224 HFP-11 "G/L3/GW3010/SD224/Boss cab 1"
|      |      |  |-- 9:3-225 HFP-11 "G/L3/GW3010/SD225/Boss cab 1"
|      |      |  |-- 9:3-226 HFP-11 "G/L3/GW3010/SD226/Entry dr Psg"
|      |      |  |-- 9:3-227 HTRI-R "G/L3/GW3010/CM227/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:3-228 HMS-S/D/M/SA "G/L3/GW3010/MCP228/Entry dr Psg"
|      |      |  |-- 9:3-229 HFP-11 "G/L3/HW4060/SD229/Main cab"
|      |      |  |-- 9:3-230 HFP-11 "G/L3/HW4060/SD230/Accounts cab"
|      |      |  |-- 9:3-231 FDOT421 "G/L3/HW4060/SD231/Psg nr MC"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:3 XDLC "XDLC @ address L3"

```
|      |      |      |-- 9:3-232 HFP-11 "G/L3/HW4060/SD232/Pantry Psg"
|      |      |      |-- 9:3-233 HTRI-R "G/L3/HW4060/CM233/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-234 HMS-S/D/M/SA "G/L3/HW4060/MCP234/Entry Psg"
|      |      |      |-- 9:3-235 HFP-11 "G/L3/FW3180/SD235/Pantry"
|      |      |      |-- 9:3-236 HFP-11 "G/L3/FW3180/SD236/Main cab"
|      |      |      |-- 9:3-237 HFP-11 "G/L3/FW3180/SD237/Main cab"
|      |      |      |-- 9:3-238 HFP-11 "G/L3/FW3180/SD238/Account cab"
|      |      |      |-- 9:3-239 HFP-11 "G/L3/FW3180/SD239/Entry dr Psg"
|      |      |      |-- 9:3-240 HTRI-R "G/L3/FW3180/CM240/Entry dr Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:3-241 HMS-S/D/M/SA "G/L3/FW3180/MCP241/Entry dr Psg"
|      |      |      |-- 9:3-242 HFP-11 "G/L3/HW4060/SD242/Psg nr Main Ca"
|      |      |      |-- 9:3-243 FDOT421 "G/L3/GW4031/SD243/Psg Nr Assort""
|      |      |      |-- 9:4 XDLC "XDLC @ address L4"
|      |      |      |-- 9:4-1 HTRI-R "G/L4/HE/4F/CM1/LIFT LOBY"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:4-2 HMS-S/D/M/SA "G/L4/HE/4F/MCP2/LIFT LOBY"
|      |      |      |-- 9:4-3 HTRI-S "G/L4/HE/4F/MM3/LIFT LOBY"
|      |      |      |-- 9:4-4 HFP-11 "G/L4/HE/4F/SD4/LIFT LOBBY"
|      |      |      |-- 9:4-5 HTRI-R "G/L4/HE/4F/CM5/DR RELEASE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:4-6 HFP-11 "G/L4/HE/4F/SD6/ELECT RM"
|      |      |      |-- 9:4-7 HTRI-R "G/L4/HE/4F/CM7/AHU RM "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:4-8 HFP-11 "G/L4/HE/4F/SD8/AHU RM "
|      |      |      |-- 9:4-9 HFP-11 "G/L4/HE/4F/SD9/CORR NR HE 4100"
|      |      |      |-- 9:4-10 HFP-11 "G/L4/HE/4F/SD10/CORR NR HE 4100"
|      |      |      |-- 9:4-11 HFP-11 "G/L4/HE/4F/SD11/CORR NR HE 4020"
|      |      |      |-- 9:4-12 HFP-11 "G/L4/H/4EF/SD12/CORR NR HE 4020"
|      |      |      |-- 9:4-13 HFP-11 "G/L4/4F/HESD13/CORR NR S/20"
|      |      |      |-- 9:4-14 HFP-11 "G/L4/HE/4F/SD14/CORR NR HE 4040"
|      |      |      |-- 9:4-15 HFP-11 "G/L4/HE/4F/SD15/CORR NR HE 4050"
|      |      |      |-- 9:4-16 HFP-11 "G/L4/HE/4F/SD16/CORR NR HE 4062"
|      |      |      |-- 9:4-17 HFP-11 "G/L4/E/4F/SD17/CORR NR HE 4070"
|      |      |      |-- 9:4-18 HTRI-R "G/L4/HW/4F/CM18/NR FIRE EXIT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:4-19 HMS-S/D/M/SA "G/L4/HW/4F/MCP19/NR FIRE EXIT"
|      |      |      |-- 9:4-20 HTRI-S "G/L4/HW/4F/MM20/NR FIRE EXIT"
|      |      |      |-- 9:4-21 HFP-11 "G/L4/HW/4F/SD21/LIFT LOBBY"
|      |      |      |-- 9:4-22 HTRI-R "G/L4/HW/4F/CM22/DR RELEASE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:4-23 HFP-11 "G/L4/HW/4F/SD23/ELECT RM"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:4 XDLC "XDLC @ address L4"

```
|      |      |      |-- 9:4-24 HTRI-R "G/L4/HW/4F/CM24/AHU RM "
```

```
|      |      |      |-- Switch ""
```

```
|      |      |      |-- Relay
```

```
|      |      |      |-- 9:4-25 HFP-11 "G/L4/HW/4F/SD25/AHU RM "
```

```
|      |      |      |-- 9:4-26 HFP-11 "G/L4/HW/4F/SD26/CORR NR HW4010"
```

```
|      |      |      |-- 9:4-27 HFP-11 "G/L4/HW/4F/SD27/CORR NR HW4010"
```

```
|      |      |      |-- 9:4-28 HFP-11 "G/L4/HW/4F/SD28/CORR NR HW4090"
```

```
|      |      |      |-- 9:4-29 HFP-11 "G/L4/HW/4F/SD29/CORR NR HW4090"
```

```
|      |      |      |-- 9:4-30 HFP-11 "G/L4/HW/4F/SD30/CORR NR S/15"
```

```
|      |      |      |-- 9:4-31 XTRI-R "G/L4/HE/3F/CM31/NR FIRE EXIT"
```

```
|      |      |      |-- Switch ""
```

```
|      |      |      |-- Relay
```

```
|      |      |      |-- 9:4-32 HMS-S/D/M/SA "G/L4/HE/3F/MCP32/NR FIRE EXIT"
```

```
|      |      |      |-- 9:4-33 HTRI-S "G/L4/HE/3F/MM33/NR FIRE EXIT"
```

```
|      |      |      |-- 9:4-34 HFP-11 "G/L4/HE/3F/SD34/LIFT LOBY"
```

```
|      |      |      |-- 9:4-35 HFP-11 "G/L4/HE/3F/SD35/PSG NR ENTRY"
```

```
|      |      |      |-- 9:4-36 HFP-11 "G/L4/HE/3F/SD36/ELECT RM"
```

```
|      |      |      |-- 9:4-37 HTRI-R "G/L4/HE/3F/CM37/AHU RM"
```

```
|      |      |      |-- Switch ""
```

```
|      |      |      |-- Relay
```

```
|      |      |      |-- 9:4-38 HFP-11 "G/L4/HE/3F/SD38/AHU RM"
```

```
|      |      |      |-- 9:4-39 HFP-11 "G/L4/HE/3F/SD39/AFC SMALL PASSAG"
```

```
|      |      |      |-- 9:4-40 HFP-11 "G/L4/HE/3F/SD40/SMALL PASSAGE"
```

```
|      |      |      |-- 9:4-41 HTRI-R "G/L4/HE/3F/CM41/LIFT LOBY"
```

```
|      |      |      |-- Switch ""
```

```
|      |      |      |-- Relay
```

```
|      |      |      |-- 9:4-42 HMS-S/D/M/SA "G/L4/HW/3F/MCP42/LIFT LOBY"
```

```
|      |      |      |-- 9:4-43 HTRI-S "G/L4/HW/3F/MM43/LIFT LOBY"
```

```
|      |      |      |-- 9:4-44 HFP-11 "G/L4/HW/3F/SD44/LIFT LOBY"
```

```
|      |      |      |-- 9:4-46 HTRI-R "G/L4/HW/3F/CM46/AHU RM"
```

```
|      |      |      |-- Switch ""
```

```
|      |      |      |-- Relay
```

```
|      |      |      |-- 9:4-47 HFP-11 "G/L4/HW/3F/SD47/AHU RM"
```

```
|      |      |      |-- 9:4-48 HFP-11 "G/L4/HW/3F/SD48/ELECT RM"
```

```
|      |      |      |-- 9:4-49 HFP-11 "G/L4/HW/3F/SD49/SMALL PASSAGE"
```

```
|      |      |      |-- 9:4-50 HFP-11 "G/L4/HW/3F/SD50/SMALL PASSAGE"
```

```
|      |      |      |-- 9:4-57 HTRI-S "G/L4/HE/4F/MM57/HE3011"
```

```
|      |      |      |-- 9:4-58 HTRI-S "G/L4/HW/3F/MM58/HW3011"
```

```
|      |      |      |-- 9:4-59 HTRI-S "G/L4/HW/3F/MM59/HW3013"
```

```
|      |      |      |-- 9:4-63 HTRI-S "G/L4/4F/MM63/HW4080"
```

```
|      |      |      |-- 9:4-64 HTRI-S "G/L4/4F/MM64/HW4070"
```

```
|      |      |      |-- 9:4-66 HTRI-S "G/L4/4F/MM66/HE4100"
```

```
|      |      |      |-- 9:4-67 HTRI-S "G/L4/4F/MM67/HE4010"
```

```
|      |      |      |-- 9:4-69 HTRI-S "G/L4/4F/MM69/HE4020"
```

```
|      |      |      |-- 9:4-70 HTRI-S "G/L4/4F/MM70/HW4100"
```

```
|      |      |      |-- 9:4-71 HTRI-S "G/L4/4F/MM71/HE4080"
```

```
|      |      |      |-- 9:4-72 XTRI-S "G/L4/4F/MM72/HE4040"
```

```
|      |      |      |-- 9:4-74 HTRI-S "G/L4/4F/MM74/HE4050"
```

```
|      |      |      |-- 9:4-75 HTRI-S "G/L4/4F/MM75/HE4061"
```

```
|      |      |      |-- 9:4-77 HTRI-S "G/L4/4F/MM77/HE4070"
```


9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:4 XDLC "XDLC @ address L4"

```
|      |      |  |-- 9:4-78 HFP-11 "G/L4/HE4030/SD78/Main cab1"
|      |      |  |-- 9:4-79 HFP-11 "G/L4/HE4030/SD79/Main cab2"
|      |      |  |-- 9:4-80 HFP-11 "G/L4/HE4030/SD80/Accounts cab"
|      |      |  |-- 9:4-81 HFP-11 "G/L4/HE4030/SD81/Psg nr MC2"
|      |      |  |-- 9:4-82 HFP-11 "G/L4/HE4030/SD82/Pantry"
|      |      |  |-- 9:4-83 HTRI-R "G/L4/HE4030/CM83/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:4-84 HMS-S/D/M/SA "G/L4/HE4030/MCP84/Entry Psg"
|      |      |  |-- 9:4-85 HFP-11 "G/L4/HE4090/SD85/Main cab"
|      |      |  |-- 9:4-86 HFP-11 "G/L4/HE4090/SD86/Accounts cab"
|      |      |  |-- 9:4-87 HFP-11 "G/L4/HE4090/SD87/Cab 1"
|      |      |  |-- 9:4-88 HFP-11 "G/L4/HE4090/SD88/Entry Psg"
|      |      |  |-- 9:4-89 HFPT-11 "G/L4/HE4090/HD89/Pantry"
|      |      |  |-- 9:4-90 HTRI-R "G/L4/HE4090/CM90/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:4-91 HMS-S/D/M/SA "G/L4/HE4090/MCP91/Entry Psg"
|      |      |  |-- 9:4-120 HFP-11 "G/L4/HW4010A/SD120/Main cab"
|      |      |  |-- 9:4-121 HTRI-R "G/L4/HW4010A/CM121/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:4-122 HMS-S/D/M/SA "G/L4/HW4010A/MCP122/Entry Psg"
|      |      |  |-- 9:4-136 HFP-11 "G/L4/HW4110/SD136/Assorter cab"
|      |      |  |-- 9:4-137 HFP-11 "G/L4/HW4110/SD137/Main cab"
|      |      |  |-- 9:4-138 HFP-11 "G/L4/HW4110/SD138/Cab 1"
|      |      |  |-- 9:4-139 HFP-11 "G/L4/HW4110/SD139/Cab 2"
|      |      |  |-- 9:4-140 HFP-11 "G/L4/HW4110/SD140/Entry Psg"
|      |      |  |-- 9:4-141 HTRI-R "G/L4/HW4110/CM141/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:4-142 HMS-S/D/M/SA "G/L4/HW4110/MCP142/Entry Psg"
|      |      |  |-- 9:4-148 HFP-11 "G/L4/HW4090/SD148/Main cab"
|      |      |  |-- 9:4-149 HFP-11 "G/L4/HW4090/SD149/Accounts cab1"
|      |      |  |-- 9:4-150 HFP-11 "G/L4/HW4090/SD150/Accounts cab2"
|      |      |  |-- 9:4-151 HFP-11 "G/L4/HW4090/SD151/Entry dr Psg"
|      |      |  |-- 9:4-152 HTRI-R "G/L4/HW4090/CM152/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |  |-- 9:4-153 HMS-S/D/M/SA "G/L4/HW4090/MCP153/Entry dr Psg"
|      |      |  |-- 9:4-160 HFP-11 "G/L4/HW4010/SD160/Store rm"
|      |      |  |-- 9:4-161 HFP-11 "G/L4/HW4010/SD161/IT Dept"
|      |      |  |-- 9:4-162 HFP-11 "G/L4/HW4010/SD162/Accounts cab1"
|      |      |  |-- 9:4-163 HFP-11 "G/L4/HW4010/SD163/Accounts cab2"
|      |      |  |-- 9:4-164 HFP-11 "G/L4/HW4010/SD164/Pantry"
|      |      |  |-- 9:4-165 HFP-11 "G/L4/HW4010/SD165/Psg nr Pantry"
|      |      |  |-- 9:4-166 HFP-11 "G/L4/HW4010/SD166/Psg nr Recepti"
|      |      |  |-- 9:4-167 HFP-11 "G/L4/HW4010/SD167/Reception"
|      |      |  |-- 9:4-168 HFP-11 "G/L4/HW4010/SD168/Entry dr"
|      |      |  |-- 9:4-169 HFP-11 "G/L4/HW4010/SD169/Psg nr MC 1"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:4 XDLC "XDLC @ address L4"

```
|      |      |      |-- 9:4-170 HFP-11 "G/L4/HW4010/SD170/Psg nr MC 2"
|      |      |      |-- 9:4-171 HFP-11 "G/L4/HW4010/SD171/Psg nr MC 3"
|      |      |      |-- 9:4-172 HFP-11 "G/L4/HW4010/SD172/Main cab3"
|      |      |      |-- 9:4-173 HFP-11 "G/L4/HW4010/SD173/Buyer rm"
|      |      |      |-- 9:4-174 HFP-11 "G/L4/HW4010/SD174/Weight rm"
|      |      |      |-- 9:4-175 HFP-11 "G/L4/HW4010/SD175/Main cab2"
|      |      |      |-- 9:4-176 HFP-11 "G/L4/HW4010/SD176/Conference rm"
|      |      |      |-- 9:4-177 HFP-11 "G/L4/HW4010/SD177/main cab1"
|      |      |      |-- 9:4-178 HFP-11 "G/L4/HW4010/SD178/main cab2"
|      |      |      |-- 9:4-179 HFP-11 "G/L4/HW4010/SD179/Assorter cab1"
|      |      |      |-- 9:4-180 HFP-11 "G/L4/HW4010/SD180/Assorter cab2"
|      |      |      |-- 9:4-181 HFP-11 "G/L4/HW4010/SD181/Assorter cab3"
|      |      |      |-- 9:4-182 HTRI-R "G/L4/HW4010/CM182/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 9:4-183 HMS-S/D/M/SA "G/L4/HW4010/MCP183/Entry dr Psg"
|      |      |      |-- 9:5 XDLC "XDLC @ address L5"
|      |      |      |      |-- 9:5-1 HTRI-R "G/L5/W/6F/CM1/AHU RM "
|      |      |      |      |      |-- Switch ""
|      |      |      |      |      |-- Relay
|      |      |      |      |-- 9:5-2 HFP-11 "G/L5/W/6F/SD2/AHU RM "
|      |      |      |      |      |-- 9:5-3 HFP-11 "G/L5/W/6F/SD3/PASSAGE AREA"
|      |      |      |      |      |-- 9:5-4 HTRI-R "G/L5/W/6F/CM4/LIFT LOBY"
|      |      |      |      |      |      |-- Switch ""
|      |      |      |      |      |      |-- Relay
|      |      |      |      |-- 9:5-5 HMS-S/D/M/SA "G/L5/W/6F/MCP5/LIFT LOBY"
|      |      |      |      |      |-- 9:5-6 HTRI-S "G/L5/W/6F/MM6/LIFT LOBY"
|      |      |      |      |      |-- 9:5-7 HFP-11 "G/L5/W/6F/SD7/LIFT LOBBY"
|      |      |      |      |      |-- 9:5-8 HFP-11 "G/L5/W/6F/SD8/LIFT LOBBY"
|      |      |      |      |      |-- 9:5-9 HFP-11 "G/L5/W/6F/SD9/CORR NR GW 6021"
|      |      |      |      |      |-- 9:5-10 HFP-11 "G/L5/W/6F/SD10/CORR NR GW 6021"
|      |      |      |      |      |-- 9:5-11 HFP-11 "G/L5/W/6F/SD11/CORR NR GW 6023"
|      |      |      |      |      |-- 9:5-12 HFP-11 "G/L5/W/6F/SD12/CORR NR GW 6023"
|      |      |      |      |      |-- 9:5-13 HTRI-R "G/L5/W/6F/CM13/DR RELEASE"
|      |      |      |      |      |      |-- Switch ""
|      |      |      |      |      |      |-- Relay
|      |      |      |      |-- 9:5-14 HFP-11 "G/L5/W/6F/SD14/ELECT RM"
|      |      |      |      |      |-- 9:5-15 HFP-11 "G/L5/W/6F/SD15/CORR NR GW 6090"
|      |      |      |      |      |-- 9:5-16 HFP-11 "G/L5/W/6F/SD16/CORR NR GW 6090"
|      |      |      |      |      |-- 9:5-17 FDOT421 "G/L5/W/6F/SD17/CORR NR GW 6032"
|      |      |      |      |      |-- 9:5-18 HFP-11 "G/L5/W/6F/SD18/CORR NR GW 6070"
|      |      |      |      |      |-- 9:5-19 HFP-11 "G/L5/W/6F/SD19/CORR NR GW 6070"
|      |      |      |      |      |-- 9:5-20 HMS-S/D/M/SA "G/L5/E/6F/MCP20/LIFT LOBY"
|      |      |      |      |      |-- 9:5-21 HTRI-S "G/L5/E/6F/MM21/LIFT LOBBY"
|      |      |      |      |      |-- 9:5-22 HFP-11 "G/L5/E/6F/SD22/LIFT LOBBY"
|      |      |      |      |      |-- 9:5-23 HFP-11 "G/L5/E/6F/SD23/LIFT LOBBY"
|      |      |      |      |      |-- 9:5-24 HTRI-R "G/L5/E/6F/CM24/DR RELEASE"
|      |      |      |      |      |      |-- Switch ""
|      |      |      |      |      |      |-- Relay
|      |      |      |      |-- 9:5-25 HFP-11 "G/L5/E/6F/SD25/ELECT RM"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:5 XDLC "XDLC @ address L5"

```
|      |      |-- 9:5-26 HTRI-R "G/L5/E/6F/CM26/AHU RM "
```

```
|      |      |  |-- Switch ""
```

```
|      |      |  |-- Relay
```

```
|      |      |-- 9:5-27 HFP-11 "G/L5/E/6F/SD27/AHU RM "
```

```
|      |      |-- 9:5-28 HFP-11 "G/L5/E/6F/SD28/CORR NR GE 6010"
```

```
|      |      |-- 9:5-29 FDOT421 "G/L5/E/6F/SD29/CORR NR GE 6010"
```

```
|      |      |-- 9:5-30 HFP-11 "G/L5/E/6F/SD30/CORR NR GW 6051"
```

```
|      |      |-- 9:5-31 FDOT421 "G/L5/E/6F/SD31/CORR NR GW 6051"
```

```
|      |      |-- 9:5-32 HFP-11 "G/L5/E/6F/SD32/CORR NR GW 6042"
```

```
|      |      |-- 9:5-33 FDOT421 "G/L5/E/6F/SD33/CORR NR GW 6042"
```

```
|      |      |-- 9:5-34 FDOT421 "G/L5/6F/SD34/CORR NR GE6051"
```

```
|      |      |-- 9:5-35 HFP-11 "G/L5/E/6F/SD35/CORR NR GE 6031"
```

```
|      |      |-- 9:5-36 FDOT421 "G/L5/E/6F/SD36/CORR NR GE 6031"
```

```
|      |      |-- 9:5-37 HFP-11 "G/L5/E/6F/SD37/CORR NR GE 6051"
```

```
|      |      |-- 9:5-38 FDOT421 "G/L5/E/6F/SD38/AFC COR NR HW6061"
```

```
|      |      |-- 9:5-39 HFP-11 "G/L5/E/6F/SD39/CORR NR GE 6062"
```

```
|      |      |-- 9:5-40 HTRI-R "G/L5/W/5F/CM40/AHU RM "
```

```
|      |      |  |-- Switch ""
```

```
|      |      |  |-- Relay
```

```
|      |      |-- 9:5-41 HFP-11 "G/L5/W/5F/SD41/AHU RM "
```

```
|      |      |-- 9:5-42 HTRI-S "G/L5/5F/MM42/GE5040"
```

```
|      |      |-- 9:5-43 HTRI-R "G/L5/W/5F/CM43/DR RELEASE"
```

```
|      |      |  |-- Switch ""
```

```
|      |      |  |-- Relay
```

```
|      |      |-- 9:5-44 HFP-11 "G/L5/W/5F/SD44/LIFT LOBBY"
```

```
|      |      |-- 9:5-45 HFP-11 "G/L5/W/5F/SD45/LIFT LOBBY"
```

```
|      |      |-- 9:5-46 FDOT421 "G/L5/W/5F/SD46/CORR NR GW 5010"
```

```
|      |      |-- 9:5-47 HFP-11 "G/L5/W/5F/SD47/CORR NR GW 5010"
```

```
|      |      |-- 9:5-48 HTRI-R "G/L5/W/5F/CM48/DR RELEASE"
```

```
|      |      |  |-- Switch ""
```

```
|      |      |  |-- Relay
```

```
|      |      |-- 9:5-49 HFP-11 "G/L5/W/5F/SD49/ELECT RM"
```

```
|      |      |-- 9:5-50 FDOT421 "G/L5/W/5F/SD50/CORR NR S/10"
```

```
|      |      |-- 9:5-51 HFP-11 "G/L5/W/5F/SD51/CORR NR S/10"
```

```
|      |      |-- 9:5-52 HFP-11 "G/L5/W/5F/SD52/CORR NR GW5050"
```

```
|      |      |-- 9:5-53 HFP-11 "G/L5/W/5F/SD53/CORR NR GW5023"
```

```
|      |      |-- 9:5-54 HFP-11 "G/L5/W/5F/SD54/CORR NR GW5023"
```

```
|      |      |-- 9:5-55 HTRI-R "G/L5/E/5F/CM55/LIFT LOBBY"
```

```
|      |      |  |-- Switch ""
```

```
|      |      |  |-- Relay
```

```
|      |      |-- 9:5-56 HMS-S/D/M/SA "G/L5/E/5F/MCP56/LIFT LOBBY"
```

```
|      |      |-- 9:5-57 HTRI-S "G/L5/E/5F/MM57/LIFT LOBBY"
```

```
|      |      |-- 9:5-58 HFP-11 "G/L5/E/5F/SD58/LIFT LOBBY"
```

```
|      |      |-- 9:5-59 HFP-11 "G/L5/E/5F/SD59/LIFT LOBBY"
```

```
|      |      |-- 9:5-60 HTRI-R "G/L5/E/5F/CM60/DR RELEASE"
```

```
|      |      |  |-- Switch ""
```

```
|      |      |  |-- Relay
```

```
|      |      |-- 9:5-61 HFP-11 "G/L5/E/5F/SD61/ELECT RM"
```

```
|      |      |-- 9:5-62 HTRI-R "G/L5/E/5F/CM62/AHU RM "
```

```
|      |      |  |-- Switch ""
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:5 XDLC "XDLC @ address L5"

9:5-62 HTRI-R "G/L5/E/5F/CM62/AHU RM "

```
|      |      | |-- Relay
|      |      | |-- 9:5-63 HFP-11 "G/L5/E/5F/SD63/AHU RM "
|      |      | |-- 9:5-64 HFP-11 "G/L5/E/5F/SD64/CORR NR GE 5011"
|      |      | |-- 9:5-65 HFP-11 "G/L5/E/5F/SD65/CORR NR GE 5011"
|      |      | |-- 9:5-66 HFP-11 "G/L5/E/5F/SD66/MIDDLE PASSAGE"
|      |      | |-- 9:5-67 HFP-11 "G/L5/E/5F/SD67/MIDDLE PASSAGE"
|      |      | |-- 9:5-68 HFP-11 "G/L5/E/5F/SD68/MIDDLE PASSAGE"
|      |      | |-- 9:5-69 HFP-11 "G/L5/E/5F/SD69/CORR NR S/12"
|      |      | |-- 9:5-70 HFP-11 "G/L5/E/5F/SD70/CORR NR GE 5021"
|      |      | |-- 9:5-71 HFP-11 "G/L5/E/5F/SD71/CORR NR GE 5021"
|      |      | |-- 9:5-72 HFP-11 "G/L5/E/5F/SD72/CORR NR GE 5021"
|      |      | |-- 9:5-73 HFP-11 "G/L5/E/5F/SD73/CORR NR GE 5030"
|      |      | |-- 9:5-74 HFP-11 "G/L5/E/5F/SD74/CORR NR GE 5030"
|      |      | |-- 9:5-75 HFP-11 "G/L5/E/5F/SD75/CORR NR GE 5040"
|      |      | |-- 9:5-76 HFP-11 "G/L5/E/5F/SD76/CORR NR HW 5012"
|      |      | |-- 9:5-77 HFP-11 "G/L5/E/5F/SD77/CORR NR HW 5012"
|      |      | |-- 9:5-78 HTRI-R "G/L5/E/5F/CM78/LIFT LOBBY"
|      |      | |-- Switch ""
|      |      | |-- Relay
|      |      | |-- 9:5-79 HMS-S/D/M/SA "G/L5/E/5F/MCP79/LIFT LOBBY"
|      |      | |-- 9:5-82 XTRI-S "G/L5/W/6F/MM82/GW6080"
|      |      | |-- 9:5-83 XTRI-S "G/L5/W/6F/MM83/GW6090"
|      |      | |-- 9:5-85 XTRI-S "G/L5/6F/MM85/GW6110"
|      |      | |-- 9:5-86 HTRI-S "G/L5/HW/5F/MM86/HW5011B"
|      |      | |-- 9:5-88 XTRI-S "G/L5/W/6F/MM088/GW6021"
|      |      | |-- 9:5-89 HTRI-S "G/L5/E/5F/MM89/GE5010A"
|      |      | |-- 9:5-91 XTRI-S "G/L5/W/6F/MM91/GW6023"
|      |      | |-- 9:5-96 XTRI-S "G/L5/W/6F/MM96/GW6041"
|      |      | |-- 9:5-97 XTRI-S "G/L5/W/6F/MM97/GW6060"
|      |      | |-- 9:5-102 HTRI-S "G/L5/E/6F/MM102/GE6052"
|      |      | |-- 9:5-103 XTRI-S "G/L5/E/5F/MM103/GE5021A"
|      |      | |-- 9:5-104 XTRI-S "G/L5/HW/6F/MM104/HW6061"
|      |      | |-- 9:5-107 XTRI-S "G/L5/E/6F/MM107/GE6010"
|      |      | |-- 9:5-110 HTRI-S "G/L5/E/5F/MM110/GE5050"
|      |      | |-- 9:5-112 HTRI-S "G/L5/E/5F/MM112/GE5030"
|      |      | |-- 9:5-114 HTRI-S "G/L5/E/5F/MM114/GE5022"
|      |      | |-- 9:5-115 HTRI-S "G/L5/E/5F/MM115/GE5070"
|      |      | |-- 9:5-116 HTRI-S "G/L5/E/5F/MM116/GE5021"
|      |      | |-- 9:5-117 HTRI-S "G/L5/E/5F/MM117/GE5011"
|      |      | |-- 9:5-118 HTRI-S "G/L5/E/5F/MM118/GE5012"
|      |      | |-- 9:5-119 HTRI-S "G/L5/E/5F/MM119/GE5031"
|      |      | |-- 9:5-120 HTRI-S "G/L5/W/5F/MM120/GW5032"
|      |      | |-- 9:5-121 HTRI-S "G/L5/W/5F/MM121/GW5033"
|      |      | |-- 9:5-122 HTRI-S "G/L5/W/5F/MM122/GW5040"
|      |      | |-- 9:5-124 HTRI-S "G/L5/W/5F/MM124/GW5050"
|      |      | |-- 9:5-125 HTRI-S "G/L5/W/5F/MM125/GW5060"
|      |      | |-- 9:5-126 HTRI-S "G/L5/W/5F/MM126/GW5010"
|      |      | |-- 9:5-127 HFP-11 "G/L5/HW5012/SD127/Entry Area"
|      |      | |-- 9:5-128 HFP-11 "G/L5/HW5012/SD128/Reception cab"
|      |      | |-- 9:5-129 HFP-11 "G/L5/HW5012/SD129/Chairmen cab"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:5 XDLC "XDLC @ address L5"

```
|      |      |-- 9:5-130 HFP-11 "G/L5/HW5012/SD130/Director rm"
|      |      |-- 9:5-131 HFP-11 "G/L5/HW5012/SD131/Director rm"
|      |      |-- 9:5-132 HFP-11 "G/L5/HW5012/SD132/cab 5"
|      |      |-- 9:5-133 HFP-11 "G/L5/HW5012/SD133/cab 4"
|      |      |-- 9:5-134 HFP-11 "G/L5/HW5012/SD134/cab 6"
|      |      |-- 9:5-135 HFP-11 "G/L5/HW5012/SD135/cab 7"
|      |      |-- 9:5-136 HFP-11 "G/L5/HW5012/SD136/cab 8"
|      |      |-- 9:5-137 HFP-11 "G/L5/HW5012/SD137/cab 8"
|      |      |-- 9:5-138 HFP-11 "G/L5/HW5012/SD138/cab 8"
|      |      |-- 9:5-139 HFP-11 "G/L5/HW5012/SD139/cab 9"
|      |      |-- 9:5-140 HFP-11 "G/L5/G/HW5012/SD140/cab 10"
|      |      |-- 9:5-141 HFP-11 "G/L5/G/HW5012/SD141/cab 11"
|      |      |-- 9:5-142 HFP-11 "G/L5/G/HW5012/SD142/Server rm"
|      |      |-- 9:5-143 HFP-11 "G/L5/G/HW5012/SD143/Pantry"
|      |      |-- 9:5-144 HFP-11 "G/L5/HW5012/SD144/Pantry"
|      |      |-- 9:5-145 HFP-11 "G/L5/HW5012/SD145/Cab 13"
|      |      |-- 9:5-146 HFP-11 "G/L5/HW5012/SD146/Cab 14"
|      |      |-- 9:5-147 HFP-11 "G/L5/HW5012/SD147/Cab 15"
|      |      |-- 9:5-148 HFP-11 "G/L5/HW5012/SD148/Psg nr cab 8"
|      |      |-- 9:5-149 HTRI-R "G/L5/HW5012/CM149/Psg nr cab 9"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-150 HMS-S/D/M/SA "G/L5/HW5012/MCP150/Psg nr cab 3"
|      |      |-- 9:5-151 HTRI-R "G/L5/HW5012/CM151/Psg nr cab 3"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-152 HMS-S/D/M/SA "G/L5/HW5012/MCP152/Main Entry"
|      |      |-- 9:5-153 HTRI-R "G/L5/HW5012/CM153/Entry dr psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-154 HFP-11 "G/L5/GW6010/SD154/Cab 2"
|      |      |-- 9:5-155 HFP-11 "G/L5/GW6010/SD155/Cab 3"
|      |      |-- 9:5-156 HFP-11 "G/L5/GW6010/SD156/Entry Psg"
|      |      |-- 9:5-157 HTRI-R "G/L5/GW6010/CM157/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-158 HMS-S/D/M/SA "G/L5/GW6010/MCP158/Entry Psg"
|      |      |-- 9:5-159 HFP-11 "G/L5/GW6010/SD159/Cab 1"
|      |      |-- 9:5-160 HFP-11 "G/L5/GW6032/SD160/Psg Nr Cab 2"
|      |      |-- 9:5-161 HFP-11 "G/L5/GW6032/SD161/Cab 5"
|      |      |-- 9:5-162 HFP-11 "G/L5/GW6032/SD162/Cab 4"
|      |      |-- 9:5-163 HFP-11 "G/L5/GW6032/SD163/Strong RM"
|      |      |-- 9:5-164 HFP-11 "G/L5/GW6032/SD164/Server RM"
|      |      |-- 9:5-165 HFP-11 "G/L5/GW6052/SD165/Main cab"
|      |      |-- 9:5-166 HFP-11 "G/L5/GW6052/SD166/Assorter cab"
|      |      |-- 9:5-167 HFP-11 "G/L5/GW6052/SD167/Accounts cab"
|      |      |-- 9:5-168 HFP-11 "G/L5/GW6052/SD168/Entry dr Psg"
|      |      |-- 9:5-169 HTRI-R "G/L5/GW6052/CM169/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:5 XDLC "XDLC @ address L5"

```
|      |      |-- 9:5-170 HMS-S/D/M/SA "G/L5/GW6052/MCP170/Entry dr Psg"
|      |      |-- 9:5-171 HFP-11 "G/L5/GW6032/SD171/Polishing cab"
|      |      |-- 9:5-172 HFP-11 "G/L5/GW6032/SD172/Cab 1"
|      |      |-- 9:5-173 HFP-11 "G/L5/GW6032/SD173/Conference rm"
|      |      |-- 9:5-174 HFP-11 "G/L5/GW6032/SD174/Main cab"
|      |      |-- 9:5-175 HFP-11 "G/L5/GW6032/SD175/Assorter cab"
|      |      |-- 9:5-176 HFP-11 "G/L5/GW6032/SD176/Accounts cab"
|      |      |-- 9:5-177 HFP-11 "G/L5/GW6032/SD177/Dinning rm"
|      |      |-- 9:5-178 HFP-11 "G/L5/GW6032/SD178/Psg nr dinning"
|      |      |-- 9:5-179 HFPT-11 "G/L5/GW6032/HD179/Pantry"
|      |      |-- 9:5-180 HFP-11 "G/L5/GW6032/SD180/Reception Psg"
|      |      |-- 9:5-181 HFP-11 "G/L5/GW6032/SD181/Entry dr Psg"
|      |      |-- 9:5-182 HTRI-R "G/L5/GW6032/CM182/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-183 HMS-S/D/M/SA "G/L5/GW6032/MCP183/Entry dr Psg"
|      |      |-- 9:5-184 HFPT-11 "G/L5/GE6031/HD184/Pantry"
|      |      |-- 9:5-185 HFP-11 "G/L5/GE6031/SD185/Assorter cab1"
|      |      |-- 9:5-186 HFP-11 "G/L5/GE6031/SD186/Assorter cab1"
|      |      |-- 9:5-187 HFP-11 "G/L5/GE6031/SD187/Assorter cab2"
|      |      |-- 9:5-188 HFP-11 "G/L5/GE6031/SD188/Dineshbhai cab"
|      |      |-- 9:5-190 HFP-11 "G/L5/GE6031/SD190/Account cab"
|      |      |-- 9:5-191 HFP-11 "G/L5/GE6031/SD191/Rohanbhai cab"
|      |      |-- 9:5-192 HFP-11 "G/L5/GE6031/SD192/Amritlalbhai c"
|      |      |-- 9:5-193 HFP-11 "G/L5/GE6031/SD193/Buyer cab1"
|      |      |-- 9:5-194 HFP-11 "G/L5/GE6031/SD194/Buyer cab2"
|      |      |-- 9:5-195 HFP-11 "G/L5/GE6031/SD195/Buyer cab3"
|      |      |-- 9:5-197 HFP-11 "G/L5/GE6031/SD197/Psg nr recepti"
|      |      |-- 9:5-198 HFP-11 "G/L5/GE6031/SD198/Entry dr Psg"
|      |      |-- 9:5-199 HTRI-R "G/L5/GE6031/CM199/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-200 HMS-S/D/M/SA "G/L5/GE6031/MCP200/Entry dr Psg"
|      |      |-- 9:5-201 HFP-11 "G/L5/GW6051/SD201/Main cab"
|      |      |-- 9:5-202 HFP-11 "G/L5/GW6051/SD202/Cab 2"
|      |      |-- 9:5-203 HFP-11 "G/L5/GW6051/SD203/Pantry"
|      |      |-- 9:5-204 HFP-11 "G/L5/GW6051/SD204/Psg nr Main ca"
|      |      |-- 9:5-205 HFP-11 "G/L5/GW6051/SD205/Reception"
|      |      |-- 9:5-206 HTRI-R "G/L5/GW6051/CM206/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-207 HMS-S/D/M/SA "G/L5/GW6051/MCP207/Entry Psg"
|      |      |-- 9:5-208 HFP-11 "G/L5/GE6051/SD208/Main cab1"
|      |      |-- 9:5-209 HFP-11 "G/L5/GE6051/SD209/Main cab2"
|      |      |-- 9:5-210 HFP-11 "G/L5/GE6051/SD210/Cab 1"
|      |      |-- 9:5-211 HFP-11 "G/L5/GE6051/SD211/Cab 2"
|      |      |-- 9:5-212 HFP-11 "G/L5/GE6051/SD212/Cab 3"
|      |      |-- 9:5-213 HFP-11 "G/L5/GE6051/SD213/Cab 4"
|      |      |-- 9:5-214 HFP-11 "G/L5/GE6051/SD214/Assorter cab 1"
|      |      |-- 9:5-215 HFP-11 "G/L5/GE6051/SD215/Assorter cab 2"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:5 XDLC "XDLC @ address L5"

```
|      |      |-- 9:5-216 HFP-11 "G/L5/GE6051/SD216/Cab 5"
|      |      |-- 9:5-217 HFP-11 "G/L5/GE6051/SD217/Pantry Psg"
|      |      |-- 9:5-218 HFP-11 "G/L5/GE6051/SD218/Reception Psg"
|      |      |-- 9:5-219 HFPT-11 "G/L5/GE6051/HD219/Pantry"
|      |      |-- 9:5-220 HTRI-R "G/L5/GE6051/CM220/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-221 HMS-S/D/M/SA "G/L5/GE6051/MCP221/Entry Psg"
|      |      |-- 9:5-222 HFP-11 "G/L5/GW6100/SD222/Main cab"
|      |      |-- 9:5-223 HFP-11 "G/L5/GW6100/SD223/Account cab"
|      |      |-- 9:5-224 HFP-11 "G/L5/GW6100/SD224/Assorter cab"
|      |      |-- 9:5-225 HTRI-R "G/L5/GW6100/CM225/Entry Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-226 HMS-S/D/M/SA "G/L5/GW6100/MCP226/Entry Psg"
|      |      |-- 9:5-227 HFP-11 "G/L5/GW6010/SD227/Entry Psg"
|      |      |-- 9:5-228 HFP-11 "G/L5/FW5131/SD228/Assorter cab"
|      |      |-- 9:5-229 HFP-11 "G/L5/FW5131/SD229/Assorter cab"
|      |      |-- 9:5-230 HFP-11 "G/L5/FW5131/SD230/Psg nr Pantry"
|      |      |-- 9:5-231 HFP-11 "G/L5/FW5131/SD231/Accounts cab 1"
|      |      |-- 9:5-232 HFP-11 "G/L5/FW5131/SD232/Main cab 1"
|      |      |-- 9:5-233 HFP-11 "G/L5/FW5131/SD233/Main cab 2"
|      |      |-- 9:5-234 HFP-11 "G/L5/FW5131/SD234/Main cab 2"
|      |      |-- 9:5-235 HFP-11 "G/L5/FW5131/SD235/Psg nr Main ca"
|      |      |-- 9:5-236 HFP-11 "G/L5/FW5131/SD236/Accounts cab 2"
|      |      |-- 9:5-237 HFP-11 "G/L5/FW5131/SD237/Reception cab"
|      |      |-- 9:5-238 HTRI-R "G/L5/FW5131/CM238/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-239 HMS-S/D/M/SA "G/L5/FW5131/MCP239/Entry dr Psg"
|      |      |-- 9:5-240 HFP-11 "G/L5/FW5131/SD240/Pantry"
|      |      |-- 9:5-241 HFP-11 "G/L5/GW6100/SD241/Entry Psg."
|      |      |-- 9:5-242 HFPT-11 "G/L5/GW6100/HD242/Pantry"
|      |      |-- 9:5-243 FDOT421 "G/L5/GW6070/SD243/Main Cabin"
|      |      |-- 9:5-244 HFP-11 "G/L5/GW6070/SD244/Account Cabin""
|      |      |-- 9:5-245 HFP-11 "G/L5/GW6070/SD245/Entry DR Psg"
|      |      |-- 9:5-246 HFPT-11 "G/L5/GW6070/HD246/Pantry"
|      |      |-- 9:5-247 XTRI-R "G/L5/GW6070/CM247/Entry dr Psg"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 9:5-248 HMS-S/D/M/SA "G/L5/GW6070/MCP248/Entry dr Psg"
|      |      |-- 9:5-250 HFP-11 "L5/G/HW5012/SD250/Psg Nr Cab 4"
|      |      |-- 9:5-251 HFP-11 "G/L5/GE6051/SD251/Entry Psg"
|      |      |-- 9:5-252 HMS-S/D/M/SA "G/L5/GE6051/MCP252/Entry Psg"
|      |-- CC-5 "Card Cage 5 Slots"
|      |  |-- 9:6 XDLC "XDLC @ address L6"
|      |  |  |-- 9:6-1 HTRI-R "H/L6/HE/6F/CM1/NR FIRE EXIT"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 9:6-2 HMS-S/D/M/SA "H/L6/HE/6F/MCP2/NR FIRE EXIT"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:6 XDLC "XDLC @ address L6"

```
|      |      |      |-- 9:6-3 HTRI-S "H/L6/HE/6F/MM3/NR FIRE EXIT"
|      |      |      |-- 9:6-4 HFP-11 "H/L6/HE/6F/SD4/LIFT LOBBY"
|      |      |      |-- 9:6-6 HFP-11 "H/L6/HE/6F/SD6/ELECT RM"
|      |      |      |-- 9:6-7 HFP-11 "H/L6/HE/6F/SD7/AHU RM "
|      |      |      |-- 9:6-8 HTRI-R "H/L6/HE/6F/CM8/AHU RM "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-9 HFP-11 "H/L6/HE/6F/SD9/ NR ELECT RM"
|      |      |      |-- 9:6-10 HFP-11 "H/L6/HE/6F/SD10/ NR ELECT RM"
|      |      |      |-- 9:6-11 HFP-11 "H/L6/HE/6F/SD11/CORR NR GW 6030"
|      |      |      |-- 9:6-12 HFP-11 "H/L6/HE/6F/SD12/CORR NR GW 6030"
|      |      |      |-- 9:6-13 HFP-11 "H/L6/HE/6F/SD13/CORR NR GW 6020"
|      |      |      |-- 9:6-14 HTRI-R "H/L6/HW/6F/CM14/NR FIRE EXIT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-15 HMS-S/D/M/SA "H/L6/HW/6F/MCP15/NR FIRE EXIT"
|      |      |      |-- 9:6-16 HFP-11 "H/L6/HW/6F/SD16/CORR NR HW 6010"
|      |      |      |-- 9:6-17 HFP-11 "H/L6/HW/6F/SD17/CORR NR HW 6010"
|      |      |      |-- 9:6-18 HFP-11 "H/L6/HW/6F/SD18/CORR NR HW 6092"
|      |      |      |-- 9:6-19 HFP-11 "H/L6/HW/6F/SD19/CORR NR HW 6092"
|      |      |      |-- 9:6-21 HFP-11 "H/L6/HW/6F/SD21/CORR NR HW6102"
|      |      |      |-- 9:6-22 HTRI-R "H/L6/HW/6F/CM22/AHU RM "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-23 HFP-11 "H/L6/HW/6F/SD23/AHU RM "
|      |      |      |-- 9:6-24 HFP-11 "H/L6/HW/6F/SD24/ELECT RM"
|      |      |      |-- 9:6-25 HTRI-R "H/L6/HW/6F/CM25/DR RELEASE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-26 HTRI-R "H/L6/HW/6F/CM26/FIRE SHAFT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-27 HMS-S/D/M/SA "H/L6/HW/6F/MCP27/FIRE SHAFT"
|      |      |      |-- 9:6-28 HTRI-S "H/L6/HW/6F/MM28/FIRE SHAFT"
|      |      |      |-- 9:6-29 HTRI-R "H/L6/HW/6F/CM29/NR FIRE EXIT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-30 HMS-S/D/M/SA "H/L6/HW/6F/MCP30/NR FIRE EXIT"
|      |      |      |-- 9:6-31 HTRI-S "H/L6/HW/6F/MM31/NR FIRE EXIT"
|      |      |      |-- 9:6-32 HFP-11 "H/L6/HW/6F/SD32/LIFT LOBBY"
|      |      |      |-- 9:6-33 HFP-11 "H/L6/HE/5F/SD33/ELECT RM"
|      |      |      |-- 9:6-34 HTRI-R "H/L6/HE/5F/CM34/AHU RM "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-35 HFP-11 "H/L6/HE/5F/SD35/AHU RM "
|      |      |      |-- 9:6-38 HFP-11 "H/L6/HE/5F/SD38/LIFT LOBBY"
|      |      |      |-- 9:6-40 HTRI-S "H/L6/HW/5F/MM40/NR FIRE EXIT"
|      |      |      |-- 9:6-41 HTRI-R "H/L6/HW/5F/CM41/NR FIRE EXIT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
```


9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:6 XDLC "XDLC @ address L6"

```
|      |      |      |-- 9:6-42 HFP-11 "H/L6/HW/5F/SD42/ELECT RM"
|      |      |      |-- 9:6-43 HTRI-R "H/L6/HW/5F/CM43/AHU RM "
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-44 HFP-11 "H/L6/HW/5F/SD44/AHU RM "
|      |      |      |-- 9:6-45 HFP-11 "H/L6/HW/5F/SD45/SMALL PASSAGE"
|      |      |      |-- 9:6-46 HFP-11 "H/L6/HW/5F/SD46/SMALL PASSAGE"
|      |      |      |-- 9:6-47 HFP-11 "H/L6/HW/5F/SD47/LIFT LOBBY"
|      |      |      |-- 9:6-55 HTRI-S "H/L6/HW/6F/MM55/HW5011"
|      |      |      |-- 9:6-57 HTRI-S "H/L6/HW/6F/MM57/HW6072"
|      |      |      |-- 9:6-58 HTRI-S "H/L6/HW/6F/MM58/HW6102"
|      |      |      |-- 9:6-59 HTRI-S "H/L6/HW/6F/MM59/HW6101"
|      |      |      |-- 9:6-62 HTRI-S "H/L6/HE/6F/MM62/HW6010"
|      |      |      |-- 9:6-63 HTRI-S "H/L6/HE/5F/MM63/HW6092"
|      |      |      |-- 9:6-64 HTRI-S "H/L6/HW/5F/MM64/HW6040"
|      |      |      |-- 9:6-65 HTRI-S "H/L6/HW/5F/MM65/HW6030"
|      |      |      |-- 9:6-68 HTRI-S "H/L6/HW/5F/MM68/HE5011"
|      |      |      |-- 9:6-69 HFP-11 "H/L6/G/HW6010A/SD69/Main cab"
|      |      |      |-- 9:6-70 HFP-11 "H/L6/G/HW6010A/SD70/Main cab"
|      |      |      |-- 9:6-71 HTRI-R "H/L6/G/HW6010A/CM71/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-72 HMS-S/D/M/SA "H/L6/G/HW6010A/MCP72/Entry Psg"
|      |      |      |-- 9:6-73 HFP-11 "H/L6/G/HW6091/SD73/Reception"
|      |      |      |-- 9:6-74 HFP-11 "H/L6/G/HW6091/SD74/Main cab"
|      |      |      |-- 9:6-75 HFP-11 "H/L6/G/HW6091/SD75/Main cab"
|      |      |      |-- 9:6-76 HFP-11 "H/L6/G/HW6091/SD76/Psg nr Pantry"
|      |      |      |-- 9:6-77 HTRI-R "H/L6/G/HW6091/CM77/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:6-78 HMS-S/D/M/SA "H/L6/G/HW6091/MCP78/Entry Psg"
|      |      |      |-- 9:7 XDLC "XDLC @ address L7"
|      |      |      |-- 9:7-1 HFP-11 "G/L7/W/9F/SD1/AHU RM"
|      |      |      |-- 9:7-2 HTRI-R "G/L7/W/9F/CM2/AHU RM"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:7-3 HTRI-R "G/L7/W/9F/CM3/NR FIRE EXIT"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:7-4 HMS-S/D/M/SA "G/L7/W/9F/MCP4/NR FIRE EXIT"
|      |      |      |-- 9:7-5 HTRI-S "G/L7/W/9F/MM5/NR FIRE EXIT"
|      |      |      |-- 9:7-6 HFP-11 "G/L7/W/9F/SD6/LIFT LOBBY"
|      |      |      |-- 9:7-7 HFP-11 "G/L7/W/9F/SD7/LIFT LOBBY"
|      |      |      |-- 9:7-8 HFP-11 "G/L7/W/9F/SD8/CORR NR GW 9020"
|      |      |      |-- 9:7-9 HFP-11 "G/L7/W/9F/SD9/CORR NR GW 9020"
|      |      |      |-- 9:7-10 HTRI-R "G/L7/W/9F/CM10/DR RELEASE"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:7-11 HFP-11 "G/L7/W/9F/SD11/ELECT RM"
|      |      |      |-- 9:7-12 HFP-11 "G/L7/W/9F/SD12/CORR NR GW 9030"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:7 XDLC "XDLC @ address L7"

```
|      |      |      |  -- 9:7-13 HFP-11 "G/L7/W/9F/SD13/CORR NR GW 9030"
|      |      |      |  -- 9:7-14 HTRI-R "G/L7/W/9F/CM14/NR MID FIRE SHAF"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 9:7-15 HMS-S/D/M/SA "G/L7/W/9F/MCP15/NR MID FIRE SHF"
|      |      |      |  -- 9:7-16 HFP-11 "G/L7/W/9F/SD16/CORR NR GE 9010"
|      |      |      |  -- 9:7-17 HFP-11 "G/L7/W/9F/SD17/CORR NR GE 9010"
|      |      |      |  -- 9:7-18 HFP-11 "G/L7/W/9F/SD18/CORR NR GE 9030"
|      |      |      |  -- 9:7-19 HFP-11 "G/L7/W/9F/SD19/CORR NR GE 9050"
|      |      |      |  -- 9:7-20 HFP-11 "G/L7/W/9F/SD20/CORR NR GE 9050"
|      |      |      |  -- 9:7-21 HFP-11 "G/L7/W/9F/SD21/CORR NR GE9120"
|      |      |      |  -- 9:7-22 HFP-11 "G/L7/W/9F/SD22/CORR NR GE9120"
|      |      |      |  -- 9:7-23 HFP-11 "G/L7/W/9F/SD23/AHU RM"
|      |      |      |  -- 9:7-24 HTRI-R "G/L7/W/9F/CM24/AHU RM"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 9:7-25 HFP-11 "G/L7/W/9F/SD25/ELECT RM"
|      |      |      |  -- 9:7-26 HTRI-R "G/L7/W/9F/CM26/NR FIRE EXIT"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 9:7-27 HFP-11 "G/L7/W/9F/SD27/LIFT LOBBY"
|      |      |      |  -- 9:7-28 HFP-11 "G/L7/W/9F/SD28/LIFT LOBBY"
|      |      |      |  -- 9:7-29 XTRI-R "G/L7/E/9F/CM29/NR FIRE EXIT"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 9:7-30 HMS-S/D/M/SA "G/L7/E/9F/MCP30/NR FIRE EXIT"
|      |      |      |  -- 9:7-31 HTRI-S "G/L7/E/9F/MM31/NR FIRE EXIT"
|      |      |      |  -- 9:7-32 HTRI-R "G/L7/E/8F/CM32/AHU RM"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 9:7-33 HFP-11 "G/L7/E/8F/SD33/AHU RM"
|      |      |      |  -- 9:7-34 HTRI-R "G/L7/E/8F/CM34/NR FIRE EXIT"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 9:7-35 HMS-S/D/M/SA "G/L7/E/8F/MCP35/NR FIRE EXIT"
|      |      |      |  -- 9:7-36 HTRI-S "G/L7/E/8F/MM36/NR FIRE EXIT"
|      |      |      |  -- 9:7-37 HFP-11 "G/L7/W/8F/SD37/LIFT LOBBY"
|      |      |      |  -- 9:7-38 HFP-11 "G/L7/W/8F/SD38/LIFT LOBBY"
|      |      |      |  -- 9:7-39 HFP-11 "G/L7/W/8F/SD39/CORR NR GW 8080"
|      |      |      |  -- 9:7-40 HFP-11 "G/L7/W/8F/SD40/CORR NR GW 8080"
|      |      |      |  -- 9:7-41 HTRI-R "G/L7/W/8F/CM41/DR RELEASE"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 9:7-42 HFP-11 "G/L7/W/8F/SD42/ELECT RM"
|      |      |      |  -- 9:7-43 HFP-11 "G/L7/W/8F/SD43/CORR NR GW 8050"
|      |      |      |  -- 9:7-44 HFP-11 "G/L7/W/8F/SD44/CORR NR GW 8050"
|      |      |      |  -- 9:7-45 HTRI-R "G/L7/W/8F/CM45/NR FIRE EXIT"
|      |      |      |      |  -- Switch ""
|      |      |      |      |  -- Relay
|      |      |      |  -- 9:7-46 HMS-S/D/M/SA "G/L7/W/8F/MCP46/NR FIRE EXIT"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:7 XDLC "XDLC @ address L7"

				--	9:7-47	HFP-11	"G/L7/W/8F/SD47/CORR NR GW 8040"
				--	9:7-48	HFP-11	"G/L7/W/8F/SD48/CORR NR GW 8020"
				--	9:7-49	HFP-11	"G/L7/W/8F/SD49/CORR NR GW 8020"
				--	9:7-50	HFP-11	"G/L7/W/8F/SD50/CORR NR GW8020"
				--	9:7-51	HFP-11	"G/L7/W/8F/SD51/CORR NR GW 8031"
				--	9:7-52	HTRI-R	"G/L7/E/8F/CM52/NR FIRE EXIT"
				--	Switch	"	"
				--	Relay		
				--	9:7-53	HMS-S/D/M/SA	"G/L7/E/8F/MCP53/NR FIRE EXIT"
				--	9:7-54	HTRI-S	"G/L7/E/8F/MM54/NR FIRE EXIT"
				--	9:7-55	HFP-11	"G/L7/E/8F/SD55/LIFT LOBBY"
				--	9:7-56	HFP-11	"G/L7/E/8F/SD56/LIFT LOBBY"
				--	9:7-57	HTRI-R	"G/L7/E/8F/CM57/DR RELEASE"
				--	Switch	"	"
				--	Relay		
				--	9:7-58	HFP-11	"G/L7/E/8F/SD58/ELECT RM"
				--	9:7-59	HTRI-R	"G/L7/E/8F/CM59/AHU RM"
				--	Switch	"	"
				--	Relay		
				--	9:7-60	HFP-11	"G/L7/E/8F/SD60/AHU RM"
				--	9:7-61	HFP-11	"G/L7/E/8F/SD61/CORR NR GE 8010"
				--	9:7-62	HFP-11	"G/L7/E/8F/SD62/CORR NR GE 8020"
				--	9:7-63	HFP-11	"G/L7/E/8F/SD63/CORR NR GE8010"
				--	9:7-64	HFP-11	"G/L7/E/8F/SD64/CORR NR GE8031"
				--	9:7-65	HFP-11	"G/L7/E/8F/SD65/CORR NR GE8031"
				--	9:7-66	HFP-11	"G/L7/E/8F/SD66/CORR NR HE 8111"
				--	9:7-67	HFP-11	"G/L7/E/8F/SD67/CORR NR HE 8120"
				--	9:7-68	HFP-11	"G/L7/E/8F/SD68/CORR NR HE 8120"
				--	9:7-69	HFP-11	"G/L7/E/8F/SD69/CORR NR HE 8130"
				--	9:7-70	HFP-11	"G/L7/E/8F/SD70/CORR NR HE 8030"
				--	9:7-71	HFP-11	"G/L7/E/8F/SD71/CORR NR HE 8030"
				--	9:7-72	HTRI-R	"G/L7/E/8F/CM72/NR FIRE EXIT"
				--	Switch	"	"
				--	Relay		
				--	9:7-73	HMS-S/D/M/SA	"G/L7/E/8F/MCP73/NR FIRE EXIT"
				--	9:7-74	HFP-11	"G/L7/E/7F/SD74/AHU RM "
				--	9:7-75	HTRI-R	"G/L7/E/7F/CM75/AHU RM "
				--	Switch	"	"
				--	Relay		
				--	9:7-76	HTRI-R	"G/L7/E/7F/CM76/NR FIRE EXIT"
				--	Switch	"	"
				--	Relay		
				--	9:7-77	HMS-S/D/M/SA	"G/L7/WC/7F/MCP77/NR FIRE EXIT"
				--	9:7-78	HTRI-S	"G/L7/WC/7F/MM78/NR FIRE EXIT"
				--	9:7-79	HFP-11	"G/L7/WC/7F/SD79/LIFT LOBBY"
				--	9:7-80	HFP-11	"G/L7/WC/7F/SD80/LIFT LOBBY"
				--	9:7-81	HFP-11	"G/L7/WC/7F/SD81/ELECT RM"
				--	9:7-82	XTRI-R	"G/L7/EC1/7F/CM82/FIRE SHAFT"
				--	Switch	"	"
				--	Relay		

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:7 XDLC "XDLC @ address L7"

			-- 9:7-83 HTRI-S "G/L7/EC1/7F/MM83/FIRE SHAFT"
			-- 9:7-84 HMS-S/D/M/SA "G/L7/EC1/7F/MCP84/LIFT LOBBY"
			-- 9:7-85 HFP-11 "G/L7/EC1/7F/SD85/LIFT LOBBY"
			-- 9:7-86 HTRI-R "G/L7/EC1/7F/CM86/AHU ROOM"
			-- Switch ""
			-- Relay
			-- 9:7-87 HFP-11 "G/L7/EC1/7F/SD87/AHU ROOM"
			-- 9:7-88 HFP-11 "G/L7/EC1/7F/SD88/ELECTRIC RM"
			-- 9:7-89 HFP-11 "G/L7/EC1/7F/SD89/PASSAGE"
			-- 9:7-90 HTRI-S "G/L7/L7/7/G/9F/MM90/GE9060"
			-- 9:7-91 HTRI-S "G/L7/9F/MM91/GE9120"
			-- 9:7-93 HTRI-S "G/L7/9F/MM93/GE9110"
			-- 9:7-94 HTRI-S "G/L7/9F/MM94/GE9070"
			-- 9:7-95 HTRI-S "G/L7/9F/MM95/GE9050"
			-- 9:7-97 HTRI-S "G/L7/9F/MM97/GE9100"
			-- 9:7-99 HFP-11 "G/L7/7F/SD99/Psg nr Ele Rm"
			-- 9:7-101 HTRI-S "G/L7/9F/MM101/GE9010"
			-- 9:7-102 HTRI-S "G/L7/9F/MM102/GE9080"
			-- 9:7-103 HTRI-S "G/L7/9F/MM103/GW9010"
			-- 9:7-106 HTRI-S "G/L7/8F/MM106/GW8090"
			-- 9:7-107 HTRI-S "G/L7/8F/MM107/GW8101"
			-- 9:7-108 HTRI-S "G/L7/8F/MM108/GW8080"
			-- 9:7-109 HTRI-S "G/L7/8F/MM109/GW8070"
			-- 9:7-112 HTRI-S "G/L7/8F/MM112/GW8103"
			-- 9:7-113 HTRI-S "G/L7/8F/MM113/GW8040"
			-- 9:7-114 HTRI-S "G/L7/8F/MM114/GW8030"
			-- 9:7-115 XTRI-S "G/L7/7F/MM115/GE9030"
			-- 9:7-116 XTRI-S "G/L7/8F/MM116/GE8020A"
			-- 9:7-117 HTRI-S "G/L7/8F/MM117/GE8031"
			-- 9:7-120 HTRI-S "G/L7/8F/MM120/GE8111"
			-- 9:7-122 HTRI-S "G/L7/8F/MM122/GE8112"
			-- 9:7-124 HTRI-S "G/L7/8F/MM124/GE8041"
			-- 9:7-125 HTRI-S "G/L7/8F/MM125/GE8120"
			-- 9:7-126 HTRI-S "G/L7/8F/MM126/HE8090"
			-- 9:7-127 HTRI-S "G/L7/8F/MM127/HE8130"
			-- 9:7-129 HTRI-S "G/L7/8F/MM129/HE8080"
			-- 9:7-130 HTRI-S "G/L7/8F/MM130/HE8030"
			-- 9:7-132 HTRI-S "G/L7/7F/MM132/HW7012 B"
			-- 9:7-133 HTRI-S "G/L7/7F/MM133/HW7012A"
			-- 9:7-134 HTRI-S "G/L7/7F/MM134/GW7011"
			-- 9:7-135 HTRI-S "G/L7/7F/MM135/HW7013"
			-- 9:7-136 HTRI-S "G/L7/GW/8F/MM136/GW7022"
			-- 9:7-137 HFP-11 "G/L7/GE9040/SD137/Main cab"
			-- 9:7-138 HFP-11 "G/L7/GE9040/SD138/Account cab"
			-- 9:7-139 HFP-11 "G/L7/GE9040/SD139/Psg nr Account"
			-- 9:7-140 HFP-11 "G/L7/GE9040/SD140/Assorter cab"
			-- 9:7-141 HFP-11 "G/L7/GE9040/SD141/Pantry"
			-- 9:7-142 HTRI-R "G/L7/GE9040/CM142/Entry dr Psg"
			-- Switch ""
			-- Relay

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:7 XDLC "XDLC @ address L7"

			-- 9:7-143 HMS-S/D/M/SA "G/L7/GE9040/MCP143/Entry dr Psg"
			-- 9:7-144 HFP-11 "G/L7/GE9020/SD144/Main cab"
			-- 9:7-145 HFP-11 "G/L7/GE9020/SD145/Assorter cab"
			-- 9:7-146 HFP-11 "G/L7/GE9020/SD146/Entry Psg"
			-- 9:7-147 HTRI-R "G/L7/GE9020/CM147/Entry Psg"
			-- Switch ""
			-- Relay
			-- 9:7-148 HMS-S/D/M/SA "G/L7/GE9020/MCP148/Entry Psg"
			-- 9:7-149 HFP-11 "G/L7/GW9020/SD149/Main cab2"
			-- 9:7-150 HFP-11 "G/L7/GW9020/SD150/Main cab1"
			-- 9:7-151 HFP-11 "G/L7/GW9020/SD151/Accounts cab"
			-- 9:7-152 HFP-11 "G/L7/GW9020/SD152/Assorter cab"
			-- 9:7-153 HFP-11 "G/L7/GW9020/SD153/Psg nr Assort "
			-- 9:7-154 HFP-11 "G/L7/GW9020/SD154/Pantry"
			-- 9:7-155 HTRI-R "G/L7/GW9020/CM155/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 9:7-156 HMS-S/D/M/SA "G/L7/GW9020/MCP156/Entry dr Psg"
			-- 9:7-157 HFP-11 "G/L7/GE9090/SD157/Main cab"
			-- 9:7-158 HFP-11 "G/L7/GE9090/SD158/Main cab"
			-- 9:7-159 HFPT-11 "G/L7/GE9090/SD159/Entry dr Psg"
			-- 9:7-160 HTRI-R "G/L7/GE9090/CM160/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 9:7-161 HMS-S/D/M/SA "G/L7/GE9090/MCP161/Entry dr Psg"
			-- 9:7-162 HFP-11 "G/L7/GW9030/SD162/cab 1"
			-- 9:7-163 HFP-11 "G/L7/GW9030/SD163/cab 2"
			-- 9:7-164 HFP-11 "G/L7/GW9030/SD164/Psg nr cab 2"
			-- 9:7-165 HFP-11 "G/L7/GW9030/SD165/cab 3"
			-- 9:7-166 HFP-11 "G/L7/GW9030/SD166/cab 4"
			-- 9:7-167 HFPT-11 "G/L7/GW9030/HD167/Pantry"
			-- 9:7-168 HFP-11 "G/L7/GW9030/SD168/Reception"
			-- 9:7-169 HTRI-R "G/L7/GW9030/CM169/Entry dr Psg"
			-- Switch ""
			-- Relay
			-- 9:7-170 HMS-S/D/M/SA "G/L7/GW9030/MCP170/Entry dr Psg"
			-- 9:7-171 HFP-11 "G/L7/GW8060/SD171/Main cab"
			-- 9:7-172 HFP-11 "G/L7/GW8060/SD172/Account cab"
			-- 9:7-173 HFP-11 "G/L7/GW8060/SD173/Psg nr Main ca"
			-- 9:7-174 HFP-11 "G/L7/GW8060/SD174/Cab nr Pantry"
			-- 9:7-175 HFPT-11 "G/L7/GW8060/HD175/Pantry"
			-- 9:7-176 HTRI-R "G/L7/GW8060/CM176/Entry Psg"
			-- Switch ""
			-- Relay
			-- 9:7-177 HMS-S/D/M/SA "G/L7/GW8060/MCP177/Entry Psg"
			-- 9:7-178 HFP-11 "G/L7/GE8010/SD178/Assorter cab"
			-- 9:7-179 HFP-11 "G/L7/GE8010/SD179/Main cab"
			-- 9:7-180 HFP-11 "G/L7/GE8010/SD180/Entry Psg"
			-- 9:7-181 HTRI-R "G/L7/GE8010/CM181/Entry Psg"
			-- Switch ""

				--	Relay
				--	9:7-182 HMS-S/D/M/SA "G/L7/GE8010/MCP182/Entry Psg"
				--	9:7-183 HFP-11 "G/L7/GE8041/SD183/cab 1"
				--	9:7-184 HFP-11 "G/L7/GE8041/SD184/cab 2"
				--	9:7-185 HFP-11 "G/L7/GE8041/SD185/cab 3"
				--	9:7-186 HFP-11 "G/L7/GE8041/SD186/Reception cab"
				--	9:7-187 HFP-11 "G/L7/GE8041/SD187/Cab 4"
				--	9:7-188 HFP-11 "G/L7/GE8041/SD188/Cab 5"
				--	9:7-189 HFP-11 "G/L7/GE8041/SD189/Pantry"
				--	9:7-190 HFP-11 "G/L7/GE8041/SD190/Cab 6"
				--	9:7-191 HFP-11 "G/L7/GE8041/SD191/Cab 7"
				--	9:7-192 HFP-11 "G/L7/GE8041/SD192/Account cab1"
				--	9:7-193 HFP-11 "G/L7/GE8041/SD193/Account cab2"
				--	9:7-194 HFP-11 "G/L7/GE8041/SD194/Reception Psg"
				--	9:7-195 HTRI-R "G/L7/GE8041/CM195/Entry Psg"
				--	Switch ""
				--	Relay
				--	9:7-196 HMS-S/D/M/SA "G/L7/GE8041/MCP196/Entry Psg"
				--	9:7-197 HFP-11 "G/L7/GW8050/SD197/cab 1"
				--	9:7-198 HFP-11 "G/L7/GW8050/SD198/cab 2"
				--	9:7-199 HFP-11 "G/L7/GW8050/SD199/cab 3"
				--	9:7-200 HFP-11 "G/L7/GW8050/SD200/cab 4"
				--	9:7-201 HFP-11 "G/L7/GW8050/SD201/cab 5"
				--	9:7-202 HFP-11 "G/L7/GW8050/SD202/cab 6"
				--	9:7-203 HFP-11 "G/L7/GW8050/SD203/psg nr cab 6"
				--	9:7-204 HFP-11 "G/L7/GW8050/SD204/pantry"
				--	9:7-205 HFP-11 "G/L7/GW8050/SD205/Entry Psg"
				--	9:7-206 HTRI-R "G/L7/GW8050/CM206/Entry Psg"
				--	Switch ""
				--	Relay
				--	9:7-207 HMS-S/D/M/SA "G/L7/GW8050/MCP207/Entry Psg"
				--	9:7-208 HFP-11 "G/L7/GE8020/SD208/Main cab1"
				--	9:7-209 HFP-11 "G/L7/GE8020/SD209/Main cab2"
				--	9:7-210 HFP-11 "G/L7/GE8020/SD210/Sales cab1"
				--	9:7-211 HFP-11 "G/L7/GE8020/SD211/Sales cab2"
				--	9:7-212 FDOT421 "G/L7/GE8020/SD212/Accounts cab1"
				--	9:7-213 HFP-11 "G/L7/GE8020/SD213/Accounts cab 2"
				--	9:7-214 HFP-11 "G/L7/GE8020/SD214/Pantry"
				--	9:7-215 HFP-11 "G/L7/GE8020/SD215/Reception"
				--	9:7-217 HMS-S/D/M/SA "G/L7/GE8020/MCP217/Entry Psg"
				--	9:7-223 HFP-11 "G/L7/GE9110/SD223/Main cab"
				--	9:7-224 HFP-11 "G/L7/GE9110/SD224/Assorter cab"
				--	9:7-225 HFPT-11 "G/L7/GE9110/HD225/Pantry"
				--	9:7-226 HTRI-R "G/L7/GE9110/CM226/AFC Pantry"
				--	Switch ""
				--	Relay
				--	9:7-227 HMS-S/D/M/SA "G/L7/GE9110/MCP227/Entry Psg"
				--	9:7-228 HFP-11 "G/L7/GW8020/SD228/Main cab"
				--	9:7-229 HFP-11 "G/L7/GW8020/SD229/Assorter cab"
				--	9:7-230 HFP-11 "G/L7/GW8020/SD230/Psg nr Assorte"

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:7 XDLC "XDLC @ address L7"

```
|      |      |      |-- 9:7-231 HFPT-11 "G/L7/GW8020/HD231/Pantry"
|      |      |      |-- 9:7-232 HTRI-R "G/L7/GW8020/CM232/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:7-233 HMS-S/D/M/SA "G/L7/GW8020/MCP233/Entry dr psg"
|      |      |      |-- 9:7-234 HMS-S/D/M/SA "G/L7/GW8010/MCP234/Entry dr psg"
|      |      |      |-- 9:7-235 HTRI-R "G/L7/GW8010/CM235/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:7-236 HFP-11 "G/L7/GW8010/SD236/Lunch cab"
|      |      |      |-- 9:7-237 HFP-11 "G/L7/GW8010/SD237/Director cab"
|      |      |      |-- 9:7-238 HFP-11 "G/L7/GW8010/SD238/Sales cab"
|      |      |      |-- 9:7-239 HFP-11 "G/L7/GW8010/SD239/Buyer cab 1"
|      |      |      |-- 9:7-240 HFP-11 "G/L7/GW8010/SD240/Account cab"
|      |      |      |-- 9:7-241 HFP-11 "G/L7/GW8010/SD241/Account cab"
|      |      |      |-- 9:7-242 HFP-11 "G/L7/GW8010/SD242/Account cab"
|      |      |      |-- 9:7-243 HFP-11 "G/L7/GW8010/SD243/Entry psg"
|      |      |      |-- 9:7-244 HFPT-11 "G/L7/GW8010/HD244/Pantry"
|      |      |      |-- 9:7-245 HTRI-R "G/L7/GE8020/CM245/Entry Psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:7-246 HFP-11 "G/L7/GE8020/SD246/ACCONTS CAB"
|      |      |      |-- 9:7-247 HFP-11 "G/L7/GE9110/SD247/Account cab"
|      |      |      |-- 9:7-248 HFP-11 "G/L7/GE8020/SD248/Psg nr Pantry"
|      |      |      |-- 9:8 XDLC "XDLC @ address L8"
|      |      |      |-- 9:8-1 HTRI-R "G/L8/8F/CM1/HE Lift Lobby"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:8-2 HMS-S/D/M/SA "G/L8/8F/MCP2/HE Lift Lobby"
|      |      |      |-- 9:8-3 HTRI-S "G/L8/8F/MM3/HE Lift Lobby"
|      |      |      |-- 9:8-4 HFP-11 "G/L8/8F/SD4/HE Lift Lobby"
|      |      |      |-- 9:8-5 HTRI-R "G/L8/8F/CM5/HE Door Release"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:8-6 HFP-11 "G/L8/8F/SD6/HE Electric Rm"
|      |      |      |-- 9:8-7 HFP-11 "G/L8/8F/SD7/HE AHU Rm"
|      |      |      |-- 9:8-8 HTRI-R "G/L8/8F/CM8/HE AHU Rm"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:8-9 HFP-11 "G/L8/8F/SD9/HE Electric Rm"
|      |      |      |-- 9:8-10 HFP-11 "G/L8/8F/SD10/HE Electric He 8011"
|      |      |      |-- 9:8-11 HFP-11 "G/L8/8F/SD11/Corr.Nr HE8011"
|      |      |      |-- 9:8-12 HFP-11 "G/L8/8F/SD12/Corr.Nr HE8020"
|      |      |      |-- 9:8-13 HFP-11 "G/L8/8F/SD13/Corr.Nr HE8040"
|      |      |      |-- 9:8-14 HFP-11 "G/L8/8F/SD14/Corr.Nr HE8040"
|      |      |      |-- 9:8-15 HFP-11 "G/L8/8F/SD15/Corr.Nr HE8060"
|      |      |      |-- 9:8-16 HFP-11 "G/L8/8F/SD16/Corr.Nr HE8060"
|      |      |      |-- 9:8-17 HFP-11 "G/L8/8F/SD17/Corr.Nr HE8070"
|      |      |      |-- 9:8-18 XTRI-R "G/L8/8F/CM18/HW Lift Lobby"
|      |      |      |-- Switch ""
```

			-- Relay
			-- 9:8-19 HMS-S/D/M/SA "G/L8/8F/MCP19/HW Lift Lobby"
			-- 9:8-20 HTRI-S "G/L8/8F/MM20/HW Lift Lobby"
			-- 9:8-21 HFP-11 "G/L8/8F/SD21/HW Lift Lobby"
			-- 9:8-22 HFP-11 "G/L8/8F/SD22/HW Electric rm"
			-- 9:8-23 HTRI-R "G/L8/8F/CM23/HW AHU rm"
			-- Switch ""
			-- Relay
			-- 9:8-24 HFP-11 "G/L8/8F/SD24/HW AHU rm"
			-- 9:8-25 HTRI-R "G/L8/7F/CM25/HE Lift Lobby"
			-- Switch ""
			-- Relay
			-- 9:8-26 HMS-S/D/M/SA "G/L8/7F/MCP26/HE Lift Lobby"
			-- 9:8-27 HTRI-S "G/L8/7F/MM27/HE Lift Lobby"
			-- 9:8-28 HFP-11 "G/L8/7F/SD28/HE Lift Lobby"
			-- 9:8-30 HFP-11 "G/L8/7F/SD30/HE Electric Rm"
			-- 9:8-31 HFP-11 "G/L8/7F/SD31/HE passage"
			-- 9:8-32 HFP-11 "G/L8/7F/SD32/HE AHU Rm"
			-- 9:8-33 HTRI-R "G/L8/7F/CM33/HE AHU Rm"
			-- Switch ""
			-- Relay
			-- 9:8-34 HFP-11 "G/L8/7F/SD34/HW Passage"
			-- 9:8-35 HFP-11 "G/L8/7F/SD35/ Corr. Nr. HW 7011E"
			-- 9:8-36 HFP-11 "G/L8/7F/SD36/HW Passage"
			-- 9:8-37 HTRI-R "G/L8/7F/CM37/HW AHU Rm"
			-- Switch ""
			-- Relay
			-- 9:8-38 HFP-11 "G/L8/7F/SD38/HW AHU Rm"
			-- 9:8-39 HFP-11 "G/L8/7F/SD39/HW Electric rm"
			-- 9:8-40 HFP-11 "G/L8/7F/SD40/HW Lift Lobby"
			-- 9:8-41 HTRI-R "G/L8/7F/CM41/HW Lift Lobby"
			-- Switch ""
			-- Relay
			-- 9:8-42 HMS-S/D/M/SA "G/L8/7F/MCP42/HW Lift Lobby"
			-- 9:8-45 HTRI-S "G/L8/HW/7F/MM45/HW7011F"
			-- 9:8-46 HTRI-S "G/L8/HE/7F/MM46/HW7010"
			-- 9:8-47 HTRI-S "G/L8/HE/8F/MM47/HE8011"
			-- 9:8-49 HTRI-S "G/L8/HE/8F/MM49/HE8011-A"
			-- 9:8-50 HTRI-S "G/L8/HE/8F/MM50/HE8020"
			-- 9:8-51 HTRI-S "G/L8/HE/8F/MM51/HE8030"
			-- 9:8-53 HTRI-S "G/L8/HE/8F/MM53/HE8040"
			-- 9:8-55 HTRI-S "G/L8/HE/8F/MM55/HE8060"
			-- 9:8-57 HTRI-S "G/L8/HE/8F/MM57/HE8-D.NAVINCHAN"
			-- 9:8-59 HFP-11 "G/L8/HE8012/SD59/Main cab"
			-- 9:8-60 HFP-11 "G/L8/HE8012/SD60/Cab 1"
			-- 9:8-61 HFP-11 "G/L8/HE8012/SD61/Entry Psg"
			-- 9:8-62 HFP-11 "G/L8/HE8012/SD62/NS Diam. Cab"
			-- 9:8-63 HTRI-R "G/L8/HE8012/CM63/Entry Psg"
			-- Switch ""
			-- Relay

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:8 XDLC "XDLC @ address L8"

```
|      |      |      |-- 9:8-64 HMS-S/D/M/SA "G/L8/HE8012/MCP64/Entry Psg"
|      |      |      |-- 9:8-65 HFP-11 "G/L8/HE8050/SD65/Assorter cab1"
|      |      |      |-- 9:8-66 HFP-11 "G/L8/HE8050/SD66/Main cab"
|      |      |      |-- 9:8-67 HFP-11 "G/L8/HE8050/SD67/Assorter cab2"
|      |      |      |-- 9:8-68 HFP-11 "G/L8/HE8050/SD68/Pantry"
|      |      |      |-- 9:8-69 HTRI-R "G/L8/HE8050/CM69/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 9:8-70 HMS-S/D/M/SA "G/L8/HE8050/MCP70/Entry dr Psg"
|      |      |      |-- 9:8-71 HFP-11 "G/L8/HE8070/SD71/Main cab"
|      |      |      |-- 9:8-72 HFP-11 "G/L8/HE8070/SD72/Accounts cab"
|      |      |      |-- 9:8-73 HFP-11 "G/L8/HE8070/SD73/Assorter cab1"
|      |      |      |-- 9:8-74 HFP-11 "G/L8/HE8070/SD74/Assorter cab2"
|      |      |      |-- 9:8-75 HFP-11 "G/L8/HE8070/SD75/Entry dr Psg"
|      |      |      |-- 9:8-76 HFPT-11 "G/L8/HE8070/HD76/Pantry"
|      |      |      |-- 9:8-77 HTRI-R "G/L8/HE8070/CM77/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 9:8-78 HMS-S/D/M/SA "G/L8/HE8070/MCP78/Entry dr Psg"
|      |      |      |-- 9:8-79 HFP-11 "G/L8/HE8090/SD79/Main cab"
|      |      |      |-- 9:8-80 HFP-11 "G/L8/HE8090/SD80/Assorter cab1"
|      |      |      |-- 9:8-81 HFP-11 "G/L8/HE8090/SD81/Assorter cab2"
|      |      |      |-- 9:8-82 HFP-11 "G/L8/HE8090/SD82/Entry Psg"
|      |      |      |-- 9:8-83 HTRI-R "G/L8/HE8090/CM83/Entry Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 9:8-84 HMS-S/D/M/SA "G/L8/HE8090/MCP84/Entry Psg"
|      |      |      |-- 9:8-85 HFP-11 "G/L8/HE8060A/SD85/Main cab1"
|      |      |      |-- 9:8-86 HFP-11 "G/L8/HE8060A/SD86/Main cab2"
|      |      |      |-- 9:8-87 HFP-11 "G/L8/HE8060A/SD87/Entry dr Psg"
|      |      |      |-- 9:8-88 HTRI-R "G/L8/HE8060A/CM88/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 9:8-89 HMS-S/D/M/SA "G/L8/HE8060A/MCP89/Entry dr Psg"
|      |      |      |-- 9:8-90 HFP-11 "G/L8/HW8012/SD90/Account cab"
|      |      |      |-- 9:8-91 HFP-11 "G/L8/HW8012/SD91/Conference rm"
|      |      |      |-- 9:8-92 HFP-11 "G/L8/HW8012/SD92/Buyer Cab 5"
|      |      |      |-- 9:8-93 HFP-11 "G/L8/HW8012/SD93/Buyer Cab 4"
|      |      |      |-- 9:8-94 HFP-11 "G/L8/HW8012/SD94/Buyer Cab 3"
|      |      |      |-- 9:8-95 HFP-11 "G/L8/HW8012/SD95/Buyer Cab 2"
|      |      |      |-- 9:8-96 HFP-11 "G/L8/HW8012/SD96/Main cab"
|      |      |      |-- 9:8-97 HFP-11 "G/L8/HW8012/SD97/Main cab"
|      |      |      |-- 9:8-98 HFP-11 "G/L8/HW8012/SD98/Buyer Cab 1"
|      |      |      |-- 9:8-99 HFP-11 "G/L8/HW8012/SD99/Assorter cab"
|      |      |      |-- 9:8-100 HFP-11 "G/L8/HW8012/SD100/Assorter cab"
|      |      |      |-- 9:8-101 HFP-11 "G/L8/HW8012/SD101/Reception Psg"
|      |      |      |-- 9:8-102 HFP-11 "G/L8/HW8012/SD102/Reception Psg"
|      |      |      |-- 9:8-103 HFP-11 "G/L8/HW8012/SD103/Pantry"
|      |      |      |-- 9:8-104 HFP-11 "G/L8/HW8012/SD104/Psg nr Pantry"
|      |      |      |-- 9:8-105 HFP-11 "G/L8/HW8012/SD105/Psg nr MC"
```

9 Desigo Fire Safety Modular "BDB TOWER G/H" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

9:8 XDLC "XDLC @ address L8"

```
|      |      |      |-- 9:8-106 HFP-11 "G/L8/HW8012/SD106/Psg nr Buyer c"
|      |      |      |-- 9:8-107 HTRI-R "G/L8/HW8012/CM107/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:8-108 HMS-S/D/M/SA "G/L8/HW8012/MCP108/Entry dr psg"
|      |      |      |-- 9:8-109 HFP-11 "H/L8/HW8011B/SD109/reception psg"
|      |      |      |-- 9:8-110 HFP-11 "H/L8/HW8011B/SD110/psg nr cab5"
|      |      |      |-- 9:8-111 HFP-11 "H/L8/HW8011B/SD111/cab5"
|      |      |      |-- 9:8-112 HFP-11 "H/L8/HW8011B/SD112/cab3"
|      |      |      |-- 9:8-113 HFP-11 "H/L8/HW8011B/SD113/cab1"
|      |      |      |-- 9:8-114 HFP-11 "H/L8/HW8011B/SD114/director cab"
|      |      |      |-- 9:8-115 HFP-11 "H/L8/HW8011B/SD115/Mayur cab"
|      |      |      |-- 9:8-116 HFP-11 "H/L8/HW8011B/SD116/cab2"
|      |      |      |-- 9:8-117 HFP-11 "H/L8/HW8011B/SD117/cab 4/A"
|      |      |      |-- 9:8-118 HFP-11 "H/L8/HW8011B/SD118/cab 4/B"
|      |      |      |-- 9:8-119 HFP-11 "H/L8/HW8011B/SD119/psg nr Server"
|      |      |      |-- 9:8-120 FDOT421 "H/L8/HW8011B/SD120/Assortor cab2"
|      |      |      |-- 9:8-121 HFP-11 "H/L8/HW8011B/SD121/Assortor cab2"
|      |      |      |-- 9:8-122 HFP-11 "H/L8/HW8011B/SD122/Assortor cab2"
|      |      |      |-- 9:8-123 HFP-11 "H/L8/HW8011B/SD123/Assortor cab1"
|      |      |      |-- 9:8-124 HFP-11 "H/L8/HW8011B/SD124/Assortor cab1"
|      |      |      |-- 9:8-125 HFP-11 "H/L8/HW8011B/SD125/Assortor cab1"
|      |      |      |-- 9:8-126 HFPT-11 "H/L8/HW8011B/HD126/pantry"
|      |      |      |-- 9:8-127 HMS-S/D/M/SA "H/L8/HW8011B/MCP127/Assortor cab"
|      |      |      |-- 9:8-128 HMS-S/D/M/SA "H/L8/HW8011B/MCP128/Entry psg"
|      |      |      |-- 9:8-129 HTRI-R "H/L8/HW8011B/CM129/Entry psg AFC"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 9:8-136 HTRI-S "G/L8/HW/7F/MM136/HW7011-E"
|      |      |      |-- 9:8-137 HTRI-S "G/L8/HW/7F/MM137/HW7011-C&D"
|      |      |      |-- 9:8-138 HTRI-S "G/L8/HW/7F/MM138/HW7011-A"
|      |      |      |-- 9:8-139 HTRI-S "G/L8/HW/7F/MM139/HW7011-B"
|      |      |      |-- 9:9 NIC-C(XNet) "NIC_Xnet @ address 9"
|      |      |      |-- 9:249 PSC-12 "PSC-12 @ address 1"
|      |      |      |-- 9:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
|      |      |      |-- 9:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
|      |      |      |-- Inner Door
|      |      |      |-- 9:253 PMI-D "PMI-D @ address 253"
|-- 10 Desigo Fire Safety Modular "BDB TOWER A" Local
|      |-- System Flags
|      |-- History Log
|      |-- Behavior
|      |-- Voice
|      |-- Maintenance
|      |-- Field Devices
|      |-- Miscellaneous
|      |-- CAB-2 "CAB-2 Enclosure #1"
|      |      |-- CC-5 "Card Cage 5 Slots"
|      |      |      |-- 10:1 XDLC "DLC @ address 1 E/W 1st FLOOR"
|      |      |      |      |-- 10:1-1 HTRI-R "A/L1/EC/1F/CM1/FIRE HYD SHAFT"
```

```
| | Switch ""  
| | | |-- Relay  
| | | |-- 10:1-2 HTRI-S "A/L1/EC/1F/MM2/FIRE HYD SHAFT"  
| | | |-- 10:1-3 HMS-S/D/M/SA "A/L1/EC/1F/MCP3/LIFT LOBBY STR"  
| | | |-- 10:1-4 FDOT421 "A/L1/EC/1F/SD4/LIFT LOBBY"  
| | | |-- 10:1-5 HTRI-R "A/L1/EC/1F/CM5/AHU ROOM"  
| | | | |-- Switch ""  
| | | | |-- Relay  
| | | |-- 10:1-6 FDOT421 "A/L1/EC/1F/SD6/AHU ROOM"  
| | | |-- 10:1-7 FDOT421 "A/L1/EC/1F/SD7/AHU ROOM"  
| | | |-- 10:1-8 FDOT421 "A/L1/EC/1F/SD8/ELECTRICAL ROOM"  
| | | |-- 10:1-9 HTRI-R "A/L1/WC/1F/CM9/FIRE HYD SHAFT"  
| | | | |-- Switch ""  
| | | | |-- Relay  
| | | |-- 10:1-10 HTRI-S "A/L1/WC/1F/MM10/FIRE HYD SHAFT"  
| | | |-- 10:1-11 HMS-S/D/M/SA "A/L1/WC/1F/MCP11/FIRE ESCAPE STR"  
| | | |-- 10:1-13 FDOT421 "A/L1/WC/1F/SD13/LIFT LOBBY"  
| | | |-- 10:1-14 FDOT421 "A/L1/WC/1F/SD14/CORR NR L.L."  
| | | |-- 10:1-15 FDOT421 "A/L1/WC/1F/SD15/LOBBY NR AW1021"  
| | | |-- 10:1-16 FDOT421 "A/L1/WC/1F/SD16/ELE ROOM"  
| | | |-- 10:1-17 FDOT421 "A/L1/WC/1F/SD17/AHU ROOM"  
| | | |-- 10:1-18 HTRI-R "A/L1/WC/1F/CM18/AHU ROOM"  
| | | | |-- Switch ""  
| | | | |-- Relay  
| | | |-- 10:1-41 XTRI-S "A/L1/1F/MM41/AW1010"  
| | | |-- 10:1-42 XTRI-S "A/L1/1F/MM42/AW1022"  
| | | |-- 10:1-43 XTRI-S "A/L1/1F/MM43/AW1021"  
| | | |-- 10:1-44 XTRI-S "A/L1/1F/MM44/AW1031"  
| | | |-- 10:1-45 HTRI-S "A/L1/1F/MM45/AE1010 1A"  
| | | |-- 10:1-46 HTRI-S "A/L1/1F/MM46/AE1010 1B"  
| | |-- 10:2 XDLC "DLC @ address 2 E/W 2nd FLOOR"  
| | | |-- 10:2-1 HTRI-R "A/L2/EC/2F/CM1/FIRE HYD SHAFT"  
| | | | |-- Switch ""  
| | | | |-- Relay  
| | | |-- 10:2-2 HTRI-S "A/L2/EC/2F/MM2/FIRE HYD SHAFT"  
| | | |-- 10:2-3 HMS-S/D/M/SA "A/L2/EC/2F/MCP3/LIFT LOBBY STR"  
| | | |-- 10:2-4 FDOT421 "A/L2/EC/2F/SD4/LIFT LOBBY"  
| | | |-- 10:2-5 HTRI-R "A/L2/EC/2F/CM5/DOOR RELEASE U"  
| | | | |-- Switch ""  
| | | | |-- Relay  
| | | |-- 10:2-6 HTRI-R "A/L2/EC/2F/CM6/AHU ROOM"  
| | | | |-- Switch ""  
| | | | |-- Relay  
| | | |-- 10:2-7 FDOT421 "A/L2/EC/2F/SD7/AHU ROOM"  
| | | |-- 10:2-8 FDOT421 "A/L2/EC/2F/SD8/ELECTRICAL ROOM"  
| | | |-- 10:2-9 FDOT421 "A/L2/EC/2F/SD9/AFC ELECT RM"  
| | | |-- 10:2-10 FDOT421 "A/L2/EC/2F/SD10/OUTSIDE ELECT RM"  
| | | |-- 10:2-11 FDOT421 "A/L2/EC/2F/SD11/AFC CORR AE2080"  
| | | |-- 10:2-12 FDOT421 "A/L2/EC/2F/SD12/AFC CORR AE2/SQ2"  
| | | |-- 10:2-13 FDOT421 "A/L2/EC/2F/SD13/CORR AE 2020A"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:2 XDLC "DLC @ address 2 E/W 2nd FLOOR"

			-- 10:2-14 FDOT421 "A/L2/EC/2F/SD14/CORRIDOR AE 2020"
			-- 10:2-15 FDOT421 "A/L2/E/2F/SD15/AFC COR NRAE2020"
			-- 10:2-16 HTRI-R "A/L2/EC/2F/CM16/CORR STR CASE"
			-- Switch ""
			-- Relay
			-- 10:2-17 HMS-S/D/M/SA "A/L2/EC/2F/MCP17/CORR STR CASE"
			-- 10:2-18 FDOT421 "A/L2/EC/2F/SD18/CORRIDOR AE 2031"
			-- 10:2-19 FDOT421 "A/L2/EC/2F/SD19/AFC CORR AE2/S10"
			-- 10:2-20 FDOT421 "A/L2/EC/2F/SD20/CORR AE2/S05"
			-- 10:2-21 FDOT421 "A/L2/E/2F/SD21/CORR NrAW2/S09AFC"
			-- 10:2-22 FDOT421 "A/L2/EC/2F/SD22/CORRIDOR AE 2044"
			-- 10:2-23 FDOT421 "A/L2/WC/2F/SD23/OUTSIDE ELECT RM"
			-- 10:2-24 HTRI-R "A/L2/WC/2F/CM24/OUTSIDE ELECT RM"
			-- Switch ""
			-- Relay
			-- 10:2-25 FDOT421 "A/L2/WC/2F/SD25/ELECTRICAL ROOM"
			-- 10:2-26 HMS-S/D/M/SA "A/L2/WC/2F/MCP26/LIFT LOBBY STR"
			-- 10:2-27 HTRI-R "A/L2/WC/2F/CM27/FIRE HYD SHAFT"
			-- Switch ""
			-- Relay
			-- 10:2-28 HTRI-S "A/L2/WC/2F/MM28/FIRE HYD SHAFT"
			-- 10:2-29 FDOT421 "A/L2/WC/2F/SD29/LIFT LOBBY"
			-- 10:2-30 FDOT421 "A/L2/WC/2F/SD30/LIFT LOBBY"
			-- 10:2-31 HTRI-R "A/L2/WC/2F/CM31/DOOR RELEASE U"
			-- Switch ""
			-- Relay
			-- 10:2-32 HTRI-R "A/L2/WC/2F/CM32/AHU ROOM"
			-- Switch ""
			-- Relay
			-- 10:2-33 FDOT421 "A/L2/WC/2F/SD33/AHU ROOM"
			-- 10:2-34 FDOT421 "A/L2/W/2F/SD34/CORRAW2/S07AFC"
			-- 10:2-35 FDOT421 "A/L2/WC/2F/SD35/CORR AW2/S07"
			-- 10:2-36 FDOT421 "A/L2/W/2F/SD36/CORRAW2022AFC"
			-- 10:2-37 FDOT421 "A/L2/WC/2F/SD37/CORR AW2150"
			-- 10:2-41 XTRI-S "A/L2/2F/MM41/AE2011"
			-- 10:2-43 XTRI-S "A/L2/2F/MM43/AE2080"
			-- 10:2-44 XTRI-S "A/L2/2F/MM44/AE2013"
			-- 10:2-46 XTRI-S "A/L2/2F/MM46/AE2020A"
			-- 10:2-51 XTRI-S "A/L2/2F/MM51/AE2031"
			-- 10:2-52 XTRI-S "A/L2/2F/MM52/AE2041"
			-- 10:2-53 XTRI-S "A/L2/2F/MM53/AE2053"
			-- 10:2-54 XTRI-S "A/L2/2F/MM54/AE2042"
			-- 10:2-56 XTRI-S "A/L2/2F/MM56/AE2043"
			-- 10:2-57 XTRI-S "A/L2/2F/MM57/AE2044"
			-- 10:2-58 XTRI-S "A/L2/2F/MM58/AE2051"
			-- 10:2-60 XTRI-S "A/L2/2F/MM60/AW2160"
			-- 10:2-61 XTRI-S "A/L2/2F/MM61/AW2022/23"
			-- 10:2-62 XTRI-S "A/L2/2F/MM62/AW2150"
			-- 10:2-63 HFP-11 "A/L2/AE2020/SD63/Main cabin"
			-- 10:2-64 HFP-11 "A/L2/AE2020/SD64/Assorter Room"

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:2 XDLC "DLC @ address 2 E/W 2nd FLOOR"

			-- 10:2-65 HFP-11 "A/L2/AE2020/SD65/Accounts cabin"
			-- 10:2-66 HFPT-11 "A/L2/AE2020/HD66/Pantry Area"
			-- 10:2-67 HFP-11 "A/L2/AE2020/SD67/Passage Area"
			-- 10:2-68 HTRI-R "A/L2/AE2020/CM68/Entry Door"
			-- Switch ""
			-- Relay
			-- 10:2-69 HMS-S/D/M/SA "A/L2/AE2020/MCP69/Entry Door"
			-- 10:2-70 HFP-11 "A/L2/AE2032/SD70/Main cabin-1"
			-- 10:2-71 HFP-11 "A/L2/AE2032/SD71/Main cabin-2"
			-- 10:2-72 HFP-11 "A/L2/AE2032/SD72/Passage Area"
			-- 10:2-73 HTRI-R "A/L2/AE2032/CM73/Entry Door"
			-- Switch ""
			-- Relay
			-- 10:2-74 HMS-S/D/M/SA "A/L2/AE2032/MCP74/Entry Door"
			-- 10:2-80 HTRI-S "A/L2/2F/MM80/AE2060"
			-- 10:2-94 HFP-11 "A/L2/AW2021/SD94/Main Cab1"
			-- 10:2-95 HFP-11 "A/L2/AW2021/SD95/Main Cab2"
			-- 10:2-96 HFP-11 "A/L2/AW2021/SD96/Main Cab2"
			-- 10:2-97 HFP-11 "A/L2/AW2021/SD97/Account cab"
			-- 10:2-98 HFP-11 "A/L2/AW2021/SD98/Assorter Cab"
			-- 10:2-99 HFP-11 "A/L2/AW2021/SD99/Reception Area"
			-- 10:2-100 HFPT-11 "A/L2/AW2021/HD100/Pantry"
			-- 10:2-101 HTRI-R "A/L2/AW2021/CM101/Entry Door Psg"
			-- Switch ""
			-- Relay
			-- 10:2-102 HMS-S/D/M/SA "A/L2/AW2021/MCP102/Entry Door"
			-- 10:3 XDLC "DLC @ address 3 E/W 3rd FLOOR"
			-- 10:3-1 HTRI-R "A/L3/EC/3F/CM1/FIRE HYD SHAFT"
			-- Switch ""
			-- Relay
			-- 10:3-2 HTRI-S "A/L3/EC/3F/MM2/FIRE HYD HAFT"
			-- 10:3-3 HMS-S/D/M/SA "A/L3/EC/3F/MCP3/LIFT LOBBY STR"
			-- 10:3-4 FDOT421 "A/L3/EC/3F/SD4/LIFT LOBBY"
			-- 10:3-5 HTRI-R "A/L3/EC/3F/CM5/DOOR RELEASE U"
			-- Switch ""
			-- Relay
			-- 10:3-6 HTRI-R "A/L3/EC/3F/CM6/AHU ROOM"
			-- Switch ""
			-- Relay
			-- 10:3-7 FDOT421 "A/L3/EC/3F/SD7/AHU ROOM"
			-- 10:3-8 FDOT421 "A/L3/EC/3F/SD8/ELECTRICAL ROOM"
			-- 10:3-9 FDOT421 "A/L3/EC/3F/SD9/AFC CORR AE3100"
			-- 10:3-10 FDOT421 "A/L3/EC/3F/SD10/CORR AE3100"
			-- 10:3-11 FDOT421 "A/L3/EC/3F/SD11/AFC CORR AE3/S02"
			-- 10:3-12 FDOT421 "A/L3/EC/3F/SD12/CORRIDOR AE3/S02"
			-- 10:3-13 FDOT421 "A/L3/EC/3F/SD13/CORRIDOR AE3021"
			-- 10:3-14 FDOT421 "A/L3/EC/3F/SD14/AFC CORR AE 3080"
			-- 10:3-15 FDOT421 "A/L3/EC/3F/SD15/CORRIDOR AE 3022"
			-- 10:3-16 HTRI-R "A/L3/EC/3F/CM16/CORR STR CASE"
			-- Switch ""

```

10 Desigo Fire Safety Modular "BDB TOWER A" Local
    CAB-2 "CAB-2 Enclosure #1"
        CC-5 "Card Cage 5 Slots"
            10:3 XDLC "DLC @ address 3 E/W 3rd FLOOR"
                10:3-16 HTRI-R "A/L3/EC/3F/CM16/CORR STR CASE"

```

[illegible]

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:3 XDLC "DLC @ address 3 E/W 3rd FLOOR"

```
|      |      |      |-- 10:3-67 HFP-11 "A/L3/AW3010/SD67/Pantry""
|      |      |      |-- 10:3-68 HTRI-R "A/L3/AW3010/CM68/Entry Door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:3-69 HMS-S/D/M/SA "A/L3/AW3010/MCP69/Entry Door"
|      |      |      |-- 10:3-70 HFP-11 "A/L3/AE3071/SD70/Main cabin-1"
|      |      |      |-- 10:3-71 HFP-11 "A/L3/AE3071/SD71/Main cabin-2"
|      |      |      |-- 10:3-72 HFP-11 "A/L3/AE3071/SD72/Assorter Room"
|      |      |      |-- 10:3-73 HFP-11 "A/L3/AE3071/SD73/Pantry Area"
|      |      |      |-- 10:3-74 HFP-11 "A/L3/AE3071/SD74/Passage Area"
|      |      |      |-- 10:3-75 XTRI-R "A/L3/AE3071/CM75/Entry Door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:3-76 HMS-S/D/M/SA "A/L3/AE3071/MCP76/Entry Door"
|      |      |      |-- 10:3-77 HFP-11 "A/L3/AE3010/SD77/Entry Door"
|      |      |      |-- 10:3-78 HFP-11 "A/L3/AE3010/SD78/Passage Area"
|      |      |      |-- 10:3-79 HFP-11 "A/L3/AE3010/SD79/Cabin 1"
|      |      |      |-- 10:3-80 HFP-11 "A/L3/AE3010/SD80/Watting Area"
|      |      |      |-- 10:3-81 HFP-11 "A/L3/AE3010/SD81/Cabin 2"
|      |      |      |-- 10:3-82 HFP-11 "A/L3/AE3010/SD82/Cabin 3"
|      |      |      |-- 10:3-83 HFP-11 "A/L3/AE3010/SD83/Cabin 4"
|      |      |      |-- 10:3-84 HFP-11 "A/L3/AE3010/SD84/Cabin 5"
|      |      |      |-- 10:3-85 HTRI-R "A/L3/AE3010/CM85/Entry Door"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:3-86 HMS-S/D/M/SA "A/L3/AE3010/MCP86/Entry Door"
|      |      |      |-- 10:3-87 HFP-11 "A/L3/AE3021/SD87/Account cab "
|      |      |      |-- 10:3-88 HFP-11 "A/L3/AE3021/SD88/Assorter cab "
|      |      |      |-- 10:3-89 HFP-11 "A/L3/AE3021/SD89/Main cab "
|      |      |      |-- 10:3-90 HFP-11 "A/L3/AE3021/SD90/Conference rm"
|      |      |      |-- 10:3-91 HFP-11 "A/L3/AE3021/SD91/Boss cab"
|      |      |      |-- 10:3-92 HFP-11 "A/L3/AE3021/SD92/Angadia cab"
|      |      |      |-- 10:3-93 HFP-11 "A/L3/AE3021/SD93/Pantry"
|      |      |      |-- 10:3-95 HFP-11 "A/L3/AE3021/SD95/Reception psg"
|      |      |      |-- 10:3-96 HTRI-R "A/L3/AE3021/CM96/Entry dr psg"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:3-97 HMS-S/D/M/SA "A/L3/AE3021/MCP97/Entry dr psg"
|      |      |      |-- 10:3-98 HFP-11 "A/L3/AE3071/SD98/DINNING CABIN "
|      |      |      |-- 10:3-108 HMS-S/D/M/SA "A/L3/AW3110/MCP108/Entry Door"
|      |      |      |-- 10:3-109 HFP-11 "A/L3/AE3022/SD109/Mani Cab"
|      |      |      |-- 10:3-110 HFP-11 "A/L3/AE3022/SD110/Assotors Cab"
|      |      |      |-- 10:3-111 HFP-11 "A/L3/AE3022/SD111/Psg Nr. Pantry"
|      |      |      |-- 10:3-112 HFPT-11 "A/L3/AE3022/HD112/Pantry"
|      |      |      |-- 10:3-113 HTRI-R "A/L3/AE3022/CM113/Assortor Cab A"
|      |      |      |-- Switch ""
|      |      |      |-- Relay
|      |      |      |-- 10:3-114 HMS-S/D/M/SA "A/L3/AE3022/SD114/Entry DR Psg"
|      |      |      |-- 10:3-115 HTRI-S "A/L3/3F/MM115/AE3090"
|      |      |      |-- 10:3-116 HFP-11 "A/L3/WC/SD116/AW3110/Entry Door"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local
CAB-2 "CAB-2 Enclosure #1"
CC-5 "Card Cage 5 Slots"

```
|      | |  |-- 10:4 XDLC "DLC @ address 4 E/W 4th FLOOR"
|      | |  |-- 10:4-1 HTRI-R "A/L4/EC/4F/CM1/FIRE HYD SHAFT"
|      | |  |  |-- Switch ""
|      | |  |  |-- Relay
|      | |  |  |-- 10:4-2 HTRI-S "A/L4/EC/4F/MM2/FIRE HYD SHAFT"
|      | |  |-- 10:4-3 HMS-S/D/M/SA "A/L4/EC/4F/MCP3/LIFT LOBBY STR"
|      | |  |-- 10:4-4 FDOT421 "A/L4/EC/4F/SD4/LIFT LOBBY"
|      | |  |-- 10:4-5 HTRI-R "A/L4/EC/4F/CM5/DOOR RELEASE U"
|      | |  |  |-- Switch ""
|      | |  |  |-- Relay
|      | |  |  |-- 10:4-6 HTRI-R "A/L4/EC/4F/CM6/AHU ROOM"
|      | |  |  |-- Switch ""
|      | |  |  |-- Relay
|      | |  |  |-- 10:4-7 FDOT421 "A/L4/EC/4F/SD7/AHU ROOM"
|      | |  |-- 10:4-8 FDOT421 "A/L4/EC/4F/SD8/ELECTRICAL ROOM"
|      | |  |-- 10:4-9 FDOT421 "A/L4/EC/4F/SD9/AFC COR NR AE4070"
|      | |  |-- 10:4-10 FDOT421 "A/L4/EC/4F/SD10/COR NR AE4070"
|      | |  |-- 10:4-11 FDOT421 "A/L4/EC/4F/SD11/AFC CORR AE4011"
|      | |  |-- 10:4-12 FDOT421 "A/L4/EC/4F/SD12/CORRIDOR AE2/S02"
|      | |  |-- 10:4-13 FDOT421 "A/L4/EC/4F/SD13/CORR NR AE4012"
|      | |  |-- 10:4-14 FDOT421 "A/L4/EC/4F/SD14/CORR NR AE4020"
|      | |  |-- 10:4-15 HTRI-R "A/L4/EC/4F/CM15/CORR STR CASE"
|      | |  |  |-- Switch ""
|      | |  |  |-- Relay
|      | |  |  |-- 10:4-16 HMS-S/D/M/SA "A/L4/EC/4F/MCP16/CORR STR CASE"
|      | |  |-- 10:4-17 FDOT421 "A/L4/E/4F/SD17/AFC CORNrAE4 S/10"
|      | |  |-- 10:4-18 FDOT421 "A/L4/EC/4F/SD18/CORRIDOR AE4032A"
|      | |  |-- 10:4-19 FDOT421 "A/L4/EC/4F/SD19/AFC COR NR AE404"
|      | |  |-- 10:4-20 FDOT421 "A/L4/EC/4F/SD20/CORRIDOR AE4032C"
|      | |  |-- 10:4-21 FDOT421 "A/L4/EC/4F/SD21/AFC COR AE S/09"
|      | |  |-- 10:4-22 FDOT421 "A/L4/EC/4F/SD22/CORRIDOR AE4032D"
|      | |  |-- 10:4-23 FDOT421 "A/L4/WC/4F/SD23/AFC COR ELE RM"
|      | |  |-- 10:4-24 FDOT421 "A/L4/WC/4F/SD24/OUTSIDE ELECT RM"
|      | |  |-- 10:4-25 HTRI-R "A/L4/WC/4F/CM25/DOOR RELEASE U"
|      | |  |  |-- Switch ""
|      | |  |  |-- Relay
|      | |  |  |-- 10:4-26 FDOT421 "A/L4/WC/4F/SD26/ELECTRICAL ROOM"
|      | |  |-- 10:4-27 HMS-S/D/M/SA "A/L4/WC/4F/MCP27/LIFT LOBBY STR"
|      | |  |-- 10:4-28 HTRI-R "A/L4/WC/4F/CM28/FIRE HYD SHAFT"
|      | |  |  |-- Switch ""
|      | |  |  |-- Relay
|      | |  |  |-- 10:4-29 XTRI-S "A/L4/WC/4F/MM29/FIRE HYD SHAFT"
|      | |  |-- 10:4-30 FDOT421 "A/L4/WC/4F/SD30/LIFT LOBBY"
|      | |  |-- 10:4-31 FDOT421 "A/L4/WC/4F/SD31/LIFT LOBBY"
|      | |  |-- 10:4-32 HTRI-R "A/L4/WC/4F/CM32/DOOR RELEASE U"
|      | |  |  |-- Switch ""
|      | |  |  |-- Relay
|      | |  |  |-- 10:4-33 HTRI-R "A/L4/WC/4F/CM33/AHU ROOM"
|      | |  |  |-- Switch ""
|      | |  |  |-- Relay
```


10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:4 XDLC "DLC @ address 4 E/W 4th FLOOR"

```
|      |      |      |-- 10:4-34 FDOT421 "A/L4/WC/4F/SD34/AHU ROOM"
|      |      |      |-- 10:4-35 FDOT421 "A/L4/WC/4F/SD35/AFC CORR AHU RM"
|      |      |      |-- 10:4-36 FDOT421 "A/L4/WC/4F/SD36/CORR AW4/S07"
|      |      |      |-- 10:4-37 FDOT421 "A/L4/WC/4F/SD37/CORR AW4140"
|      |      |      |-- 10:4-38 HTRI-S "A/L4/4F/MM38/AE4032B"
|      |      |      |-- 10:4-39 HTRI-S "A/L4/4F/MM39/AE4032C"
|      |      |      |-- 10:4-42 HTRI-S "A/L4/4F/MM42/AE4011"
|      |      |      |-- 10:4-43 HTRI-S "A/L4/4F/MM43/AE4060"
|      |      |      |-- 10:4-45 HTRI-S "A/L4/4F/MM45/AE4020"
|      |      |      |-- 10:4-46 HTRI-S "A/L4/4F/MM46/AE4050"
|      |      |      |-- 10:4-47 HTRI-S "A/L4/4F/MM47/AE4031"
|      |      |      |-- 10:4-48 HTRI-S "A/L4/4F/MM48/AE4032A"
|      |      |      |-- 10:4-49 HTRI-S "A/L4/4F/MM49/AE4042B"
|      |      |      |-- 10:4-50 HTRI-S "A/L4/4F/MM50/AE4032D"
|      |      |      |-- 10:4-51 HTRI-S "A/L4/P1/4F/MM51/AE4042A""
|      |      |      |-- 10:4-52 HTRI-S "A/L4/4F/MM52/AW4010"
|      |      |      |-- 10:4-54 XTRI-S "A/L4/4F/MM54/AW4150"
|      |      |      |-- 10:4-55 XTRI-S "A/L4/4F/MM55/AW4021/22"
|      |      |      |-- 10:4-56 XTRI-S "A/L4/4F/MM56/AW4140"
|      |      |      |-- 10:4-57 HFP-11 "A/L4/AE4012/SD57/Accounts Cabin"
|      |      |      |-- 10:4-58 HFPT-11 "A/L4/AE4012/HD58/Pantry Area"
|      |      |      |-- 10:4-59 HFP-11 "A/L4/AE4012/SD59/Main cabin"
|      |      |      |-- 10:4-60 HFP-11 "A/L4/AE4012/SD60/Passage Area"
|      |      |      |-- 10:4-61 HFP-11 "A/L4/AE4012/SD61/Conference Room"
|      |      |      |-- 10:4-62 HFP-11 "A/L4/AE4012/SD62/Assorter Room"
|      |      |      |-- 10:4-63 HFP-11 "A/L4/AE4012/SD63/Main Cabin-1"
|      |      |      |-- 10:4-64 HFP-11 "A/L4/AE4012/SD64/Main Cabin-2"
|      |      |      |-- 10:4-65 HTRI-R "A/L4/AE4012/CM65/Entry door"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:4-66 HMS-S/D/M/SA "A/L4/AE4012/MCP66/Entry door"
|      |      |      |-- 10:4-67 HFP-11 "A/L4/AE4041/SD67/Main Cabin-1"
|      |      |      |-- 10:4-68 HFP-11 "A/L4/AE4041/SD68/Main Cabin-2"
|      |      |      |-- 10:4-69 HFP-11 "A/L4/AE4041/SD69/Passage Area"
|      |      |      |-- 10:4-70 HFP-11 "A/L4/AE4041/SD70/Assorter Room"
|      |      |      |-- 10:4-71 HTRI-R "A/L4/AE4041/CM71/Entry Door"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:4-72 HMS-S/D/M/SA "A/L4/AE4041/MCP72/Entry Door"
|      |      |      |-- 10:4-83 HFP-11 "A/L4/AE4070/SD83/Main cabin"
|      |      |      |-- 10:4-84 HFP-11 "A/L4/AE4070/SD84/Pantry"
|      |      |      |-- 10:4-85 HTRI-R "A/L4/AE4070/CM85/Entry Door"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:4-86 HMS-S/D/M/SA "A/L4/AE4070/MCP86/Entry Door"
|      |      |      |-- 10:5 XDLC "DLC @ address 5 E/W 5th FLOOR"
|      |      |      |-- 10:5-1 HTRI-R "A/L5/EC/5F/CM1/FIRE HYD SHAFT"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:5-2 XTRI-S "A/L5/EC/5F/MM2/FIRE HYD SHAFT"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:5 XDLC "DLC @ address 5 E/W 5th FLOOR"

| | |-- 10:5-3 HMS-S/D/M/SA "A/L5/EC/5F/MCP3/LIFT LOBBY STR"
| | |-- 10:5-4 FDOT421 "A/L5/EC/5F/SD4/LIFT LOBBY"
| | |-- 10:5-5 HTRI-R "A/L5/EC/5F/CM5/DOOR RELEASE U"
| | | |-- Switch ""
| | | |-- Relay
| | |-- 10:5-6 HTRI-R "A/L5/EC/5F/CM6/AHU ROOM"
| | | |-- Switch ""
| | | |-- Relay
| | |-- 10:5-7 FDOT421 "A/L5/EC/5F/SD7/AHU ROOM"
| | |-- 10:5-8 FDOT421 "A/L5/EC/5F/SD8/ELECTRICAL ROOM"
| | |-- 10:5-9 FDOT421 "A/L5/EC/5F/SD9/AFC CORR AE5021 "
| | |-- 10:5-10 FDOT421 "A/L5/EC/5F/SD10/CORRIDOR AE 5010"
| | |-- 10:5-11 FDOT421 "A/L5/EC/5F/SD11/CORR AE5/S02"
| | |-- 10:5-12 FDOT421 "A/L5/EC/5F/SD12/CORRIDOR AE5030"
| | |-- 10:5-13 FDOT421 "A/L5/EC/5F/SD13/AFC CORR AE 5030"
| | |-- 10:5-14 FDOT421 "A/L5/EC/5F/SD14/CORR NR STR CASE"
| | |-- 10:5-15 HTRI-R "A/L5/EC/5F/CM15/CORR NR STR CASE"
| | | |-- Switch ""
| | | |-- Relay
| | |-- 10:5-16 HMS-S/D/M/SA "A/L5/EC/5F/MCP16/CORR STR CASE"
| | |-- 10:5-17 FDOT421 "A/L5/EC/5F/SD17/AFC CORR AE5050"
| | |-- 10:5-18 FDOT421 "A/L5/EC/5F/SD18/CORRIDOR AE 5040"
| | |-- 10:5-19 FDOT421 "A/L5/EC/5F/SD19/CORRIDOR AE 5080"
| | |-- 10:5-20 FDOT421 "A/L5/EC/5F/SD20/AFC CORR AE5070"
| | |-- 10:5-21 FDOT421 "A/L5/EC/5F/SD21/CORR NR ELE RM"
| | |-- 10:5-22 FDOT421 "A/L5/WC/5F/SD22/ELECTRICAL ROOM"
| | |-- 10:5-23 HTRI-R "A/L5/WC/5F/CM23/DOOR RELEASE U"
| | | |-- Switch ""
| | | |-- Relay
| | |-- 10:5-24 HMS-S/D/M/SA "A/L5/WC/5F/MCP24/LIFT LOBBY STR"
| | |-- 10:5-25 HTRI-R "A/L5/WC/5F/CM25/FIRE HYD SHAFT"
| | | |-- Switch ""
| | | |-- Relay
| | |-- 10:5-26 XTRI-S "A/L5/WC/5F/MM26/FIRE HYD SHAFT"
| | |-- 10:5-27 FDOT421 "A/L5/WC/5F/SD27/LIFT LOBBY"
| | |-- 10:5-28 FDOT421 "A/L5/WC/5F/SD28/LIFT LOBBY"
| | |-- 10:5-29 HTRI-R "A/L5/WC/5F/CM29/DOOR RELEASE U"
| | | |-- Switch ""
| | | |-- Relay
| | |-- 10:5-30 HTRI-R "A/L5/WC/5F/CM30/AHU ROOM"
| | | |-- Switch ""
| | | |-- Relay
| | |-- 10:5-31 FDOT421 "A/L5/WC/5F/SD31/AHU ROOM"
| | |-- 10:5-32 FDOT421 "A/L5/WC/5F/SD32/CORR AW5130AFC"
| | |-- 10:5-33 FDOT421 "A/L5/WC/5F/SD33/CORR AW5130"
| | |-- 10:5-34 FDOT421 "A/L5/WC/5F/SD34/AFC CORR AW5020"
| | |-- 10:5-35 FDOT421 "A/L5/WC/5F/SD35/CORRIDOR AW5020"
| | |-- 10:5-36 HTRI-S "A/L5/5F/MM36/AW5130"
| | |-- 10:5-42 HTRI-S "A/L5/5F/MM42/AE5021"
| | |-- 10:5-43 HTRI-S "A/L5/5F/MM43/AE5110"

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:5 XDLC "DLC @ address 5 E/W 5th FLOOR"

```
|      |      |-- 10:5-44 HTRI-S "A/L5/5F/MM44/AE5030A"
|      |      |-- 10:5-46 HTRI-S "A/L5/5F/MM46/AE5100"
|      |      |-- 10:5-47 HTRI-S "A/L5/5F/MM47/AE5040"
|      |      |-- 10:5-49 HTRI-S "A/L5/5F/MM49/AE5050"
|      |      |-- 10:5-50 HTRI-S "A/L5/5F/MM50/AE5080"
|      |      |-- 10:5-51 HTRI-S "A/L5/5F/MM51/AE5060"
|      |      |-- 10:5-52 HTRI-S "A/L5/5F/MM52/AE5070"
|      |      |-- 10:5-53 HTRI-S "A/L5/5F/MM53/AW5010"
|      |      |-- 10:5-55 HTRI-S "A/L5/5F/MM55/AW5122"
|      |      |-- 10:5-56 HTRI-S "A/L5/5F/MM56/AW5121"
|      |      |-- 10:5-57 HTRI-S "A/L5/5F/MM57/AW5020"
|      |      |-- 10:5-59 HTRI-S "A/L5/5F/MM59/AE5010"
|      |      |-- 10:5-60 HFP-11 "A/L5/AW5030/SD60/Main cabin"
|      |      |-- 10:5-61 HFP-11 "A/L5/AW5030/SD61/Store Room"
|      |      |-- 10:5-62 HFP-11 "A/L5/AW5030/SD62/Conference room"
|      |      |-- 10:5-63 HFP-11 "A/L5/AW5030/SD63/Account Departm"
|      |      |-- 10:5-64 HFP-11 "A/L5/AW5030/SD64/Tiffin room"
|      |      |-- 10:5-65 HFP-11 "A/L5/AW5030/SD65/Reception"
|      |      |-- 10:5-66 HTRI-R "A/L5/AW5030/CM66/Entry Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:5-67 HMS-S/D/M/SA "A/L5/AW5030/MCP67/Entry Door"
|      |      |-- 10:5-68 HFP-11 "A/L5/AW5030/SD68/Pantry"
|      |      |-- 10:5-69 FDOT421 "A/L5/AE5030/SD69/Passage Area"
|      |      |-- 10:5-70 HFPT-11 "A/L5/AE5030/HD70/Pantry "
|      |      |-- 10:5-71 HFP-11 "A/L5/AE5030/SD71/Assorter Room 1"
|      |      |-- 10:5-72 HFP-11 "A/L5/AE5030/SD72/Assorter Room 2"
|      |      |-- 10:5-73 HFP-11 "A/L5/AE5030/SD73/Assorter Room 3"
|      |      |-- 10:5-74 HFP-11 "A/L5/AE5030/SD74/Assorter Room 4"
|      |      |-- 10:5-75 HFP-11 "A/L5/AE5030/SD75/Assorter Room 5"
|      |      |-- 10:5-76 HFP-11 "A/L5/AE5030/SD76/Locker Room"
|      |      |-- 10:5-77 HFP-11 "A/L5/AE5030/SD77/Main Cabin"
|      |      |-- 10:5-78 HTRI-R "A/L5/AE5030/CM78/Entry Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:5-79 HMS-S/D/M/SA "A/L5/AE5030/MCP79/Entry Door"
|      |      |-- 10:5-84 HFP-11 "A/L5/AE5090/SD84/Pantry Area"
|      |      |-- 10:5-85 HFP-11 "A/L5/AE5090/SD85/Passage Area"
|      |      |-- 10:5-86 HFP-11 "A/L5/AE5090/SD86/Main cabin"
|      |      |-- 10:5-87 HFP-11 "A/L5/AE5090/SD87/Cabin 1"
|      |      |-- 10:5-88 HTRI-R "A/L5/AE5090/CM88/Entry Door"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:5-89 HMS-S/D/M/SA "A/L5/AE5090/MCP89/Entry Door"
|      |  |-- CC-5 "Card Cage 5 Slots"
|      |  |-- 10:6 XDLC "DLC @ address 6 E/W 6th FLOOR"
|      |  |  |-- 10:6-1 HTRI-R "A/L6/EC/6F/CM1/FIRE HYD SHAFT"
|      |  |  |  |-- Switch ""
|      |  |  |  |-- Relay
|      |  |  |-- 10:6-2 HTRI-S "A/L6/EC/6F/MM2/FIRE HYD SHAFT"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:6 XDLC "DLC @ address 6 E/W 6th FLOOR"

			-- 10:6-3 HMS-S/D/M/SA "A/L6/EC/6F/MCP3/LIFT LOBBY STR"
			-- 10:6-4 FDOT421 "A/L6/EC/6F/SD4/LIFT LOBBY"
			-- 10:6-5 HTRI-R "A/L6/EC/6F/CM5/DOOR RELEASE U"
			-- Switch ""
			-- Relay
			-- 10:6-6 HTRI-R "A/L6/EC/6F/CM6/AHU ROOM"
			-- Switch ""
			-- Relay
			-- 10:6-7 FDOT421 "A/L6/EC/6F/SD7/AHU ROOM"
			-- 10:6-8 FDOT421 "A/L6/EC/6F/SD8/ELECTRICAL ROOM"
			-- 10:6-9 FDOT421 "A/L6/EC/6F/SD9/AFC CORR NR AHU R"
			-- 10:6-10 FDOT421 "A/L6/EC/6F/SD10/CORR NR AHU RM"
			-- 10:6-11 FDOT421 "A/L6/WC/6F/SD11/AFC COR AW6/S03"
			-- 10:6-12 FDOT421 "A/L6/WC/6F/SD12/COR AW6/03"
			-- 10:6-13 FDOT421 "A/L6/WC/6F/SD13/AFC CORR AW6060"
			-- 10:6-14 FDOT421 "A/L6/WC/6F/SD14/CORRIDOR AW 6060"
			-- 10:6-15 HTRI-R "A/L6/WC/6F/CM15/CORR STR CASE"
			-- Switch ""
			-- Relay
			-- 10:6-16 HMS-S/D/M/SA "A/L6/WC/6F/MCP16/CORR STR CASE"
			-- 10:6-17 FDOT421 "A/L6/WC/6F/SD17/CORRIDOR AW 6071"
			-- 10:6-18 FDOT421 "A/L6/WC/6F/SD18/AFC COR AW 6080"
			-- 10:6-19 FDOT421 "A/L6/WC/6F/SD19/CORRIDOR AW6/S05"
			-- 10:6-20 FDOT421 "A/L6/WC/6F/SD20/AFC CORR AW6020"
			-- 10:6-21 FDOT421 "A/L6/WC/6F/SD21/CORR AW6/S09"
			-- 10:6-22 HTRI-R "A/L6/WC/6F/CM22/DOOR RELEASE U"
			-- Switch ""
			-- Relay
			-- 10:6-23 FDOT421 "A/L6/WC/6F/SD23/ELECTRICAL ROOM"
			-- 10:6-24 HMS-S/D/M/SA "A/L6/WC/6F/MCP24/LIFT LOBBY STR"
			-- 10:6-25 HTRI-R "A/L6/WC/6F/CM25/FIRE HYD SHAFT"
			-- Switch ""
			-- Relay
			-- 10:6-26 HTRI-S "A/L6/WC/6F/MM26/FIRE HYD SHAFT"
			-- 10:6-27 FDOT421 "A/L6/WC/6F/SD27/LIFT LOBBY"
			-- 10:6-28 FDOT421 "A/L6/WC/6F/SD28/LIFT LOBBY"
			-- 10:6-29 XTRI-R "A/L6/WC/6F/CM29/DOOR RELEASE U"
			-- Switch ""
			-- Relay
			-- 10:6-30 HTRI-R "A/L6/WC/6F/CM30/AHU ROOM"
			-- Switch ""
			-- Relay
			-- 10:6-31 FDOT421 "A/L6/WC/6F/SD31/AHU ROOM"
			-- 10:6-32 FDOT421 "A/L6/WC/6F/SD32/AFC CORR AW6252"
			-- 10:6-33 FDOT421 "A/L6/WC/6F/SD33/CORRIDOR AW6252"
			-- 10:6-34 FDOT421 "A/L6/WC/6F/SD34/AFC COR AW6251"
			-- 10:6-35 FDOT421 "A/L6/WC/6F/SD35/CORRIDOR AW6251"
			-- 10:6-40 XTRI-S "A/L6/6F/MM40/AW6020"
			-- 10:6-41 HTRI-S "A/L6/6F/MM41/AW6053"
			-- 10:6-42 XTRI-S "A/L6/6F/MM42/AW6052"

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:6 XDLC "DLC @ address 6 E/W 6th FLOOR"

```
|      |      |      |-- 10:6-44 HTRI-S "A/L6/6F/MM44/AW6040"
|      |      |      |-- 10:6-46 HTRI-S "A/L6/6F/MM46/AW6071"
|      |      |      |-- 10:6-48 HTRI-S "A/L6/6F/MM48/AW6030"
|      |      |      |-- 10:6-50 HTRI-S "A/L6/6F/MM50/AW6090"
|      |      |      |-- 10:6-52 HTRI-S "A/L6/6F/MM52/AW6010"
|      |      |      |-- 10:6-53 HTRI-S "A/L6/6F/MM53/AW6100"
|      |      |      |-- 10:6-54 XTRI-S "A/L6/6F/MM54/AW6110"
|      |      |      |-- 10:6-57 HTRI-S "A/L6/6F/MM57/AW6251"
|      |      |      |-- 10:6-58 HTRI-S "A/L6/6F/MM58/AE6011"
|      |      |      |-- 10:6-59 HFP-11 "A/L6/AW6080/SD59/MAIN CABIN"
|      |      |      |-- 10:6-60 HFP-11 "A/L6/AW6080/SD60/ACCOUNT CAB"
|      |      |      |-- 10:6-61 HFP-11 "A/L6/AW6080/SD61/PASSASGE AREA"
|      |      |      |-- 10:6-62 HFP-11 "A/L6/AW6080/SD62/PANTRY AREA"
|      |      |      |-- 10:6-63 HMS-S/D/M/SA "A/L6/AW6080/MCP63/PASSAGE AREA"
|      |      |      |-- 10:6-64 HTRI-R "A/L6/AW6080/CM64/PASSAGE AREA"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:6-65 HFP-11 "A/L6/AW6240/SD65/Accounts Cab"
|      |      |      |-- 10:6-66 HFP-11 "A/L6/AW6240/SD66/Main cab"
|      |      |      |-- 10:6-67 HFP-11 "A/L6/AW6240/SD67/Assorter cab"
|      |      |      |-- 10:6-68 HFP-11 "A/L6/AW6240/SD68/Assorter cab"
|      |      |      |-- 10:6-69 HFP-11 "A/L6/AW6240/SD69/Pantry"
|      |      |      |-- 10:6-70 HTRI-R "A/L6/AW6240/CM70/Psg nr Entry do"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:6-71 HMS-S/D/M/SA "A/L6/AW6240/MCP71/Psg nr Entry d"
|      |      |      |-- 10:6-83 HFP-11 "A/L6/AW6260/SD83/PAS NR ENTRY"
|      |      |      |-- 10:6-84 HFP-11 "A/L6/AW6260/SD84/ASSORTER CAB"
|      |      |      |-- 10:6-85 HMS-S/D/M/SA "A/L6/AW6260/MCP85/Passage Near E"
|      |      |      |-- 10:6-86 HTRI-R "A/L6/AW6260/CM86/Passage Near En"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:6-90 HFP-11 "A/L6/AW6060/SD90/Pantry"
|      |      |      |-- 10:6-91 HFP-11 "A/L6/AW6060/SD91/ASSORTER CAB"
|      |      |      |-- 10:6-92 HFP-11 "A/L6/AW6060/SD92/ASSORTER CAB"
|      |      |      |-- 10:6-93 HTRI-R "A/L6/AW6060/CM93/Entry dr Psg"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:6-94 HMS-S/D/M/SA "A/L6/AW6060/MCP94/Entry dr Psg"
|      |      |      |-- 10:7 XDLC "DLC @ address 7 E/W 7th FLOOR"
|      |      |      |-- 10:7-1 HTRI-R "A/L7/EC/7F/CM1/FIRE HYD SHAFT"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:7-2 HTRI-S "A/L7/EC/7F/MM2/FIRE HYD SHAFT"
|      |      |      |-- 10:7-3 HMS-S/D/M/SA "A/L7/EC/7F/MCP3/LIFT LOBBY STR"
|      |      |      |-- 10:7-4 FDOT421 "A/L7/EC/7F/SD4/LIFT LOBBY"
|      |      |      |-- 10:7-5 HTRI-R "A/L7/EC/7F/CM5/DOOR RELEASE U"
|      |      |      |      |-- Switch ""
|      |      |      |      |-- Relay
|      |      |      |-- 10:7-6 HTRI-R "A/L7/EC/7F/CM6/AHU ROOM"
```

```
| | | | Switch ""
| | | | -- Relay
| | | | -- 10:7-7 FDOT421 "A/L7/EC/7F/SD7/AHU ROOM"
| | | | -- 10:7-8 FDOT421 "A/L7/EC/7F/SD8/ELECTRICAL ROOM"
| | | | -- 10:7-9 FDOT421 "A/L7/EC/7F/SD9/NR ELEC RM"
| | | | -- 10:7-10 FDOT421 "A/L7/EC/7F/SD10/AFC CORR NR ELE "
| | | | -- 10:7-11 FDOT421 "A/L7/EC/7F/SD11/CORRIDOR AE7/S12"
| | | | -- 10:7-12 FDOT421 "A/L7/EC/7F/SD12/AFC CORR AE7093"
| | | | -- 10:7-13 FDOT421 "A/L7/EC/7F/SD13/CORRIDOR AE 7021"
| | | | -- 10:7-14 FDOT421 "A/L7/EC/7F/SD14/AFC AE7/S11"
| | | | -- 10:7-15 FDOT421 "A/L7/EC/7F/SD15/CORRIDOR AE7030"
| | | | -- 10:7-16 HTRI-R "A/L7/EC/7F/CM16/CORR STR CASE"
| | | | | Switch ""
| | | | | Relay
| | | | -- 10:7-17 HMS-S/D/M/SA "A/L7/EC/7F/MCP17/CORR STR CASE"
| | | | -- 10:7-18 FDOT421 "A/L7/EC/7F/SD18/CORRIDOR AE 7040"
| | | | -- 10:7-19 FDOT421 "A/L7/EC/7F/SD19/CORRIDOR AE 7060"
| | | | -- 10:7-20 FDOT421 "A/L7/EC/7F/SD20/AFC CORR AE 7080"
| | | | -- 10:7-21 FDOT421 "A/L7/EC/7F/SD21/AFC CORR AE7/S09"
| | | | -- 10:7-22 FDOT421 "A/L7/EC/7F/SD22/CORRIDOR AE 7070"
| | | | -- 10:7-23 FDOT421 "A/L7/WC/7F/SD23/ELECTRICAL ROOM"
| | | | -- 10:7-24 HTRI-R "A/L7/WC/7F/CM24/DOOR RELEASE U"
| | | | | Switch ""
| | | | | Relay
| | | | -- 10:7-25 HMS-S/D/M/SA "A/L7/WC/7F/MCP25/LIFT LOBBY STR"
| | | | -- 10:7-26 HTRI-R "A/L7/WC/7F/CM26/FIRE HYD SHAFT"
| | | | | Switch ""
| | | | | Relay
| | | | -- 10:7-27 HTRI-S "A/L7/WC/7F/MM27/FIRE HYD SHAFT"
| | | | -- 10:7-28 FDOT421 "A/L7/WC/7F/SD28/LIFT LOBBY"
| | | | -- 10:7-29 FDOT421 "A/L7/WC/7F/SD29/LIFT LOBBY"
| | | | -- 10:7-30 HTRI-R "A/L7/WC/7F/CM30/AHU ROOM"
| | | | | Switch ""
| | | | | Relay
| | | | -- 10:7-31 FDOT421 "A/L7/WC/7F/SD31/AHU ROOM"
| | | | -- 10:7-32 FDOT421 "A/L7/WC/TERCE/SD32/LIFT MACHINE "
| | | | -- 10:7-33 FDOT421 "A/L7/WC/TERCE/SD33/LIFT MACHINE "
| | | | -- 10:7-34 HTRI-R "A/L7/WC/7F/CM34/AW TERRACE"
| | | | | Switch ""
| | | | | Relay
| | | | -- 10:7-41 HTRI-S "A/L7/7F/MM41/AE7093"
| | | | -- 10:7-42 HTRI-S "A/L7/7F/MM42/AE7010"
| | | | -- 10:7-43 HTRI-S "A/L7/7F/MM43/AE7021"
| | | | -- 10:7-44 XTRI-S "A/L7/7F/MM44/AE7022"
| | | | -- 10:7-45 HTRI-S "A/L7/7F/MM45/AE7092"
| | | | -- 10:7-46 HTRI-S "A/L7/7F/MM46/AE7030"
| | | | -- 10:7-47 HTRI-S "A/L7/7F/MM47/AE7091"
| | | | -- 10:7-49 HTRI-S "A/L7/7F/MM49/AE7050"
| | | | -- 10:7-50 HTRI-S "A/L7/7F/MM50/AE7060"
| | | | -- 10:7-51 HTRI-S "A/L7/7F/MM51/AE7080"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:7 XDLC "DLC @ address 7 E/W 7th FLOOR"

				--	10:7-52	HTRI-S	"A/L7/7F/MM52/AE7070"
				--	10:7-53	HTRI-S	"A/L7/7F/MM53/AW7010"
				--	10:7-55	HFP-11	"A/L7/AE7040/SD55/Main Cabin"
				--	10:7-56	HFP-11	"A/L7/AE7040/SD56/Assorter Room"
				--	10:7-57	HFP-11	"A/L7/AE7040/SD57/Passage nr Asst"
				--	10:7-58	HFP-11	"A/L7/AE7040/SD58/Assorter Cab2"
				--	10:7-59	HTRI-R	"A/L7/AE7040/CM59/Entry Door"
				--	Switch	"	"
				--	Relay	"	"
				--	10:7-60	HMS-S/D/M/SA	"A/L7/AE7040/MCP60/Entry Door"
				--	10:7-61	HFP-11	"A/L7/AW7020/SD61/Cabin 1"
				--	10:7-62	HFP-11	"A/L7/AW7020/SD62/Passage Area"
				--	10:7-63	HFP-11	"A/L7/AW7020/SD63/ASSORTER CAB"
				--	10:7-64	HTRI-R	"A/L7/AW7020/CM64/Entry Door"
				--	Switch	"	"
				--	Relay	"	"
				--	10:7-65	HMS-S/D/M/SA	"A/L7/AW7020/MCP65/ENTRY PSG."
				--	10:8	XDLC	"DLC @ address 8 E/W GND FLOOR"
				--	10:8-1	FDOT421	"A/L8/EC/GF/SD1/AFC LIFT LOBBY"
				--	10:8-2	FDOT421	"A/L8/EC/GF/SD2/INSIDE TICKET COU"
				--	10:8-3	FDOT421	"A/L8/EC/GF/SD3/LIFT LOBBY"
				--	10:8-4	HTRI-S	"A/L8/EC/GF/MM4/AFC LL SHAFT"
				--	10:8-5	HTRI-R	"A/L8/EC/GF/CM5/AFC LL SHAFT"
				--	Switch	"	"
				--	Relay	"	"
				--	10:8-6	HMS-S/D/M/SA	"A/L8/EC/GF/MCP6/LIFT LOBBY"
				--	10:8-7	FDOT421	"A/L8/EC/GF/SD7/AHU ROOM"
				--	10:8-8	HTRI-R	"A/L8/EC/GF/CM8/AHU ROOM"
				--	Switch	"	"
				--	Relay	"	"
				--	10:8-9	FDOT421	"A/L8/EC/GF/SD9/ELECT ROOM"
				--	10:8-10	FDOT421	"A/L8/EC/GF/SD10/LIFT LOBBY"
				--	10:8-12	FDOT421	"A/L8/WC/GF/SD12/LIFT LOBBY"
				--	10:8-13	FDOT421	"A/L8/WC/GF/SD13/LIFT LOBBY"
				--	10:8-14	FDOT421	"A/L8/WC/GF/SD14/LIFT LOBBY"
				--	10:8-15	FDOT421	"A/L8/WC/GF/SD15/LIFT LOBBY"
				--	10:8-16	HMS-S/D/M/SA	"A/L8/WC/GF/MCP16/LIFT LOBBY"
				--	10:8-17	FDOT421	"A/L8/WC/GF/SD17/ELECT ROOM"
				--	10:8-18	FDOT421	"A/L8/WC/GF/SD18/AHU ROOM"
				--	10:8-19	HTRI-R	"A/L8/WC/GF/CM19/AHU ROOM"
				--	Switch	"	"
				--	Relay	"	"
				--	10:8-20	HTRI-R	"A/L8/WC/GF/AFC LL CM20/FOR HTR"
				--	Switch	"	"
				--	Relay	"	"
				--	10:8-22	HTRI-S	"A/L8/WC/GF/AFC LL MM22/SHAFT"
				--	10:8-23	FDOT421	"A/L8/WC/GF/SD23/SECUR CABIN LL"
				--	10:8-24	HTRI-S	"A/L8/WC/GND/MM24/NR AHU Room AFC"
				--	10:8-50	HFPT-11	"A/A/L8/AE/GF/HD50/FOOD COUNTER 1"
				--	10:8-51	HFPT-11	"A/L8/AE/GF/HD51/FOOD COUNTER 2"

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:8 XDLC "DLC @ address 8 E/W GND FLOOR"

			-- 10:8-52 HFPT-11 "A/L8/AE/GF/HD52/FOOD COUNTER 3"
			-- 10:8-53 HFPT-11 "A/L8/AE/GF/HD53/FOOD COUNTER 4"
			-- 10:8-54 FDOT421 "A/L8/AE/GF/SD54/Psg FOOD COUNT 2"
			-- 10:8-55 FDOT421 "A/L8/AE/GF/SD55/Psg FOOD COUNT 1"
			-- 10:8-56 XTRI-R "A/L8/AE/GF/CM56/FoodCont Ent Psg"
			-- Switch ""
			-- Relay
			-- 10:8-57 HMS-S/D/M/SA "A/L8/AE/GF/MCP57/FoodCont Ent Ps"
			-- 10:8-101 HTRI-R "A/L8/EC/UB/CM101/LIFT ROOM"
			-- Switch ""
			-- Relay
			-- 10:8-102 FDOT421 "A/L8/EC/UB/SD102/LIFT ROOM"
			-- 10:8-103 FDOT421 "A/L8/EC/UB/SD103/LIFT ROOM"
			-- 10:8-104 FDOT421 "A/L8/EC/UB/SD104/BMS ROOM"
			-- 10:8-105 FDOT421 "A/L8/EC/UB/SD105/ELEC ROOM"
			-- 10:8-106 HTRI-R "A/L8/EC/UB/CM106/ELEC ROOM"
			-- Switch ""
			-- Relay
			-- 10:8-107 FDOT421 "A/L8/EC/UB/SD107/DMS RM"
			-- 10:8-108 FDOT421 "A/L8/AE/UB/SD108/DMS RM"
			-- 10:8-110 HMS-S/D/M/SA "A/L8/WC/UB/MCP110/STAIRCASE"
			-- 10:8-111 HTRI-R "A/L8/WC/UB/CM111/STAIRCASE"
			-- Switch ""
			-- Relay
			-- 10:8-112 HTRI-S "A/L8/WC/UB/MM112/STAIRCASE"
			-- 10:8-113 HMS-S/D/M/SA "A/L8/EC/UB/MCP113/STAIRCASE 5"
			-- 10:8-114 HTRI-R "A/L8/EC/UB/CM114/STAIRCASE 5"
			-- Switch ""
			-- Relay
			-- 10:8-116 FDOT421 "A/L8/EC/UB/SD116/NR LIFT RM"
			-- 10:8-117 FDOT421 "A/L8/WC/UB/SD117/ELEC RM"
			-- 10:8-118 HTRI-R "A/L8/WC/UB/CM118/ELEC RM"
			-- Switch ""
			-- Relay
			-- 10:8-119 FDOT421 "A/L8/WC/UB/SD119/DRIVER ROOM"
			-- 10:8-120 FDOT421 "A/L8/WC/UB/SD120/FAN ROOM"
			-- 10:8-121 HMS-S/D/M/SA "A/L8/EC/UB/MCP121/NR. DMS ROOM"
			-- 10:8-122 HTRI-R "A/L8/EC/UB/CM122/NR. DMS ROOM"
			-- Switch ""
			-- Relay
			-- 10:8-124 HFP-11 "A/L8/EC/UB/SD124/NR. DMS ROOM"
			-- 10:8-151 HMS-S/D/M/SA "A/L8/WC/LB/MCP151/ST NR FAN RM 1"
			-- 10:8-152 HTRI-R "A/L8/WC/LB/CM152/ST NR FAN RM 1"
			-- Switch ""
			-- Relay
			-- 10:8-153 HMS-S/D/M/SA "A/L8/WC/LB/MCP153/ST NR FAN RM "
			-- 10:8-154 HTRI-R "A/L8/WC/LB/CM154/ST NR FAN RM 2"
			-- Switch ""
			-- Relay
			-- 10:8-155 HMS-S/D/M/SA "A/L8/WC/LB/MCP155/ST NR FAN RM 3"

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:8 XDLC "DLC @ address 8 E/W GND FLOOR"

```
|      |      |      |-- 10:8-156 HTRI-R "A/L8/WC/LB/CM156/ST NR FAN RM 3"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-157 HMS-S/D/M/SA "A/L8/WC/LB/MCP157/RAMP NO. 1"
|      |      |      |-- 10:8-158 HTRI-R "A/L8/WC/LB/CM158/RAMP NO. 1"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-159 HTRI-S "A/L8/EC/LB/MM159/FAN ROOM"
|      |      |      |-- 10:8-160 HMS-S/D/M/SA "A/L8/EC/LB/MCP160/BK OFF. FIRE E"
|      |      |      |-- 10:8-161 HTRI-R "A/L8/EC/LB/CM161/BK OFF. FIRE EX"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-162 FDOT421 "A/L8/EC/LB/SD162/FAN ROOM"
|      |      |      |-- 10:8-163 FDOT421 "A/L8/EC/LB/SD163/FAN ROOM"
|      |      |      |-- 10:8-164 FDOT421 "A/L8/EC/LB/SD164/FAN ROOM"
|      |      |      |-- 10:8-165 HMS-S/D/M/SA "A/L8/WC/LB/MCP165/NR FAN ROOM"
|      |      |      |-- 10:8-166 HTRI-R "A/L8/WC/LB/CM166/NR FAN ROOM"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-167 HMS-S/D/M/SA "A/L8/WC/LB/MCP167/EXIT PARK AREA"
|      |      |      |-- 10:8-168 XTRI-R "A/L8/WC/LB/CM168/EXIT PARK AREA "
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-169 FDOT421 "A/L8/WC/LB/SD169/FAN ROOM"
|      |      |      |-- 10:8-170 FDOT421 "A/L8/WC/LB/SD170/DMS RM"
|      |      |      |-- 10:8-171 HMS-S/D/M/SA "A/L8/UB/MCP171/DMS RM"
|      |      |      |-- 10:8-172 FDOT421 "A/L8/UB/SD172/DMS RM"
|      |      |      |-- 10:8-173 FDOT421 "A/L8/UB/SD173/DMS RM"
|      |      |      |-- 10:8-174 FDOT421 "A/L8/UB/SD174/DMS RM"
|      |      |      |-- 10:8-175 FDOT421 "A/L8/UB/SD175/DMS RM"
|      |      |      |-- 10:8-176 FDOT421 "A/L8/UB/SD176/DMS RM"
|      |      |      |-- 10:8-177 FDOT421 "A/L8/UB/SD177/DMS RM"
|      |      |      |-- 10:8-178 HMS-S/D/M/SA "A/L8/UB/MCP178/DMS RM"
|      |      |      |-- 10:8-179 FDOT421 "A/L8/UB/SD179/DMS RM"
|      |      |      |-- 10:8-180 FDOT421 "A/L8/UB/SD180/DMS RM"
|      |      |      |-- 10:8-181 FDOT421 "A/L8/UB/SD181/DMS RM"
|      |      |      |-- 10:8-182 FDOT421 "A/L8/UB/SD182/DMS RM"
|      |      |      |-- 10:8-183 FDOT421 "A/L8/UB/SD183/DMS RM"
|      |      |      |-- 10:8-184 FDOT421 "A/L8/UB/SD184/DMS RM"
|      |      |      |-- 10:8-185 FDOT421 "A/L8/UB/SD185/DMS RM"
|      |      |      |-- 10:8-186 HTRI-R "A/L8/UB/CM186/DMS RM Entry"
|      |      |      |  |-- Switch ""
|      |      |      |  |-- Relay
|      |      |      |-- 10:8-187 FDOT421 "A/L8/UB/SD187/DMS RM"
|      |      |      |-- 10:8-188 FDOT421 "A/L8/UB/SD188/DMS RM"
|      |      |      |-- 10:8-189 FDOT421 "A/L8/UB/SD189/DMS RM"
|      |      |      |-- 10:9 NIC-C(XNet) "NIC_Xnet @ address 9"
|      |      |      |-- 10:10 XDLC "L10/A/UB/BACK OFFICE"
|      |      |      |-- 10:10-3 FDOT421 "A/L10/UB/SD03/RECEPTION"
|      |      |      |-- 10:10-4 FDOT421 "A/L10/UB/SD04/AFC/RECEPTION"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:10 XDLC "L10/A/UB/BACK OFFICE"

```
|      |      |-- 10:10-5 HFPT-11 "A/L10/UB/HD05/CONFERANCE PANTRY"
|      |      |-- 10:10-7 FDOT421 "A/L10/UB/SD07/CONFERANCE RM"
|      |      |-- 10:10-9 HMS-S/D/M/SA "A/L10/UB/MCP09/ENT. RECEPT"
|      |      |-- 10:10-10 HTRI-R "A/L10/UB/CM10/ENT. RECEPT"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-11 FDOT421 "A/L10/UB/SD11/PRAKASH SIR CAB"
|      |      |-- 10:10-12 FDOT421 "A/L10/UB/SD12/LEGAL MET RM "
|      |      |-- 10:10-13 FDOT421 "A/L10/UB/SD13/AFC LEGAL MET RM "
|      |      |-- 10:10-14 FDOT421 "A/L10/UB/SD14/LAGAL HOD CABIN"
|      |      |-- 10:10-15 FDOT421 "A/L10/UB/SD15/FOOD FACILITY"
|      |      |-- 10:10-16 FDOT421 "A/L10/UB/SD16/AFC FOOD FACILITY"
|      |      |-- 10:10-17 FDOT421 "A/L10/UB/SD17/LAGAL"
|      |      |-- 10:10-18 FDOT421 "A/L10/UB/SD18/AFC-IT"
|      |      |-- 10:10-19 FDOT421 "A/L10/UB/SD19/ADMIN"
|      |      |-- 10:10-20 FDOT421 "A/L10/UB/SD20/AFC IT-LOBBY"
|      |      |-- 10:10-21 FDOT421 "A/L10/UB/SD21/IT-LOBBY"
|      |      |-- 10:10-22 FDOT421 "A/L10/UB/SD22/PEUN-DESK"
|      |      |-- 10:10-23 FDOT421 "A/L10/UB/SD23/LOBBY STORA"
|      |      |-- 10:10-24 FDOT421 "A/L10/UB/SD24/AFC PRINTER STN "
|      |      |-- 10:10-25 HMS-S/D/M/SA "A/L10/UB/MCP25/FIRE EXIT-UB"
|      |      |-- 10:10-26 HTRI-R "A/L10/UB/CM26/FIRE EXIT-UB"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-27 FDOT421 "A/L10/UB/SD27/LOOBY-NR TOILET"
|      |      |-- 10:10-28 FDOT421 "A/L10/UB/SD28/AFC LOOBY-NR TOILE"
|      |      |-- 10:10-29 FDOT421 "A/L10/UB/SD29/PANTRY"
|      |      |-- 10:10-30 FDOT421 "A/L10/UB/SD30/TRAINING RM 1"
|      |      |-- 10:10-31 FDOT421 "A/L10/UB/SD31/AFC TRAINING RM "
|      |      |-- 10:10-32 FDOT421 "A/L10/UB/SD32/TRAINING RM 3"
|      |      |-- 10:10-33 FDOT421 "A/L10/UB/SD33/LOBBY-NR ACCOUNTS"
|      |      |-- 10:10-34 FDOT421 "A/L10/UB/SD34/AFC LOBBY-NR ACCOU"
|      |      |-- 10:10-35 FDOT421 "A/L10/UB/SD35/ACCOUNT HOD CAB"
|      |      |-- 10:10-36 FDOT421 "A/L10/UB/SD36/HR"
|      |      |-- 10:10-37 FDOT421 "A/L10/UB/SD37/AFC PURCHASE DEPT"
|      |      |-- 10:10-38 FDOT421 "A/L10/UB/SD38/PURCHASE DEPT"
|      |      |-- 10:10-39 FDOT421 "A/L10/UB/SD39/MINI CONFERENCE"
|      |      |-- 10:10-40 FDOT421 "A/L10/UB/SD/40/DGM CAB"
|      |      |-- 10:10-41 FDOT421 "A/L10/UB/SD/41/MANAGING COMMITTE"
|      |      |-- 10:10-42 FDOT421 "A/L10/UB/SD42/DH-SECURITY"
|      |      |-- 10:10-43 FDOT421 "A/L10/UB/SD43/NR WAIT RM ENT DR "
|      |      |-- 10:10-44 FDOT421 "A/L10/UB/SD44/NR WAIT RM ENT.DR"
|      |      |-- 10:10-45 HMS-S/D/M/SA "A/L10/UB/MCP45/NR WAIT RM ENT.DR"
|      |      |-- 10:10-46 XTRI-R "A/L10/UB/CM46/NR WAIT RM ENT.DR"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-47 FDOT421 "A/L10/UB/SD47/AFC WATING ROOM "
|      |      |-- 10:10-48 FDOT421 "A/L10/UB/SD48/WAITING ROOM"
|      |      |-- 10:10-49 FDOT421 "A/L10/LB/SD49/BACK DR CAB 1"
|      |      |-- 10:10-50 FDOT421 "A/L10/LB/SD50/BACK DR CAB 1"
```

10 Desigo Fire Safety Modular "BDB TOWER A" Local

CAB-2 "CAB-2 Enclosure #1"

CC-5 "Card Cage 5 Slots"

10:10 XDLC "L10/A/UB/BACK OFFICE"

```
|      |      |-- 10:10-51 FDOT421 "A/L10/LB/SD51/BACK DR CAB 2"
|      |      |-- 10:10-52 HMS-S/D/M/SA "A/L10/LB/MCP52/BACK DR CAB1 ENT"
|      |      |-- 10:10-54 FDOT421 "A/L10/LB/SD54/LOBBY ELECTRIC RM"
|      |      |-- 10:10-55 FDOT421 "A/L10/LB/SD55/ELECTRIC RM"
|      |      |-- 10:10-56 FDOT421 "A/L10/LB/SD56/SERVER RM"
|      |      |-- 10:10-57 FDOT421 "A/L10/LB/SD57/AFC LOBBY HVAC "
|      |      |-- 10:10-58 FDOT421 "A/L10/LB/SD58/LOBBY HVAC "
|      |      |-- 10:10-59 FDOT421 "A/L10/LB/SD59/ELECTRIC DEPT"
|      |      |-- 10:10-60 FDOT421 "A/L10/LB/SD60/AFC ELECTRICAL "
|      |      |-- 10:10-61 FDOT421 "A/L10/LB/SD61/PLUMBING DEPT"
|      |      |-- 10:10-62 FDOT421 "A/L10/LB/SD62/AFC CIVIL "
|      |      |-- 10:10-63 FDOT421 "A/L10/LB/SD63/HK DEPT"
|      |      |-- 10:10-64 FDOT421 "A/L10/LB/SD64/GM CAB"
|      |      |-- 10:10-65 FDOT421 "A/L10/LB/SD65/PRINTER STATION"
|      |      |-- 10:10-66 FDOT421 "A/L10/LB/SD66/CABIN 2"
|      |      |-- 10:10-67 FDOT421 "A/L10/LB/SD67/NR AGM CAB"
|      |      |-- 10:10-68 FDOT421 "A/L10/LB/SD68/AFC LOBBY AGM CAB"
|      |      |-- 10:10-69 HMS-S/D/M/SA "A/L10/LB/MCP69/LOBBY-AGM"
|      |      |-- 10:10-70 HTRI-R "A/L10/LB/CM70/LOBBY-AGM"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-71 FDOT421 "A/L10/LB/SD71/ CAB NR HK DEPT"
|      |      |-- 10:10-72 FDOT421 "A/L10/LB/SD72/LOBBY NR PANTRY"
|      |      |-- 10:10-73 FDOT421 "A/L10/LB/SD73/AFC NR PANTRY"
|      |      |-- 10:10-74 FDOT421 "A/L10/LB/SD74/NR XEROX MACHINE"
|      |      |-- 10:10-75 FDOT421 "A/L10/LB/SD75/AFC NR XEROX MACHI"
|      |      |-- 10:10-77 FDOT421 "A/L10/LB/SD77/PANTRY"
|      |      |-- 10:10-78 HMS-S/D/M/SA "A/L10/LB/MCP78/LOBBY-ENTRANCE 2"
|      |      |-- 10:10-79 HTRI-R "A/L10/LB/CM79/LOBBY-ENTRANCE 2"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-80 FDOT421 "A/L10/LB/SD80/PANTRY"
|      |      |-- 10:10-83 FDOT421 "A/L10/LB/SD83/LOBBY-MEETING RM 4"
|      |      |-- 10:10-84 FDOT421 "A/L10/LB/SD84/AFC LOBBY-MEETING "
|      |      |-- 10:10-85 FDOT421 "A/L10/LB/SD85/MEETING RM 4"
|      |      |-- 10:10-86 FDOT421 "A/L10/LB/SD86/RECEPTION-LB "
|      |      |-- 10:10-87 FDOT421 "A/L10/LB/SD87/AFC RECEPTION-LB"
|      |      |-- 10:10-88 FDOT421 "A/L10/LB/SD88/MEETING RM 3"
|      |      |-- 10:10-89 FDOT421 "A/L10/LB/SD89/SECURITY HOD"
|      |      |-- 10:10-90 FDOT421 "A/L10/LB/SD90/STORES"
|      |      |-- 10:10-91 FDOT421 "A/L10/LB/SD91/REST RM"
|      |      |-- 10:10-92 FDOT421 "A/L10/LB/SD92/CAB NR WASH RM"
|      |      |-- 10:10-93 HTRI-R "A/L10/LB/CM93/LOBBY-ENTRANCE 2"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-94 HMS-S/D/M/SA "A/L10/LB/MCP94/LOBBY-ENTRANCE 2"
|      |      |-- 10:10-95 HTRI-R "A/L10/LB/CM95/RECEPTION-LB"
|      |      |  |-- Switch ""
|      |      |  |-- Relay
|      |      |-- 10:10-96 HMS-S/D/M/SA "A/L10/LB/MCP96/RECEPTION-LB"
```

```
10 Desigo Fire Safety Modular "BDB TOWER A" Local
  CAB-2 "CAB-2 Enclosure #1"
    CC-5 "Card Cage 5 Slots"
      10:10 XDLC "L10/A/UB/BACK OFFICE"
```

```
|      |      |-- 10:10-97 FDOT421 "A/L10/SD97/Admin LB DOC RM Nr Re"
```

```
|      |-- 10:249 PSC-12 "PSC-12 @ address 1"
```

```
|      |      |-- 10:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"
```

```
|      |      |-- 10:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"
```

```
|      |      |-- 10:249-3 Relay "Relay @ address 249-3"
```

```
|      |      |-- 10:249-4 Relay "Relay @ address 249-4"
```

```
|      |-- Inner Door
```

```
|      |-- 10:253 PMI-D "PMI-D @ address 253"
```

```
|-- 11 Desigo Fire Safety Modular "BDB DC-2" Local
```

```
|-- System Flags
```

```
|-- History Log
```

```
|-- Behavior
```

```
|-- Voice
```

```
|-- Maintenance
```

```
|-- Field Devices
```

```
|-- Miscellaneous
```

```
|-- CAB-1 "CAB-1 Enclosure #1"
```

```
|-- CC-5 "Card Cage 5 Slots"
```

```
|  |-- 11:1 DLC "DLC @ address 1"
```

```
|  |  |-- 11:1-1 HTRI-R "DC2/L1/CM1/GSS/Z1"
```

```
|  |  |  |-- Switch ""
```

```
|  |  |  |-- Relay
```

```
|  |  |-- 11:1-2 HTRI-R "DC2/L1/CM1/GSS/Z2"
```

```
|  |  |  |-- Switch ""
```

```
|  |  |  |-- Relay
```

```
|  |  |-- 11:1-3 HFP-11 "DC2/L1/SD 3/SERVER RM/BFF"
```

```
|  |  |-- 11:1-4 HFP-11 "DC2/L1/SD 4/SERVER RM/BFF"
```

```
|  |  |-- 11:1-5 HFP-11 "DC2/L1/SD 5/SERVER RM/BFF"
```

```
|  |  |-- 11:1-6 HFP-11 "DC2/L1/SD 6/SERVER RM/BFF"
```

```
|  |  |-- 11:1-7 HFP-11 "DC2/L1/SD 7/NOC RM/BFF"
```

```
|  |  |-- 11:1-8 HFP-11 "DC2/L1/SD 8/ELECTRICAL RM/BFF"
```

```
|  |  |-- 11:1-9 HFP-11 "DC2/L1/SD 9/ELECTRICAL RM/BFF"
```

```
|  |  |-- 11:1-10 HTRI-S "DC2/L1/MM 10/BUILDING FAS INPUT"
```

```
|  |  |-- 11:1-11 HTRI-S "DC2/L1/MM 11/VESDA INPUT"
```

```
|  |  |-- 11:1-12 HFP-11 "DC2/L2/SD 12/SERVER RM"
```

```
|  |  |-- 11:1-13 HTRI-R "DC2/L2/CM 13/SERVER RM HOOTER"
```

```
|  |  |  |-- Switch ""
```

```
|  |  |  |-- Relay
```

```
|  |  |-- 11:1-14 HMS-S/D/M/SA "DC2/L2/MCP14/SER RM/NR FIRE EXIT"
```

```
|  |  |-- 11:1-15 HFP-11 "DC2/L2/SD 15/SERVER RM"
```

```
|  |  |-- 11:1-16 HFP-11 "DC2/L2/SD 16/SERVER RM"
```

```
|  |  |-- 11:1-17 HFP-11 "DC2/L2/SD 17/SERVER RM"
```

```
|  |  |-- 11:1-18 HFP-11 "DC2/L2/SD 18/NOC RM"
```

```
|  |  |-- 11:1-19 HFP-11 "DC2/L2/SD 19/ELECTRICAL RM"
```

```
|  |  |-- 11:1-20 HFP-11 "DC2/L2/SD 20/ELECTRICAL RM"
```

```
|  |  |-- 11:1-21 HFP-11 "DC2/L2/SD 21/NR MAIN ENTRANCE"
```

```
|  |  |-- 11:1-22 HTRI-R "DC2/L1/CM 22/ FAS INPUT TO BUILD"
```

```
|  |  |  |-- Switch ""
```

```
|  |  |  |-- Relay
```

```
|  |-- 11:2 NIC-C(XNet) "NIC_Xnet @ address 2"
```

11 Desigo Fire Safety Modular "BDB DC-2" Local
CAB-1 "CAB-1 Enclosure #1"

|-- 11:249 PSC-12 "PSC-12 @ address 249"

| |-- 11:249-1 PSC Relay "Relay @ 001:001 - Common Alarm"

| |-- 11:249-2 PSC Relay "Relay @ 001:002 - Common Trouble"

|-- **Inner Door**

|-- 11:253 PMI-D "PMI-D @ address 253"

Project : Project (Physical View)

Type	Project
Country	USA / Other
Sales Channel	Desigo
Site ID	ME0:70:EA:AB:A4:A0_20240209053758
Customer Number	
Customer Name	
Customer Address 1	
Customer Address 2	
City	
State	
Zip Code	
Customer Country	USA
Time Zone Area [TZ Area / Region]	
Phone #	
Job Number	
Job Description	
Contact Name	
Contact Phone	
Project Base Language	English
Project Alternate Language	None
Company Logo File Name	
Imported MXL XML data filename	
NFPA System Type	Local
XNet Wiring Type	Class B
Remote/Central Station AC Fail Trouble Delay (min)	
Dialer Mode	
Dialer Type	none
Voice System Type	Stand Alone Voice
Single Point of Control	
Disable Function Optimization	No
Reset Configuration Versions	No
Configuration of Event Types	ALM,SUP,SEC,TBL
NetLink Name	
GCNET Networked System	No

Global System Flags

Global System Flags

Type	Global System Flags
------	---------------------

Management Station : Management Station Node

Management System @ address12

Type	Management Station
XNet Address	12
Base Lang. Cust. Message	Management System @ address12
Alternate Language Cust. Message	
NetLink Name	
IP Address	
Management Station Use	Control and Command
Supervise Management Station	Yes
Legacy 4-Queue Event Model	

Desigo Fire Safety Modular : Desigo Modular Node

BDB TOWER J

Type	Desigo Fire Safety Modular
XNet Address	1
Base Language	English
Alternate Language	None
Base Lang. Cust. Message	BDB TOWER J
On Site Contact Name	
On Site Contact Phone	
Last Saved Revision Level	2540
NFPA System Type	Local
HNet Wiring Class	Class B
Max Standby Duration	24 Hrs
Max Alarm Duration	15 Mins
Battery Capacity Reserved (%)	0
DNet Wiring Class	Class B
Unspecified Node Responding Troubles	Display All nodes
Node Not Responding Troubles	Display All Nodes
Node Not Resp Annunciation List	
NetLink Name	

System Flags

BDB TOWER J\System Flags

Type	System Flags
------	--------------

History Log : Modular Node System History Log

BDB TOWER J\History Log

Type	History Log
FireFinder XLS Node Log Mode	Circular
Suppress History-Full Troubles	Yes
Log Event Types	ALM,SUP,SEC,TBL
Log Status Events	No
Log Alarm Verification Events	No
Log Output Activations By Logic	No
Log System Resets	Yes
Log Event Acknowledgements	Yes
Log Block Acknowledgements	Yes
Log Audible Silence Sys Flag Changes	Yes
Log Sensitivity Changes	No
Log Sensitivity Changes By Logic	No
Log Arm/Disarm Commands	No
Log Arm/Disarm By Logic	No
Log Manual Output Overrides	Yes
Log Output Overrides By Logic	No
Log Time Changes	Yes
Log Menu Logins	Yes
Log ASD Changes	No
Log ASD Changes By Logic	No
Log Test Activations	Yes
Log Fan/Damper Commands	Yes
Log PMI Menu Input Activations	Yes
Log Factory Diags	No

Behavior : FireFinder XLS NodeProperties - Behavior

BDB TOWER J|BDB TOWER J

Base Lang. Cust. Message	BDB TOWER J
Alternate Language Cust. Message	
GPMI System Display Name	
1st Event Display On Top	No
Legacy 4-Queue Event Model	Yes
Self Restoring Troubles	Yes
24 Hour Event Resound	ALM,SUP,TBL
Self Restoring Supervision	Yes
FireFinder XLS Map File Names	
Voice Degrade Enabled	No
AC Trouble Report Delay Time (sec)	0

Voice : FireFinder XLS NodeProperties - Voice

BDB TOWER J|Voice

DAC Default Tones PMF	
DAC Default Messages PMF	
AIC Emergency Microphone High Priority	No
Composite Message Description file	
Composite Factory Phrase Library file	
Composite Custom Phrase Library File	

Maintenance : FireFinder XLS NodeProperties - Maintenance

BDB TOWER J|Maintenance

Maintenance/Control Password	12345678
Ack. Silenceable Reset Password	
Function Key Password	
Reports Password	
Walktest Password	55555

Field Devices : FireFinder XLS NodeProperties - Field Devices

BDB TOWER J|Field Devices

Annunciate IEC Pre-Dirty Events	No
Annunciate IEC Limit-Reached Events	No
DLC/XDLC Alarm Verification Retard/Reset Time (sec)	54
DLC/XDLC Alarm Verification Confirmation Time (sec)	65
Annunciate Pre-Alarm Events	Yes
Pre-Alarm Learn Mode	No
Pre-Alarm Learn Period (days)	
Fan Control Confirmation Time Out (sec)	60
Fan Control Stagger Delay Time (sec)	0
Damper Control Confirmation Time Out (sec)	0
MLC Photo Alarm Verification Time (sec)	0
MLC Ion Alarm Verification Time (sec)	0
MLC Damper Trouble Delay Time (sec)	0
Activate LED on Pre-Alarm	No

Miscellaneous : FireFinder XLS NodeProperties - Miscellaneous

BDB TOWER J|Miscellaneous

Intelligent Env. Compensation (IEC)	Yes
-------------------------------------	-----

Miscellaneous : FireFinder XLS NodeProperties - Miscellaneous

BDB TOWER J\Miscellaneous

Non-Silenceable Time Period	Not Used
Auto Silence Waiting Time	Not Used

CAB-2 : Enclosure, 2-Row

BDB TOWER J\CAB-2 Enclosure #1

Type	CAB-2
Enclosure Number	1
Base Lang. Cust. Message	CAB-2 Enclosure #1
Alternate Language Cust. Message	
Power Supply PSC/X HNet Address	
Power Supply PSC/X Node Address	

CC-5 : Card Cage, 5-Slot

BDB TOWER J\CAB-2 Enclosure #1\Card Cage 5 Slots

Type	CC-5
Base Lang. Cust. Message	Card Cage 5 Slots
Alternate Language Cust. Message	

DLC : Detector Loop Card Type 1

BDB TOWER J\CAB-2 Enclosure #1\Card Cage 5 Slots\DLC @ address 1 L1

Type	DLC
HNet Address	1
Base Lang. Cust. Message	DLC @ address 1 L1
Alternate Language Cust. Message	
Class A Wiring	No

HFP-11 : FirePrint Detector Type 11

BDB TOWER J\CAB-2 Enclosure #1\Card Cage 5 Slots\DLC @ address 1 L1\J/L1/EC/GND/SD5/SECURITY CABIN

Type	HFP-11
Device Address	5
Base Lang. Cust. Message	J/L1/EC/GND/SD5/SECURITY CABIN
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1/Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/EC/GND/SD6/LIFT LOBY

Type	HFP-11
Device Address	6
Base Lang. Cust. Message	J/L1/EC/GND/SD6/LIFT LOBY
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1/Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/EC/GND/SD7/LIFT LOBY

Type	HFP-11
Device Address	7
Base Lang. Cust. Message	J/L1/EC/GND/SD7/LIFT LOBY
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1/Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/EC/GND/SD8/LIFT LOBY

Type	HFP-11
Device Address	8
Base Lang. Cust. Message	J/L1/EC/GND/SD8/LIFT LOBY
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1/Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/WC/GND/SD15/SECURITY CABIN

Type	HFP-11
Device Address	15
Base Lang. Cust. Message	J/L1/WC/GND/SD15/SECURITY CABIN
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/WC/GND/SD16/LIFT LOBY

Type	HFP-11
Device Address	16
Base Lang. Cust. Message	J/L1/WC/GND/SD16/LIFT LOBY
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/WC/GND/SD17/LIFT LOBY

Type	HFP-11
Device Address	17
Base Lang. Cust. Message	J/L1/WC/GND/SD17/LIFT LOBY
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1/Card Cage 5 Slots\DLCL @ address 1 L1/J/L1/WC/GND/SD18/LIFT LOBY

Type	HFP-11
Device Address	18
Base Lang. Cust. Message	J/L1/WC/GND/SD18/LIFT LOBY
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1/Card Cage 5 Slots\DLCL @ address 1 L1/J/L1/J-DTC/SD-42/Cab 25

Type	HFP-11
Device Address	42
Base Lang. Cust. Message	J/L1/J-DTC/SD-42/Cab 25
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-43/Cab 26

Type	HFP-11
Device Address	43
Base Lang. Cust. Message	J/L1/J-DTC/SD-43/Cab 26
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-44/Cab 27

Type	HFP-11
Device Address	44
Base Lang. Cust. Message	J/L1/J-DTC/SD-44/Cab 27
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-45/Cab 28

Type	HFP-11
Device Address	45
Base Lang. Cust. Message	J/L1/J-DTC/SD-45/Cab 28
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-46/Cab 29

Type	HFP-11
Device Address	46
Base Lang. Cust. Message	J/L1/J-DTC/SD-46/Cab 29
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1/Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-47/Cab 30

Type	HFP-11
Device Address	47
Base Lang. Cust. Message	J/L1/J-DTC/SD-47/Cab 30
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER J/CAB-2 Enclosure #1/Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-48/Cab 31

Type	HFP-11
Device Address	48
Base Lang. Cust. Message	J/L1/J-DTC/SD-48/Cab 31
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-49/Cab 32

Type	HFP-11
Device Address	49
Base Lang. Cust. Message	J/L1/J-DTC/SD-49/Cab 32
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-50/Cab 33

Type	HFP-11
Device Address	50
Base Lang. Cust. Message	J/L1/J-DTC/SD-50/Cab 33
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-51/Cab 34

Type	HFP-11
Device Address	51
Base Lang. Cust. Message	J/L1/J-DTC/SD-51/Cab 34
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-52/Cab 35

Type	HFP-11
Device Address	52
Base Lang. Cust. Message	J/L1/J-DTC/SD-52/Cab 35
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-53/Cab 36

Type	HFP-11
Device Address	53
Base Lang. Cust. Message	J/L1/J-DTC/SD-53/Cab 36
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None

HFP-11 : FirePrint Detector Type 11

BDB TOWER JICAB-2 Enclosure #1\Card Cage 5 Slots\DLCL @ address 1 L1\J/L1/J-DTC/SD-54/Cab 37

Type	HFP-11
Device Address	54
Base Lang. Cust. Message	J/L1/J-DTC/SD-54/Cab 37
Alternate Language Cust. Message	
Usage	Automatic Alarm
Event Type	Alarm
Use Loop Isolator	No
Intelligent Env. Compensation (IEC)	No
Pre-Alarm	No
ASD Application	Office
Alarm Verification	
Degrade Mode Alarm Activation	No
LED Deactivated	No
Zone Code	No
Zone Code Priority Level	
Zone Code Output Pattern	
Thermal Element Permanently Disabled	No
Thermal Rate Of Rise Enabled	No
Relay Base Lang. Cust. Message	
Relay Alternate Lang. Cust. Message	
Relay Usage	Output Only
Detector Base Type	DB-11
Detector Lamp Type	None