

SuryaScope: Solar Feasibility Report

A comprehensive analysis of your rooftop solar potential under the PM Surya Ghar Muft Bijli Yojana.

Site Details

Location: Test Location

Gross Roof Area: 435.14 sq. meters

Usable Roof Area (net): 435.14 sq. meters

System Sizing & Generation

Parameter	Value
Recommended System Capacity	43.5 kWp
Estimated Annual Generation	60900.0 kWh / year
Average Daily Generation	166.85 kWh / day
Estimated Panel Count	197 Panels (500Wp each)
CO ₂ Offset	49.94 tonnes / year

Financial Analysis

Parameter	Amount (INR)
Estimated Gross Cost	₹ 2,610,000.00
PM Surya Ghar Subsidy	₹ 78,000.00
Net Payable Cost	₹ 2,532,000.00
Annual Electricity Savings	₹ 487,200.00
Estimated Payback Period	5.2 Years

Note: This is an automated feasibility report generated by SuryaScope based on satellite imagery and typical meteorological year (TMY) data. Obstructions (AC units, water tanks, etc.) have been excluded from the usable area. Actual costs and generation may vary based on site-specific factors like shading, roof tilt, and local vendor pricing.