

Brandon Phillips Field 5425 Winton Ridge Lane, Cincinnati OH 45232





- 1. The field maintenance manager indicates that the infield and left field dry very well. These areas are even playable in the late afternoon after a heavy morning rain. The area circled on the photo can take 1 and maybe 2 days to dry after a heavy rain.
- 2. The right field area circled in yellow does not drain well and they often have to rope of a section of this area.
- 3. The Reds would like to have the right field playable when the rest of the field is playable.
- 4. The washout occurring where the centerfield and leftfield fence intersect is NOT a problem that the Reds are concerned about. We should not design for this issue.
- 5. The drain pipe is not drainage for the field itself but rather to keep the water coming downhill from the north from entering the field. So the water enters a manhole to the north of the field and takes it south end of the field to the south.