



Water Well And Pump Record

Completion is required under authority of Part 127 Act 368 PA 1978.



Import ID:

Failure to comply is a misdemeanor.

Tax No:	Permit No: W-7484	County: Jackson		Township: Spring Arbor	
Well ID: 38000004655 Elevation: Latitude: 42.21872769 Longitude: -84.55232039 Method of Collection: Interpolation-Map		Town/Range: 03S 02W	Section: 9	Well Status: Active	WSSN:
		Source ID/Well No:			
		Distance and Direction from Road Intersection: ON NORTH SIDE OF KING ROAD 6/10 MILE WEST OF DEARING ROAD LOT #3			
		Well Owner: MJ FARM ENTERPRISES			
		Well Address: 7334 KING RD MI		Owner Address: 7334 KING RD MI	

Drilling Method: Rotary		Pump Installed: No	
Well Depth: 142.00 ft.		Pressure Tank Installed: No	
Well Type: New		Pressure Relief Valve Installed: No	
Well Use: Household			
Date Completed: 1/5/2001			
Casing Type: PVC plastic		Height:	
Casing Joint: Welded			
Casing Fitting: Shale packer/trap			
Diameter: 5.00 in. to 104.00 ft. depth			
Borehole: 8.00 in. to 104.00 ft. depth 4.50 in. to 142.00 ft. depth			
Static Water Level: 33.00 ft. Below Grade			
Well Yield Test:		Yield Test Method: Air	
Pumping level 80.00 ft. after 1.00 hrs. at 30 GPM			
Screen Installed: No		Intake: Bedrock Well	
Well Grouted: Yes		Grouting Method: Unknown	
Grouting Material	Bags	Additives	Depth
Bentonite slurry	7.00	None	0.00 ft. to 104.00 ft.
Geology Remarks:			
Wellhead Completion: 12 inches above grade			
Nearest Source of Possible Contamination:		Drilling Machine Operator Name: MARC MCKEAGUE	
Type	Distance	Employment: Employee	
Septic tank	50 ft.		
Direction		Contractor Type: Water Well Drilling Contractor	
Southeast		Reg No: 13-1593	
		Business Name: KATZ WELL DRILLING IN	
		Business Address:	
		Water Well Contractor's Certification	
		This well was drilled under my supervision and this report is true to the best of my knowledge and belief.	
		Signature of Registered Contractor	
		Date	
General Remarks: PUMP WILL BE INSTALLED BY MATTHEWS PUMPS			
Other Remarks:			