

TEST REPORT: COMPRESSION TEST ON CONCRETE CUBES

PROJECT ID: {{projectID}}

PROJECT: {{projectName}}

COMPANY: {{companyName}}

ADDRESS: {{companyAddress}}

ATTENTION: {{attnTo}}

TEST DATE: {{testDate}}

SUPPLIER: {{supplier}}

TEST STANDARD: {{testStandard}}



TÜV SÜD PSB Pte. Ltd.

60 Tuas South Street 1

Singapore 639925

Business Reg No. 199002667R

Set	Date Cast	Age At Test	Grade	Specified Strength (N/mm2)	Average Stress (N/mm2)	Sub Client Ref	Sub Ref	Cube Dimension (mm)	Max Load (kN)	Stress At Failure (N/mm2)	Mode of Failure
1	2023-08-01	7	37	27.8	42.0	CB3704/B1-16	1	150	932.162	41.43	Satisfactory
						CB3704/B1-17	2	150	927.769	41.23	Satisfactory
						CB3704/B1-18	3	150	973.973	43.29	Satisfactory
						LOCATION: TAISEI-CSCEC JV-CR105 (PW PLANT)					