

TEST REPORT: COMPRESSION TEST ON CONCRETE CUBES

PROJECT ID: {{projectID}}
PROJECT: {{projectName}}
COMPANY: {{companyName}}
ADDRESS: {{companyAddress}}
ATTENTION: {{attnTo}}, {{attnEmail}}



TÜV SÜD PSB Pte. Ltd.
60 Tuas South Street 1
Singapore 639925
Business Reg No. 199002667R

Tel: 6240 0217
Fax: 6240 0201

Test Date: {{testDate}}				Supplier: {{supplier}}		Specification: {{specification}}			Testing Standard: {{testStandard}}		
Set	Date Cast	Age At Test	Grade	Specified Strength (N/mm2)	Average Stress (N/mm2)	Sub Client Ref	Sub Ref	Cube Dimension (mm)	Max Load (kN)	Stress At Failure (N/mm2)	Mode of Failure
1	2023-08-01	7	37	27.8	42.0	CB3704/B1-16	1	150	932.162	41.43	Satisfactory
						CB3704/B1-17	2	150	927.769	41.23	Satisfactory
						CB3704/B1-18	3	150	973.973	43.29	Satisfactory
						LOCATION: TAISEI-CSCEC JV-CR105 (PW PLANT)					



LA-2007-0380-A

LA-2007-0381-F

LA-2007-0382-B

LA-2007-0383-G

LA-2007-0384-G

LA-2007-0385-E

LA-2007-0386-C

LA-2010-0464-D

LA-2018-0702-B

LA-2018-0703-G

The results reported herein have been performed in accordance with the terms of accreditation under the Singapore Accreditation Council. Inspections/Calibrations/Tests marked "Not SAC-SINGLAS Accredited" in this Report are not included in the SAC-SINGLAS Accreditation Schedule for our inspection body/laboratory.



ONG SOON TUCK