

SCN-001: SAFETY INSPECTION CHECKLIST

Area: Cooling Tower CT-01

Inspector: Deepak Joshi

Date: 05-Apr-2026

Time: 10:30 hrs

Item	OK	NOK	N/A

1. Guardrails and handrails	[Y]	[]	[]
2. Fan guard condition	[Y]	[]	[]
3. Water distribution nozzles clear	[Y]	[]	[]
4. Fill media condition	[N]	[Y]	[]
>> Moderate scaling in Cell #3			
5. Basin water level	[Y]	[]	[]
6. Gearbox oil level	[Y]	[]	[]
7. V-belt tension	[Y]	[]	[]
8. Electrical panel seal	[Y]	[]	[]
9. Emergency stop button functional	[Y]	[]	[]
10. LOTO point identified	[Y]	[]	[]

TOTAL OK: 9 | NOT OK: 1

Inspector Signature: ____Deepak Joshi____

Reviewed By: _____Rajesh Mehta_____

--- End of Checklist ---