



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00125TSI15972

Issued Date : 21-11-2025

Organization Type : Educational Institutions

Expiry Date : 20-11-2026

Name of the Organization : ST JOSEPH PUBLIC SCHOOL

Address : 4/137/1 WARD NO 4 SURVEY NO 231/1A1,231/1B1

PANPOZHI-SHENKOTTAI ROAD EASTERN ROW, THENPOTHAI

AREA

I, DOMINIC MUNDULT owner/manager of the ST JOSEPH PUBLIC SCHOOL functioning as Educational Institutions located at Kanakkapillaivalasai in Tenkasi district hereby declare that

- This Self-Declared Sanitation certificate is valid from 21-11-2025 to 20-11-2026 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 352 people/pupils and has 16 urinals and 36 toilets which is proportionate to the number of users as per government norms.
- 4 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

BLOCK HEALTH SUPERVISOR
Govt. Primary Health Centre
VADAKARA KILPIDAKAL
Tenkasi Block
Tenkasi District

Signature of the Owner/Manager



(அ) TN00125TSI15972 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளூடு செய்து சரிபார்க்கவும்.

(ஆல்லது)

(ஆ) கைப்பேசியில் பார்க்காடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a) Keying in the unique certificate number TN00125TSI15972 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
REGIONAL PUBLIC HEALTH WATER ANALYSIS LABORATORY, TIRUNELVELI-11

From
Thiru.D.Asir Selvaraj B.Sc., B.Ed.,
Chief Water Analyst ,
Regional Public Health Water
Analysis Laboratory,
Tirunelveli - 627 011.

To
The Principal,
St.Joseph Public School,
Thenpoothai,
Shengottai,
Tenkasi District- 627 809.

R.No: 751/L/2025/M.22/CWA/Tvl., Dated: 12.08.2025

Sir / Madam,

Sub: Report on Examination of water sample from St.Joseph Public School, Thenpoothai, Shengottai, Tenkasi district collected on 08.08.2025

A sample of water stated to have been collected on 28.07.2025 from R.O unit outlet first floor, St.Joseph School, Thenpoothai, Shengottai, Tenkasi district (Source: Bore well) by Thiru.Rince.K.Joseph, Administrator was received at this laboratory on the same day from the addressee to assess its suitability for drinking purpose.

The results of analysis are furnished overleaf.

The sample of water is colorless and clear in physical appearance.

It is of satisfactory bacteriological quality for drinking.

The chemical analysis reveals that it is soft. Though, it is of drinkable chemical quality, the total hardness is only 6 mg/l. The Calcium and Magnesium minerals are almost removed from the water, Calcium and Magnesium are very essential minerals for healthy living of human beings. Consumption of water with such very low content of Calcium and Magnesium minerals for a prolonged period will be deleterious to the health of the consumers.

Hence, it is advised that, the supplier of the R.O. unit should be contacted immediately to set right the R.O. unit in such a way that, the outlet water should contains atleast a minimum content of total hardness (30 mg/l) so as to have some amount of Calcium and Magnesium in the outlet water of R.O. unit, which are very essential for a healthy life of the consumers.

The R.O. unit should be maintained periodically as per the supplier's manual to get hygienically safe water at all times.

SEN/12.08.2025
CHIEF WATER ANALYST
REGIONAL PUBLIC HEALTH WATER
ANALYSIS LABORATORY
TIRUNELVELI - 627 011