



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

FALCON CHEMICALS LLC

AL HATTA HIBAB ROAD, JABEL ALI INDUSTRIAL AREA NO: 3, DUBAI , UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2023 AL SA'FAT DUBAI GREEN BUILDING SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).

ENG. MAJED AL SHAMSI

Certification and Quality Control of Products Section's Manager
Dubai Central Laboratory Department-Dubai Municipality



Certificate No: CL18020593
Valid Until: 28/05/2027



Current Issue Date: 29/05/2026
Original Issue Date: 29/05/2018



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020593

Certificate Issued To: **FALCON CHEMICALS LLC**
Al Hatta Hibab Road, Jabel Ali Industrial Area No. 3,
Dubai, UAE

Applicable Standard Specification: **2023 Al Sa'fat Dubai Green Building System**
2nd edition clauses [404.01] and/or [404.02], [304.01],
[304.04] [304.07], [701.04] and related clauses in 2021- Dubai
Building Code.

Applicable Specific Rules: **DM-DCLD-RD-DP21-2180-(IC)** : Certification of Low Emitting
Materials as per Al Sa'fat – Dubai Green Building System &
Dubai Building Code.

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Primers (Category 7)	LAVADEC FR	Water based Primer for Interior/Exterior Applications: VOC (Al Sa'fat DGBS limit is max.30 g/l) Heavy metals: Cadmium and Chromium VI (Al Sa'fat DGBS limit < 500 mg/Kg), Arsenic, Mercury and Lead (Al Sa'fat DGBS limit <100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		LAVATEX 100	
		LAVASOL	Solvent based Primer for Interior/Exterior Applications: VOC (Al Sa'fat DGBS limit is max.350 g/l) Heavy metals: Cadmium and Chromium VI (Al Sa'fat DGBS limit < 500 mg/Kg), Arsenic, Mercury and Lead Al Sa'fat DGBS limit <100 mg/Kg
2		LAVACOOOL	Water Base Coating for Interior/Exterior Applications:

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020593

	One -pack Performance Coatings (Category 9)	ECOTHANE COLORTOP	VOC (Al Sa'fat DGBS limit is max 140 g/l) SRI (Result of sample tested is ≥ 78) White Color (See Note 3)
		LAVASHIELD GP	
		LAVASHIELD SUPER	
		LAVATHANE	
		LAVAFLEX 1K	Water Base Coating for Interior/Exterior Applications: VOC (Al Sa'fat DGBS limit is max 140 g/l) SRI (Result of sample tested is ≥ 78) White Color (See Note 3)
		LAVADEC 600 FRC	
		LAVATEX R- 10	Water Base Coating for Interior Applications: VOC (Al Sa'fat DGBS limit is max 140 g/l)
		FLEXKOTE	
		LAVATEX 2000	
		LAVATEX RBE	
3	Two -pack Reactive Performance Coatings for specific end such as floor (Category 10)	ECOPOXY 310	Solvent Base Coating for Interior Application: VOC (Al Sa'fat DGBS limit is max 500 g/l)
		ECOPOXY 410	
		LAVAFLEX 2K	Water Base Coating for Interior / Exterior Application: VOC (Al Sa'fat DGBS limit is max 140 g/l) SRI (Result of sample tested is ≥ 78) White Color (See Note 3)
		ECOPOXY 610	Solvent Base Coating for Interior / Exterior Application: VOC (Al Sa'fat DGBS limit is max 500 g/l) SRI (Result if tested is <29) Black Color (See Note 3)
4	CERAMIC TILE ADHESIVE	ULTRATILE UTA	Ceramic Tile Adhesive - VOC (Al Sa'fat DGBS limit is max 65 g/l)
		ULTRATILE PD	
		ULTRATILE ST	
5	MULTI PURPOSE CONST. ADHESIVE	MARBLEX	Multi-Purpose construction Adhesive - VOC (Al Sa'fat DGBS limit is max 70 g/l)
		ULTRABOND F 440	
		ULTRABOND HD	

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020593

6	ARCHITECTURAL NON POROUS SEALANTS	ULTRAGROUT	Architectural Non Porous Sealants - VOC (Al Sa'fat DGBS limit is max 250 g/l)
7	DRY WALL & PANEL ADHESIVES	BONDEX FRP NIPPOCOL AS	DRY WALL & PANEL ADHESIVES – VOC (Al Sa'fat DGBS limit is max 50 g/l)
8	WOOD FLOORING ADHESIVES	NIPPOCOL SUPER	WOOD FLOORING ADHESIVES – VOC (Al Sa'fat DGBS limit is max 100 g/l)

NOTE 1: This document forms an integral part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCLD Conformity Mark.

NOTE 3: As applicable, other properties in the product standard specification which were excluded in the specific rules as approved by the certification body authorized personnel are to be verified by the end user of the product (if needed).

NOTE4: The above SRI value is just for information. The user (owner, contractor and/or consultant) shall be fully responsible for ensuring that the correct SRI value is followed according to the requirements of the applicable clause in the standard specification. Acceptance limit shall be as per these values for each application of the product.

NOTE 5: In accordance with Dubai Municipality requirements, any mandatory product manufactured in a certified factory and not covered under the approved scope of certification shall not be distributed, sold, or used within the Emirate of Dubai.

Original Issue Date : 29-05-2018

Current Issue Date : 29-05-2026

Valid Until : 28-05-2027



ENG. MAJED AL SHAMSI

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION'S MANAGER