

SOLAR BARRIER							COOLING DUCT A							SHIELD AT TAP. START				TAPPING SHIELD				OUTER LEAD			
A	B	T	P	H	W	QTY	A	B	T	P	H	W	QTY	A	B	T	QTY	A	B	T	QTY	A	B	T	QTY
1203	798	0.25	19	4.25	6	2	1302	798	0.25	19	4.25	6	1	840	180	1	2	840	180	1	2	1040	220	1	1
							460	798	0.25	19	4.25	6	2												





PB FOR ELEC. SHIELD				
A	B	T	QTY	
1203	798	1	1	

EDGE STRIP					
A	B	C	T	QTY	
1142	29.5	48.5	4.5	1	
1171	29.5	48.5	4.5	1	
1199	29.5	48.5	4.5	1	
1228	29.5	48.5	4.5	1	
1257	29.5	48.5	4.5	1	
1286	29.5	48.5	4.5	1	
1315	29.5	48.5	4.5	1	

Issued for Production
27 JAN 2023
QA DEPT

CONTROLLED
IF GREEN

GENERAL TOLERANCES UNLESS OTHERWISE SPECIFIED
HOLE SIZE ± 0.05 / HOLE C-C ± 0.05 / OTHER LINIER DIMENSIONS ± 1

REVISION NO.	DATE	DRAWN	DESCRIPTION	APPROVED BY
<div><div></div><div><div>LTL Transformers (Pvt) Ltd</div><div>154/11, Railway Station Road, Angulana, Moratuwa, Sri Lanka</div></div></div>				
PROJECT: INSEE SIAM CITY CEMENT				
TITLE : HV WINDING INSULATIONS 2000kVA 3.3kV/440V TRANSFORMER				
DESIGNED BY: 	SCALE: NTS	UNITS: mm	SIZE: A4	
REVIEWED BY: 	DRAWN BY: PRASHANTH	DESIGN NO:		
APPROVED BY: 	DRAWING NO: DRW/CT-2237/80-2			
APPROVED BY:	DATE: 2023/01/25	REV: 00		

NOTE: ABOVE GIVEN QUANTITIES ARE REQUIRED FOR SINGLE WINDING