







HV LV BARRIER							COOLING DUCT A							SHIELD AT TAP. START				TAPPING SHIELD				OUTER LEAD			
																									
A	B	P	H	W	T	QTY	A	B	T	P	H	W	QTY	A	B	T	QTY	A	B	T	QTY	A	B	T	QTY
999	838	40	13	10	2	1	1205	838	0.25	19	4.25	6	1	880	150	1	2	880	150	1	2	1000	100	1	1
							0	0	0	0	0	0	0												

NOTE: ABOVE GIVEN QUANTITIES ARE REQUIRED FOR SINGLE WINDING

GENERAL TOLERANCES UNLESS OTHERWISE SPECIFIED				
HOLE SIZE ±0.05 / HOLE C-C ±0.05 / OTHER LINIER DIMENSIONS ±1				
REVISION NO.	DATE	DRAWN	DESCRIPTION	APPROVED BY
<div>  <div> <div>LTL Transformers (Pvt) Ltd</div> <div>154/11, Railway Station Road, Angulana, Moratuwa, Sri lanka</div> </div> </div>				
PROJECT: APS TANZANIA LIMITED				
TITLE : HV WINDING INSULATIONS				
800kVA 11kV/400V TRANSFORMER				
DESIGNED BY:	SCALE: NTS	UNITS: mm	SIZE: A4	
REVIEWED BY:	DRAWN BY: PRASHANTH	DESIGN NO:		
APPROVED BY:	DRAWING NO: DRW/CT-2314/80-2			
	DATE: 2023/07/06	REV: 00		