



NOTE:

01. UNIT WEIGHT IS 6240KG
02. ALL WEIGHT & DIMENSIONS SUBJECT TO ± 5% TOLERANCE

Issued for Production
27 JAN 2023
QA DEPT
CONTROLLED
IF GREEN

1	BASE SKID	2
2	EARTH FLAGS 2NOS ON BASE & 1NO ON COVER PLATE	3
3	PANEL TYPE RADIATOR	6
4	LIFTING LUGS - FOR COMPLETE UNIT	4
5	LV BUSHINGS EN 3150 I	4
6	HV BUSHINGS PLUG IN	3
7	FILTER VALVE	1
8	PRESSURE RELIEF DEVICE T-50	1
9	RATING / DIAGRAM PLATE	1
10	OTI / PT100	1
11	SILICA GEL BREATHER 1KG TYPE C	1
12	PHASE MARKING PLATES	7
13	CT TERMINAL BOX	1
14	OIL LEVEL INDICATOR SO-4	1
15	TANK	1
16	BUCHHOLZ RELAY / EW712	1
17	CONSERVATOR SHUT OFF VALVE	1
18	CONSERVATOR FILLING CAP	1
19	CONSERVATOR	1
20	PULLING LUGS FOR TRANSFORMER	4
21	MARSHALLING BOX WITH WTI & OTI	1
22	TAP SELECTOR HM 28.43.885	1
23	CONSERVATOR DRAIN VALVE	1
24	HV CABLE LADDER SUPPORT	1
26	THERMOMETER POCKET	1
27	COOLING FAN	6
28	BI-DIRECTIONAL WHEELS	4
29	DRAIN VALVE / NW31	1
30	SAMPLING VALVE / DN15 DIN42568	1
31	WTI / PT100	1
32	COOLING FAN CONTROL BOX	1
33	LV BUSDUCT	1
34	HV CABLE LADDER	1

REVISION NO.	DATE	DRAWN	DESCRIPTION	APPROVED BY
--------------	------	-------	-------------	-------------



LTL Transformers (Pvt) Ltd

154/11, Railway Station Road, Angulana, Moratuwa, Sri Lanka

PROJECT:

SIAM CITY CEMENT

TITLE :

OUTLINE ARRANGEMENT

2000kVA 3.3kV/440V TRANSFORMER

DESIGNED BY:	SCALE: 1:30	UNITS: mm	SIZE: A4
DRAWN BY: PRASHANTH	DESIGN NO: 20003.3440		
REVIEWED BY:	DRAWING NO: DRW/CT-2237/ 22-1		
APPROVED BY:	DATE: 27/01/2023	REV:00	