

LTL TRANSFORMERS (PVT) LTD

154 / 11, Railway Station Road, Angulana, Moratuwa, Sri Lanka.

Tel: +94 112 605 101-3 Fax: +94 112 607 312

Email: transformer@ltl.lk

SUBMISSION OF DOCUMENTS FOR APPROVAL

Date: 16/12/2022 **Our Ref**: CT 2237

Attention:

Mr. Sujith Gunawardhana, Siam City Cement (Lanka) Limited.

Dear Sir,

<u>Sub: Supply of 2000kVA 3.3kV 440V Transformer with LV Busduct, Plugin type HV bushings, OTI, WTI and Cooling fans–01 No.</u>

Drawing and technical specification for the above mentioned transformer is submitted herewith for your kind perusal and approval.

We shall be much obliged if you could provide us your approval at the earliest to proceed with production.

Thanking you

Yours Faithfully, LTL Transformers (Pvt) Ltd

Electrical Engineer - Design

Level Rober

P.S.: Please contact us for any clarification.

Contact 01: Contact 02:

Menusha Nanayakkara Electrical Superintendent 076-6763792

menusha.srinath@ltl.lk

Indula Amarasinghe Electrical Engineer 076-3968192 indula.amarasinghe@ltl.lk









Registered Office

67, Park Street, Colombo 02, Sri Lanka Telephone: +94(0)112 695 007 Fax: +94(0)112 684 900

Issued for Production 30 JAN 2023 QA DEPT

> CONTROLLED IF GREEN

Email: info@ltl.lk

Company Registration Number: PV 66299

www.ltlt.lk

LTL TRANSFORMERS (PVT) LTD

FRM/CI/02

CONTROLLED IF GREEN

Transformer Technical Specifications


Customer	Siam City					
Project:	Factory power Supply					
Contract/Quotation No.	CT-2237	Date:	16/12/2022			

Basic Technical Features	Unit	Customer Requirements	Review by LTL	Remarks
1. Capacity	kVA	2000	2000	
2. No. of Units required	Nos.	1	1	
3. Frequency	Hz	50	50	
4. No. of Phases	112	3	3	
5. Primary Voltage	V	3300	3300	
6. Tappings 1	v	3300	5%	
2			2.5%	
3			0%	
4			-2.5%	
5			-2.3% -5%	
3			-5%	
			-	
			-	
7. C 1 (N. 1 1)	17	110	- 140	
7. Secondary Voltage (No Load) 8. Vector Symbol	V	440	440 Dyn5	
	1 7 7	Dyn5	,	
9. Lightning Impulse Withstand Voltage (Primary / Secondary)	kV		60/-	
10. Power Frequency Withstand Voltage (Primary / Secondary)	kV	G / G	20/3	
11. Conductor Material (Primary / Secondary)	0.0	Cu / Cu	Cu / Cu	
12. Temp. Rise Windings	°C		60	
Top Oil	°C		55	
13. Efficiency at 100% load (P.F = 0.8)	%		98.68	
14. Voltage regulation at 100% load (P.F = 0.8)	%		7.70	
15. No Load current	%		0.23	IEC Tolerances Applicable
16. Method of cooling			ONAN	
17. No load loss	W		1300	IEC Tolerances Applicable
18. Load loss	W		20100	IEC Tolerances Applicable
19. Impedance voltage	%		7.70	IEC Tolerances Applicable
20. Sound level	dB		<85	
21. Dimensions				
Length	mm		2296	
Width	mm		2565	
Height	mm		2584	
22.Total Weight	kg		6240	
23.Oil Weight	kg		1175	
24.Un-tanking Weight	kg		2750	
25. Availabilty of Cable box in Primary side, Y/N			N	
26. Availabilty of Cable box in Secondary side, Y/N			Y	LV Busduct
27. Hermetically sealed/Conservator		Conservator	Conservator	
28. Painting Method, Galvanize/Marine paint/Powder			Powder	C5-M
29. Unit Colour			RAL 9002	Grey White
30. Service conditions				
Max. ambient temp.	°C		45	
Monthly average temp.	°C		35	
Yearly average temp.	°C		25	
31. Altitude (Maximum)	m		1000	
32. Standard			IEC60076:2011	

33. Protection Available		34. Remarks : K factor is considered as 9					
Buchholz Relay	Y						
Oil Level Indicator	Y		Designation	Sig.	Date		
Pressure Release Device (With Contacts)	Y	Designed by:	EE	\$	16/12/2022		
Winding Temperature Indicator & Oil Temperature Indicator	Y	Reviewed by:	EE	Luk Pohen.	16/12/2022		
Bi- Directional Rollers	Y	Approved by:	EE		16/12/2022		

Revision No.: 03/01-12-2015





NOTE:

01. UNIT WEIGHT IS 6240KG 02. ALL WEIGHT & DIMENSIONS SUBJECT OA DEPT

Issued for Production

CONTROLLED IF GREEN

1	BASE SKI	D		2
2	EARTH FLAGS 2NOS ON BASE & 1NO ON COVER PLATE			3
3	PANEL TY	PE RADIAT	OR	6
4	LIFTING L	UGS - FOF	R COMPLETE UNIT	4
5	LV BUSHI	NGS EN 31	L50 I	4
6	HV BUSH	INGS PLUG	i IN	3
7	FILTER VA	ALVE		1
8	PRESSUR	E RELIEF D	EVICE T-50	1
9	RATING /	DIAGRAM	PLATE	1
10	OTI / PT1	00		1
11	SILICA GI	L BREATH	ER 1KG TYPE C	1
12	PHASE MA	ARKING PL	ATES	7
13	CT TERMI			1
14	_	_ INDICAT(OR SO-4	1
15	TANK			1
16	BUCHHOLZ RELAY / EW712			1
17	CONSERVATOR SHUT OFF VALVE			1
18	CONSERVATOR FILLING CAP			1
19	CONSERVATOR			1
20	PULLING LUGS FOR TRANSFORMER			4
21	MARSHALLING BOX WITH WTI & OTI			1
22	TAP SELECTOR HM 28.43.885			1
23		ATOR DRA		1
24	HV CABLE	LADDER S	SUPPORT	1
26		<u>1ETER POC</u>	KET	1
27	COOLING	FAN		6
28	BI-DIREC	TIONAL WI	HEELS	4
29	DRAIN VA	LVE / NW3	31	1
30	SAMPLING VALVE / DN15 DIN42568			1
31	WTI / PT100			1
32	COOLING FAN CONTROL BOX			1
33	LV BUSDUCT			1
34	HV CABLE LADDER			1
04	2023/01/12			EE-01
03	2023/01/11	2023/01/11 THARINDU IR WINDOW LOCATION REVISED		EE-01
02	2023/01/09	3/01/09 PRASHANTH IR WINDOW PROVIDED		
01				EE-01
REVISION NO.	DATE	DRAWN	DESCRIPTION	APPROVED BY
	1			



LTL Transformers (Pvt) Ltd

154/11, Railway Station Road, Angulana, Moratuwa, Sri lanka

PROJECT:


SIAM CITY CEMENT


TITLE :


OUTLINE ARRANGEMENT

2000kVA 3.3kV/440V TRANSFORMER

DESIGNED BY:	fa	SCALE:	1:30	UNITS:	mm	SIZE:	A4
REVIEWED BY:	Lua Pohen	DRAWN BY:	PRASHANTH	DESIGN	NO: 20	0003.34	40
DRAW		DRAWING NO:	DRW/QTMTF2214/22-	-1			
APPROVED BY:		DATE:	12/01/2023	REV:04			









Issued for Production 30 JAN 2023 QA DEPT CONTROLLED IF GREEN





DETAIL AE SCALE 1 : 5



	02	2023/01/12	THARINDU	IR WINDOW LOCATION REVISED	EE-01
	01	2023/01/09	PRASHANTH	IR WINDOW PROVIDED	EE-01
REVISION NO. DATE		DRAWN	DESCRIPTION	APPROVED BY	



LTL Transformers (Pvt) Ltd

154/11, Railway Station Road, Angulana, Moratuwa, Sri lanka

ROJECT:

SIAM CITY CEMENT

TITLE :

LV BUSDUCT

2000kVA 3.3kV/440V TRANSFORMER

DESIGNED BY:	£_	SCALE:	1:37	UNITS: mm	SIZE: A4
REVIEWED BY:	Lua Polan	DRAWN BY:	PRASHANTH	DESIGN NO: 2	0003.3440
		DRAWING NO:	DRW/QTMTF2214/22	-2	
APPROVED BY:		DATE:	12/01/2023	REV:02	

NEDRIVE - LAKDHANAVI LIMITED | DRAWINGS IN LTL-DB | QUOTATIONS | 2022 | QTMTF2214 | MODEL-5 (LEFT)