

TAPPING BOARD

TAPPING BOARD SUPPORT

DRW/CT-2314/7-2

BETWEEN TAPPING & TANK

A	B	T	QTY
996	220	2	1

BETWEEN DELTA & TAPPING

A	B	T	QTY
220	180	2	3

BETWEEN DELTA&CLAMP

A	B	C	C1	T	QTY
936	180	388	194	4	1

E BLOCK

A	B	C	D	L	H	T	QTY
20	9	44	95	102	120	6	12

BETWEEN LEAD&TANK

A	B	T	QTY
996	220	4	1

BETWEEN LEAD&CLAMP

A	B	C	T	QTY
936	180	388	4	1

GENERAL TOLERANCES UNLESS OTHERWISE SPECIFIED

HOLE SIZE ±0.05 / HOLE C-C ±0.05 / OTHER LINIER DIMENSIONS ±1

REVISION NO.	DATE	DRAWN	DESCRIPTION	APPROVED BY
<div> <div> </div> <div> <div>LTL Transformers (Pvt) Ltd</div> <div>154/11, Railway Station Road, Angulana, Moratuwa, Sri lanka</div> </div> </div>				
PROJECT: APS TANZANIA LIMITED				
TITLE : <b>ASSEMBLY STAGE 2 INSULATION</b> 800kVA 11kV/400V TRANSFORMER				
DESIGNED BY:	SCALE: NTS	UNITS: mm	SIZE: A4	
REVIEWED BY:	DRAWN BY: PRASHANTH	DESIGN NO:		
APPROVED BY:	DRAWING NO: DRW/CT-2314/80-4			
	DATE: 2023/07/05	REV: 00		

DETAIL A

NOTE: ABOVE GIVEN QUANTITIES ARE REQUIRED FOR SINGLE TRANSFORMER (3xWINDINGS).