



DELTA
TESTING & RESEARCH LABORATORIES PVT. LTD.



Plot No.C-5, Block- C, Main Kanjawala Road
Rajiv Nagar, Delhi -110086
Mob.: 9910596777, 9810479889, 9811037450, 9310843393
E: dtrinfo@gmail.com, info@deltatestinglab.com
W: www.deltatestinglab.com

TEST REPORT

Issued to:
M/s Uttar Dilli C&D Waste Recycling Pvt. Ltd.
MCD Colony, Hanuman Mandir Road,
Gate No. 1, Jahangirpuri, New Delhi

Report No. : DTRL/GEN/05072429207
ULR No. : TC741424000002531F
Report Date : 12/07/2024
Your Ref. No. : Nil,
Dt. 05/07/2024
Date of Receipt : 05/07/2024
Period of Testing : 05/07/2024 – 10/07/2024

DTRL-2024-2692



Sample Description : Sand (C&D Waste)
Sample Condition : Good

S. No.	Test	Units	Test Method	Result	Requirement IS 383:2016 Amnd. Upto -2 Zone-II	Conformity
Discipline: Mechanical Group: Building Material						
1.	Sieve Analysis, % Material Passing through IS Sieve, mm	%	IS 2386 (Pt-1):1963 RA-2021			No
	10			100	100	
	4.75			99.62	90 – 100	
	2.36			89.61	75 – 100	
	1.18			76.8	55 – 90	
	0.600			67.63	35 – 59	
	0.300			48.87	8 – 30	
	0.150			18.22	0 – 10	
2.	Water Absorption (Avg.)	%	IS 2386 (Pt-3):1963 RA-2021	3.30	-	-

****End of Report****

Reviewed By :

Gurdeep Singh

Authorised Signatory

Roushan Kumar
Tech. Manager

- (1) The results listed refer only to tested samples and applicable parameters. Endorsement of product is neither inferred nor implied.
(2) Total liability of our Lab is limited to the invoiced amount.
(3) Samples will be destroyed after 30 days from the date of test report unless otherwise specified.
(4) This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of Law and should not be used in any advertising media without our special permission in writing
(5) Report refer to the sample submitted to us and not drawn by us unless mentioned otherwise.



DELTA
TESTING & RESEARCH LABORATORIES PVT. LTD.



Plot No.C-5, Block- C, Main Kanjawala Road
Rajiv Nagar, Delhi -110086
Mob.: 9910596777, 9810479889, 9811037450, 9310843393
E: dtrinfo@gmail.com, info@deltatestinglab.com
W: www.deltatestinglab.com

TEST REPORT

Issued to:

M/s Uttar Dilli C&D Waste Recycling Pvt. Ltd.
MCD Colony, Hanuman Mandir Road,
Gate No. 1, Jahangirpuri, New Delhi

Report No. : DTRL/GEN/05072429206
ULR No. : TC741424000002530F
Report Date : 12/07/2024
Your Ref. No. : Nil,
Dt. 05/07/2024
Date of Receipt : 05/07/2024
Period of Testing : 05/07/2024 – 10/07/2024

DTRL-2024-2691



Sample Description : Sand (Ghaggar)
Sample Condition : Good

S. No.	Test	Units	Test Method	Result	Requirement IS 383:2016 Amnd. Upto -2 Zone-II	Conformity
Discipline: Mechanical						
Group: Building Material						
1.	Sieve Analysis, % Material Passing through IS Sieve, mm	%	IS 2386 (Pt-1):1963 RA-2021			No
	10			99.18	100	
	4.75			90.41	90 – 100	
	2.36			81.01	75 – 100	
	1.18			71.39	55 – 90	
	0.600			63.97	35 – 59	
	0.300			48.29	8 – 30	
	0.150			8.48	0 – 10	
2.	Water Absorption (Avg.)	%	IS 2386 (Pt-3):1963 RA-2021	2.25	-	-

****End of Report****

Reviewed By :

Hardeep Singh

Authorised Signatory

Roushan Kumar
Tech. Manager

- (1) The results listed refer only to tested samples and applicable parameters. Endorsement of product is neither inferred nor implied.
- (2) Total liability of our Lab is limited to the invoiced amount.
- (3) Samples will be destroyed after 30 days from the date of test report unless otherwise specified.
- (4) This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of Law and should not be used in any advertising media without our special permission in writing
- (5) Report refer to the sample submitted to us and not drawn by us unless mentioned otherwise.



DELTA
TESTING & RESEARCH LABORATORIES PVT. LTD.



Plot No.C-5, Block- C, Main Kanjawala Road
Rajiv Nagar, Delhi -110086
Mob.: 9910596777, 9810479889, 9811037450, 9310843393
E: dtrlinfo@gmail.com, info@deltatestinglab.com
W: www.deltatestinglab.com

TEST REPORT

Issued to:
M/s Uttar Dilli C&D Waste Recycling Pvt. Ltd.
MCD Colony, Hanuman Mandir Road,
Gate No. 1, Jahangirpuri, New Delhi

Report No. : DTRL/GEN/05072429208
ULR No. : TC741424000002532F
Report Date : 12/07/2024
Your Ref. No. : Nil,
Dt. 05/07/2024
Date of Receipt : 05/07/2024
Period of Testing : 05/07/2024 – 10/07/2024

DTRL-2024-2693



Sample Description : Sand (Yamuna)
Sample Condition : Good

S. No.	Test	Units	Test Method	Result	Requirement IS 383:2016 Amnd. Upto -2 Zone-II	Conformity
Discipline: Mechanical Group: Building Material						
1.	Sieve Analysis, % Material Passing through IS Sieve, mm	%	IS 2386 (Pt-1):1963 RA-2021			No
	10			98.16	100	
	4.75			73.27	90 – 100	
	2.36			53.93	75 – 100	
	1.18			34.01	55 – 90	
	0.600			21.74	35 – 59	
	0.300			11.88	8 – 30	
	0.150			4.83	0 – 10	
2.	Water Absorption (Avg.)	%	IS 2386 (Pt-3):1963 RA-2021	1.85	-	-

****End of Report****

Reviewed By :

Awdeep Singh

Authorised Signatory

Roushan Kumar
Tech. Manager

- (1) The results listed refer only to tested samples and applicable parameters. Endorsement of product is neither inferred nor implied.
(2) Total liability of our Lab is limited to the invoiced amount.
(3) Samples will be destroyed after 30 days from the date of test report unless otherwise specified.
(4) This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of Law and should not be used in any advertising media without our special permission in writing
(5) Report refer to the sample submitted to us and not drawn by us unless mentioned otherwise.