

Delta Testing & Research LaboratoriesPlot No- C-5, Block-C, Main Kanjhawala Road
Rajiv Nagar, Delhi-110086

Contact : 9910596777, 9810479889, 9811037450, 9310843393

E-Mail : dtrinfo@gmail.com

Tax Invoice

Issued under Section 31 of GST Act 2017

Buyer (Bill To)**Consignee (Shipped To)**Uttar Dilli C&D Waste Private Limited
217-A, Ground Floor, Okhla Phase-3
New Delhi-110020
GSTIN : 07AACCU9122A1ZP
State : Delhi, Code : 07
PAN No : AACCU9122AUttar Dilli C&D Waste Private Limited
217-A, Ground Floor, Okhla Phase-3
New Delhi-110020
GSTIN : 07AACCU9122A1ZP
State : Delhi, Code : 07Invoice No : 24-25/454
Invoice Date : 6-Sep-24
Reference : S.SHUKLA
Place of Supply : Delhi

Ref.No : NIL, Dated: 05/09/2024

Name of Work:

Agency :

Agreement No:

SNo	Report No	Particulars	HSN	Quantity	Rate (Rs)	Amount (Rs)
1	DTRL/GEN/05092430096	Concrete Cube Compressive Strength Test (V-Mark, Without Mark)	998346	1	1,000.00	1,000.00

Bank Name : INDIAN BANK A/C NO 50414704835
Account No : 50414704835
IFSC Code : IDIB000P163
Branch : 53, WEST AVENUE ROAD, PUNJABI BAGH, NEW DELHI
Tax is Payable on Reverse Charge ? NoTotal Amount 1,000.00
CGST_ 90.00
SGST_ 90.00

Net Payable Amount ₹ 1,180.00

Amount in Words: INR One Thousand One Hundred Eighty Only

HSN/SAC	Taxable Value	CGST		SGST/UTGST		Total Tax Amount
		Rate	Amount	Rate	Amount	
998346	1,000.00	9%	90.00	9%	90.00	180.00
Total	1,000.00		90.00		90.00	180.00

PAN : AAOFD0428K
GSTIN : 07AAOFD0428K1ZC
Service Code: 998346
Terms & Conditions :

For : Delta Testing & Research Laboratories

Authorised Signatory



DELTA
TESTING & RESEARCH LABORATORIES PVT. LTD.



Plot No.C-5, Block- C, Main Kanjawala Road
Rajiv Nagar, Delhi -110086
Mob.: 9910596777, 9810479889, 9811037450, 9310843393
E: dtrinfo@gmail.com, W: www.deltatestinglab.com

TEST REPORT

Issued to:

M/s Uttar Dilli C&D Waste Recycling Pvt. Ltd.
MCD Colony, Hanuman Mandir Road,
Gate No. 1, Jahangirpuri, New Delhi

Report No. : DTRL/GEN/05092430096
ULR No. : TC741424000003420F
Report Date : 06/09/2024
Your Ref. No. : Nil,
Dt. 05/09/2024
Date of Receipt : 05/09/2024

DTRL-2024-3606



Sample Description : Concrete Cube M-10
Sample Quantity : 2 Pcs.
Sample Condition : Good Condition (Loose)
Identification Mark : V-Mark, Without Mark
Details of Machine Used : CTM (3000kN) Automated, Rate of Loading:-5.25 kN/sec, Date of Calibration: 12/04/2024
Test Method Followed : IS 516 (Part-1/Sec-1):2021
Type of Specimen : Casted Concrete Cube
Date of Casting : 28/08/2024
Date of Testing : 05/09/2024

S. No.	Test Parameter	Units	Avg. Size of Specimen (mm)	Weight of specimen (kg)	Maximum Load (kN)	Observed Results (MPa)	Type of Failure
Discipline: Mechanical							
Group: Building Material							
1.	Compressive Strength	MPa					
	(i) V-Mark		150x150	7.950	197.9	8.8	Satisfactory
	(ii) Without Mark		150x150	8.120	252.1	11.2	Satisfactory

****End of Report****

Reviewed By : *Ritesh Singh*

Roushan
Authorised Signatory

Roushan Kumar
Tech. Manager

- (1) The results listed refer only to tested samples and applicable parameters. Endorsement of product is neither inferred nor implied.
(2) Total liability of our Lab is limited to the invoiced amount.
(3) Samples will be destroyed after 30 days from the date of test report unless otherwise specified.
(4) This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of Law and should not be used in any advertising media without our special permission in writing
(5) Report refer to the sample submitted to us and not drawn by us unless mentioned otherwise.