



ACE TEST HOUSE

(GOVT. APPROVED TESTING LABORATORY)
ISO 9001-2015 OHSAS 45001:2018 ISO 14001:2015
Certified Testing Laboratory



Committed to Precision....

H. O. Kh. No. 1048/1088, Pepsi Wali Gali, Near Laxmi Narayan Mandir, Village-bhalaswa, Delhi-110033
B. O. : H. No. 1, Rajender Nagar, Shatabdi Enclave, Jogiwala Ring Road, Dehradun, Uttarakhand, 240005
M: +91-7042858881/82/83 E-mail : acetesthouse@gmail.com, website : www.acetesthouse.com



TEST REPORT

(THIS CERTIFICATE IS NOT VALID WITHOUT A HOLOGRAM)

JOB CARD NO./ JOB I.D. NO.		30-20230821-01	DISCIPLINE	Mechanical Testing
REPORT NO.		ATH30-20230822-002	GROUP	Building Material
SAMPLE TYPE		Sand	MAKE	--
NAME AND ADDRESS OF CUSTOMER		Uttar Dilli C&D Waste Recycling Private Limited MCD Colony, Hanuman Mandir Road, Gate No-1, Jahangirpuri, New Delhi.	GRADE	--
REFERENCE NO.		--		
AGREEMENT NO.		--		
			DATED	21-08-2023
NAME OF WORK		--	DATE OF RECEIPT	21-08-2023
			START DATE OF ANALYSIS	21-08-2023
NAME OF AGENCY/CONTRACTOR		--	END DATE OF ANALYSIS	22-08-2023
INDIAN STANDARD REFERENCE		IS: 383-2016 Zone-II	REPORT ISSUE DATE	22-08-2023
ANY OTHER INFORMATION		--	LOCATION	--

SR NO.	TEST PARAMETER	UNIT OF MEASUREMENTS	RESULTS	REQUIREMENT AS PER IS: 383-2016 ZONE-II	METHOD REFERENCE
1)	Sieve Analysis (Sieve Size)				
i.	10mm	-	100	100	IS: 2386(P-1)-1963
ii.	4.75mm	-	99.2	90-100	IS: 2386(P-1)-1963
iii.	2.36mm	-	86.5	75-100	IS: 2386(P-1)-1963
iv.	1.18mm	-	70.6	55-90	IS: 2386(P-1)-1963
v.	600micron	-	57.3	35-59	IS: 2386(P-1)-1963
vi.	300micron	-	27.2	8-30	IS: 2386(P-1)-1963
vii.	150micron	-	18.4	0-20	IS: 2386(P-1)-1963
2)	Moisture Content	%	9.2	-	IS: 2386(P-3)-1963

Remark : The sample conforms to IS: 383-2016 w.r.to the above tests.

End Of Report

Delhi

Dehradun

Jaipur



Signature

Terms & Conditions : 1 Test Reports Are Valid Only For The Sample Tested In Our Laboratory. 2 Sample Will Be Stored/kept In Our Stores For 30 Days Form The Date Of Testing And Shall Be Destroyed Thereafter Without Any Intimation. 3. Samples Tested Are Non-returnable If The Specific Duration Of 30 Days Are Over 4 This Report Will Not Be Valid For Judicial Purpose. 5. Total Liability Of Our Test House Is Limited To Invoiced Amount.