

TEST REPORT

Test Order/Report No: BVIPL: FINE AGGREGATE/25951C/1607/3/2024
Job ID No: 2024/Mar/2407764-{UIN-24011224}

Date of Issue: 08.04.2024
Date of Receipt: 16.03.2024
Page 1 of 2

Issued to: **INDO ENVIRO INTEGRATED SOLUTIONS PRAVITE LIMITED**
Shashtri Park C&D Plant Delhi C&D Waste processing fac shastri Park New Delhi India 110053

TEST REPORT ON FINE AGGREGATE

Source of Sample* : INDO ENVIRO INTEGRATED SOLUTIONS LIMITED
No. of Sample Tested : 1 (One)
Customer Reference* : PO No. 5200000671/4000001450 dated 14.02.2024
Project* : Not Furnished
Condition of Sample : Satisfactory
Sample Drawn by : Customer
Sample Identification* : Fine Aggregate , Sample -1
Grade/Type* : Not Furnished
Brand* : Not Furnished
Period of Test : 16.03.2024 to 02.04.2024

Mechanical Testing-(Building Materials)-Fine Aggregate

S. No.	Tests	Results	Test Method
1.	Sieve Analysis,% passing,IS:Sieve Size		IS-2386(Part-1)-1963
a.	10.0 mm	100	
b.	4.75 mm	98	
c.	2.36 mm	97	
d.	1.18 mm	86	
e.	600 micron	77	
f.	300 micron	58	
g.	150 micron	19	
2.	Bulking of Sand,%	4	
3.	Water Absorption,% by mass	5.05	
4.	Bulk Density,kg/liter (Compacted)	1.59	IS:2386(Part-1)-1963
5.	Specific Gravity	2.36	
6.	Total Deleterious Material,%		
a.	Material finer than 75 microns,%	7.8	IS:2386(Part-2)-1963
b.	Coal & Lignite % by wt.	0.0	
c.	Clay Lumps,% by wt.	0.5	IS:2386(Part-5)-1963
7.	Soundness(after 5 cycles),% loss by weight		
a	With Sodium Sulphate(Na ₂ SO ₄)	2.06	

****End of Report****



UMA SHANKAR JHA
[Signature]
Authorized Signatory
(Mechanical)



This page of the report is not under NABL accreditation

TEST REPORT

Test Order/Report No: BVIPL: FINE AGGREGATE/25951C/1607/3/2024
Job ID No: 2024/Mar/2407764-(UIN-24011224)

Date of Issue: 08.04.2024
Date of Receipt: 16.03.2024
Page 2 of 2

Issued to: INDO ENVIRO INTEGRATED SOLUTIONS PRAVITE LIMITED
Shashtri Park C&D Plant Delhi C&D Waste processing fac shastri Park New Delhi India 110053

TEST REPORT ON FINE AGGREGATE

Source of Sample* : INDO ENVIRO INTEGRATED SOLUTIONS LIMITED
No. of Sample Tested : 1 (One)
Customer Reference* : PO No. 5200000671/4000001450 dated 14.02.2024
Project* : Not Furnished
Condition of Sample : Satisfactory
Sample Drawn by : Customer
Sample Identification* : Fine Aggregate, Sample -1
Grade/Type* : Not Furnished
Brand* : Not Furnished
Period of Test : 16.03.2024 to 02.04.2024

Mechanical Testing-(Building Materials)-Fine Aggregate

S. No.	Tests	Results	Test Method
1.	Total Deleterious Materials,% by wt.	0.5	IS:2386(Part-2)-1963

****End of Report****



UMA SHANKAR JHA

Authorized Signatory
(Mechanical)



This page of the report is not under NABL accreditation

TEST REPORT

Test Order/Report No: BVIPL: FINE AGGREGATE/25951C/1607/3/2024
Job ID No: 2024/Mar/2407764-(UIN-24011225)

Date of Issue: 08.04.2024
Date of Receipt: 16.03.2024
Page 1 of 2

Issued to: INDO ENVIRO INTEGRATED SOLUTIONS PRAVITE LIMITED
Shashtri Park C&D Plant Delhi C&D Waste processing fac shastri Park New Delhi India 110053

TEST REPORT ON FINE AGGREGATE

Source of Sample* : INDO ENVIRO INTEGRATED SOLUTIONS LIMITED
No. of Sample Tested : 1 (One)
Customer Reference* : PO No. 5200000671/4000001450 dated 14.02.2024
Project* : Not Furnished
Condition of Sample : Satisfactory
Sample Drawn by : Customer
Sample Identification* : Fine Aggregate, Sample -2
Grade/Type* : Not Furnished
Brand* : Not Furnished
Period of Test : 16.03.2024 to 02.04.2024

Mechanical Testing-(Building Materials)-Fine Aggregate

S. No.	Tests	Results	Test Method
1.	Sieve Analysis,% passing,IS:Sieve Size		IS-2386(Part-1)-1963
a.	10.0 mm	100	
b.	4.75 mm	97	
c.	2.36 mm	96	
d.	1.18 mm	80	
e.	600 micron	76	
f.	300 micron	54	
g.	150 micron	20	
2.	Bulking of Sand,%	4	
3.	Water Absorption,% by mass	5.60	
4.	Bulk Density,kg/liter (Compacted)	4	IS:2386(Part-1)-1963
5.	Specific Gravity	2.33	
6.	Total Deleterious Material,%		
a.	Material finer than 75 microns,%	7.5	IS:2386(Part-2)-1963
b.	Coal & Lignite % by wt.	0.0	
c.	Clay Lumps,% by wt.	0.6	IS:2386(Part-5)-1963
7.	Soundness(after 5 cycles),% loss by weight		
a	With Sodium Sulphate(Na ₂ SO ₄)	3.06	

****End of Report****



UMA SHANKAR JHA
Signature
Authorized Signatory
(Mechanical)



This page of the report is not under NABL accreditation

TEST REPORT

Test Order/Report No: BVIPL: FINE AGGREGATE/25951C/1607/3/2024
Job ID No: 2024/Mar/2407764-(UIN-24011225)

Date of Issue: 08.04.2024
Date of Receipt: 16.03.2024
Page 2 of 2

Issued to: INDO ENVIRO INTEGRATED SOLUTIONS PRAVITE LIMITED
Shashtri Park C&D Plant Delhi C&D Waste processing fac shastri Park New Delhi India 110053

TEST REPORT ON FINE AGGREGATE

Source of Sample* : INDO ENVIRO INTEGRATED SOLUTIONS LIMITED
No. of Sample Tested : 1 (One)
Customer Reference* : PO No. 5200000671/4000001450 dated 14.02.2024
Project* : Not Furnished
Condition of Sample : Satisfactory
Sample Drawn by : Customer
Sample Identification* : Fine Aggregate, Sample -2
Grade/Type* : Not Furnished
Brand* : Not Furnished
Period of Test : 16.03.2024 to 02.04.2024

Mechanical Testing-(Building Materials)-Fine Aggregate

S. No.	Tests	Results	Test Method
1.	Total Deleterious Materials,% by wt.	0.6	IS:2386(Part-2)-1963

****End of Report****



UMA SHANKAR JHA
Uma Shankar Jha
Authorized Signatory
(Mechanical)



This page of the report is not under NABL accreditation