

Water Quality Analysis Report

Generated for Internal Review & Compliance

Location: River Discharge Point 3
Date of Sampling: Oct 14, 2023
Report ID: WQ-2023-10-119

Executive Summary

Surface water and groundwater samples were collected and analyzed for physico-chemical parameters to ensure compliance with the National Environmental Standards for surface water discharge.

Laboratory Results

Parameter	Unit	Sample W1 (Upstream)	Sample W2 (Discharge)	Regulatory Limit
pH	-	7.2	6.8	6.5 - 8.5
Total Suspended Solids (TSS)	mg/ L	15.0	45.0	100.0
Total Dissolved Solids (TDS)	mg/ L	210	540	2100
Biological Oxygen Demand (BOD)	mg/ L	2.5	18.4	30.0
Chemical Oxygen Demand (COD)	mg/ L	12.0	42.0	250.0