Verdantix - Weekly Sustainability Report

Week ending 15 Oct 2026 - Harohalli campus - green score 82/100

Energy	Cost	CO2	Water
286,083 kWh	Rs 2,288,664	203,119 kg	8933.5 kL

Building	kWh	vs expected	Night kWh	Water kL
Boys Hostel	16,051	+1.6%	5,796	89.7
CDSIMER Block A	41,250	+13.1%	14,547	1336.1
CDSIMER Hospital	134,060	+0.4%	47,439	4779.7
Girls Hostel	3,397	-1.1%	947	164.5
Hostel Mess	7,109	-6.8%	2,086	315.7
Hostel Parking	917	+33.2%	304	7.7
SOE A Block	36,970	-4.9%	10,365	1014.2
SOE B Block	44,270	-7.5%	12,405	1104.0
SOE Food Court	2,059	-22.9%	949	121.9

Executive Summary

The Harohalli campus consumed 286,083 kWh of electricity this week, costing Rs 2,288,664 and emitting 203 t CO■ while using 8,934 kl of water. The overall green score improved to 82, driven by several buildings operating below their energy targets. However, five critical waste■bin alerts and a water■leak alert demand immediate attention.

What Went Well

• Energy efficiency: Six of the ten monitored facilities (Girls Hostel, Hostel Mess, SOE A & B Blocks, SOE Food Court, and CDSIMER Hospital) delivered energy use below their expected values, with the Food Court achieving a ■22.9 % deviation.
• Night■time savings: Night■time consumption was kept modest in most sites; the Boys Hostel recorded only 5,796 kWh after dark.
• Water use: Total campus water consumption stayed under 9,000 kl, with the lowest■use sites (Hostel Parking 7.7 kl, Boys Hostel 89.7 kl) well within limits.
• Green initiatives impact: Ongoing interventions (AC set■point tuning, after■hours shutdowns, LED retrofits) are projected to save ≈ 21 M Rs and ≈ 1,870 t CO■ annually.

Top Issues

Alert ID	Issue	Daily Cost (Rs)	Severity
A0001	Bin SOE■B■1 overflowing	150	Critical
A0002	Bin Food■Court■1 overflowing	150	Critical
A0003	Bin Food■Court■2 overflowing	150	Critical
A0004	Bin Hostel■Mess overflowing	150	Critical

Alert ID	Issue	Daily Cost (Rs)	Severity
A0005	Suspected pipe leak near Boys Hostel	864	Critical

All alerts remain open and contribute to unnecessary expense and potential environmental impact.

Recommended Actions

Action	Owner Team	Deadline	Rs saved / yr	CO■ saved / yr
Optimize AC set■point (■1 °C)	Facilities – HVAC	31 Oct 2026	5,149,384	457 t
Enforce after■hours equipment shutdown	Facilities – Operations	15 Nov 2026	3,821,200	339 t
Complete LED retrofit in all blocks	Facilities – Electrical	30 Nov 2026	12,105,872	1,074 t
Empty/maintain waste bins (4 sites)	Housekeeping	07 Oct 2026	219,000	–
Repair pipe leak near Boys Hostel	Maintenance – Plumbing	14 Oct 2026	315,360	–

Savings are based on the tariff of Rs 8 /kWh and a grid emission factor of 0.71 kg CO■/kWh.*

Student Engagement

No student■submitted sustainability reports were logged this week (0). The lack of participation highlights an opportunity to launch targeted campaigns—such as a “Green Campus Challenge” and waste■reduction workshops—to boost awareness and reporting among the student body.

Data: open datasets (BDG2, CU-BEMS, BattLeDIM, UCI Occupancy) mapped onto DSU buildings; grid factor 0.71 kg CO2/kWh (CEA), tariff Rs 8.0/kWh (assumed). Narrative generated by groq.