EcoTwin DSU - Weekly Sustainability Report

Week ending 15 Oct 2026 - Harohalli campus - green score 87/100

Energy	Cost	CO2	Water
284,411 kWh	Rs 2,275,288	201,932 kg	8827.1 kL

Building	kWh	vs expected	Night kWh	Water kL
Boys Hostel	16,055	+1.6%	5,796	89.0
CDSIMER Block A	41,230	+13.1%	14,547	1324.5
CDSIMER Hospital	134,154	+0.5%	47,439	4778.8
Girls Hostel	3,324	-3.2%	947	155.4
Hostel Mess	7,003	-8.2%	2,086	304.9
Hostel Parking	915	+33.0%	304	7.6
SOE A Block	36,245	-6.7%	10,365	977.8
SOE B Block	43,454	-9.3%	12,405	1078.0
SOE Food Court	2,031	-24.1%	949	111.1

Executive summary

For the week ending 15 Oct 2026, DSU Harohalli campus recorded total energy consumption of 284411 kWh costing Rs 2275288, generating 201932 kg of CO2 and consuming 8827.1 kl of water. The campus achieved an overall green score of 87 across all facility operations. Applying planned interventions can deliver an energy reduction of 17.8%, saving Rs 21391820 and 1872.1 tonnes of CO2 annually.

What went well

• SOE Food Court achieved significant energy savings, using 2031 kWh (-24.1% versus expected and -12.1% versus previous week).
• SOE B Block consumed 43454 kWh (-9.3% versus expected).
• Hostel Mess consumed 7003 kWh (-8.2% versus expected).
• SOE A Block recorded 36245 kWh (-6.7% versus expected).
• Girls Hostel registered 3324 kWh (-3.2% versus expected).

Top issues

• Alert A0001 (critical severity): Suspected pipe leak near Boys Hostel, with an estimated loss of Rs 864 per day.
• Alert A0002 (critical severity): Waste bin bin-foodcourt-1 is overflowing, causing an estimated loss of Rs 150 per day.
• Hostel Parking exceeded its projection, consuming 915 kWh (33.0% versus expected).
• CDSIMER Block A recorded high consumption of 41230 kWh (13.1% versus expected and 5.0% versus previous week).

Recommended actions

Action	Owner team	Deadline	Rs saved per year	CO2 saved
Implement campus intervention package (LED retrofit, AC setpoint, after-hours controls)	Facilities Management	Immediate	Rs 21391820	1872.1 tonnes
Repair pipe leak near Boys Hostel (Alert A0001)	Plumbing Maintenance	Immediate	Not specified	Not specified
Clear and service bin-foodcourt-1 (Alert A0002)	Campus Housekeeping	Immediate	Not specified	Not specified

Student engagement

Student reports logged for the week stood at 0. Communication channels should be promoted across student hostels and blocks to encourage reporting of waste overflows and water leaks.

Data: open datasets (BDG2, CU-BEMS, BattLeDIM, UCI Occupancy) mapped onto DSU buildings; grid factor 0.71 kg CO2/kWh (CEA), tariff Rs 8.0/kWh (assumed). Narrative generated by gemini.