MUNICIPAL STREET LIGHTING AND ILLUMINATION STANDARDS
Document ID: DOC-2026-000005
Source: Bureau of Indian Standards (IS 1944 Code of Practice for Lighting of Public Thoroughfares)
Department: Electrical & Street Lighting
Version: 1.0

Section 1: Standards Overview
This document specifies the photometric lux levels, maintenance protocols, and grievance redressal standards for municipal street lighting as mandated by BIS IS 1944 and the Model Municipal Charter. All municipal bodies are required to comply with these standards for all public roads, footpaths, underpasses, and pedestrian crossings within their jurisdiction.

Section 2: Minimum Lux Level Requirements
1. Class A1 Arterial High-Traffic Roads: Minimum 30 Lux.
2. Class B Secondary / Commercial Thoroughfares: Minimum 15 Lux.
3. Class C Residential Collector Streets: Minimum 8 to 10 Lux.
4. Pedestrian Crosswalks & Dark Spots: Minimum 20 Lux.

Section 3: Repair Turnaround and Defect Rectification SLA
1. Single Fixture Failure (Burned LED bulb or fused starter): Must be replaced within 24 hours of citizen notification.
2. Multiple Fixture Circuit Failure (Dark span > 3 consecutive poles): Mandatory restoration within 12 hours.
3. Downed Electrical Pole / Exposed Live Cable Hazard: Emergency response within 1 hour with electrical circuit isolation.
4. Vandalism / Damaged Lamp Post: Assessment within 4 hours; repair within 48 hours.
5. Persistent Flicker Complaints: Night-time inspection within 24 hours.

Section 4: Energy Efficiency and Automated Timers
All municipal lighting circuits must be governed by astronomical timers or ambient lux sensors to switch ON at dusk and OFF at dawn. Manual overrides are only permitted during civic events with written authorization from the Municipal Commissioner.

Section 5: Citizen Grievance Redressal
Street lighting complaints submitted via the civic portal are acknowledged within 2 hours and inspected within 6 hours. Repeated failure of a fixture three times within 30 days mandates root-cause analysis and permanent infrastructure upgrade. Citizens may escalate unresolved complaints to the Electrical Department Head within 72 hours.

Section 6: Compliance and Audit
Quarterly night-time audits must be conducted by a certified Electrical Engineer. Non-compliance attracts municipal penalty as per the Municipal Corporation Act. Annual energy savings reports must be submitted to the State Energy Conservation Bureau.