



NAWaL Analytical Laboratories



Test Report

154043

Recognized by: BIS, MoEF, Approved by AGMARK & Certified as per ISO 9001:2015, OHSAS 18001:2007

ULR NO. TC583421000041019F

Date: 24/11/2021

Sample ID No. : NAL/202111000041019
Discipline / Group : Chemical & Biological / Water
Name of the Customer : BMR GLOBAL SCHOOL
Address : Mallasandiram, Bagalur, Hosur.


Sample Described by the Customer : BOREWELL WATER
Quantity of the Sample Received : 5 Ltr
Condition on Receipt : Fit for Analysis
Requested By : Mr. Sathish Kumar
Information about Sampling : Submitted by Customer
Customer Reference : By letter Dated 16/11/2021
Date of Sample Receipt : 17/11/2021
Date of test Starting : 17/11/2021
Date of test Completed : 24/11/2021

S.No	TEST PARAMETERS	TEST PROTOCOL	UNIT	TEST RESULT	Requiriments as per 10500.2012	
					Acceptable Limit	Permissible Limit
PHISICAL EXAMINATIONS						
1	Appearance	Visual Examination	-	Clear liquid	-	-
2	Colour	IS 3025 (Part - 4)	Hazen	BLQ[LOQ-1.0]	5.0 Max	15.0 Max
3	Odour	IS 3025 (Part - 5)	-	Agreeable	Agreeable	Agreeable
4	Turbidity	IS 3025 (Part -10)	NTU	BLQ[LOQ-0.5]	1.0 Max	5.0 Max
5	Total Dissolved Solids	IS 3025 (Part -16)	mg/l	994.0	500.0 Max	2000.0 Max
6	Electrical Coductivity	IS 3025 (Part -14)	µs/cm	1316.0	-	-
CHEMICAL EXAMINATION						
7	pH@25°C	IS 3025 (Part -11)	-	6.62	6.5 to 8.5	No relaxation
8	Alkalinity ph as CaCo3	IS 3025 (Part -23)	mg/l	Nil	-	-
9	Total Alkalinity (as CaCO3)	IS 3025 (Part - 23)	mg/l	72.10	200.0 max	600.0 Max
10	Total Hardness (as CaCO3)	IS 3025 (Part - 21)	mg/l	709.60	200.0 Max	600.0 Max
11	Calcium as Ca	IS 3025 (Part - 40)	mg/l	168.34	75.0 max	200.0 Max
12	Magnesium as Mg	IS 3025 (Part - 46)	mg/l	63.19	30.0 Max	100.0 Max
13	Iron as Fe	IS 3025(Part - 53)	mg/l	BLQ[LOQ-0.05]	1.0 Max	No relaxation
14	Manganes as Mn	IS 3025(Part - 59)	mg/l	BLQ[LOQ-0.05]	0.1 Max	0.3 Max
15	Free Ammonia as NH3	IS 3025 (Part -34)	mg/l	BLQ[LOQ-0.25]	-	-
16	Nitrite as NO2	IS 3025 (Part -34)	mg/l	BLQ[LOQ-0.01]	-	-
17	Nitrate as NO3	IS 3025 (Part - 34)	mg/l	1.14	45.0 Max	No relaxation



Page 1 of 2

Authorized Signatory



Regd. Office & Lab: Plot No: 98-A1, 100 & 109 New SIDCO Industrial Estate, Sri Nagar, Hosur - 635109, Tamil Nadu
Phone: 04344 - 245841, 9894785841 E-mail: ecogreen.labs@gmail.com, green_balu74@yahoo.com

Marketing Office: No:110, 1st Floor, The commodity Exchange Building, Plot No: 2, 3 & 4, Sector-19A, Vashi, Navi Mumbai - 400 705, Maharashtra

Recognized by: BIS, MoEF, Approved by AGMARK & Certified as per ISO 9001:2015, ISO 45001: 2018

ULR NO. TC583421000041019F


S.No	TEST PARAMETERS	TEST PROTOCOL	UNIT	TEST RESULT	Requiriments as per 10500.2012	
					Acceptable Limit	Permissible Limit
18	Chloride as Cl	IS 3025 (Part - 32)	mg/l	347.13	250.0 Max	1000.0 Max
19	Fluoride as F	IS 3025 (Part - 60)	mg/l	0.86	1.0 Max	1.5 Max
20	Sulphate as SO ₄	IS 3025 (Part - 24)	mg/l	124.75	200.0 Max	400.0 Max
21	Phosphate as PO ₄	IS 3025 (Part - 31)	mg/l	BLQ[LOQ-0.05]	-	-
22	Free Residual chlorine	IS 3025 (Part - 26)	mg/l	BLQ[LOQ-0.01]	0.2 Min*	1.0 Max
23	Tidys Test 4 Hrs as O ₂	IS 3025(P-63).2007	mg/l	BLQ[LOQ-0.1]	-	-
BIOLOGICAL PARAMETERS						
24	Fecal Coliform	IS 1622,1981	MPN/100ml	27	-	-

Disclaimer:

This report is valid strictly for the sample submitted for analysis to NAWaL Analytical Laboratories and shall not be under any circumstance extrapolated to any other product(s) made out of this sample. All the above test parameters are carried out with the sample "as received condition".

Note:

BLQ-Below Limit of Quantification, LOQ- Limit of Quantification




Authorized Signatory

V.Rohini

Dy.Tech Manager Microbiology

For NAWaL Analytical Laboratories



Authorized Signatory

S.Elamathi

Deputy Technical Manager

End of Report

