Projects 6 and 14

GOAL:

Create a configuration screen where the Operator can monitor and input all of the required parameters to govern the system's operation.

SUMMARY:

Should the system backwash automatically? When? When should we see an alarm telling us that the tank level is too low – at 5% or at 10%? How much pressure is too much pressure for our schedule 80 CPVC pipes?

Let's create a screen where the Operator is able to check and change all of the alarm and control setpoints for our system. After all – a system that isn't flexible is not going to be particularly useful for long. Things change, needs change, usage changes, and a good system needs to be capable of accommodating various conditions.

One more small detail: we wouldn't want any unauthorized persons getting in here and monkeying around with the setpoints, would we? Let's use security here and require a credential to make any changes on this page.

TAG USAGE:

B3:5/15	BACKWASH_LOCKOUT	Backwash Lockout
F8:4	BACKWASH_SP	Backwash Cycle Trigger Setpoint
B3:6/1	BW_ENABLE_PB	Enable Backwash Pushbutton from HMI
B3:6/0	BW_LOCKOUT_PB	Backwash Lockout Pushbutton from HMI
F8:9	LEVEL_H_SP	Storage Tank High Level Setpoint
F8:7	LEVEL_HH_SP	Storage Tank HH Alarm Setpoint
F8:8	LEVEL_L_SP	Storage Tank Low Level Setpoint
F8:6	LEVEL_LL_SP	Storage Tank LL Alarm Setpoint
F8:5	PRESSURE_HH_SP	Pressure HH Alarm Setpoint