Assignment Title: Liquid Level Control using Siemens S7-1200 in TIA

Assigned by	**Rajvir Singh**
Submission date	
Name	
ID number	

What you will learn from this assignment?

- Writing SCL code for scaling the analog input
- Writing SCL code for Semi Automation ON/OFF Control
- Writing SCL code for Proportional Control

Task 1) Scale the Level meter 'ID30' in TIA in percentage (0-100%) and height (0-300 cm).

Task 2) Display the scaled values on the Panel

Task 3) Make an Auto FC using SCL code such that it fills the tank in such a way that:

If tank Level is < 40% = Fill Valve Opening 100%
If tank Level is > 40% and < 80% = Fill Valve Opening 50%
If tank Level is > 80% = Fill Valve Opening 0%
Use Toggle button to drain the level (at 50% flow rate)
Automatic ON/OFF CONTROL

Task 4) Make an arrangement to change the Set Point of Water Level using Potentiometer (0 – 100%). Write a code in SCL to achieve the set point using only Proportional Control.

Automation Proportional CONTROL

Task 5) Install a Potentiometer in Panel for Proportional Gain with your calibrated minimum and maximum limit.