
Sorting_weight_Udemy / PLC_1 [CPU 1212C AC/DC/Rly] / Program blocks

Main [OB1]

Main Properties							
General							
Name	Main	**Number**	1	**Type**	OB	**Language**	LAD
Numbering	automatic						
Information							
Title	"Main Program Sweep (Cycle)"	**Author**		**Comment**		**Family**	
Version	0.1	**User-defined ID**					


Main			
Name	**Data type**	**Default value**	**Comment**
▼ Input			
Initial_Call	Bool		Initial call of this OB
Remanence	Bool		=True, if remanent data are available
Temp			
Constant			

Network 1: Start/Stop main Conveyor




Symbol	Address	Type	Comment
"Entry Conveyor"	%Q0.0	Bool	
"Front Conveyor"	%Q0.4	Bool	
"Left Conveyor"	%Q0.5	Bool	
"Load Scale"	%Q0.7	Bool	
"Right COnveyor"	%Q0.6	Bool	
"Roller forward"	%Q0.1	Bool	
"Start"	%I1.0	Bool	
"Stop"	%I1.1	Bool	

Network 2: Couting the Boxes




Symbol	Address	Type	Comment
"Falling Edge"	%M0.0	Bool	
"IEC_Counter_0_DB".CV		Int	
"Tag_3"	%I0.0	Bool	

Network 3: Storing the values in Array




Symbol	Address	Type	Comment
"Entry sensor"	%I0.1	Bool	
"IEC_Counter_0_DB".CV		Int	
"Rising Edge1"	%M0.1	Bool	
"Tag_2"	%Q0.2	Bool	
"Tag_4"	%Q0.3	Bool	
"Tag_7"	%ID100	Real	
"Tag_11"	%MW30	Int	
"Tag_13"	%QD100	DInt	
"Weight".Weight		Array	

Network 4: Couting the boxes




Symbol	Address	Type	Comment
"Exit left"	%I0.2	Bool	
"Left count"	%QD104	DWord	
"Rising edge 2"	%M0.2	Bool	

Network 5:




Symbol	Address	Type	Comment
"Exit right"	%I0.3	Bool	
"Right Count"	%QD108	DWord	
"Rising edge 3"	%M0.3	Bool	

Network 6:



Symbol	Address	Type	Comment
"Exit front"	%I0.4	Bool	
"Forward Count"	%QD112	DWord	
"Rising Edge 4"	%M0.4	Bool	


Network 7:



Symbol	Address	Type	Comment
"Forward Count"	%QD112	DWord	
"Left count"	%QD104	DWord	

Symbol	Address	Type	Comment
"Reset Counts"	%I1.2	Bool	
"Right Count"	%QD108	DWord	

Network 8:



Symbol	Address	Type	Comment
"Tag_8"	%I0.5	Bool	
"Tag_9"	%M0.5	Bool	
"Tag_11"	%MW30	Int	
"Tag_12"	%QD116	DInt	