

# On-off valve with TOPControl ON/OFF



**bürkert**

Fluid Control Systems

## GENERAL NOTES



These instructions explain with the aid of an example the commissioning of a single-acting on-off valve. A detailed description of the device, including the external connection of the terminals and the data bit configuration and LED displays, can be found in the operating instructions for the TOPControl ON/OFF Type 8631, as well as in the operating instructions for the process valves on the accompanying CD.

## Safety notes



- Keep to standard engineering rules in planning the use of and operating the device!
- Installation and intervention for maintenance work are only allowed by qualified personnel using suitable tools!
- Observe the current regulations on accident prevention and safety for electrical devices during operation and maintenance of the device!
- Before interfering with the system, always switch off the voltage!
- Note that in systems under pressure, piping and valves may not be loosened!
- Take suitable precautions to prevent inadvertent operation or damage by unauthorized action!
- After interruption of the electrical or pneumatic supply, make sure the process is restarted in a well-defined, controlled manner!

## GENERAL NOTES



### ATTENTION EXERCISE CAUTION ON HANDLING! ELECTROSTATICALLY SENSITIVE COMPONENTS / MODULES

This device contains electronic components that are sensitive to electrostatic discharge (ESD). Contact to electrostatically charged persons or objects will endanger these components. In the worst case, they will be immediately destroyed or will fail after commissioning. Observe the requirements of EN 100 015 - 1 in order to minimize the possibility of, or avoid, damage from instantaneous electrostatic discharge. Also take care not to touch components that are under supply voltage.

## Intended use



Please observe the notes in these operating instructions together with the conditions of use and permitted data that are specified in the data sheet Type 8631, in order that the device will function perfectly and remain operable for a long time. On non-observance of these notes and unauthorized interference with the device, we will refuse all liability and the warranty on device and accessories will become void! The device serves exclusively to actuate pneumatically operated process valves. Any other use or use exceeding the specific scope is considered to be **non-intended use**. Bürkert will not be liable for any damage resulting therefrom. The risk will be borne by the user.



When connecting units with EEx-i approval, always follow the operation instructions in detail!

### Notes for use in the Ex-area

Please comply with the following:

- In the case of installation and operation in areas that have a risk of explosion, the respective national regulations. In Germany, this is VDE 0165.
- When making electrical connections to the inherently safe circuit, the information given in the corresponding conformity certificates.
- Always follow the information contained in the ATEX approval.

### Notes for devices with EEx-i-approval

- Take suitable measures to avoid an electrostatic discharge from the plastic parts of the housing (see EN 100 015 - 1).
- No component should be connected to the inputs and outputs of the circuit board whose electrical data is outside the limits determined for intrinsically safe operation quoted in the data sheet of the positioner.
- Work out on the device with the housing open should not be carried in very damp or aggressive atmospheres. Take precautions to exclude unintentional mechanical damage to the circuit boards or their components. Limit the period during which the unit is opened to that which is absolutely necessary.

### Electrical data (EEx-i-approval)

Connections: 2 x M16 cable connector with screw terminals for cable cross-sections 0,14 ... 1,5 mm<sup>2</sup>

Power supply:

Sensor see Manufacturer's Declaration form  
Fa. Pepperl & Fuchs <sup>1)</sup>

Valve see Qualification Test Certificate  
PTB 01 ATEX 2173 <sup>1)</sup>

<sup>1)</sup> see detailed operating instructions

### Safety requirements

The maximum permissible voltages and the associated maximum permissible short-circuit currents for the corresponding gas group may be taken from Table A1 in the standard DIN EN 50020, 1994 Edition.

In order that the maximum permissible temperature at the solenoid coil of the valve installed is not exceeded, the following limits to the applied power for use in the corresponding temperature class must be observed:

| Temperature class | Max. permissible ambient temperature <sup>2)</sup> [°C] | Max. permissible power [W] |
|-------------------|---|----------------------------|
| T6                | +50   | 0,4                        |
|                   | +45   | 0,5                        |
|                   | +40   | 0,7                        |
|                   | +35   | 0,8                        |
| T5                | +50   | 0,8                        |
|                   | +45   | 1,0                        |
|                   | +40   | 1,1                        |

<sup>2)</sup> Ambient temperature for compl. TopControl 8631  
(temperature inside the device is higher by max. 5°C )



The control head must not be exposed directly to sunshine or strong light sources: this would cause additional warming!

### Functional data

Resistance at 20°C (R<sub>20</sub>): 510 Ohm

Minimum terminal voltage: 11,7 V

Minimum current: 23 mA

The maximum voltage and current values are determined by the permissible electrical operating equipment.

**Technical Data**
**Operating conditions**

|                     |                     |
|---------------------|---------------------|
| Ambient temperature | -10... +50°C        |
| Protection class    | IP 65 nach EN 60529 |

**Electrical data**

|                                   |  |
|-----------------------------------|--|
| Voltage supply<br>(see nameplate) | 24 V DC $\pm$ 10 % <sup>3)</sup><br>110 / 230 V AC <sup>4)</sup> |
| Protection class                  | 3 to VDE 0580  |

**Pneumatic data**

|  |   |
|--|---|
| Control medium                         | Quality classes<br>to DIN ISO 8573-1  |
| - Dust content                         | max. particle size 40 $\mu$ m<br>max. particle density 10 mg/m <sup>3</sup> |
| - Water content                        | max. pressure dew point -20 °C  |
| - Oil content                          | max. 25 mg/m <sup>3</sup>   |
| Temperature range of<br>compressed air | -10 ... +50 °C  |
| Pressure range                         | 3 ... 7 bar   |


<sup>3)</sup> Attention: do not use industrial DC.

<sup>4)</sup> At present not available

**Possible expansion steps**

- Mechanical over travel switch
- AS interface
- DeviceNet

Various process valves from the Bürkert range can be combined with the TOPControl ON/OFF to suit different applications. Y-, flat-seat, diaphragm or ball valves are suitable.

**Connection of the control air**

**Fixing the TOPControl ON/OFF**

The fixing screw (connection between TopControl and process valve) may only be tightened with a maximum torque of 1.2 Nm.

**Installation of the valve**

- Installation in any orientation but preferably upright.
- Observe the flow direction of the fitting.
- Clean piping from contamination!
- Before attaching the valve housing, make sure the piping is aligned.
- If the housing is to be welded on, make absolutely sure that the actuator is removed beforehand.

**Contact addresses / Kontaktadressen****Germany / Deutschland / Allemagne**

Bürkert Fluid Control System

Sales Centre

Chr.-Bürkert-Str. 13-17

D-74653 Ingelfingen

Tel. + 49 (0) 7940 - 10 91 111


Fax + 49 (0) 7940 - 10 91 448

E-mail: [info@de.buerkert.com](mailto:info@de.buerkert.com)**International**

Contact addresses can be found on the internet at:

Die Kontaktadressen finden Sie im Internet unter:

Les adresses se trouvent sur internet sous :

[www.burkert.com/Burkert/Company/Locations](http://www.burkert.com/Burkert/Company/Locations)**Connections****24-V-Version**

| Terminal | Inductive proximity switch          | Mechanical limit switch                 |
|----------|-------------------------------------|---|
| 1        | Valve actuation GND                 | Valve actuation GND                     |
| 2        | Valve actuation 0 V/ 24 V           | Valve actuation 0 V/ 24 V               |
| 3        | Supply to initiators GND            | Supply to limit switches GND            |
| 4        | common reference for initiators GND | Common reference for limit switches GND |
| 5        | n. c.                               | Output limit switch 2 (NC)              |
| 6        | Binary output initiator 2 (NO)      | Output limit switch 2 (NO)              |
| 7        | n.c.                                | Output limit switch 1 (NC)              |
| 8        | Binary output initiator 1 / (NO)    | Output limit switch 1 (NO)              |
| 9        | Supply to initiators +24 V          | Supply to limit switches +24 V          |

**Connections****110 / 230-V-Version**


| Terminal | Mechanical limit switch    |
|----------|----------------------------|
| 1        | Valve actuation N          |
| 2        | Valve actuation L 1        |
| 3        | Supply to limit switches   |
| 4        | Output common pole         |
| 5        | Output limit switch 2 (NC) |
| 6        | Output limit switch 2 (NO) |
| 7        | Output limit switch 1 (NC) |
| 8        | Output limit switch 1 (NO) |
| 9        | Supply to limit switches   |

**Adjustments on commissioning**

To adjust the initiators / proximity switches or limit switches:

- open the housing of the TOPControl ON/OFF and
- adjust the initiators using the setscrews (see illustration: Connection of the control air).

Turn clockwise:  
movement upwardTurn anticlockwise:  
movement downward

**Bus drive via AS interface**


Watchdog function  
No. of valves /  
power consumption  
Power reduction  
Bus connection

yes

1 x 1 W  
yes, after ca. 30 ms  
- via M 12 plug  
(Pin 1 = Bus +, Pin 3 = Bus -)  
- via screw terminals and  
PG bushing

**Bus drive via AS interface**
**Programming data**
**Standard Device**

IO code: D hex (1 output, 3 inputs)  
ID code: F hex (ext. ID-Codes 1 and 2 = F)  
Profile: S - D. F. F  
Certification: yes, Cert.-no. 32901 (to V.2.11)

**Device for A/B-Slave addressing**



IO code: D hex (1 output, 3 inputs)  
ID code: A hex (ext. ID-Codes 1 = 7 hex and 2 = E hex)  
Profile: S - D. A. E  
Certification: yes, Cert.-no. 47601 (to V.2.11)

**Observe bit configuration!**


| Data bit configuration      | D3                | D2                | D1              | D0             |
|-----------------------------|-------------------|-------------------|-----------------|----------------|
|                             | Input initiator 1 | Input initiator 2 | Input diagnosis | Output valve 1 |
| Parameter bit configuration | P3                | P2                | P1              | P0             |
|                             | not connected     |                   |                 |                |

**Bus drive via AS interface**
**Status display**


| LED 1 Bus (green) | LED 2 Bus (red) | Status signalled   |
|-------------------|-----------------|--|
| off               | off             | POWER OFF  |
| off               | on              | no data traffic (watchdog expired with slave address non-zero) |
| on                | off             | ok   |
| flashes           | on              | slave address = 0  |
| off               | flashes         | Overload of sensor supply                                      |

**Standard addressing**

**A/B-Slave addressing**


## Bus drive via DeviceNet



## Bus connection (circular plug connector M 12, 5-pole)



## Bus drive via DeviceNet

### Settings of the DeviceNet address

MAC ID - Medium Access Control Identifier:

DIP1=off=0, DIP1=on=1

MAC ID=DIP 1\*2<sup>0</sup>+DIP2\*2<sup>1</sup>+...+DIP6\*2<sup>5</sup>

| DIP 1<br>[2 <sup>0</sup> =1] | DIP 2<br>[2 <sup>1</sup> =2] | DIP 3<br>[2 <sup>2</sup> =4] | DIP 4<br>[2 <sup>3</sup> =8] | DIP 5<br>[2 <sup>4</sup> =16] | DIP 6<br>[2 <sup>5</sup> =32] | MAC ID |
|------------------------------|------------------------------|------------------------------|------------------------------|-------------------------------|-------------------------------|--------|
| off                          | off                          | off                          | off                          | off                           | off                           | 0      |
| on                           | off                          | off                          | off                          | off                           | off                           | 1      |
| off                          | on                           | off                          | off                          | off                           | off                           | 2      |
| ...                          | ...                          | ...                          | ...                          | ...                           | ...                           | ...    |
| off                          | on                           | on                           | on                           | on                            | on                            | 62     |
| on                           | on                           | on                           | on                           | on                            | on                            | 63     |

## Bus drive via DeviceNet

### Setting the network data rate

| DIP 7 | DIP 8 | Network data rate |
|-------|-------|-------------------|
| off   | off   | 125 kBaud         |
| on    | off   | 250 kBaud         |
| off   | on    | 500 kBaud         |
| on    | on    | not allowed       |

Adaption to the data rate of the network