

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
1	01-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Port Qasim	Curtailed	Bhiki	1.32	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
2	01-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Lucky	Curtailed	HBS	1.22	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
3	01-Apr-2025	Stability Consideration	China hubco	Curtailed	Sahiwal Coal	1.123	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
4	02-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Port Qasim	Curtailed	Bhiki	1.33	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
5	02-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Lucky	Curtailed	HBS	1.23	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
6	02-Apr-2025	Stability Consideration	China hubco	Curtailed	Sahiwal Coal	1.13	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
7	03-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Port Qasim	Curtailed	Bhikki	1.35	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
8	03-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Lucky	Curtailed	HBS	1.25	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
9	03-Apr-2025	Stability Consideration	China hubco	Curtailed	Sahiwal Coal	1.12	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
10	04-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Port Qasim	Curtailed	Bhikki	1.33	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
11	04-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Lucky	Curtailed	HBS	1.23	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
12	04-Apr-2025	Stability Consideration	China hubco	Curtailed	Sahiwal Coal	1.13	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
13	05-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Port Qasim	Curtailed	Bhikki	1.36	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
14	05-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Lucky	Curtailed	HBS	1.22	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
15	05-Apr-2025	Stability Consideration	China hubco	Curtailed	Sahiwal Coal	1.14	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
16	06-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Port Qasim	Curtailed	Nandipur	1.01	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
17	06-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Lucky	Curtailed	orient	0.56	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
18	06-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	China hubco	Curtailed	Punjab Themal	1.05	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
19	07-Apr-2025	Stability Consideration	Port Qasim	Curtailed	Saif	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Sapphire	0.6		
20	07-Apr-2025	Stability Consideration	Lucky	Curtailed	Halmore	0.9	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
21	07-Apr-2025	Stability Consideration	China hubco	Curtailed	Nandipur	1.2	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
22	08-Apr-2025	Stability Consideration	Port Qasim	Curtailed	AGL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Saif	0.7		
23	08-Apr-2025	Stability Consideration	Lucky	Curtailed	Saphire	1	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
24	08-Apr-2025	Stability Consideration	China hubco	Curtailed	Halmore	1.1	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
25	09-Apr-2025	Stability Consideration	Port Qasim	Curtailed	NPL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.6		
26	09-Apr-2025	Stability Consideration	Lucky	Curtailed	KEL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					AGL	0.6		
27	09-Apr-2025	Stability Consideration	China hubco	Curtailed	Saif	1.2	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
28	10-Apr-2025	Stability Consideration	Lucky	Curtailed	NCPL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					FKPCL	0.6		
29	10-Apr-2025	Stability Consideration	China hubco	Curtailed	KEL	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					AGL	0.5		

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
30	11-Apr-2025	Stability Consideration	Lucky	Curtailed	Halmore	0.2	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Nandipur	0.5		
31	11-Apr-2025	Stability Consideration	China hubco	Curtailed	orient	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Punjab Thermal	0.7		
32	12-Apr-2025	Stability Consideration	Lucky	Curtailed	KEL	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					AGL	0.5		
33	12-Apr-2025	Stability Consideration	China hubco	Curtailed	saif	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Saphire	0.5		
34	13-Apr-2025	Stability Consideration,	Lucky	Curtailed	KEL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					AGL	0.7		
35	13-Apr-2025	Stability Consideration	China hubco	Curtailed	saif	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Saphire	0.8		
36	14-Apr-2025	Stability Consideration	Lucky	Curtailed	Hubco(N)	0.2	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Liberty Tech(N)	0.3		
					NPL	0.7		

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
37	14-Apr-2025	Stability Consideration	China hubco	Curtailed	NCPL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					FKPCL	0.4		
38	15-Apr-2025	Stability Consideration	Lucky	Curtailed	Hubco(N)	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	SDC 1.7.4
					Liberty Tech	0.4		
39	15-Apr-2025	Stability Consideration	China hubco	Curtailed	NPL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
40	16-Apr-2025	Stability Consideration	Lucky	Curtailed	Hubco(N)	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					FKPCL	0.6		
41	16-Apr-2025	Stability Consideration	China hubco	Curtailed	Liberty Tech	0.6	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NPL	0.4		

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
42	17-Apr-2025	Stability Consideration	Lucky	Curtailed	NPL	0.6	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.7		
43	17-Apr-2025	Stability Consideration	China hubco	Curtailed	KEL	0.7	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					AGL	0.6		
44	18-Apr-2025	Stability Consideration	Lucky	Curtailed	NPL	0.7	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.4		
45	18-Apr-2025	Stability Consideration	China hubco	Curtailed	KEL	0.6	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					AGL	0.4		
46	19-Apr-2025	Stability Consideration	Lucky	Curtailed	NPL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.4		
					KEL	0.5		
47	19-Apr-2025	Stability Consideration	China hubco	Curtailed	AGL	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					SAIF	0.7		

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
48	20-Apr-2025	Stability Consideration	Lucky	Curtailed	NPL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.45		
					KEL	0.55		
49	20-Apr-2025	Stability Consideration	China hubco	Curtailed	AGL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					SAIF	0.6		
50	21-Apr-2025	Stability Consideration	Lucky	Curtailed	NPL	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.3		
					KEL	0.49		
51	21-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	China hubco	Curtailed	AGL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					SAIF	0.3		
					Sapphire	0.6		
52	22-Apr-2025	Stability Consideration,	Lucky	Curtailed	KEL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					AGL	0.4		
					SAIF	0.5		
53	22-Apr-2025	Stability Consideration	China hubco	Curtailed	Sapphire	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Nandipur	0.7		
54	23-Apr-2025	Stability Consideration	Lucky	Curtailed	Saif	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Sapphire	0.3		
					Nandipur	0.5		

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
55	23-Apr-2025	Stability Consideration	China hubco	Curtailed	Halmore	0.6	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					orient	0.5		
56	24-Apr-2025	Stability Consideration	Port Qasim	Curtailed	Saif	0.2	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Sapphire	0.3		
57	24-Apr-2025	Stability Consideration	Lucky	Curtailed	Nandipur	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Halmore	0.6		
58	24-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	China hubco	Curtailed	orient	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Punjab Themal	0.6	2.RLNG Consumption as per Monthly Production Plan	
59	25-Apr-2025	Stability Consideration	Port Qasim	Curtailed	Nandipur	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Halmore	0.5		
60	25-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Lucky	Curtailed	orient	0.6	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Punjab Themal	0.4	2.RLNG Consumption as per Monthly Production Plan	
61	25-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	China hubco	Curtailed	Bhikki	1.1	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
62	26-Apr-2025	Stability Consideration	Port Qasim	Curtailed	NPL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.3		
					KEL	0.4		

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
63	26-Apr-2025	Stability Consideration	Lucky	Curtailed	AGL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Saif	0.5		
					Sapphire	0.4		
64	26-Apr-2025	Stability Consideration	China hubco	Curtailed	Halmore	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					orient	0.3		
65	27-Apr-2025	Stability Consideration	Port Qasim	Curtailed	Saif	0.1	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Sapphire	0.2		
					Halmore	0.1		
66	27-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	Lucky	Curtailed	Orient	0.6	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Punjab Thermal	0.5		
67	27-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	China hubco	Curtailed	Bhikki	1.1	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
68	28-Apr-2025	Stability Consideration	Port Qasim	Curtailed	NPL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.4		
					KEL	0.2		
69	28-Apr-2025	Stability Consideration	Lucky	Curtailed	AGL	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					saif	0.4		
					Sapphire	0.3		

Report Sheet of Power Plants Operated for Security Constrained Economic Dispatch for the Month of April-2025

Sr. No.	Date	Reason for EMO deviation due to Security Constrained Economic Dispatch (SCED	Power Plants	Generation Taken/(Curtailed)	Power Plants Dispatched/Curtailed due to Deviation	Replaced Energy due to Deviations (GWh)	Remarks/reasons	Grid Code Clause
70	28-Apr-2025	Stability Consideration	China hubco	Curtailed	Halmore	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					orient	0.4		
71	29-Apr-2025	Stability Consideration	Port Qasim	Curtailed	Hubco(N)	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					FKPCL	0.5		
					Liberty Tech	0.3		
72	29-Apr-2025	Stability Consideration	Lucky	Curtailed	NPL	0.3	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					NCPL	0.33		
					KEL	0.44		
73	29-Apr-2025	Stability Consideration	China hubco	Curtailed	AGL	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Saif	0.5		
74	30-Apr-2025	Stability Consideration	Port Qasim	Curtailed	KEL	0.33	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					AGL	0.4		
					SAIF	0.41		
75	30-Apr-2025	Stability Consideration	Lucky	Curtailed	Saphire	0.5	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Halmore	0.6		
76	30-Apr-2025	Stability Consideration, Contracutal Obligation, Must Run Generation	China hubco	Curtailed	orient	0.4	1.To ensure compliance of HVDC +HVAC safe evacuation as per SCS strategy table for systetm stability 2.RLNG Consumption as per Monthly Production Plan	OC7.5.1, OC 7.5.9,SDC 1.7.4,SDC 1.7.3
					Punjab Thernal	0.5		