

FIELD SERVICE REPORT

SERVICE REPORT NO. 3C690DB3	DATE 14-09-2026	CASE ID PHS1209261823436	CALL TYPE —	CALL STATUS ! Incomplete
--------------------------------	--------------------	-----------------------------	----------------	-----------------------------

Ticket Created 12/09/2026 12:53 · Preferred Visit — · Ticket Closed —

CUSTOMER		PRODUCT & CALL		VISIT TIMING	
NAME	DEMO AND LTD	MODEL	GVSUPS60KHINS	ARRIVAL	14/09/2026 11:34
ADDRESS	FARIDABAD, India, FARIDABAD, India, FARIDABAD, India	UPS SR NO.	DEMO2347	DEPARTURE	14/09/2026 11:37
PHONE • EMAIL	9599068010 • demo@1234.com	CALL TYPE	—	ON-SITE TIME	3m
GSTIN	URP	OEM CALL	No	PREFERRED VISIT	—

PROBLEM REPORTED	Service request for GVSUPS60KHINS / DEMO2347
REASON FOR VISIT	Warranty

SITE OBSERVATION		CONNECTED LOAD		POWER CONDITION	
MAINS L-N	25 V	LOAD	None	DG SET	Yes
MAINS N-E	33 V	POWER FAILURES	2 nos / 58 min	DG CAP. (KVA)	25
AC PROVIDED	Yes	LOAD ON DG	25 %	AMF PANEL	Yes
DG PROVIDED	Yes			NON-BIZ / HOL.	No / No
ENV. DUTY	No				
UPS LOCATION	Electrical Room				

BATTERY RECORD			
MAKE QUANTA	VOLTAGE —	AH 42	QTY 2
CHARGING VOLTAGE	DISCHARGING VOLTAGE		
B1 25	B2 36	B1 36	B2 25

PART REPLACEMENT						FEEDBACK & SIGN-OFF		
#	Item Replaced	Old Sr No	New Sr No	Qty	Charges ₹	FSE FEEDBACK	—	
1	Accessories	DEMO65773	DEMONEW5572	1	₹ 3,580	CUSTOMER FDBK	—	
						RATING	— / 10	
						FSR STATUS	☐ ✓ Complete ☐ ⚙ Under Obs. ☒ ! Incomplete	
						FSR VERDICT	—	

CUSTOMER		FIELD SERVICE ENGINEER	
Signature	Name: Mr. DAKSH DEMO DEMO		Name: EST ENG No: 4657465647
Office Seal	Date	FSE Signature	Date