

FIELD SERVICE REPORT

SERVICE REPORT NO. SMPL-FSR	DATE 15-09-2026	CASE ID CS-2026-0915-0042	CALL TYPE —	CALL STATUS ✓ Complete
--------------------------------	--------------------	------------------------------	----------------	---------------------------

Ticket Created 13/09/2026 10:00 · Preferred Visit 14/09/2026 16:30 · Ticket Closed 15/09/2026 12:00

CUSTOMER		PRODUCT & CALL		VISIT TIMING	
NAME	7Minion Technology Pvt. Ltd.	MODEL	APC Smart-UPS SRT10KXLI	ARRIVAL	15/09/2026 09:40
ADDRESS	WDWFEFWGRG, Tower B, 9th Floor, Sector 62, Gurugram, Haryana - 122011, Gurugram, Haryana	UPS SR NO.	210924H95V	DEPARTURE	15/09/2026 11:20
PHONE • EMAIL	+91-98765-43210 • accounts@7minion.com	CALL TYPE	—	ON-SITE TIME	1h 40m
GSTIN	06AAACZ8266C1Z9	OEM CALL	Yes	PREFERRED VISIT	14/09/2026 16:30

PROBLEM REPORTED	UPS beeping in battery mode with intermittent output voltage fluctuation during office hours
------------------	--

REASON FOR VISIT	Warranty — Check battery bank health and mains input wiring
------------------	---

SITE OBSERVATION		CONNECTED LOAD		POWER CONDITION	
MAINS L-N	228 V	PC	21" × 4 19" × 2	DG SET	No
MAINS N-E	4 V	PRINTER	300W × 1	DG CAP. (KVA)	—
AC PROVIDED	Yes	SCANNER	200W × 1	AMF PANEL	Yes
DG PROVIDED	No	POWER FAILURES	6 nos / 45 min	NON-BIZ / HOL.	Yes / No
ENV. DUTY	Yes	LOAD ON DG	0 %		
UPS LOCATION	Server Room — 2nd Floor				

BATTERY RECORD															
MAKE Exide				VOLTAGE 12V				AH 100Ah				QTY 16			
CHARGING VOLTAGE								DISCHARGING VOLTAGE							
B1	B2	B3	B4	B5	B6	B7	B8	B1	B2	B3	B4	B5	B6	B7	B8
13.8	13.7	13.8	13.6	13.7	13.8	13.7	13.6	12.9	12.8	12.9	12.7	12.8	12.9	12.8	12.7
B9	B10	B11	B12	B13	B14	B15	B16	B9	B10	B11	B12	B13	B14	B15	B16
13.8	13.7	13.5	13.8	13.7	13.6	13.8	13.7	12.9	12.8	12.6	12.9	12.8	12.7	12.9	12.8

PART REPLACEMENT					FEEDBACK & SIGN-OFF	
#	Item Replaced	Old Sr No	New Sr No	Qty	Charges ₹	FSE FEEDBACK
1	Battery 12V 100Ah	EXD22A001	EXD26I101	2	₹ 12,500	—
2	DC Capacitor 4700uF	CAP-8812	CAP-9031	1	₹ 1,800	CUSTOMER FDBK
3	Cooling Fan 120mm	FAN-4410	FAN-5523	2	₹ 950	RATING
4	Control Card	CTL-1102	CTL-1187	1	₹ 6,400	9 / 10
5	Fuse Kit 63A	FUS-0063	FUS-0071	4	₹ 450	FSR STATUS
						☒ ✓ Complete ☐ ⦿ Under Obs. ☐ ! Incomplete
						FSR VERDICT
						—

CUSTOMER		FIELD SERVICE ENGINEER	
Signature	Name: Rahul Sharma		Name: Amit Kumar
			No: +91-98111-22334
Office Seal	Date	FSE Signature	Date