

FIELD SERVICE REPORT

SERVICE REPORT NO. SMPL-FSR	DATE 15-09-2026	CASE ID CS-2026-0915-0042	CALL TYPE —	CALL STATUS ✓ Complete
--------------------------------	--------------------	------------------------------	----------------	---------------------------

Ticket Created 13/09/2026 10:00 · Preferred Visit 14/09/2026 16:30 · Ticket Closed 15/09/2026 12:00

CUSTOMER		PRODUCT & CALL		VISIT TIMING	
NAME	7Minion Technology Pvt. Ltd.	MODEL	APC Smart-UPS SRT10KXLI	ARRIVAL	15/09/2026 09:40
ADDRESS	WDWFEFWGRG, Tower B, 9th Floor, Sector 62, Gurugram, Haryana - 122011, Gurugram, Haryana	UPS SR NO.	210924H95V	DEPARTURE	15/09/2026 11:20
PHONE • EMAIL	+91-98765-43210 • accounts@7minion.com	CALL TYPE	—	ON-SITE TIME	1h 40m
GSTIN	06AAACZ8266C1Z9	OEM CALL	Yes	PREFERRED VISIT	14/09/2026 16:30

PROBLEM REPORTED	UPS beeping in battery mode with intermittent output voltage fluctuation during office hours
------------------	--

REASON FOR VISIT	Warranty — Check battery bank health and mains input wiring
------------------	---

SITE OBSERVATION		CONNECTED LOAD		POWER CONDITION	
MAINS L-N	228 V	PC	21" × 4 19" × 2	DG SET	No
MAINS N-E	4 V	PRINTER	300W × 1	DG CAP. (KVA)	—
AC PROVIDED	Yes	SCANNER	200W × 1	AMF PANEL	Yes
DG PROVIDED	No	POWER FAILURES	6 nos / 45 min	NON-BIZ / HOL.	Yes / No
ENV. DUTY	Yes	LOAD ON DG	0 %		
UPS LOCATION	Server Room — 2nd Floor				

BATTERY RECORD															
MAKE Exide				VOLTAGE 12V				AH 100Ah				QTY 16			
CHARGING VOLTAGE								DISCHARGING VOLTAGE							
B1	B2	B3	B4	B5	B6	B7	B8	B1	B2	B3	B4	B5	B6	B7	B8
13.8	13.7	13.8	13.6	13.7	13.8	13.7	13.6	12.9	12.8	12.9	12.7	12.8	12.9	12.8	12.7
B9	B10	B11	B12	B13	B14	B15	B16	B9	B10	B11	B12	B13	B14	B15	B16
13.8	13.7	13.5	13.8	13.7	13.6	13.8	13.7	12.9	12.8	12.6	12.9	12.8	12.7	12.9	12.8

PART REPLACEMENT								FEEDBACK & SIGN-OFF							
Old Charges # Items Old Replaced New Battery, 12V 100Ah 12,500 DC Cap. 2 Capacitor 4700uF 1,800 Cooling Fan 3 Fan 120mm 2,950 Control Card 4 Card 1,400 Fuses 5 Kit 7450 63A								FSE FEEDBACK	—						
								CUSTOMER FDBK	—						
								RATING	9 / 10						
								FSR STATUS	☒ ✓ Complete ☐ Under Obs. ☐ ! Incomplete						
								FSR VERDICT	—						

CUSTOMER		FIELD SERVICE ENGINEER	
Signature	Name: Rahul Sharma		Name: Amit Kumar No: +91-98111-22334
Office Seal	Date	FSE Signature	Date