

FIELD SERVICE REPORT

SERVICE REPORT NO.
SMPL-FSR

DATE
15-09-2026

CASE ID
CS-2026-0915-0042

CALL TYPE
—

CALL STATUS
✓ Complete

Ticket Created 13/09/2026 10:00 · Preferred Visit 14/09/2026 16:30 · Ticket Closed 15/09/2026 12:00

CUSTOMER		PRODUCT & CALL		VISIT TIMING	
NAME	7Minion Technology Pvt. Ltd.	MODEL	APC Smart-UPS SRT10KXLI	ARRIVAL	15/09/2026 09:40
ADDRESS	WDWFEFWGRG, Tower B, 9th Floor, Sector 62, Gurugram, Haryana - 122011, Gurugram, Haryana	UPS SR NO.	210924H95V	DEPARTURE	15/09/2026 11:20
PHONE • EMAIL	+91-98765-43210 • accounts@7minion.com	CALL TYPE	—	ON-SITE TIME	1h 40m
GSTIN	06AAACZ8266C1Z9	OEM CALL	Yes	PREFERRED VISIT	14/09/2026 16:30

PROBLEM REPORTED	UPS beeping in battery mode with intermittent output voltage fluctuation during office hours
REASON FOR VISIT	Warranty — Check battery bank health and mains input wiring

SITE OBSERVATION		CONNECTED LOAD		POWER CONDITION	
MAINS L-N	228 V	PC	21" × 4 19" × 2	DG SET	No
MAINS N-E	4 V	PRINTER	300W × 1	DG CAP. (KVA)	—
AC PROVIDED	Yes	SCANNER	200W × 1	AMF PANEL	Yes
DG PROVIDED	No	POWER FAILURES	6 nos / 45 min	NON-BIZ / HOL.	Yes / No
ENV. DUTY	Yes	LOAD ON DG	0 %		
UPS LOCATION	Server Room — 2nd Floor				

BATTERY RECORD															
MAKE Exide · VOLTAGE 12V · AH 100Ah · QTY 32															
CHARGING VOLTAGE								DISCHARGING VOLTAGE							
B1	B2	B3	B4	B5	B6	B7	B8	B1	B2	B3	B4	B5	B6	B7	B8
13.8	13.7	13.8	13.6	13.7	13.8	13.7	13.6	12.9	12.8	12.9	12.7	12.8	12.9	12.8	12.7
B9	B10	B11	B12	B13	B14	B15	B16	B9	B10	B11	B12	B13	B14	B15	B16
13.8	13.7	13.5	13.8	13.7	13.6	13.8	13.7	12.9	12.8	12.6	12.9	12.8	12.7	12.9	12.8
B17	B18	B19	B20	B21	B22	B23	B24	B17	B18	B19	B20	B21	B22	B23	B24
13.8	13.6	13.7	13.8	13.7	13.6	13.5	13.8	12.9	12.7	12.8	12.9	12.8	12.7	12.6	12.9
B25	B26	B27	B28	B29	B30	B31	B32	B25	B26	B27	B28	B29	B30	B31	B32
13.7	13.8	13.6	13.7	13.8	13.7	13.6	13.8	12.8	12.9	12.7	12.8	12.9	12.8	12.7	12.9

PART REPLACEMENT						FEEDBACK & SIGN-OFF	
#	Item Replaced	Old Sr No	New Sr No	Qty	Charges ₹	FSE FEEDBACK	—
1	Battery 12V 100Ah	EXD22A001	EXD26I101	2	₹ 12,500	CUSTOMER FDBK	—
2	DC Capacitor 4700uF	CAP-8812	CAP-9031	1	₹ 1,800	RATING	9 / 10
3	Cooling Fan 120mm	FAN-4410	FAN-5523	2	₹ 950	FSR STATUS	☒ ✓ Complete ☐ ⦿ Under Obs. ☐ ! Incomplete
4	Control Card	CTL-1102	CTL-1187	1	₹ 6,400	FSR VERDICT	—
5	Fuse Kit 63A	FUS-0063	FUS-0071	4	₹ 450		

CUSTOMER		FIELD SERVICE ENGINEER	
Signature	Name: Rahul Sharma	FSE Signature	Name: Amit Kumar
			No: +91-98111-22334
Office Seal	Date	Date	