

MUST2 DSSD Energy Calibration Report

1 Calibration Summary

Experiment : MUGAST@LISE23
Operator : Valerian and Hugo
App. Date : 16/02/23
Source : 3 alpha peaks ^{239}Pu , ^{241}Am , ^{244}Cm
Dead Layer : Al $0.3\mu\text{m}$ + Si $0\mu\text{m}$
Comment : MUST2

Calibration Method : ZeroExtrapolation
Telescope Treated : 1
Strip Treated : 1 to 128
DSSD Side : X


Source Description :

Isotope	Original Energy (MeV)	Branching Ratio
^{239}Pu	5.15659	70.77
^{239}Pu	5.14438	17.11
^{239}Pu	5.1055	11.94
^{241}Am	5.48556	84.8
^{241}Am	5.4428	13.1
^{241}Am	5.388	1.66
^{244}Cm	5.80477	76.4
^{244}Cm	5.76264	23.6

2 Telescope 1

Bad Strip :

Strip Number	Problem
1	0 peak(s) found ; zero extrapolation too high :8203.4channels ;
2	0 peak(s) found ; zero extrapolation too high :8203.4channels ;
11	0 peak(s) found ; zero extrapolation too high :8203.4channels ;
22	1 peak(s) found ; zero extrapolation too high :8203.4channels ;



Sigma fit centroid : 2.29251
Sigma fit sigma : 0.147491