

Equipment Datasheet — 100-D-103

Distillation Column | CDU Unit

Document ID	DS-100-D-103
Equipment Tag	100-D-103
Equipment Name	Distillation Column
Process Unit	Crude Distillation Unit (100)
Manufacturer	Forbes Marshall
Install Date	2015-12-21
Design Pressure	127.3 barg
Design Temperature	224.6 degC
Material of Construction	Duplex Stainless Steel
Criticality Rating	Medium
Governing SOP	SOP-100-001
Governing Safety Procedure	SP-004

1. Equipment Description

100-D-103 is a Distillation Column installed in the Crude Distillation Unit (CDU) at PRPC. It was supplied by Forbes Marshall and commissioned on 2015-12-21. The equipment is classified as Medium criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 127.3 barg with a design temperature of 224.6 degC. Primary material of construction is Duplex Stainless Steel, selected for compatibility with process fluid composition and corrosion allowance requirements specific to CDU service.

3. Operating & Safety References

Operation of 100-D-103 is governed by procedure SOP-100-001 (Crude Charge Pump Startup and Shutdown). Isolation and personnel safety during maintenance follow SP-004 (H2S Detection and Emergency Response).

4. Maintenance Philosophy

100-D-103 is included in the CDU rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (Medium).