

Equipment Datasheet — 100-V-105

Knock-out Drum | CDU Unit

Document ID	DS-100-V-105
Equipment Tag	100-V-105
Equipment Name	Knock-out Drum
Process Unit	Crude Distillation Unit (100)
Manufacturer	BHEL
Install Date	2001-07-04
Design Pressure	66.9 barg
Design Temperature	191.3 degC
Material of Construction	Carbon Steel
Criticality Rating	High
Governing SOP	SOP-100-001
Governing Safety Procedure	SP-003

1. Equipment Description

100-V-105 is a Knock-out Drum installed in the Crude Distillation Unit (CDU) at PRPC. It was supplied by BHEL and commissioned on 2001-07-04. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 66.9 barg with a design temperature of 191.3 degC. Primary material of construction is Carbon Steel, selected for compatibility with process fluid composition and corrosion allowance requirements specific to CDU service.

3. Operating & Safety References

Operation of 100-V-105 is governed by procedure SOP-100-001 (Crude Charge Pump Startup and Shutdown). Isolation and personnel safety during maintenance follow SP-003 (Confined Space Entry - Vessels and Tanks).

4. Maintenance Philosophy

100-V-105 is included in the CDU rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).